

**Comment 1 for Airborne Toxic Control Measure (atcm2010) - 45 Day.**

First Name: Timothy A.  
Last Name: Blubaugh  
Email Address: tblubaugh@emamail.org  
Affiliation:

Subject: EMA Comments Airborne Toxic Control Measure for Stationary Compression Ignition Engines

Comment:

EMA Comments Airborne Toxic Control Measure for Stationary Compression Ignition Engines

Attachment: [www.arb.ca.gov/lists/atcm2010/2-pdf\\_letter\\_to\\_carb.pdf](http://www.arb.ca.gov/lists/atcm2010/2-pdf_letter_to_carb.pdf)

Original File Name: PDF Letter to CARB.PDF

Date and Time Comment Was Submitted: 2010-10-18 11:14:12

No Duplicates.

## **Comment 2 for Airborne Toxic Control Measure (atcm2010) - Non-Reg.**

First Name: saeed

Last Name: ahdout

Email Address: sahdout@sierraeng.net

Affiliation:

Subject: NOX REDUCTION

Comment:

The stationary diesel engines addresses the PM issue, but it seems that the NOX limit is imposed by the local air district for the emergency generator, which does not ease the BACT requirement. Compliance with the NOX limit for Tier I or II engines can only be met by installing SCR, which exceed the actual cost of the generator.

Attachment:

Original File Name:

Date and Time Comment Was Submitted: 2010-10-15 18:07:28

No Duplicates.

### **Comment 3 for Airborne Toxic Control Measure (atcm2010) - 45 Day.**

First Name: David

Last Name: Lusk

Email Address: dlusk@bcaqmd.org

Affiliation: Butte County AQMD

Subject: Proposed Amendments to Stationary ATCM

Comment:

Please see attached comments.

Attachment: [www.arb.ca.gov/lists/atcm2010/4-emergency\\_engine\\_atcm\\_amendments.pdf](http://www.arb.ca.gov/lists/atcm2010/4-emergency_engine_atcm_amendments.pdf)

Original File Name: Emergency Engine ATCM Amendments.pdf

Date and Time Comment Was Submitted: 2010-10-20 11:22:01

No Duplicates.

**Comment 4 for Airborne Toxic Control Measure (atcm2010) - 45 Day.**

First Name: Dana

Last Name: Roxon

Email Address: Non-web submitted comment

Affiliation:

Subject: Marin Municipal Water District

Comment:

Please see attached.

Attachment: [www.arb.ca.gov/lists/atcm2010/5-water\\_municipal.pdf](http://www.arb.ca.gov/lists/atcm2010/5-water_municipal.pdf)

Original File Name: Water Municipal.pdf

Date and Time Comment Was Submitted: 2010-11-05 12:30:17

No Duplicates.

**There are no comments posted to Airborne Toxic Control Measure (atcm2010) that were presented during the Board Hearing at this time.**