STATE OF CALIFORNIA

PETE WILSON, *Governor*

AIR RESOURCES BOARD
1102 Q STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

January 23, 1991

David J. Parrish
Engineering Manager
Emco Wheaton, Inc.
4001 Weston Parkway
Cary, NC 27513

#91-1

Dear Mr. Parrish:

Certification of Emco Wheaton A1100 Two Point Guardian

You requested certification of the Emco Wheaton A1100 Guardian overfill prevention system. The coaxial unit is still under evaluation. The two point unit has been found to be acceptable at this time.

As required by the Air Resources Board certification and test procedures, you requested the approval of the Division of Occupational Health and Safety, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the use of the Emco Wheaton A1100 overfill prevention system will not adversely affect vapor recovery systems on which it may be installed. Therefore, the Emco Wheaton A1100 Guardian overfill prevention system is certified for use with two point Phase I gasoline vapor recovery systems.

If you have any questions, please call Laura McKinney, Associate Air Pollution Specialist, at (916) 327-1525.

Sincerely,

Robert Lenard

James J. Morgester, Chief
Compliance Division

cc: All APCDs and AQMDs
Vapor Recovery Technical Committee Members
CAP Gasoline Marketing and Distribution Manual