STATE OF CALIFORNIA
**AIR RESOURCES BOARD**
1102 Q STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

PETE WILSON, Governor

August 2, 1991

William J. Brown
Technical Liaison Manager
OPW Fueling Components
Post Office Box 405003
Cincinnati, OH 45240-5003

#91-13

Dear Mr. Brown

OPW 111-V Bellows Sleeve

We have examined the sleeve/handgrip you propose for the OPW 111-V nozzle and we agree that it may provide some protection for the lower bellows and may provide a surface for two handed users to hold. The addition of this sleeve is a minor modification and will not adversely affect the function of the nozzle.

As OPW noted in a July 26 letter from Donald Leininger, this item is to be sold only as a part of the nozzle or as a part of the bellows replacement kit. This will help prevent use of the sleeve to cover up a damaged lower bellows. Under this condition, the bellows sleeve/handgrip is approved for use with the OPW 111-V nozzle on Phase II gasoline vapor recovery systems in California.

If you have any questions, please call Laura McKinney, Associate Air Pollution Specialist, at (916) 327-1525 or Darrell Hawkins, Associate Air Resources Engineer, at (916) 324-7343.

Sincerely,

James J. Morgester, Chief
Compliance Division

cc: All APCDs and AQMDs
Vapor Recovery Technical Committee Members
CAP Gasoline Marketing and Distribution Manual