STATE OF CALIFORNIA

PETE WILSON, Governor

AIR RESOURCES BOARD
1102 Q STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

August 28, 1991

James W. Healy
President
Healy Systems Inc.
17 Hampshire Drive
Hudson, NH 03051

#91-17

Dear Mr. Healy:

Healy Systems Model 9000 Mini-Jet Certification

You requested California Air Resources Board (CARB) certification of the Mini-Jet Model 9000 vacuum pump for use in Healy Phase II vapor recovery systems. My staff has evaluated the Mini-Jet and has determined that its design is indeed similar to the CARB certified Multi-Jet Model 8500 vacuum pump and that the Multi-Jet has had an adequate history of performance and dependability. As you know, the Mini-Jet has a smaller capacity and its use will be restricted to installations where no more than eight nozzles can be in service simultaneously.

As required by the California Air Resources Board certification and test procedures, you requested the approval of the Division of Occupational Safety and Health, the State fire Marshal, and the Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that use of the Model 9000 Mini-Jet will not adversely affect Healy vapor recovery systems. Therefore, the Mini-Jet vacuum pump is certified for use with Healy Phase II gasoline vapor recovery systems in California. One Mini-Jet is required for each eight nozzles which can be in service simultaneously.

If you have any questions please call Laura McKinney at (916) 327-1525 or Darrell Hawkins at (916) 324-7343.

Sincerely,

James J. Morgester, Chief
Compliance Division