STATE OF CALIFORNIA
AIR RESOURCES BOARD
2020 L STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

PETE WILSON, Governor

September 7, 1993

Detlev E. Hasselmann
President
Hasstech, Inc.
6985 Flanders Drive
San Diego, CA 92121

#93-20

Dear Mr. Hasselmann:

Approval of Hazlett H-PVB-1 Valves on Hasstech VCP-2/2A System

You requested California Air Resources Board (CARB) approval to use the Hazlett Engineering Company's Blue Label H-PVB-1 Pressure/Vacuum (p/v) valves on the Hasstech VCP-2/2A Vapor Recovery System.

The Hasstech VCP-2/2A system is currently approved for use only with the Varec 2010-811-2 p/v valve. The Blue Label Hazlett H-PVB-1 p/v valve is already certified for use with Phase II vapor recovery systems (Approval Letter #92-20)

I find that the use of the Blue Label H-PVB-1 valves will not adversely affect the vapor recovery performance of the Hasstech VCP-2/2A system. Therefore, the Hazlett Blue Label H-PVB-1 Pressure/Vacuum Valves (Approval Letter #92-20) are certified for use with the Hasstech VCP-2/2A Vapor Recovery System (Executive Order #G-70-7-AD). If you have any questions, please call Basharat Iqbal at (916) 324-7343 or Laura McKinney at (916) 327-1525.

Sincerely,

for

James J. Morgester, Chief
Compliance Division

cc: Vapor Recovery Technical Committee