STATE OF CALIFORNIA

PETE WILSON, Governor

AIR RESOURCES BOARD
2020 L STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

December 31, 1994

Mr. Dave Dodson
Director of Engineering
Bennett Pump Company
2470 Wood Street
Post Office Box 597
Muskegon, Michigan 49443-0597

#94-31

Dear Mr. Dodson:

Approval of the Bennett Pump Company 9000 and 7000 Series Dispensers

Mr. Charles R. McKinney of Bennett Pump Company requested California Air Resources Board (CARB) certification of the Bennett 9000 and 7000 series dispensers on April 19, 1993. The Bennett Model 9000 and 7000 series dispensers are high hang hose type dispensers designed to operate with balance vapor recovery systems. The Bennett 9000 and 7000 series dispensers consist of the following models:

9000 Series
9024, 9032, 9033, 9036, 9044, 9048, 9432, 9433, 9436

7000 Series
7011, 7012, 7022, 7024

As required by the Air Resources Board certification procedures, you requested the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the use of the Bennett 9000 and 7000 series dispensers, when installed in accordance with the manufacturer's instructions, will not adversely affect the performance of vapor recovery systems on which they are installed. Therefore, the Bennett Pump Company 9000 and 7000 series dispensers are certified for use with balance type vapor recovery systems.

Should you have any questions or need further assistance, please contact Mr. Basharat Iqbal at (916) 324-7343 or Ms. Laura Sullivan McKinney at (916) 327-1525.

Sincerely,

Mary N. Boyer for
James J. Morgester, Chief
Compliance Division

cc: Mr. Kenneth Kunaniec, Chairman,
CAPCOA Vapor Recovery Committee

Mr. Gary Hunter, Manager,
CARB Compliance Assistance Section

STATE OF CALIFORNIA

PETE WILSON, Governor

AIR RESOURCES BOARD
2020 L STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

January 6, 1995

Mr. Donald L. Leininger
Technical Liaison Manager
OPW Fueling Components
Post Office Box 405003
Cincinnati, Ohio 45240-5003

#95-1

Dear Mr. Leininger:

Approval of the OPW Model 61SA-1000 Phase I Rotatable Adaptor

Mr. Bob Clary of OPW Fueling Components requested certification of the OPW Model 61SA-1000 Phase I rotatable adaptor on June 9, 1994. The OPW Model 61SA-1000 rotatable adaptor is Phase I product adaptor designed to be installed on the underground storage tank liquid product riser pipe. The top section of the adaptor rotates with the drop hose movements while the bottom section remains in place and maintains the integrity of the seal preventing venting of the tank to atmosphere by a leak path.

As required by the Air Resources Board certification procedures, you requested the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the use of the OPW 61SA-1000 adaptor, when installed in accordance with the manufacturer's instructions, will not adversely affect the performance of vapor recovery systems on which it is installed. Therefore, the OPW Model 61SA-1000 Phase I rotatable adaptor is certified for use on the underground storage tank liquid product riser pipes of Phase I vapor recovery systems.

Should you have any questions or need further assistance, please contact Mr. Basharat Iqbal at (916) 324-7343 or Ms. Laura Sullivan McKinney at (916) 327-1525.

Sincerely,

James J. Morgester, Chief
Compliance Division

cc: Mr. Kenneth Kunaniec, Chairman,
CAPCOA Vapor Recovery Committee

Mr. Gary Hunter, Manager,
CARB Compliance Assistance Section