STATE OF CALIFORNIA PETE WILSON, Governor

AIR RESOURCES BOARD
2020 L STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

March 13, 1995

Mr. Thomas A. Hanna
Design Engineer
Catlow Incorporated
2750 U.S. Route 40
Tipp City, Ohio 45371

#95-16

Dear Mr. Hanna:

Approval of the Catlow Model 200PV Conversion Fitting

Mr. Jim Asbury, Manger of Quality Assurance for Catlow Incorporated, requested California Air Resources Board (CARB) certification of the Catlow Incorporated Model 200PV conversion fitting on September 4, 1994.

The 200PV conversion fitting is used to provide the necessary connection between a standard coaxial hose and dispenser piping. The unit is intended to be mounted near a dispensing device liquid outlet. The splitter valve joins the concentric vapor and liquid lines of a standard coaxial type connection fitting to individual liquid and vapor ports. The individual ports are 3/4 inch NPT connections. The 200PV shall be installed in conformity to the manufacturer's instructions and all applicable codes. As required by the California State Fire Marshal (CSFM), the manufacturer's name, model number, fuel port and vapor port shall be cast in the body of the fitting. The Underwriters Laboratory's label "U/L Inc." shall also be affixed to the conversion fitting body.

As required by the Air Resources Board certification procedures, you requested the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the use of the 200PV fitting, when installed in accordance with the manufacturer's instructions and the conditions listed above, will not adversely affect the performance of vapor recovery systems on which it is installed. Therefore, the Catlow Incorporated Model 200PV conversion fitting is certified for use with Phase II vapor recovery systems which utilize standard coaxial type hoses.

Should you have any questions or need further assistance, please contact Mr. Basharat Iqbal at (916) 324-7343 or Ms. Laura Sullivan McKinney at (916) 327-1525.

Sincerely,

James J. Morgester, Chief
Compliance Division

cc: Mr. Kenneth Kunaniec, Chairman,
CAPCOA Vapor Recovery Committee

Mr. Gary Hunter, Manager,
CARB Compliance Assistance Section