

## **REGULATION II PROHIBITIONS**

### **Rule 213**      **Storage of Gasoline Products**

1.      **Submerged Fill Pipe**

No person shall install or maintain any stationary gasoline tank with a capacity of 250 gallons or more that is not equipped for loading through a permanent submerged fill pipe.

2.      **Exemptions to Subdivision (1)**

- A.      Storage tanks installed prior to December 31, 1970.
- B.      Storage tank is a pressure tank, floating roof tank, or tank equipped with a vapor recovery system.
- C.      Storage tanks used primarily for fueling implements of husbandry, as such vehicles are defined in Division 16, Chapter 1, of the Vehicle Code.

3.      **Federal Ozone Non-attainment Areas**

The following provisions shall apply only in those portions of the District designated as non-attainment of any federal ambient air quality standard for ozone and are in addition to and supersede all other provisions of this rule:

- A.      No person shall install or maintain any stationary gasoline tank with a capacity greater than 250 gallons that is not equipped with a CARB certified Phase I Vapor Recovery System.
- B.      Any gasoline tank required to be equipped with a Phase I Vapor Recovery System shall utilize that system during any and all transfers of gasoline.