EVENT INFORMATION

FACILITY # : 1234 FACILITY NAME : XYZ COMPANY

DETAIL INFORMATION

EVENT #: 0954 EVENT TYPE: Breakdown
EVENT DATE: 01/07/2003 TIME: 0035 DATE REPORTED: 01/07/2003
RECVD BY: Olson, Lyle ASSIGNED TO: Olson, Lyle
LETTER RECEIVED DATE: 01/09/20

STATUS/OUTCOME

STATUS: Complete
DATE CLOSED: 01/30/2003 CLOSE ID: Olson, Lyle
OUTCOME : No Further Action

EVENT COMMENTS

Call In: MAY DAY
321 FORREST GREEN Street, NEWBURY PARK, CA 92320

Another brief outage of Volatile Organic Thermal Oxidizer. Outage occurred at 12:35 am on 1/7/03. The occurrence I am getting, just now getting, all the details related to the occurrence. But it appears as though it was related to a loss of power that affected numerous devices around the facility. I will follow up with the rest of the information regarding the outage in a written report. That written report will be combined with a written report for the other outages. Appears at this trime the root cause of this outage was different from the other recent outages. The other recent outages were quite brief and again to a diferent root cause. This outage was related to a general loss of supplied power for a brief period of time. If you have questions, my number is

Investigation: Brief SCE power outage blacked out the facility at 2342 on 1/9/03. Thermal oxidizer was on bypass and lost temperture for 46 minutes. Excess ROC emissions wre approximately 14.12 pounds.