



Linda S. Adams
Secretary for
Environmental Protection

Air Resources Board

Mary D. Nichols, Chairman
1001 I Street • P.O. Box 2815
Sacramento, California 95812 • www.arb.ca.gov



Arnold Schwarzenegger
Governor

July 13, 2009

Mr. M. A. Mannan
Business Manager
NETT Technologies Inc.
2-6707 Goreway Drive
Mississauga, ON, L4V 1P7

Dear Mr. Mannan:

The Air Resources Board (ARB) has reviewed the NETT Technologies Incorporated application for the verification of the NETT GreenTRAP™ Diesel Particulate Filter (DPF) and determined that the NETT GreenTRAP™ DPF is the same product as the Süd-Chemie Inc. EnviCat-DPF®. Since the Süd-Chemie Inc. EnviCat-DPF® is an ARB verified Level 3 Plus system based on the evaluation of the same data as provided for the NETT GreenTRAP™ DPF verification application, ARB hereby verifies the NETT GreenTRAP™ DPF as a Level 3 Plus system for the same control group.

The NETT GreenTRAP™ DPF reduces emissions of diesel particulate matter (PM) by 85 percent or greater and does not increase nitrogen dioxide (NO₂) emissions beyond the 2009 limit of 20 percent of the baseline oxides of nitrogen (NO_x) emissions (Level 3 Plus) when in use in stationary prime and emergency standby (E/S) generators and pumps powered by 1996 or later certified off-road engines meeting 0.2 grams per brake horsepower hour (g/bhp-hr) diesel PM or less based on certification or in-use emissions testing and meet the U.S. EPA Tier 1, Tier 2, or Tier 3 off-road diesel engine certification standards. The Executive Order for the NETT GreenTRAP™ DPF, including a list of the applicable engine families, is attached.

The energy challenge facing California is real. Every Californian needs to take immediate action to reduce energy consumption. For a list of simple ways you can reduce demand and cut your energy costs, see our website: <http://www.arb.ca.gov>.

California Environmental Protection Agency

The verification is valid provided the following operating criteria are met:

Parameter	Value
Application	Stationary Prime and E/S Power Generation and Prime and E/S Pumping
Engine Type	Diesel, with or without turbocharger, without Exhaust-Gas Recirculation (EGR), mechanically or electronically controlled, certified off-road engines meeting 0.2 g/bhp-hr diesel PM or less based on certification or in-use emission testing.
Minimum Exhaust Temperature for Filter Regeneration	The engine must operate at the load level required to achieve 400 degrees Celsius (°C) for a minimum of 30 minutes. Operation at lower temperatures is allowed, but only for a limited duration as specified below.
Maximum Consecutive Minutes Operating Below Passive Regeneration Temperature	300 Minutes
Number of Cold Start and 30 Minute Idle Sessions before Regeneration Required	10
Number of Hours of Operation Before Cleaning of Filter Required	2,000 when using diesel with <15 ppm sulfur.
Fuel	California diesel fuel with less than or equal to 15 ppm sulfur or a biodiesel blend provided that the biodiesel portion of the blend complies with ASTM International D6751, the diesel portion of the blend complies with CCR, title 13, sections 2281 and 2282 and the blend contains no more than 20 percent biodiesel by volume.
PM Verification Level	Level 3 Plus Verification: <ul style="list-style-type: none"> • PM – at least 85% reduction • NO₂ – meets January 2009 limit

Since there may be significant variations from application to application, NETT Technologies must review actual operating conditions (duty cycle, baseline emissions, exhaust temperature profiles, and engine backpressure) prior to retrofitting an engine with a NETT GreenTRAP™ DPF to ensure compatibility.

Furthermore, the engine on which the NETT GreenTRAP™ DPF is installed should be well maintained and not consume lubricating oil at a rate greater than that specified by

Mr. M. A. Mannan
July 13, 2009
Page 3

the engine manufacturer. NETT Technologies must install the NETT PT LOG™ back pressure monitor, or equivalent, on all engines retrofitted with a NETT GreenTRAP™ DPF.

ARB hereby assigns the NETT GreenTRAP™ DPF the designated family name of:

CA/NET/2009/PM3+/N00/ST/DPF01

This identification number should be used in reference to this verification as part of the system labeling requirement.

Additionally, as stated in the Diesel Emission Control Strategy Verification Procedure, NETT Technologies is responsible for honoring their warranty (CCR, title 13, section 2707) and conducting in-use compliance testing (CCR, title 13, section 2709).

Should you have any questions or comments, please contact Mr. John Lee, Air Resources Engineer at (916) 327-5975.

Sincerely,

/s/

Robert D. Fletcher, Chief
Stationary Source Division

Attachments

cc: John Lee
Air Resources Engineer
Control Strategies Section