

Subpart E - Standards of Performance for Incinerators

Applicability - §60.50

General	<ol style="list-style-type: none">1.) This subpart is applicable to each incinerator of more than 45 metric tons per day charging rate (50 tons/day).2.) Any facility above that commences construction or modification after August 17, 1971, is subject to the requirements of this subpart.
---------	---

Emission Standards - §60.52

Source	PM
General	On and after the date on which the performance test required to be conducted is completed, no facility shall emit any gases which contain particulate matter in excess of 0.18 g/dscm (0.08 gr/dscf) corrected to 12 percent CO ₂ .

Monitoring of Operations - §60.53

Source	All Emissions
General	<ol style="list-style-type: none">1.) Facility shall record the daily charging rates and hours of operation.

Test Methods and Procedures - §60.54

Source	All Emissions
General	<ol style="list-style-type: none">1.) In conducting the performance tests the facility shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in §60.54 (a-c).2.) The owner or operator shall determine compliance with the particulate matter standard using the procedures found in §60.54 (b) (1-2)3.) The owner or operator may use either of the procedures found in §60.54 (c) to determine the adjusted CO₂ concentration.