

Comment 1 for Distributed Generation Certification Regulation (dg06) - 45 Day.

First Name: Carlo
Last Name: Castaldini
Email Address: carlo@cmc-engineering.com
Affiliation: CMC-Engineering

Subject: Conflict with existing regulations
Comment:

DG equipment can be coupled with heat recovery equipment that is currently regulated for NOx emissions. An example would be a microturbine coupled with a packaged industrial or commercial size steam generator that is fired with a low emission burner. Since there is only one stack for such combined systems the total emissions from that single source would be the result of the DG and the burner for the steam generator. Under this situation, would the source be classified as a steam generator or a DG and which emission regulations would apply, the planned DG regulations or the existing boiler regulations? If the fuel burn rate in the DG is much smaller than the steam generator burn rate can the current steam generator regulations compensate for the added emissions from the DG.
Thank you.

Attachment:

Original File Name:

Date and Time Comment Was Submitted: 2006-09-28 14:30:38

No Duplicates.

Comment 2 for Distributed Generation Certification Regulation (dg06) - 45 Day.

First Name: Stephen
Last Name: Gillette
Email Address: sgillette@capstoneturbine.com
Affiliation: Capstone Turbine Corporation

Subject: October 19, 2006 Board Meeting
Comment:

The attached letter has been sent FedEx to the Clerk of the Board.
An electronic copy is included herewith for your reference.

Attachment: www.arb.ca.gov/lists/dg06/18-capstone_comments_carb_2007_16oct06.pdf

Original File Name: Capstone Comments CARB 2007 16Oct06.pdf

Date and Time Comment Was Submitted: 2006-10-17 10:35:20

No Duplicates.

Comment 3 for Distributed Generation Certification Regulation (dg06) - 45 Day.

First Name: Leslie

Last Name: Witherspoon

Email Address: Non-web submitted comment

Affiliation: Solar Turbines

Subject: Comment for Distributed Generation Certification Program

Comment:

Please see the attached comment.

Attachment: www.arb.ca.gov/lists/dg06/19-dg06-3.pdf

Original File Name: dg06-3.pdf

Date and Time Comment Was Submitted: 2006-10-17 16:35:11

No Duplicates.

Comment 4 for Distributed Generation Certification Regulation (dg06) - 45 Day.

First Name: James

Last Name: Watts

Email Address: Non-web submitted comment

Affiliation: Ingersoll Rand

Subject: Comments from Ingersoll Rand to Proposed Reg. Order Amendments to the Distributed Gen.

Comment:

Please see the attached comment.

Attachment: www.arb.ca.gov/lists/dg06/41-dg06-4.pdf

Original File Name: dg06-4.pdf

Date and Time Comment Was Submitted: 2007-06-04 11:20:25

No Duplicates.

There are no comments posted to Distributed Generation Certification Regulation (dg06) that were presented during the Board Hearing at this time.