



# Transcritical CO<sub>2</sub> Supermarket Refrigeration

BY COLLIN WEBER, ASSOCIATE MEMBER ASHRAE; HARRISON HORNING, P.E.

Hannaford Supermarkets opened a store in Turner, Maine, featuring the first transcritical (TC) carbon dioxide supermarket refrigeration system in the United States. The two-year-old, 35,000 ft<sup>2</sup> (3252 m<sup>2</sup>) new-construction supermarket includes conditioned and refrigerated merchandising space, as well as food preparation areas and offices. The TC CO<sub>2</sub> refrigeration system serves a total of 740 kBtu/h (217 kW) of combined low- and medium-temperature loads, while providing high-quality waste heat that meets much of the store's space heating needs.

From Fall 2013 through Summer 2014, Hannaford partnered with the U.S. Department of Energy's Better Buildings Alliance (<http://tinyurl.com/qbxucjf>) to conduct a study comparing the site to a legacy store in Bradford, Vermont, that uses a hydrofluorocarbon (HFC) refrigeration system. During the one-year data collection period, the TC CO<sub>2</sub> system achieved approximate energy parity with the HFC system, while reducing storewide carbon equivalent emissions by 12%. The full report, Case Study: Transcritical Carbon Dioxide Supermarket Refrigeration Systems, is available at <http://tinyurl.com/qbrx4hs>.

## Installation Overview and Study Background

TC CO<sub>2</sub> systems, unlike carbon dioxide cascade systems, use carbon dioxide as the sole working fluid. The TC cycle, as the name suggests, involves cycling of the refrigerant between the subcritical and supercritical phases. When a refrigeration system is operating transcritically, heat rejection occurs above the critical pressure, while cooling takes place below the critical pressure. The use of carbon dioxide as the sole working fluid and the inherent high working pressure arising from it is the driver of many design differences between TC CO<sub>2</sub> booster systems and conventional refrigeration systems.

Collin Weber is a managing consultant with Navigant Consulting in Washington, D.C. Harrison Horning, P.E., is a director of equipment purchasing, maintenance and energy at Delhaize America in Scarborough, Maine.

TABLE 1 Refrigeration system profiles.		
REFRIGERATION LOAD TYPE	BRADFORD (HFC)	TURNER (TC)
Low-Temperature Reach-In Cases (Number of Doors)	102	102
Low-Temperature Island Cases (ft)	28	28
Medium-Temperature Open Cases (ft)	318	314
Medium-Temperature Reach-In Cases (Number of Doors)	49	49
Walk-In Coolers	4	4
Walk-In Freezers	2	2
Total Refrigeration Load (Btu/h)	750,000	740,000
Total Installed Compressor Power (hp)	181	201
Type of Expansion Valves	EEV (Pulse Type)	EEV (Stepper Type)
Defrost Scheme	Electric	Hot Gas

Compressor output pressure often exceeds 1,000 psia (6895 kPa).

While a mature technology in Europe and Canada, TC CO<sub>2</sub> refrigeration is in the early stages of deployment in the United States. Motivated by the success of the technology in other cold-weather regions, Northeastern U.S. retailer Hannaford elected to pilot a TC CO<sub>2</sub> refrigeration system in its new-construction supermarket in Turner, Maine. Hannaford worked with a supplier with significant experience in the sector to develop a system for its application.

The TC CO<sub>2</sub> system at the Hannaford store in Turner consists of a single rack for both medium- and low-temperature applications, comprising three low-temperature compressors and six medium-temperature TC compressors. The store uses an air-cooled gas cooler (the equivalent of the condenser in a conventional system) mounted on the roof for heat rejection. For heat reclaim, an array of heat exchangers is connected to the system using steel piping, which is commonly used in TC CO<sub>2</sub> systems due to the need to accommodate the extremely high compressor discharge pressures. The heat reclaim loop uses a propylene glycol and water mixture as the working fluid.

In addition to TC CO<sub>2</sub>, the refrigeration system also uses hot-gas defrost and stepper type electronic expansion valves (EEVs). Hannaford estimates that the incremental cost of the TC CO<sub>2</sub> system (over a prototypical brand-standard HFC system) was about 40% for the refrigeration equipment alone, in addition to a 10% to 15% incremental cost for piping and display

TABLE 2 Building HVAC specifications.		
HVAC SYSTEM PARAMETER	BRADFORD (HFC)	TURNER (TC)
Air Handler Outdoor Airflow Capacity (cfm)	4,100	5,000
Air Handler Supply Airflow Capacity (cfm)	36,100	34,000
Space Cooling Capacity (MBtu/h)	950	908
Estimated Heat Reclaim Capacity (MBtu/h) (Based On Available Heat of Rejection from Refrigeration)*	Up to 900	500–1,000
Nominal Heat Reclaim Loop Design Temperature (°F)	100	120
Nominal Boiler Output Capacity (MBtuH)	638	638

\*TC CO<sub>2</sub> systems differ from full condensing heat reclaim in that heat reclaim is conducted directly off the compressor discharge line. As a result, not all of the available waste heat is reclaimed. However, this configuration is better-suited to the characteristics of TC CO<sub>2</sub>, which performs inefficiently at the high heat rejection temperatures that would be needed to obtain high quality waste heat from a full-condensing type configuration applied to the CO<sub>2</sub> gas cooler.

cases. Additionally, due to the unique nature of this pilot project, installation and start-up costs were elevated above those associated with a prototypical HFC system.

In Spring 2013, Hannaford and the U.S. Department of Energy's Better Buildings Alliance Refrigeration Technology Solutions Team began a collaborative study of the TC CO<sub>2</sub> pilot site. The study focused on a year's worth of submetered energy data collected at the pilot store, and at a comparable store in the region, to evaluate the energy, climate, and operational impacts of implementing the TC CO<sub>2</sub> system.

### Study Site and Comparison Store

For the purposes of this study, Hannaford and DOE focused on the Turner TC CO<sub>2</sub> pilot store, and chose a supermarket using a conventional HFC-based system located in nearby Bradford, Vermont, as a baseline for comparison of the energy performance. Turner and Bradford (about 95 miles west of Turner) experience similar climates, and both stores are in ASHRAE Climate Zone 6A,<sup>1</sup> making them well-suited for comparison.

The supermarkets at the two sites have very similar layouts, refrigeration loads, and envelope characteristics. The number and configuration of the display cases and walk-in coolers/freezers is nearly identical in the two stores, and they share the same temperature set-points. *Tables 1 and 2* provide characteristics of the stores' refrigeration and HVAC systems.



## TECHNICAL FEATURE

### Heat Reclaim

Both stores compared in this case study use similar HVAC and heat reclaim systems. The main HVAC equipment has a direct expansion cooling coil, glycol/water heat reclaim coil, and glycol/water boiler coil, in that order. The heat reclaim system provides the primary means of space heating (i.e., the first stage of heat during the heating season) and reheat (for dehumidification of outdoor air during the cooling season). The boiler system provides auxiliary (second-stage) heat as needed.

The Bradford (HFC) system is set up for “full-condensing”<sup>2</sup> heat reclaim for heating in the winter, and reheat during active dehumidification in the summer. When space



heating is needed, the refrigeration system operates at elevated head pressures to achieve the condensing temperature desired for heat reclaim.

Maintaining an elevated head pressure during the heating season significantly increases electricity use. To mitigate this energy penalty, the Bradford store has three stages of heat reclaim, one per rack. For

many hours during the heating season, one or more of the refrigeration racks are not called for heating, and they continue to operate with a very efficient “floating head” strategy.<sup>3</sup>

In spite of the increased electricity use, the heat reclaim system displaces a significant amount of purchased fuel. Given the high cost of propane (the heating fuel available for rural stores in the Northeastern U.S.), Hannaford finds that this makes economic sense. The cost of electricity at Bradford is around \$0.115/kWh throughout the year,<sup>4</sup> but the winter prices of propane can rise to upwards of \$2 per gallon. On a per-Btu basis, this is analogous to a price of \$2.19 per therm of natural gas.<sup>5</sup> Operators having access to low-cost natural gas might reach

## Your Source for HVAC and Building Automation Solutions



Relays, Definite Purpose Contactors, Scroll Compressor Soft Starts and other products for HVAC OEMs



The innovative SBWEB BACnet Controller reduces labor and wiring costs



A wide variety of device level input and output devices for switches, lighting, etc.

For over 80 years, CARLO GAVAZZI has delivered high quality, cutting-edge components and systems to the market. Labor and wiring costs can often be 50% or more of the total cost of a typical building automation project. This cost can be significantly reduced by as much as 40% by using our industry proven Dupline® Fieldbus to concentrate hundreds of field devices like sensors, actuators, and lighting control

over a standard pair of wires to our SBWEB BACnet controller for seamless integration with any DDC.

CARLO GAVAZZI also offers energy meters and a wide range of products for HVAC OEMs, including definite purpose contactors, scroll compressor soft starters, electromechanical and solid state relays, and many more.

**GavazziOnline.com • 847.465.6100 • Info@CarloGavazzi.com**

[www.info.hotims.com/54433-20](http://www.info.hotims.com/54433-20)



# GET COMFORTABLE WITH HIGHER EFFICIENCY.

**Up to 99% with Lasting Durability.**

Engineered for high performance with ultra-reliability. RBI commercial boilers and water heaters are as strong as they are diverse. From 199 to 5,000 mbh...RBI has the solutions to any application.

[rbiwaterheaters.com](http://rbiwaterheaters.com)



Futera III



**RBI**<sup>®</sup>  
RELIABLE. BOLD. INNOVATIVE.

 A MESTEK COMPANY

[www.info.hotims.com/54433-7](http://www.info.hotims.com/54433-7)



## TECHNICAL FEATURE

a different conclusion regarding this space-heating technology.

In contrast to Bradford, the Turner system is set up for conventional series heat reclaim, leveraging the naturally high discharge temperatures of TC CO<sub>2</sub>. Due to the fundamental thermodynamics of a TC CO<sub>2</sub> process, “full-condensing” heat reclaim is not practical. However, the

high discharge temperatures allow for substantial heat recovery at moderate load conditions. (Note: It is considered uneconomical to pursue heat reclaim at high load conditions due to the high electricity demand at high discharge temperatures with TC CO<sub>2</sub> systems.)

When a low indoor temperature is recorded at Turner, the control system calls for the first stage

of heating and the racks switch over to heat-reclaim mode: hot gas from the compressor discharge is diverted through a heat exchanger on its way to the gas cooler. Heat recovery from the compressor discharge line occurs at about 120°F (49°C) in the glycol/water loop, compared to a nominal heat glycol/water design temperature of about 100°F (38°C) at the Bradford store.


The higher reclaim temperature at Turner allows for smaller coils and lower airflow than are needed in the HVAC system at Bradford. The Turner heat reclaim system also appears, nearly two years into its operation, to be more intuitive than the Bradford system and is likely to have better persistence of savings after initial commissioning.

### Site Data Collection

Hannaford monitored the stores for one year, from September 2013 to August 2014, for the purposes of this case study. Hannaford collected submetered electric data at each compressor rack, as well as the gas cooler and glycol pump for the Turner TC CO<sub>2</sub> system, at five-minute intervals. In addition, Hannaford monitored monthly utility bills (electricity and propane) to evaluate the effect of heat reclaim from the TC CO<sub>2</sub> system on building heating, ventilating, and air-conditioning energy use.<sup>6</sup>

## HOW RENEWAIRE DOES DOAS:

**100% outdoor air  
+ 0% exhaust air transfer  
100% total ventilation solution**



RD2XIN unit shown



1-800-627-4499  
renewaire.com

[www.info.hotims.com/54433-27](http://www.info.hotims.com/54433-27)

When you need major horsepower  
in a tight space.



Tune-in to see AERCO on "Operation Build"  
airing on History Channel and H2!

9/26 at 7:30am ET/PT on History Channel

10/3 at 7:30am ET/PT on H2

Visit [aerco.com](http://aerco.com) or [OperationBuild.tv](http://OperationBuild.tv) for more details.



There's nothing small about its performance...just its dimensions.

AERCO's Benchmark 6000 boiler packs six million BTU/hr., 94.5% efficiency and unmatched reliability into a compact footprint that's a third the size of the competition. You can park it anywhere.

**AERCO**®

A Watts Water Technologies Company


AERCO International Inc.

800.526.0288 ■ [aerco.com](http://aerco.com)



## TECHNICAL FEATURE

FIGURE 1 Comparison of refrigeration system monthly electricity consumption.




Hannaford also installed additional electric submeters to capture the energy use of systems that differed between the stores. Specifically, the Turner store featured a well and a wastewater treatment facility. Additionally, there were differences in exterior lighting between the two sites. Submetering of these disparate loads allowed the net energy consumption data to be adjusted to provide a more accurate comparison between the sites.

### Measured Energy Performance

Refrigeration system energy consumption, comprising the energy use of the compressor rack and gas cooler or condenser, was captured and plotted on a monthly basis for the two stores. As can be seen in Figure 1, the TC CO<sub>2</sub> system's electricity consumption is within the same range as that of the conventional system in Bradford. The electricity consumption is higher in the hotter months (by up to 14%) and is nearly equal or lower (by up to 18%) in winter.

Figure 2 compares monthly electricity consumption of the refrigeration system in Turner with the average monthly outdoor air temperature, accounting for the combined electricity use of the compressor racks, the glycol pump, and the gas cooler. Average daily and monthly temperatures were calculated from the submetered data, where, alongside refrigeration system energy consumption, the outdoor air temperature was also recorded at five-minute intervals. As expected, the electricity consumption of the TC CO<sub>2</sub> booster refrigeration system correlated with outdoor temperature.

FIGURE 2 Turner store temperature and power consumption trends—monthly.



### Climate Impacts

In addition to the energy profiles of the stores, the study also examined climate impacts. The main sources of climate impact are refrigerant leakage and propane use (direct impact) and electricity use (indirect impact). Chain-wide, Hannaford supermarkets average a leakage rate of about 15% annually, which is below the EPA national average leak rate estimate of 20%.<sup>7</sup> For the two supermarkets considered for this case study, measured annual refrigerant leakage was equal (200 lb [91 kg] of refrigerant per store over the year-long analysis period). Though the leakage masses are identical, the associated climate impacts differ tremendously due to the substantially higher global warming potential (GWP) of the HFC-407A refrigerant used in Bradford. Carbon dioxide emissions associated with burning propane at the locations were calculated using the U.S. EPA's Emission Factors for Greenhouse Gas Inventories.<sup>8</sup>

Indirect environmental impact was calculated from the electricity bills at both supermarkets over the course of the year using the publicly available EPA Climate Impact Calculator.<sup>9</sup> Table 3 compares the climate impacts (including direct and indirect impacts) of the two stores.

The direct leakage of refrigerant at Bradford constituted about one-third of the total climate impact of the refrigeration system. This is in line with the breakdown of impacts shown in past analytical studies of supermarket refrigeration life-cycle performance.<sup>10</sup> For the system in Turner, the direct impact is almost negligible.



Reliability    Part-load efficiencies    Full-load efficiency    Quiet operation    Superior control    Robust design    Low life cycle cost    Refrigerant choices



### Unlock the perfect combination of benefits.

Trane® Sintesis™ air-cooled chillers give you choices to meet your performance criteria, acoustic requirements and sustainability objectives. These chillers also offer you the choice of either R-134a or R-513A, a next-generation low global warming potential (GWP) refrigerant.



Sintesis chillers are part of the Ingersoll Rand EcoWise™ portfolio of high-efficiency products that can operate on next-generation, low-GWP refrigerants.



For more information, contact your Trane account manager or visit [Trane.com/Sintesis](http://Trane.com/Sintesis).



Scan the code or visit  
[Trane.com/Sintesis](http://Trane.com/Sintesis)  
to learn more.

© 2015 Trane  
Trane is a brand of Ingersoll Rand, a world leader in creating comfortable, sustainable and efficient environments.  
Ingersoll Rand's family of brands includes Club Car®, Ingersoll Rand®, Thermo King® and Trane®

[www.info.hotims.com/54433-30](http://www.info.hotims.com/54433-30)






## TECHNICAL FEATURE

TABLE 3 Direct and indirect whole-store climate impacts – September 2013 to July 2014.

		BRADFORD (HFC)	TURNER (TC)
Electricity Use	Site (kWh)	1,414,683	1,415,920
	Source (MtCO <sub>2</sub> Eq.)	975	976
Propane Use	Site (MMBtu)	766	1,543
	Source (MtCO <sub>2</sub> Eq.)	48.2	97.0
Refrigerant GWP	–	2,100	1
Refrigerant Leakage	(lb)	200	200
	(MtCO <sub>2</sub> Eq.)	191	0.1
Net Impact	(MtCO <sub>2</sub> Eq.)	1,214	1,073

On a full-store basis, the data indicate that the Turner store exhibited a 12% lower overall climate impact compared to the Bradford store over the data collection period, as shown by Figure 3. The Bradford store achieves refrigeration leakage rates well under the national average and uses a refrigerant (HFC-407A) that has almost half the GWP compared to

FIGURE 3 Net storewide climate impacts.



other conventional refrigerants (such as HFC-404A and HFC-507A). Therefore, the climate benefits achieved at the Turner store would be even more significant compared to many other conventional stores.

## HIGH TEMPERATURE, HOT WATER HTH SMARTER BY DESIGN

Designed to withstand today's ever increasing demands, the Evolve HTHW boiler achieves unparalleled operating efficiencies. While such performance justifies our claim as being the best, further investigation will reveal that we can justify other, more quantifiable claims such as having the lowest emissions, the fastest heating, and the easiest operation and maintenance in its class. Visit us online and see all the ways we're dominating this market. One look and you'll know you've arrived at the most intelligent HTHW choice available.



 **MADE IN U.S.A.**

 **100% IMPERVIOUS TO THERMAL SHOCK DAMAGE**

**25 YEAR WARRANTY**

 **MODERN HEAT EXCHANGER DESIGN**

**MAXIMUM ENGINEERING.  
MAXIMUM PERFORMANCE.  
MAXIMUM VALUE.**



**WE BACK OUR CLAIMS AT:**  
[EVOLVindustrial.com](http://EVOLVindustrial.com)

[www.info.hotims.com/54433-9](http://www.info.hotims.com/54433-9)



## THE REAL BEAUTY IS HOW MUCH IT **SAVES.**

IT'S NOT ONLY A MARVEL OF ENGINEERING, IT'S A WONDER OF ECONOMICS. JUST ONE AIRVOLUTION-D FAN CREATES THE SAME COOLING EFFECT AS 20 SMALL CEILING FANS AT A FRACTION OF THE ENERGY COSTS. SO YOU CAN COOL A 20,000 SQ. FT BUILDING FOR JUST PENNIES A DAY. **[MACROAIRFANS.COM/SAVING](http://MACROAIRFANS.COM/SAVING)**



[www.info.hotims.com/54433-56](http://www.info.hotims.com/54433-56)

© 2015 MacroAir Technologies, Inc. 1995-2015 All Rights Reserved

**MacroAir**  
engineers of air™



# METALAIRE™

comfortable  
environments





Dr. Johnson's examining room is now so comfortable that Jake actually enjoys his visit to the vet, thanks to the innovations in air quality control from **Metal Industries**.

## Round Retrofit Air Terminal Unit

Designed to  
regulate the flow  
of conditioned  
air in single  
or dual duct  
air distribution  
systems.

Series  
RT-500



metalaire.com



Metal Industries Inc.  
800-476-4646

PHOTO 2 Transcritical CO<sub>2</sub> compressors and oil separators.



## Lessons Learned

During the first year of operating the TC CO<sub>2</sub> system at Turner, Hannaford gained valuable experience in issues specific to this technology type. For example, during commissioning, pressure testing is critical due to the high working pressures of TC CO<sub>2</sub> systems. Further, strict adherence to ASHRAE Standards 15 and 34 (*Safety Standard for Refrigeration Systems* and *Designation and Classification of Refrigerants*, respectively) must be maintained. Even though CO<sub>2</sub> is not classified as toxic, it is an asphyxiant.


Additionally, careful control system operation and operator training are important, as control systems for TC CO<sub>2</sub> refrigeration systems differ from those used for conventional systems. The new control system installed in the Turner store (needed for the TC CO<sub>2</sub> booster system) also allowed store operators to more easily override lighting schedules and other controls compared to standard store formats. Steps had to be taken to mitigate operator unfamiliarity with the new configuration.

Due to the nascence of this technology, there may be concern regarding a lack of easily available components and replacement parts. To address this concern, Hannaford required the supplier to preemptively make parts available. An inventory of spares (a parts cabinet) was set up on site, and whenever a part was used, a replacement was procured. This alleviated concerns about unavailable or difficult-to-find replacement parts. Hannaford found this to be a convenient arrangement for this pilot, and benefited significantly by keeping a sustained relationship with the supplier during a pilot

[www.info.hotims.com/54433-41](http://www.info.hotims.com/54433-41)

# Chance of a **LIFETIME**

Nexus Valve is pleased to introduce the **NexLok™** connection system. The **NexLok™** system is HVAC's first industrial strength, push-fit, connection system available exclusively on Nexus Valve products with a **lifetime warranty**.



- Commercial Grade Construction and Materials
- No Tools - No Mess - No Flame
- Compatible with Copper, PEX & CPVC-CTS Tubing
- Designed, Assembled & Tested in the USA.
- **Lifetime Warranty**


← **NexLok™**

**UltraMatic™** - Combination Automatic Flow Control Valve, Ball Valve, and Union. Featuring **NexLok™**.



**NEXUS**  
VALVE

888.900.0947  
[www.nexusvalve.com](http://www.nexusvalve.com)  
[info@nexusvalve.com](mailto:info@nexusvalve.com)



[www.info.hotims.com/54433-25](http://www.info.hotims.com/54433-25)

**Ai** AALBERTS  
INDUSTRIES



## TECHNICAL FEATURE

project such as this, leveraging their resources and learning from their experience.

### Recommendations

Colder regions such as Maine have historically been targets for cost-effective implementation of TC CO<sub>2</sub> systems. However, suppliers claim that new developments have extended the climate range of the technology, making installations in warmer regions increasingly attractive. Little field data are currently available to substantiate those performance claims. We recommend more pilot installations with detailed documentation across a range of climate zones and operating conditions to demonstrate the performance of the newest evolutions in these systems.

### Notes and References

1. Climate Zone 6A is defined as Cold – Humid with  $7200 < \text{HDD } 65^\circ\text{F} \leq 9000$ .
2. In this heat reclaim scheme, the reclaim coil is placed in parallel with the refrigerant condenser, allowing effectively 100% of the

heat of rejection to be captured for heating use when the system is operating in heat reclaim mode.

3. In a floating head pressure control scheme, the condensing pressure is allowed to vary as a function of the ambient heat rejection temperature. Thus, at lower ambient temperatures, the condensing pressure is significantly reduced, and the compressor power needed decreases commensurately.

4. Based on Hannaford's utility bills for this store.

5. Based on heat content values for propane and natural gas from, respectively, DOE Alternative Fuels Data Center ([http://www.afdc.energy.gov/fuels/fuel\\_comparison\\_chart.pdf](http://www.afdc.energy.gov/fuels/fuel_comparison_chart.pdf)) and EIA NG Monthly, 2014 Average (<http://www.eia.gov/todayinenergy/detail.cfm?id=18371>).

6. Due to the time frame constraints on this study, utility bill data was only available through July 2014 at the conclusion of the study period, so whole-store impacts were evaluated from September 2013 through July 2014.

7. Estimate per EPA GreenChill Partnership; <http://www2.epa.gov/greenchill>.

8. Available at: <http://www.epa.gov/climateleadership/documents/emission-factors.pdf>.

9. The calculator is available at: <http://www.epa.gov/cleanenergy/energy-resources/calculator.html>.

10. Fricke, Brian A., Pradeep Bansal, and Shitong Zha. 2013. "Energy Efficiency and Environmental Impact Analyses of Supermarket Refrigeration Systems," ASHRAE Annual Meeting Conference Paper Session 7. ■

## TIP THE SCALE IN YOUR DIRECTION.

### Fastest Biodegradable Descaler Yet!

Goodway **ScaleBreak**® recaptures lost efficiency by eliminating water scale deposits faster in boilers, chillers, heat exchangers or any hydronic system.



**GOODWAY**®

CALL 888-364-3433  
[www.goodway.com](http://www.goodway.com)

## SurConnect™ XT

—Green means go

### Visual Indication of a Positive Connection



#### The XT Advantage

- Green ring indicates a secure connection
- Easily installed on existing XT Connectors or available fully assembled
- Compatible with standard industry quick connect tips

### Instant Connections for Expanded Tubes



**FastTest**®

Your Productivity Connection

[www.fastestinc.com](http://www.fastestinc.com) 1.800.444.2373

[www.info.hotims.com/54433-33](http://www.info.hotims.com/54433-33)

[www.info.hotims.com/54433-22](http://www.info.hotims.com/54433-22)