

VRF/VRV HVAC Systems and the Transition to Lower GWP Refrigerants


Doug Tucker

Director, Industry and Government Relations
Mitsubishi Electric US, Heating and Air
Conditioning Division


Variable Refrigerant Volume (VRV) Variable Refrigerant Flow (VRF)



- VRV and VRF systems are popular for saving energy and allowing better control of the interior environment
- The Mechanical Code permits these systems using current refrigerants
- Newer systems will likely be using A2L refrigerants
- The use of A2L refrigerants is not economical based on current requirements, however changes are being considered
- Not all A2L refrigerants are suitable for comfort cooling equipment and must be evaluated to ensure performance, efficiency, safety, etc.




Components in VRF and VRV




VRV and VRF Technology

- Both VRV and VRF use computer technology to control the heating and cooling in a building
- The system is considered a multi-split system (multiple indoor units) with refrigerant piping to an outdoor central unit
- Integrated controls determine when heating or cooling is required
- A system may be configured with different model types of Indoor Units to suit individual room requirements



Energy Efficiency Increases

- The purpose of a VRV or VRF system is to increase efficiency and comfort
- Heat recovery systems allow for cooling and heating simultaneously
- First costs can be higher than rooftop systems, but higher efficiencies can result in overall cost savings
- Individual rooms or zones may be turned on or off as may be needed without impacting comfort in other areas



Evaluation of RCL For VRF/VRV Systems

- The refrigerant concentration limit (RCL) becomes an important calculation for A2L refrigerants
- RCL is based on the LFL for flammable refrigerants
- Each space with an indoor unit must be evaluated for compliance with the RCL




Refrigerant Concentration Limit (RCL)

Refrigerant Concentration Limit (RCL):
“the refrigerant concentration limit, in air, determined in accordance with this standard and intended to reduce the risks of acute toxicity, asphyxiation and flammability hazards in normally occupied, enclosed spaces”

Expressed in pounds of refrigerant charge per 1000 cubic feet

AHRI Low-GWP AREP



List of Low GWP Candidates in Phase I

Baseline	Refrigerant	Composition	(Mass%)	Classification (Note 1)	GWP ₁₀₀ (Note 2)
R410A	ARM-70a	R-32/R-134a/R-1234yf	(50/10/40)	A2L	482
	D2Y60	R-32/R-1234yf	(40/60)	A2L	272
	DR-5	R-32/R-1234yf	(72.5/27.5)	A2L	490
	HPR1D	R-32/R-744/R-1234ze(E)	(60/6/34)	A2L	407
	L41a	R-32/R-1234yf/R-1234ze(E)	(73/15/12)	A2L	494
	L41b	R-32/R-1234ze(E)	(73/27)	A2L	494
	R32	R32	100	A2L	675
	R-32/R-134a	R-32/R-134a	(95/5)	A2L	713
	R-32/R-152a	R-32/R-152a	(95/5)	A2L	647

List of Low GWP Candidates in Phase II

Baseline	Refrigerant	Composition	(Mass%)	Classification (Note 1)	GWP ₁₀₀ (Note 2)
R410A	ARM-71a	R-32/R-1234yf/R-1234ze(E)	68/26/6	A2L	460
	DR-5A (R-454B)	R-32/R-1234yf	68.9/31.1	A2L	466
	DR-55	R-32/R-125/R-1234yf	67/7/26	A2L	698
	HPR2A	R-32/134a/1234ze(E)	76/6/18	A2L	600
	L-41-1 (R-446A)	R-32/R-1234ze/Butane	68/29/3	A2L	461
	L-41-2 (R-447A)	R-32/R-1234ze/R-125	68/28.5/3.5	A2L	583

2L “Lower Flammability” Class

F L A M M A B I L I T Y	SAFETY GROUP		
	Higher Flammability	A3	B3
	Flammable	A2	B2
	Lower Flammability	A2L	B2L
	No Flame Propagation	A1	B1
		Lower Toxicity	Higher Toxicity
		INCREASING TOXICITY	

Ammonia

R-410A

A2L: R-32, HFO-1234yf, R-454B, and new blends

The 2L safety group was introduced to differentiate the lower-GWP HFC refrigerants within class 2 based on *burning velocity*.

RCL Applicable to VRF/VRV

TABLE 1102.3
REFRIGERANT GROUPS, PROPERTIES, AND ALLOWABLE QUANTITIES⁸
[ASHRAE 34: TABLE 4-1, TABLE 4-2]

REFRIGERANT	CHEMICAL FORMULA	CHEMICAL NAME ¹ (COMPOSITION FOR BLENDS)	SAFETY GROUP ⁷	OEL ² (ppm)	POUNDS PER 1000 CUBIC FEET OF SPACE
R-11	CCl ₃ F	Trichlorofluoromethane	A1	C1000	0.39
R-12	CCl ₂ F ₂	Dichlorodifluoromethane	A1	1000	0.39

REFRIGERANT	CHEMICAL FORMULA	CHEMICAL NAME ¹ (COMPOSITION FOR BLENDS)	SAFETY GROUP ⁷	OEL ² (ppm)	POUNDS PER 1000 CUBIC FEET OF SPACE
R-22	CHClF ₂	Chlorodifluoromethane	A1	1000	13
R-23	CHF ₃	Trifluoromethane	A1	1000	7.3
R-30	CH ₂ Cl ₂	Dichloromethane (methylene chloride)	B1	—	—
R-31	CH ₂ ClF	Chlorofluoromethane	—	—	—
R-32	CH ₂ F ₂	Difluoromethane (methylene fluoride)	A2L	1000	4.8
R-410A	zeotrope	R-32/125 (50.0/50.0)	A1	1000	26

R-41	CH ₃ F	Fluoromethane (methyl fluoride)	A1	1000	13
R-50	CH ₄	Methane	A1	1000	7.3
R-113	CCl ₂ FCFCl ₂	1, 1, 2-trichloro-1, 2, 2-trifluoroethane	A1	1000	13
R-114	CClF ₂ CClF ₂	1, 2-dichloro-1, 1, 2, 2-tetrafluoroethane	A1	1000	13
R-115	CClF ₂ CF ₃	Chloropentafluoroethane	A1	1000	13
R-116	CF ₃ CF ₃	Hexafluoroethane	A1	1000	13
R-123	CHCl ₂ CF ₃	2, 2-dichloro-1, 1, 1-trifluoroethane	B1	50	3.5
R-124	CHClFCF ₃	2-chloro-1, 1, 1, 2-tetrafluoroethane	A1	1000	3.5
R-125	CHF ₂ CF ₃	Pentafluoroethane	A1	1000	23
R-134a	CH ₂ FCF ₃	1, 1, 1, 2-tetrafluoroethane	A1	1000	13

Charge size of an A2L refrigerant is 18.5% the charge size of an A1

Risk Mitigation Methods

A1

- Refrigerant Concentration Limit is based on either the Oxygen Deprivation Limit (ODL) or the Acute Toxicity Exposure Limit (ATEL)
- Maximum Refrigerant Concentration [System Charge divided by the volume of the space] must not exceed the RCL



A2L



- RCL = Flammable Concentration Limit = 25% of the Lower Flammability Limit (ASHRAE 34)
- Leak tightness
- Limits on charge size
- Refrigerant detection
- Air circulation & ventilation
- Shut-off valves
- Eliminate or reduce proximity to sources of ignition
- Warnings and signage
- Operation, Installation and Service Manuals

ASHRAE Standard 15-2019

- Refrigerant concentration limits must not be exceeded, whether A1 or A2L
- For A2L systems, refrigerant detectors required when system charge $> 0.212 \times \text{LFL}$ (in lb.)
- Example, detector required for systems with charge of R-32 > 4 lb.
- When detector senses concentration above 25% LFL, minimum supply fan airflow rate must be $Q_{\min} = 1000 \times M / \text{LFL}$, where M = system charge
- Detector must be located in the indoor unit for ducted products

UL 60335-2-40 3rd Edition

Safety mitigation for systems with flammable refrigerants are based on the system refrigerant charge within three charge-level classifications: m1, m2, and m3, based on the lower flammability limit of the refrigerant. m1 is the lowest charge designation and m3 the maximum possible charge allowed for most systems with A2L-classified refrigerant. The charge designation determines which safety mitigation method must be provided with the system from the factory or during installation.

Unitary air conditioning systems with a charge less than m1 don't require safety controls, but from charges greater than m1, up to and including m3, it must have a mitigation safety control in the event a refrigerant leak occurs.

UL 60335-2-40 3rd Edition

Annex 101.DVG – Additional requirements for multi-split system appliances, provides stricter requirements for multi-split systems due to larger charge quantities that could leak from a single indoor unit.

Mitigation options do exist: natural ventilation, circulation airflow, mechanical ventilation, enhanced tightness, and limiting the releasable charge.


Mitigation options will likely be required in most multi-split application which will increase cost from design through installation.

UL 60335-2-40 3rd Edition

- Three forms of mitigation available for multi-split equipment:
 - **Mechanical Ventilation:** operate continuously or initiated by the refrigerant detection system
 - **Alarm Systems:** turn on with refrigerant detection; 70dBA at 3m; visible and audible in the occupied space
 - **Safety Shut-off Valves:** normally closed; close within 30 seconds; seat leakage requirements; Body leakage test

- Additional requirements specific to Multi-Split Systems
 - Maximum refrigerant charge is restricted
 - Larger Charge Size allowed with mitigation (see below)
 - Mitigation test and design requirements
 - More stringent strength tests
 - Specific installation design requirements
- Larger Charge Size: Enough to have a meaningful impact when factoring in mitigation costs?
 - 101.DVG.3.4 defines maximum refrigerant charge, below m_{max} no mitigation required.
$$m_{max} = 0.25 * LFL * H * A$$
 - 101.DVG.3.5 defines maximum refrigerant charge, below m_{max} one form of mitigation is required.
$$m_{max} = 0.5 * LFL * H * A$$
 - H = room height (2.2m max)
 - A = floor area (250m² max)

UL/CSA 60335-2-40 Allowances When Exceeding RCL in Room



- If a room or space with refrigerant piping exceeds the RCL, detection and ventilation are required when using Group A2L refrigerant
- Safety shut off valves can also be used to isolate the refrigerant piping
- The ventilation of the space maintains the refrigerant concentration below the lower flammable limit (LFL)

Questions???