

State of California
Environment Protection Agency
AIR RESOURCES BOARD

Notice of Decision

Project Title: Amendments To Vapor Recovery Certification And Test Procedures For Underground And Aboveground Storage Tanks Used At Gasoline Dispensing Facilities Including Gasoline Dispensing Facility Hose Regulation

Project Location: Statewide

Public Meeting Date: 09/22/2011; Agenda Item 11-7-4

Project Description: ARB staff worked with the California Independent Oil Marketers Association (CIOMA) and other industry representatives to develop revised language clarifying a statutory provision providing owners of existing Gasoline Dispensing Facilities (GDF) four years to replace their current equipment when new or amended standards and specifications become effective. The amendments to the underground storage tank Certification Procedure for Vapor Recovery Systems at Gasoline Dispensing Facilities (CP-201) and the Certification Procedure for Vapor Recovery Systems at Gasoline Dispensing Facilities Using Aboveground Storage Tanks (CP-206) improve clarity and readability, and amendments to the definitions in D-200 clarify and add terms used in the vapor recovery certification and test procedures. The amendments also provide a new certification performance standard for GDF hoses, limiting permeation to no more than 10.0 grams per square meter per day (g/m²/day). This standard will apply to hoses which carry liquid gasoline against the outermost hose wall.

Approved By: Air Resources Board
Executive Order R-12-004
Dated: July 26, 2012

This notice is to advise that ARB, as the lead agency, has adopted the above described *regulatory action on July 26, 2012 and determined that the regulatory action will not* have a significant adverse effect on the environment (see attached Executive Order R-12-004).

In accordance with CEQA and ARB's certified regulatory program, ARB prepared an environmental analysis as part of the Staff Report: Initial Statement of Reasons for Amendments to Vapor Recovery Certification And Test Procedures For Underground

And Aboveground Storage Tanks Used At Gasoline Dispensing Facilities Including Gasoline Dispensing Facility Hose Regulation

The Staff Report identified no significant adverse environmental effects and no comments were received identifying any significant environmental issues pertaining to this item.

No mitigation measures, findings, or statement of overriding considerations were adopted for this regulatory action because the regulation will not have a significant adverse impact on the environment.

The copy of the environmental analysis included in the Staff Report and the Final Statement of Reasons are available at the ARB rulemaking webpage at: <http://www.arb.ca.gov/regact/2011/evr11/evr11.htm>

These rulemaking documents may also be examined at:

California Air Resources Board
Attn: Board Administration and Regulatory Coordination Unit
1001 I Street
Sacramento, CA 95814

Certified: _____ /s/_____
ARB CEQA Unit

Date: July 27, 2012

Attachments:

- Executive Order R-12-004