APPENDIX G

HISTORICAL OPERATING DATA FROM CITY OF PASADENA WATER AND POWER DEPARTMENT

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA
SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1975	AUG	8	14:20	15:22	NATURAL GAS	0.10	1.0	4.1	4.0	73.0	0.0
1975	AUG	11	13:32	14:34	NATURAL GAS	0.10	1.0	4.1	4.0	49.0	0.0
1975	AUG	12	15:00	16:09	NATURAL GAS	0.10	1.1	4.6	4.0	106.0	0.0
1975	AUG	13	16:08	16:42	NATURAL GAS	0.10	0.6	2.3	4.0	105.0	0.0
1975	AUG	15	11:26	11:48	NATURAL GAS	0.10	0.4	1.5	4.0	103.0	0.0
1975	AUG	18	9:21	10:51	NATURAL GAS	0.10	1.5	15.0	10.0	90.0	0.0
1975	AUG	21	11:12	11:44	NATURAL GAS	0.10	0.5	6.4	12.0	90.0	0.0
1975	AUG	22	14:10	16:09	NATURAL GAS	0.10	2.0	27.8	14.0	104.0	0.0
1975	AUG	25	13:53	14:27	NATURAL GAS	0.10	0.6	7.9	14.0	106.0	0.0
1975	AUG	27	13:46	14:06	NATURAL GAS	0.10	0.3	4.7	14.0	44.0	0.0
1975	AUG	29	15:00	15:20	NATURAL GAS	0.10	0.3	3.3	10.0	69.0	0.0
1975	SEP	10	8:39	9:16	NATURAL GAS	0.10	0.6	3.1	5.0	66.0	0.0
1975	SEP	11	14:42	15:52	NATURAL GAS	0.10	1.2	4.7	4.0	69.0	0.0
1975	SEP	16	12:35	12:55	NO. 2 FUEL OIL	0.10	0.3	6.7	20.0	64.0	0.0
1975	SEP	17	13:50	15:03	NATURAL GAS	0.10	1.2	24.3	20.0	72.0	0.0
1975	NOV	7	12:30	12:55	NO. 2 FUEL OIL	0.10	0.4	1.7	4.0	41.0	0.0
1975	NOV	10	14:53	15:16	NO. 2 FUEL OIL	0.10	0.4	1.5	4.0	41.0	0.0
1975	NOV	11	13:50	14:36	NO. 2 FUEL OIL	0.10	0.8	7.7	10.0	91.0	0.0
1975	NOV	14	14:23	16:26	NO. 2 FUEL OIL	0.10	2.0	67.6	33.0	113.0	0.0
1975	NOV	17	14:13	14:58	NO. 2 FUEL OIL	0.10	0.8	15.0	20.0	72.0	0.0
1975	NOV	18	10:47	13:31	NATURAL GAS	0.10	2.7	54.7	20.0	97.0	0.0
1975	NOV	19	13:58	16:10	NATURAL GAS	0.10	2.2	281.6	128.0	104.0	0.0
1975	NOV	24	15:31	16:04	NATURAL GAS	0.10	0.6	11.0	20.0	91.0	0.0
1975	DEC	17	11:24	12:18	NATURAL GAS	0.10	0.9	93.6	104.0	111.0	0.0
1976	JAN	17	12:56	14:06	NO. 2 FUEL OIL	0.10	1.2	4.7	4.0	61.0	0.0
1976	FEB	3	9:01	15:53	NO. 2 FUEL OIL	0.10	6.9	82.4	12.0	65.0	0.0
1976	FEB	4	9:08	14:38	NO. 2 FUEL OIL	0.10	5.5	154.0	28.0	102.0	0.0
1976	FEB	5	8:24	10:04	NO. 2 FUEL OIL	0.10	1.7	13.3	8.0	81.0	0.0
1976	FEB	6	6:48	7:46	NO. 2 FUEL OIL	0.10	1.0	14.5	15.0	72.0	0.0
1976	FEB	11	18:16	22:07	NATURAL GAS	0.10	3.8	103.9	27.0	66.0	0.0
1976	FEB	17	9:02	13:42	NO. 2 FUEL OIL	0.10	4.7	102.7	22.0	69.0	0.0
1976	FEB	18	8:12	12:25	NO. 2 FUEL OIL	0.10	4.2	105.4	25.0	70.0	0.0
1976	FEB	23	11:04	11:25	NO. 2 FUEL OIL	0.10	0.3	1.4	4.0	107.0	0.0
1976	FEB	24	9:32	13:14	NO. 2 FUEL OIL	0.10	3.7	37.0	10.0	73.0	0.0
1976	FEB	26	14:59	15:51	NO. 2 FUEL OIL	0.10	0.9	5.2	6.0	76.0	0.0
1976	MAR	1	8:45	10:32	NO. 2 FUEL OIL	0.10	1.8	23.2	13.0	72.0	0.0
1976	MAR	2	8:28	10:37	NO. 2 FUEL OIL	0.10	2.1	30.1	14.0	72.0	0.0
1976	MAR	4	9:52	11:36	NO. 2 FUEL OIL	0.10	1.7	22.5	13.0	71.0	0.0
1976	MAR	6	18:01	21:00	NO. 2 FUEL OIL	0.10	3.0	29.8	10.0	47.0	0.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA
SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1976	MAR	7	18:05	20:08	NO. 2 FUEL OIL	0.10	2.0	20.5	10.0	85.0	0.0
1976	MAR	8	8:05	11:35	NO. 2 FUEL OIL	0.10	3.5	35.0	10.0	65.0	0.0
1976	MAR	13	17:28	19:31	NO. 2 FUEL OIL	0.10	2.0	20.5	10.0	84.0	0.0
1976	MAR	16	13:44	17:23	NATURAL GAS	0.10	3.6	91.2	25.0	76.0	0.0
1976	MAR	18	9:45	20:09	NO. 2 FUEL OIL	0.10	10.4	187.2	18.0	68.0	0.0
1976	MAR	19	8:24	21:34	NO. 2 FUEL OIL	0.10	13.2	144.8	11.0	66.0	0.0
1976	MAR	25	11:09	17:22	NATURAL GAS	0.10	6.2	161.6	26.0	73.0	0.0
1976	MAR	26	14:00	14:40	NO. 2 FUEL OIL	0.10	0.7	2.7	4.0	72.0	0.0
1976	MAR	31	15:06	15:17	NO. 2 FUEL OIL	0.10	0.2	0.4	2.0	76.0	0.0
1976	APR	3	18:50	20:42	NO. 2 FUEL OIL	0.10	1.9	9.3	5.0	51.0	0.0
1976	APR	6	14:52	14:59	NO. 2 FUEL OIL	0.10	0.1	0.2	2.0	63.0	0.0
1976	APR	28	14:42	14:46	NO. 2 FUEL OIL	0.10	0.1	0.1	2.0	69.0	0.0
1976	APR	29	15:57	16:06	NATURAL GAS	0.10	0.2	0.5	3.0	70.0	0.0
1976	APR	30	10:44	14:33	NO. 2 FUEL OIL	0.10	3.8	45.8	12.0	82.0	0.0
1976	MAY	1	11:30	19:26	NO. 2 FUEL OIL	0.10	7.9	79.3	10.0	51.0	0.0
1976	MAY	11	14:36	14:47	NO. 2 FUEL OIL	0.10	0.2	0.4	2.0	87.0	0.0
1976	MAY	12	11:24	19:19	NATURAL GAS	0.10	7.9	87.1	11.0	93.0	0.0
1976	MAY	13	11:18	20:58	NO. 2 FUEL OIL	0.10	9.7	116.0	12.0	92.0	0.0
1976	MAY	14	11:50	16:00	NO. 2 FUEL OIL	0.10	4.2	50.0	12.0	89.0	0.0
1976	MAY	19	8:03	9:56	NO. 2 FUEL OIL	0.10	1.9	22.6	12.0	84.0	0.0
1976	MAY	24	13:41	14:25	NATURAL GAS	0.10	0.7	7.3	10.0	67.0	0.0
1976	MAY	25	13:31	13:46	NATURAL GAS	0.10	0.3	0.5	2.0	70.0	0.0
1976	JUN	3	11:18	11:48	NO. 2 FUEL OIL	0.10	0.5	1.0	2.0	70.0	0.0
1976	JUN	10	15:52	19:06	NO. 2 FUEL OIL	0.10	3.2	38.8	12.0	81.0	0.0
1976	JUN	12	8:55	22:51	NO. 2 FUEL OIL	0.10	13.9	111.5	8.0	28.0	0.0
1976	JUN	13	11:44	22:37	NO. 2 FUEL OIL	0.10	10.9	54.4	5.0	24.0	0.0
1976	JUN	14	9:28	10:45	NATURAL GAS	0.10	1.3	7.7	6.0	70.0	0.0
1976	JUN	15	10:29	22:27	NATURAL GAS	0.10	12.0	143.6	12.0	93.0	0.0
1976	JUN	18	11:41	17:18	NATURAL GAS	0.10	5.6	67.4	12.0	96.0	0.0
1976	JUN	22	11:08	16:31	NATURAL GAS	0.10	5.4	64.6	12.0	44.0	0.0
1976	JUN	23	10:26	20:18	NATURAL GAS	0.10	9.9	19.7	2.0	97.0	0.0
1976	JUN	24	10:30	21:42	NATURAL GAS	0.10	11.2	156.8	14.0	115.0	0.0
1976	JUN	25	9:26	20:33	NO. 2 FUEL OIL	0.10	11.1	155.6	14.0	113.0	0.0
1976	JUN	28	10:36	18:37	NO. 2 FUEL OIL	0.10	8.0	120.2	15.0	132.0	0.0
1976	JUN	29	9:11	15:58	NO. 2 FUEL OIL	0.10	6.8	81.4	12.0	114.0	0.0
1976	JUN	30	15:16	16:38	NO. 2 FUEL OIL	0.10	1.4	15.0	11.0	124.0	0.0
1976	JUL	1	11:10	17:36	NO. 2 FUEL OIL	0.10	6.4	96.5	15.0	94.0	0.0
1976	JUL	2	14:18	16:09	NO. 2 FUEL OIL	0.10	1.8	18.5	10.0	87.0	0.0
1976	JUL	4	16:57	18:09	NO. 2 FUEL OIL	0.10	1.2	12.0	10.0	41.0	0.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA
SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1976	JUL	6	13:09	20:50	NO. 2 FUEL OIL	0.10	7.7	92.2	12.0	94.0	0.0
1976	JUL	7	9:50	12:18	NO. 2 FUEL OIL	0.10	2.5	27.1	11.0	107.0	0.0
1976	JUL	12	10:13	12:34	NO. 2 FUEL OIL	0.10	2.3	25.8	11.0	92.0	0.0
1976	JUL	14	12:58	17:22	NO. 2 FUEL OIL	0.10	4.4	52.8	12.0	91.0	0.0
1976	JUL	19	13:07	20:16	NATURAL GAS	0.10	7.1	143.0	20.0	75.0	0.0
1976	JUL	20	10:56	17:52	NATURAL GAS	0.10	6.9	76.3	11.0	95.0	0.0
1976	JUL	21	13:56	15:26	NO. 2 FUEL OIL	0.10	1.5	31.5	21.0	99.0	0.0
1976	JUL	27	11:38	11:59	NO. 2 FUEL OIL	0.10	0.3	0.7	2.0	102.0	0.0
1976	JUL	30	12:07	24:00	NO. 2 FUEL OIL	0.10	11.9	154.5	13.0	104.0	0.0
1976	JUL	31	0:00	0:54	NO. 2 FUEL OIL	0.10	0.9	9.9	11.0	25.0	0.0
1976	AUG	5	10:23	13:29	NO. 2 FUEL OIL	0.10	3.1	49.6	16.0	84.0	0.0
1976	AUG	6	8:44	9:50	NO. 2 FUEL OIL	0.10	1.1	13.2	12.0	76.0	0.0
1976	AUG	9	7:59	10:30	NO. 2 FUEL OIL	0.10	2.5	30.2	12.0	74.0	0.0
1976	AUG	11	9:40	18:50	NO. 2 FUEL OIL	0.10	9.2	73.3	8.0	86.0	0.0
1976	AUG	12	12:10	17:32	NO. 2 FUEL OIL	0.10	5.4	59.0	11.0	86.0	0.0
1976	AUG	17	14:10	15:52	NATURAL GAS	0.10	1.7	17.0	10.0	79.0	0.0
1976	AUG	26	9:42	18:16	NO. 2 FUEL OIL	0.10	8.6	111.4	13.0	78.0	0.0
1976	AUG	27	10:03	18:42	NO. 2 FUEL OIL	0.10	8.5	121.1	14.0	96.0	0.0
1976	AUG	28	13:05	17:22	NO. 2 FUEL OIL	0.10	4.3	42.8	10.0	80.0	0.0
1976	AUG	30	12:42	16:07	NO. 2 FUEL OIL	0.10	3.4	34.2	10.0	131.0	0.0
1976	SEP	15	11:32	12:04	NATURAL GAS	0.10	0.5	4.3	8.0	43.0	0.0
1976	SEP	24	8:54	15:35	NATURAL GAS	0.10	6.7	100.2	15.0	41.0	0.0
1976	SEP	29	14:44	16:45	NO. 2 FUEL OIL	0.10	2.0	24.2	12.0	45.0	0.0
1976	SEP	30	10:58	17:59	NO. 2 FUEL OIL	0.10	7.0	140.3	20.0	82.0	0.0
1976	OCT	15	16:11	16:18	NO. 2 FUEL OIL	0.10	0.1	0.2	2.0	35.0	0.0
1976	OCT	18	15:27	16:14	NO. 2 FUEL OIL	0.10	0.8	3.9	5.0	41.0	0.0
1976	OCT	22	13:10	14:24	NO. 2 FUEL OIL	0.10	1.2	7.4	6.0	35.0	0.0
1976	OCT	28	8:19	16:22	NO. 2 FUEL OIL	0.10	8.0	112.7	14.0	81.0	0.0
1976	OCT	29	8:01	16:54	NO. 2 FUEL OIL	0.10	8.9	97.7	11.0	86.0	0.0
1976	NOV	1	13:13	15:19	NO. 2 FUEL OIL	0.10	2.1	25.2	12.0	101.0	0.0
1976	NOV	11	13:30	13:47	NO. 2 FUEL OIL	0.10	0.3	0.6	2.0	109.0	0.0
1976	NOV	17	10:30	11:02	NO. 2 FUEL OIL	0.10	0.5	1.6	3.0	35.0	0.0
1976	NOV	19	16:05	20:15	NO. 2 FUEL OIL	0.10	4.2	66.7	16.0	34.0	0.0
1976	NOV	24	11:43	16:38	NO. 2 FUEL OIL	0.10	4.9	49.2	10.0	31.0	0.0
1976	NOV	27	17:10	22:22	NO. 2 FUEL OIL	0.10	5.2	67.6	13.0	58.0	0.0
1976	DEC	6	9:55	10:39	NO. 2 FUEL OIL	0.10	0.7	2.9	4.0	24.0	0.0
1976	DEC	14	21:48	23:27	NO. 2 FUEL OIL	0.10	1.6	18.1	11.0	63.0	0.0
1976	DEC	16	11:23	14:49	NO. 2 FUEL OIL	0.10	3.4	51.5	15.0	51.0	0.0
1976	DEC	17	21:46	24:00	NO. 2 FUEL OIL	0.10	2.2	33.5	15.0	52.0	0.0

NEG = NEGLIGIBLE

ELECTRIC GAS TURBINE FIRING UNIT HISTORICAL OPERATING DATA
SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1976	DEC	18	0:00	0:23	NO. 2 FUEL OIL	0.10	0.4	2.7	7.0	69.0	0.0
1976	DEC	27	7:56	14:48	NO. 2 FUEL OIL	0.10	6.9	34.3	5.0	45.0	0.0
1977	JAN	4	21:43	22:54	NO. 2 FUEL OIL	0.10	1.2	11.8	10.0	74.0	0.0
1977	JAN	5	11:52	12:19	NO. 2 FUEL OIL	0.10	0.5	0.9	2.0	73.0	0.0
1977	JAN	11	9:04	23:07	NO. 2 FUEL OIL	0.10	14.0	168.6	12.0	76.0	0.0
1977	JAN	12	7:46	18:18	NO. 2 FUEL OIL	0.10	10.5	189.6	18.0	95.0	0.0
1977	JAN	13	15:00	15:47	NO. 2 FUEL OIL	0.10	0.8	1.6	2.0	81.0	0.0
1977	JAN	14	15:31	16:10	NO. 2 FUEL OIL	0.10	0.7	8.4	13.0	71.0	0.0
1977	JAN	17	6:13	16:14	NO. 2 FUEL OIL	0.10	10.0	200.3	20.0	90.0	0.0
1977	JAN	19	10:38	19:54	NO. 2 FUEL OIL	0.10	9.3	92.7	10.0	93.0	0.0
1977	JAN	20	15:58	21:58	NO. 2 FUEL OIL	0.10	6.0	66.0	11.0	90.0	0.0
1977	JAN	21	14:48	23:53	NO. 2 FUEL OIL	0.10	9.1	99.9	11.0	87.0	0.0
1977	JAN	22	8:01	23:31	NO. 2 FUEL OIL	0.10	15.5	186.0	12.0	86.0	0.0
1977	JAN	24	16:29	17:07	NO. 2 FUEL OIL	0.10	0.6	1.3	2.0	91.0	0.0
1977	JAN	27	8:05	19:17	NO. 2 FUEL OIL	0.10	11.2	89.6	8.0	89.0	0.0
1977	JAN	28	14:54	14:58	NO. 2 FUEL OIL	0.10	0.1	0.1	2.0	89.0	0.0
1977	FEB	1	7:07	10:16	NO. 2 FUEL OIL	0.10	3.1	15.7	5.0	93.0	0.0
1977	FEB	4	8:41	9:58	NO. 2 FUEL OIL	0.10	1.3	16.7	13.0	96.0	0.0
1977	FEB	7	7:09	22:15	NO. 2 FUEL OIL	0.10	15.1	302.0	20.0	96.0	0.0
1977	FEB	8	7:26	11:36	NO. 2 FUEL OIL	0.10	4.2	108.3	26.0	125.0	0.0
1977	FEB	9	18:00	20:43	NO. 2 FUEL OIL	0.10	2.7	27.2	10.0	97.0	0.0
1977	FEB	10	16:10	16:19	NO. 2 FUEL OIL	0.10	0.1	0.3	2.0	99.0	0.0
1977	FEB	17	9:50	10:19	NO. 2 FUEL OIL	0.10	0.5	2.9	6.0	92.0	0.0
1977	FEB	25	14:38	14:57	NO. 2 FUEL OIL	0.10	0.3	0.6	2.0	98.0	0.0
1977	FEB	28	10:12	17:15	NATURAL GAS	0.10	7.0	49.3	7.0	99.0	0.0
1977	MAR	1	15:58	16:10	NO. 2 FUEL OIL	0.10	0.2	1.2	6.0	93.0	0.0
1977	MAR	2	15:13	17:02	NO. 2 FUEL OIL	0.10	1.8	45.4	25.0	95.0	0.0
1977	MAR	3	17:55	20:17	NO. 2 FUEL OIL	0.10	2.4	26.0	11.0	99.0	0.0
1977	MAR	13	6:16	11:23	NO. 2 FUEL OIL	0.10	5.1	25.6	5.0	68.0	0.0
1977	MAR	18	8:14	10:02	NO. 2 FUEL OIL	0.10	1.8	7.2	4.0	45.0	0.0
1977	MAR	22	13:10	17:30	NATURAL GAS	0.10	4.3	43.3	10.0	101.0	0.0
1977	APR	8	10:45	11:32	NO. 2 FUEL OIL	0.10	0.8	8.6	11.0	85.0	0.0
1977	APR	13	8:23	9:08	NO. 2 FUEL OIL	0.10	0.8	15.0	20.0	99.0	0.0
1977	APR	19	8:28	9:28	NO. 2 FUEL OIL	0.10	1.0	20.0	20.0	96.0	0.0
1977	APR	21	9:52	17:04	NO. 2 FUEL OIL	0.10	7.2	86.4	12.0	106.0	0.0
1977	APR	25	9:42	17:27	NO. 2 FUEL OIL	0.10	7.8	85.3	11.0	105.0	0.0
1977	APR	26	10:04	17:16	NO. 2 FUEL OIL	0.10	7.2	86.4	12.0	105.0	0.0
1977	MAY	6	14:26	15:26	NATURAL GAS	0.10	1.0	11.0	11.0	85.0	0.0
1977	MAY	10	14:32	15:52	NO. 2 FUEL OIL	0.10	1.3	14.7	11.0	46.0	0.0

NEG = NEGLIGIBLE

HISTORICAL OPERATING DATA
SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1977	MAY	12	10:49	12:56	NO. 2 FUEL OIL	0.10	2.1	29.6	14.0	87.0	0.0
1977	MAY	13	15:40	15:45	NO. 2 FUEL OIL	0.10	0.1	0.2	2.0	86.0	0.0
1977	MAY	19	13:46	15:05	NO. 2 FUEL OIL	0.10	1.3	14.5	11.0	92.0	0.0
1977	JUN	2	13:17	15:55	NO. 2 FUEL OIL	0.10	2.6	29.0	11.0	86.0	0.0
1977	JUN	6	8:30	18:23	NO. 2 FUEL OIL	0.10	9.9	138.4	14.0	103.0	0.0
1977	JUN	10	11:49	17:09	NATURAL GAS	0.10	5.3	64.0	12.0	105.0	0.0
1977	JUN	20	11:56	17:06	NO. 2 FUEL OIL	0.10	5.2	56.8	11.0	100.0	0.0
1977	JUN	21	13:13	17:48	NATURAL GAS	0.10	4.6	50.4	11.0	101.0	0.0
1977	JUN	22	10:45	18:26	NO. 2 FUEL OIL	0.10	7.7	76.8	10.0	100.0	0.0
1977	JUN	23	10:48	18:38	NATURAL GAS	0.10	7.8	117.5	15.0	105.0	0.0
1977	JUN	24	10:04	19:46	NATURAL GAS	0.10	9.7	155.2	16.0	110.0	0.0
1977	JUN	27	10:03	22:15	NATURAL GAS	0.10	12.2	195.2	16.0	106.0	0.0
1977	JUN	29	9:14	22:27	NO. 2 FUEL OIL	0.10	13.2	211.5	16.0	113.0	0.0
1977	JUN	30	8:44	22:17	NO. 2 FUEL OIL	0.10	13.5	271.0	20.0	114.0	0.0
1977	JUL	1	9:07	19:18	NO. 2 FUEL OIL	0.10	10.2	162.9	16.0	109.0	0.0
1977	JUL	6	11:43	17:32	NO. 2 FUEL OIL	0.10	5.8	69.8	12.0	118.0	0.0
1977	JUL	7	9:08	19:05	NATURAL GAS	0.10	9.9	189.0	19.0	122.0	0.0
1977	JUL	8	9:18	19:00	NATURAL GAS	0.10	9.7	194.0	20.0	120.0	0.0
1977	JUL	11	9:49	18:04	NATURAL GAS	0.10	8.3	165.0	20.0	114.0	0.0
1977	JUL	12	8:59	17:59	NATURAL GAS	0.10	9.0	189.0	21.0	118.0	0.0
1977	JUL	13	11:46	11:49	NO. 2 FUEL OIL	0.10	0.0	0.1	2.0	110.0	0.0
1977	JUL	14	10:49	10:56	NO. 2 FUEL OIL	0.10	0.1	0.2	2.0	103.0	0.0
1977	JUL	16	12:15	18:00	NO. 2 FUEL OIL	0.10	5.8	86.3	15.0	104.0	0.0
1977	JUL	18	8:36	22:01	NO. 2 FUEL OIL	0.10	13.4	214.7	16.0	110.0	0.0
1977	JUL	19	8:52	19:27	NATURAL GAS	0.10	10.6	190.5	18.0	108.0	0.0
1977	JUL	21	13:32	17:20	NO. 2 FUEL OIL	0.10	3.8	76.0	20.0	134.0	0.0
1977	JUL	22	9:45	19:07	NATURAL GAS	0.10	9.4	168.6	18.0	121.0	0.0
1977	JUL	25	9:15	19:11	NATURAL GAS	0.10	9.9	158.9	16.0	127.0	0.0
1977	JUL	26	14:12	17:54	NO. 2 FUEL OIL	0.10	3.7	40.7	11.0	126.0	0.0
1977	JUL	27	11:18	18:33	NO. 2 FUEL OIL	0.10	7.3	79.8	11.0	130.0	0.0
1977	JUL	28	12:49	19:02	NO. 2 FUEL OIL	0.10	6.2	87.0	14.0	122.0	0.0
1977	JUL	29	8:54	24:00	NO. 2 FUEL OIL	0.10	15.1	286.9	19.0	114.0	0.0
1977	JUL	30	0:00	1:28	NO. 2 FUEL OIL	0.10	1.5	14.7	10.0	94.0	0.0
1977	AUG	1	9:13	19:26	NO. 2 FUEL OIL	0.10	10.2	143.0	14.0	127.0	0.0
1977	AUG	3	13:56	17:28	NO. 2 FUEL OIL	0.10	3.5	42.4	12.0	158.0	0.0
1977	AUG	5	9:10	19:02	NO. 2 FUEL OIL	0.10	9.9	187.5	19.0	131.0	0.0
1977	AUG	11	10:27	18:25	NO. 2 FUEL OIL	0.10	8.0	119.5	15.0	108.0	0.0
1977	AUG	12	12:00	17:18	NO. 2 FUEL OIL	0.10	5.3	68.9	13.0	124.0	0.0
1977	AUG	15	9:30	14:10	NO. 2 FUEL OIL	0.10	4.7	60.7	13.0	110.0	0.0

NEG = NEGLIGIBLE

SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1977	OCT	28	18:06	22:56	NO. 2 FUEL OIL	0.10	4.8	58.0	12.0	82.0	0.0
1977	OCT	29	11:22	11:47	NO. 2 FUEL OIL	0.10	0.4	0.8	2.0	86.0	0.0
1977	NOV	2	2:36	4:32	NO. 2 FUEL OIL	0.10	1.9	46.4	24.0	61.0	0.0
1977	NOV	3	2:04	4:02	NO. 2 FUEL OIL	0.10	2.0		16.0	46.0	0.0
1977	NOV	3	14:46	16:08	NO. 2 FUEL OIL	0.10	1.4	46.5	11.0	97.0	0.0
1977	NOV	10	9:17	10:06	NO. 2 FUEL OIL	0.10	0.8	1.6	2.0	103.0	0.0
1977	NOV	21	11:11	19:35	NO. 2 FUEL OIL	0.10	8.4	100.8	12.0	105.0	0.0
1977	DEC	5	8:59	16:29	NO. 2 FUEL OIL	0.10	7.5	90.0	12.0	79.0	0.0
1977	DEC	13	10:54	11:00	NO. 2 FUEL OIL	0.10	0.1	0.2	2.0	38.0	0.0
1977	DEC	19	8:49	13:47	NO. 2 FUEL OIL	0.10	5.0	104.3	21.0	66.0	0.0
1977	DEC	28	14:45	14:48	NO. 2 FUEL OIL	0.10	0.0	0.1	2.0	32.0	0.0

NEG = NEGLIGIBLE

SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1975	SEP	5	15:48	16:14	NATURAL GAS	0.10	0.4	2.6	6.0	62.0	0.0
1975	SEP	8	9:57	13:58	NATURAL GAS	0.10	4.0	24.1	6.0	68.0	0.0
1975	SEP	9	14:56	16:16	NATURAL GAS	0.10	1.3	12.0	9.0	76.0	0.0
1975	SEP	16	13:50	15:03	NATURAL GAS	0.10	1.2	7.3	6.0	78.0	0.0
1975	SEP	17	12:46	16:20	NATURAL GAS	0.10	3.6	71.3	20.0	102.0	0.0
1975	OCT	2	14:31	16:20	NATURAL GAS	0.10	1.8	29.1	16.0	75.0	0.0
1975	OCT	6	14:08	17:49	NO. 2 FUEL OIL	0.10	3.7	103.1	28.0	54.0	0.0
1975	OCT	7	15:16	16:59	NO. 2 FUEL OIL	0.10	1.7	54.9	32.0	109.0	0.0
1975	OCT	8	14:34	17:40	NO. 2 FUEL OIL	0.10	3.1	80.6	26.0	62.0	0.0
1975	OCT	13	9:27	10:03	NATURAL GAS	0.10	0.6	6.0	10.0	55.0	0.0
1975	OCT	14	15:59	17:46	NATURAL GAS	0.10	1.8	44.6	25.0	60.0	0.0
1975	OCT	17	14:56	15:52	NO. 2 FUEL OIL	0.10	0.9	14.0	15.0	67.0	0.0
1975	OCT	21	13:31	16:53	NATURAL GAS	0.10	3.4	67.3	20.0	57.0	0.0
1975	OCT	22	15:35	17:58	NO. 2 FUEL OIL	0.10	2.4	76.3	32.0	61.0	0.0
1975	OCT	24	14:12	16:28	NATURAL GAS	0.10	2.3	72.5	32.0	72.0	0.0
1975	NOV	13	13:53	15:18	NO. 2 FUEL OIL	0.10	1.4	8.5	6.0	104.0	0.0
1975	DEC	3	14:13	14:24	NO. 2 FUEL OIL	0.10	0.2	19.2	105.0	111.0	0.0
1975	DEC	4	15:45	18:12	NO. 2 FUEL OIL	0.10	2.4	29.4	12.0	88.0	0.0
1975	DEC	8	9:11	9:27	NO. 2 FUEL OIL	0.10	0.3	1.3	5.0	77.0	0.0
1975	DEC	9	15:28	16:00	NO. 2 FUEL OIL	0.10	0.5	3.2	6.0	79.0	0.0
1975	DEC	10	15:22	15:49	NO. 2 FUEL OIL	0.10	0.4	4.5	10.0	74.0	0.0
1975	DEC	12	16:13	16:16	NATURAL GAS	0.10	0.0	0.2	4.0	113.0	0.0
1975	DEC	15	14:10	14:49	NO. 2 FUEL OIL	0.10	0.6	6.5	10.0	72.0	0.0
1975	DEC	31	12:12	12:18	NO. 2 FUEL OIL	0.10	0.1	0.5	5.0	90.0	0.0
1976	JAN	2	10:41	10:52	NO. 2 FUEL OIL	0.10	0.2	0.7	4.0	71.0	0.0
1976	JAN	6	9:18	10:25	NO. 2 FUEL OIL	0.10	1.1	11.2	10.0	94.0	0.0
1976	JAN	7	13:47	16:50	NO. 2 FUEL OIL	0.10	3.0	61.0	20.0	74.0	0.0
1976	JAN	17	14:19	14:54	NO. 2 FUEL OIL	0.10	0.6	7.0	12.0	60.0	0.0
1976	JAN	21	13:58	14:42	NO. 2 FUEL OIL	0.10	0.7	53.5	73.0	73.0	0.0
1976	JAN	26	11:40	16:08	NO. 2 FUEL OIL	0.10	4.5	89.3	20.0	69.0	0.0
1976	JAN	27	8:30	15:46	NO. 2 FUEL OIL	0.10	7.3	145.3	20.0	69.0	0.0
1976	JAN	28	8:01	16:30	NO. 2 FUEL OIL	0.10	8.5	152.7	18.0	68.0	0.0
1976	JAN	29	8:38	10:10	NO. 2 FUEL OIL	0.10	1.5	4.6	3.0	63.0	0.0
1976	JAN	30	9:15	10:17	NATURAL GAS	0.10	1.0	17.6	17.0	71.0	0.0
1976	FEB	4	12:21	20:25	NO. 2 FUEL OIL	0.10	8.1	121.0	15.0	100.0	0.0
1976	FEB	5	16:50	18:13	NO. 2 FUEL OIL	0.10	1.4	27.7	20.0	75.0	0.0
1976	FEB	11	9:13	18:05	NATURAL GAS	0.10	8.9	221.7	25.0	65.0	0.0
1976	FEB	23	10:22	13:58	NO. 2 FUEL OIL	0.10	3.6	72.0	20.0	107.0	0.0
1976	MAR	9	8:02	14:56	NO. 2 FUEL OIL	0.10	6.9	193.2	28.0	70.0	0.0

NEG = NEGLIGIBLE

SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1976	MAR	11	15:35	16:47	NATURAL GAS	0.10	1.2	12.0	10.0	70.0	0.0
1976	MAR	12	13:41	14:19	NO. 2 FUEL OIL	0.10	0.6	2.5	4.0	71.0	0.0
1976	MAR	15	8:50	14:48	NO. 2 FUEL OIL	0.10	6.0	119.3	20.0	71.0	0.0
1976	MAR	16	9:26	10:50	NATURAL GAS	0.10	1.4	19.6	14.0	72.0	0.0
1976	MAR	17	9:00	14:31	NO. 2 FUEL OIL	0.10	5.5	82.7	15.0	78.0	0.0
1976	MAR	20	18:50	20:49	NO. 2 FUEL OIL	0.10	2.0	9.9	5.0	45.0	0.0
1976	MAR	22	10:45	16:00	NO. 2 FUEL OIL	0.10	5.3	63.0	12.0	76.0	0.0
1976	MAR	23	8:37	12:25	NO. 2 FUEL OIL	0.10	3.8	53.2	14.0	76.0	0.0
1976	MAR	28	5:43	9:39	NO. 2 FUEL OIL	0.10	3.9	39.3	10.0	51.0	0.0
1976	APR	1	9:02	10:11	NO. 2 FUEL OIL	0.10	1.1	4.6	4.0	68.0	0.0
1976	APR	6	15:10	15:13	NO. 2 FUEL OIL	0.10	0.0	0.1	2.0	63.0	0.0
1976	APR	8	14:27	15:00	NO. 2 FUEL OIL	0.10	0.6	1.1	2.0	69.0	0.0
1976	APR	9	15:16	16:25	NO. 2 FUEL OIL	0.10	1.1	14.9	13.0	64.0	0.0
1976	APR	10	18:10	20:14	NO. 2 FUEL OIL	0.10	2.1	20.7	10.0	47.0	0.0
1976	APR	12	15:23	15:37	NO. 2 FUEL OIL	0.10	0.2	0.5	2.0	65.0	0.0
1976	APR	14	13:15	14:25	NO. 2 FUEL OIL	0.10	1.2	18.7	16.0	66.0	0.0
1976	APR	15	11:25	13:19	NO. 2 FUEL OIL	0.10	1.9	43.7	23.0	69.0	0.0
1976	APR	17	15:10	20:12	NO. 2 FUEL OIL	0.10	5.0	60.4	12.0	42.0	0.0
1976	APR	19	15:17	15:56	NO. 2 FUEL OIL	0.10	0.6	1.3	2.0	71.0	0.0
1976	APR	20	11:52	13:07	NO. 2 FUEL OIL	0.10	1.3	15.0	12.0	77.0	0.0
1976	APR	22	13:52	14:57	NATURAL GAS	0.10	1.1	8.7	8.0	67.0	0.0
1976	APR	23	14:30	15:16	NO. 2 FUEL OIL	0.10	0.8	10.0	13.0	68.0	0.0
1976	APR	25	11:15	12:33	NO. 2 FUEL OIL	0.10	1.3	15.6	12.0	58.0	0.0
1976	APR	26	1:04	2:35	NO. 2 FUEL OIL	0.10	1.5	3.0	2.0	41.0	0.0
1976	MAY	1	16:19	16:36	NATURAL GAS	0.10	0.3	1.7	6.0	55.0	0.0
1976	MAY	3	15:07	15:09	NO. 2 FUEL OIL	0.10	0.0	0.1	2.0	73.0	0.0
1976	MAY	11	11:00	11:26	NO. 2 FUEL OIL	0.10	0.4	0.9	2.0	77.0	0.0
1976	MAY	14	13:29	15:08	NO. 2 FUEL OIL	0.10	1.6	19.8	12.0	92.0	0.0
1976	MAY	28	10:28	11:17	NO. 2 FUEL OIL	0.10	0.8	11.4	14.0	72.0	0.0
1976	JUN	2	8:22	10:48	NO. 2 FUEL OIL	0.10	2.4	48.7	20.0	74.0	0.0
1976	JUN	3	11:04	11:14	NO. 2 FUEL OIL	0.10	0.2	0.3	2.0	69.0	0.0
1976	JUN	4	14:40	15:09	NO. 2 FUEL OIL	0.10	0.5	3.4	7.0	71.0	0.0
1976	JUN	7	11:09	13:39	NO. 2 FUEL OIL	0.10	2.5	15.0	6.0	70.0	0.0
1976	JUN	10	8:00	9:26	NO. 2 FUEL OIL	0.10	1.4	22.9	16.0	100.0	0.0
1976	JUN	14	7:08	14:57	NO. 2 FUEL OIL	0.10	7.8	164.1	21.0	70.0	0.0
1976	JUN	16	10:30	18:19	NATURAL GAS	0.10	7.8	93.8	12.0	94.0	0.0
1976	JUN	20	11:08	16:31	NATURAL GAS	0.10	5.4	32.3	6.0	44.0	0.0
1976	JUN	21	8:06	9:51	NO. 2 FUEL OIL	0.10	1.8	29.8	17.0	89.0	0.0
1976	JUN	23	15:18	15:55	NO. 2 FUEL OIL	0.10	0.6	7.4	12.0	106.0	0.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA
SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1976	JUN	24	8:50	17:27	NO. 2 FUEL OIL	0.10	8.6	172.3	20.0	119.0	0.0
1976	JUN	25	10:46	19:48	NO. 2 FUEL OIL	0.10	9.0	171.6	19.0	113.0	0.0
1976	JUN	26	13:52	15:20	NATURAL GAS	0.10	1.5	17.6	12.0	98.0	0.0
1976	JUN	28	8:27	17:21	NO. 2 FUEL OIL	0.10	8.9	169.1	19.0	129.0	0.0
1976	JUN	29	15:48	17:51	NO. 2 FUEL OIL	0.10	2.0	24.6	12.0	117.0	0.0
1976	JUL	5	13:07	22:26	NO. 2 FUEL OIL	0.10	9.3	102.5	11.0	52.0	0.0
1976	JUL	6	12:19	18:06	NO. 2 FUEL OIL	0.10	5.8	69.4	12.0	110.0	0.0
1976	JUL	12	12:24	17:40	NO. 2 FUEL OIL	0.10	5.3	57.9	11.0	91.0	0.0
1976	JUL	13	13:13	16:49	NO. 2 FUEL OIL	0.10	3.6	39.6	11.0	83.0	0.0
1976	JUL	23	11:25	17:51	NO. 2 FUEL OIL	0.10	6.4	83.6	13.0	95.0	0.0
1976	JUL	26	9:36	12:13	NO. 2 FUEL OIL	0.10	2.6	36.6	14.0	101.0	0.0
1976	JUL	29	11:06	17:08	NATURAL GAS	0.10	6.0	78.4	13.0	91.0	0.0
1976	JUL	30	19:14	24:00	NATURAL GAS	0.10	4.8	57.2	12.0	60.0	0.0
1976	JUL	31	0:00	0:19	NATURAL GAS	0.10	0.3	3.2	10.0	25.0	0.0
1976	AUG	6	9:08	10:41	NO. 2 FUEL OIL	0.10	1.5	18.6	12.0	76.0	0.0
1976	AUG	11	14:19	17:41	NATURAL GAS	0.10	3.4	43.8	13.0	91.0	0.0
1976	AUG	19	16:06	16:42	NO. 2 FUEL OIL	0.10	0.6	1.2	2.0	82.0	0.0
1976	AUG	26	12:37	17:10	NO. 2 FUEL OIL	0.10	4.5	54.6	12.0	93.0	0.0
1976	AUG	27	8:43	17:43	NO. 2 FUEL OIL	0.10	9.0	126.0	14.0	96.0	0.0
1976	AUG	29	14:26	16:06	NO. 2 FUEL OIL	0.10	1.7	16.7	10.0	77.0	0.0
1976	AUG	30	16:12	17:37	NO. 2 FUEL OIL	0.10	1.4	14.2	10.0	94.0	0.0
1976	OCT	6	13:06	17:37	NO. 2 FUEL OIL	0.10	4.5	22.6	5.0	49.0	0.0
1976	OCT	7	11:50	18:00	NO. 2 FUEL OIL	0.10	6.2	49.3	8.0	50.0	0.0
1976	OCT	8	12:45	18:19	NO. 2 FUEL OIL	0.10	5.6	44.5	8.0	48.0	0.0
1976	OCT	11	12:38	17:50	NO. 2 FUEL OIL	0.10	5.2	46.8	9.0	45.0	0.0
1976	OCT	12	8:35	18:12	NO. 2 FUEL OIL	0.10	9.6	96.2	10.0	49.0	0.0
1976	OCT	13	12:02	17:30	NO. 2 FUEL OIL	0.10	5.5	54.7	10.0	61.0	0.0
1976	OCT	14	13:28	14:05	NATURAL GAS	0.10	0.6	3.7	6.0	54.0	0.0
1976	OCT	18	10:57	11:18	NO. 2 FUEL OIL	0.10	0.4	1.8	5.0	41.0	0.0
1976	OCT	28	8:34	9:36	NO. 2 FUEL OIL	0.10	1.0	13.4	13.0	5.0	0.0
1976	NOV	1	12:08	20:25	NO. 2 FUEL OIL	0.10	8.3	99.4	12.0	101.0	0.0
1976	NOV	8	13:47	17:08	NO. 2 FUEL OIL	0.10	3.3	33.5	10.0	54.0	0.0
1976	NOV	11	14:26	14:46	NO. 2 FUEL OIL	0.10	0.3	0.7	2.0	109.0	0.0
1976	NOV	23	9:34	11:55	NO. 2 FUEL OIL	0.10	2.3	11.7	5.0	64.0	0.0
1976	NOV	24	16:27	20:43	NO. 2 FUEL OIL	0.10	4.3	42.7	10.0	35.0	0.0
1976	NOV	29	7:57	23:05	NO. 2 FUEL OIL	0.10	15.1	136.2	9.0	52.0	0.0
1976	NOV	30	7:39	10:00	NO. 2 FUEL OIL	0.10	2.3	28.2	12.0	77.0	0.0
1976	DEC	1	16:56	19:20	NO. 2 FUEL OIL	0.10	2.4	12.0	5.0	37.0	0.0
1976	DEC	2	14:41	17:11	NO. 2 FUEL OIL	0.10	2.5	12.5	5.0	24.0	0.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA
SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1976	DEC	5	12:09	12:45	NO. 2 FUEL OIL	0.10	0.6	1.2	2.0	38.0	0.0
1976	DEC	13	21:28	22:53	NO. 2 FUEL OIL	0.10	1.4	7.1	5.0	39.0	0.0
1976	DEC	16	11:31	12:31	NO. 2 FUEL OIL	0.10	1.0	23.0	23.0	51.0	0.0
1976	DEC	23	12:48	22:09	NO. 2 FUEL OIL	0.10	9.3	140.2	15.0	79.0	0.0
1976	DEC	27	18:47	24:00	NO. 2 FUEL OIL	0.10	5.2	67.8	13.0	80.0	0.0
1976	DEC	28	0:00	0:19	NO. 2 FUEL OIL	0.10	0.3	3.2	10.0	73.0	0.0
1977	JAN	5	14:55	22:05	NO. 2 FUEL OIL	0.10	7.2	107.5	15.0	79.0	0.0
1977	JAN	11	8:43	9:12	NO. 2 FUEL OIL	0.10	0.5	3.4	7.0	80.0	0.0
1977	JAN	12	8:39	11:33	NO. 2 FUEL OIL	0.10	2.9	40.6	14.0	109.0	0.0
1977	JAN	14	11:34	12:19	NO. 2 FUEL OIL	0.10	0.8	11.3	15.0	78.0	0.0
1977	JAN	19	11:46	20:59	NO. 2 FUEL OIL	0.10	9.2	138.2	15.0	93.0	0.0
1977	JAN	20	16:11	20:43	NO. 2 FUEL OIL	0.10	4.5	49.9	11.0	90.0	0.0
1977	JAN	21	15:30	19:49	NO. 2 FUEL OIL	0.10	4.3	47.5	11.0	91.0	0.0
1977	JAN	23	16:20	22:50	NO. 2 FUEL OIL	0.10	6.5	71.5	11.0	82.0	0.0
1977	JAN	28	10:49	19:20	NO. 2 FUEL OIL	0.10	8.5	59.6	7.0	89.0	0.0
1977	FEB	10	7:16	7:22	NO. 2 FUEL OIL	0.10	0.1	0.2	2.0	92.0	0.0
1977	FEB	14	18:58	19:49	NO. 2 FUEL OIL	0.10	0.9	4.3	5.0	100.0	0.0
1977	FEB	24	10:44	11:18	NATURAL GAS	0.10	0.6	3.4	6.0	53.0	0.0
1977	FEB	25	10:30	14:15	NO. 2 FUEL OIL	0.10	3.8	37.5	10.0	101.0	0.0
1977	MAR	3	10:00	10:59	NATURAL GAS	0.10	1.0	6.9	7.0	110.0	0.0
1977	MAR	18	18:15	21:44	NO. 2 FUEL OIL	0.10	3.5	90.6	26.0	90.0	0.0
1977	MAR	24	16:46	18:34	NO. 2 FUEL OIL	0.10	1.8	21.6	12.0	97.0	0.0
1977	MAR	25	16:27	17:25	NO. 2 FUEL OIL	0.10	1.0	11.6	12.0	98.0	0.0
1977	MAR	28	14:43	15:27	NO. 2 FUEL OIL	0.10	0.7	3.7	5.0	99.0	0.0
1977	APR	6	10:26	17:48	NO. 2 FUEL OIL	0.10	7.4	88.4	12.0	103.0	0.0
1977	APR	27	9:46	15:56	NO. 2 FUEL OIL	0.10	6.2	74.0	12.0	101.0	0.0
1977	MAY	3	15:26	15:43	NATURAL GAS	0.10	0.3	0.6	2.0	86.0	0.0
1977	MAY	5	6:34	7:42	NO. 2 FUEL OIL	0.10	1.1	28.3	25.0	81.0	0.0
1977	MAY	16	11:51	14:06	NO. 2 FUEL OIL	0.10	2.3	29.3	13.0	87.0	0.0
1977	MAY	18	10:43	11:24	NATURAL GAS	0.10	0.7	7.5	11.0	90.0	0.0
1977	MAY	31	13:39	16:09	NO. 2 FUEL OIL	0.10	2.5	27.5	11.0	103.0	0.0
1977	JUN	2	14:02	14:14	NO. 2 FUEL OIL	0.10	0.2	0.4	2.0	86.0	0.0
1977	JUN	3	9:50	18:37	NO. 2 FUEL OIL	0.10	8.8	149.3	17.0	107.0	0.0
1977	JUN	7	11:07	17:18	NO. 2 FUEL OIL	0.10	6.2	92.7	15.0	113.0	0.0
1977	JUN	8	11:51	17:08	NO. 2 FUEL OIL	0.10	5.3	79.2	15.0	109.0	0.0
1977	JUN	9	11:46	17:06	NO. 2 FUEL OIL	0.10	5.3	53.3	10.0	102.0	0.0
1977	JUN	28	9:41	19:21	NO. 2 FUEL OIL	0.10	9.7	174.0	18.0	110.0	0.0
1977	JUN	29	13:28	16:43	NO. 2 FUEL OIL	0.10	3.3	35.8	11.0	124.0	0.0
1977	JUN	30	13:55	17:14	NO. 2 FUEL OIL	0.10	3.3	36.5	11.0	123.0	0.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA
SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1977	JUL	5	9:54	18:06	NO. 2 FUEL OIL	0.10	8.2	98.4	12.0	105.0	0.0
1977	JUL	6	9:35	19:36	NO. 2 FUEL OIL	0.10	10.0	180.3	18.0	127.0	0.0
1977	JUL	7	11:19	17:53	NO. 2 FUEL OIL	0.10	6.6	78.8	12.0	127.0	0.0
1977	JUL	8	11:12	17:15	NATURAL GAS	0.10	6.0	60.5	10.0	127.0	0.0
1977	JUL	11	13:13	16:43	NATURAL GAS	0.10	3.5	35.0	10.0	122.0	0.0
1977	JUL	12	11:56	16:36	NATURAL GAS	0.10	4.7	56.0	12.0	120.0	0.0
1977	JUL	13	9:18	18:00	NATURAL GAS	0.10	8.7	174.0	20.0	110.0	0.0
1977	JUL	14	9:56	18:19	NO. 2 FUEL OIL	0.10	8.4	150.9	18.0	103.0	0.0
1977	JUL	15	9:57	18:58	NO. 2 FUEL OIL	0.10	9.0	189.3	21.0	113.0	0.0
1977	JUL	18	14:11	18:20	NO. 2 FUEL OIL	0.10	4.1	49.8	12.0	119.0	0.0
1977	JUL	20	9:55	19:21	NO. 2 FUEL OIL	0.10	9.4	160.4	17.0	109.0	0.0
1977	JUL	21	9:34	23:08	NO. 2 FUEL OIL	0.10	13.6	230.6	17.0	114.0	0.0
1977	JUL	22	8:03	23:03	NO. 2 FUEL OIL	0.10	15.0	330.0	22.0	122.0	0.0
1977	JUL	23	9:33	17:07	NO. 2 FUEL OIL	0.10	7.5	90.8	12.0	109.0	0.0
1977	JUL	25	8:46	21:21	NO. 2 FUEL OIL	0.10	12.6	264.2	21.0	126.0	0.0
1977	JUL	26	9:15	19:11	NATURAL GAS	0.10	9.9	158.9	16.0	127.0	0.0
1977	JUL	27	8:42	23:02	NO. 2 FUEL OIL	0.10	14.3	215.0	15.0	123.0	0.0
1977	JUL	28	8:54	24:00	NO. 2 FUEL OIL	0.10	15.1	271.8	18.0	114.0	0.0
1977	JUL	29	13:31	17:25	NO. 2 FUEL OIL	0.10	3.9	42.9	11.0	128.0	0.0
1977	JUL	30	11:39	21:37	NO. 2 FUEL OIL	0.10	10.0	179.4	18.0	108.0	0.0
1977	AUG	1	14:59	16:30	NO. 2 FUEL OIL	0.10	1.5	16.7	11.0	144.0	0.0
1977	AUG	3	12:01	21:02	NO. 2 FUEL OIL	0.10	9.0	153.3	17.0	145.0	0.0
1977	AUG	4	8:41	19:28	NO. 2 FUEL OIL	0.10	10.8	172.5	16.0	122.0	0.0
1977	AUG	5	16:26	17:26	NO. 2 FUEL OIL	0.10	1.0	11.0	11.0	147.0	0.0
1977	AUG	6	11:12	16:14	NO. 2 FUEL OIL	0.10	5.0	55.4	11.0	92.0	0.0
1977	AUG	8	11:12	16:14	NO. 2 FUEL OIL	0.10	5.0	55.4	11.0	92.0	0.0
1977	AUG	9	14:55	15:16	NO. 2 FUEL OIL	0.10	0.4	1.4	4.0	104.0	0.0
1977	AUG	10	8:39	18:15	NO. 2 FUEL OIL	0.10	9.6	134.4	14.0	103.0	0.0
1977	AUG	11	15:11	16:32	NO. 2 FUEL OIL	0.10	1.3	14.8	11.0	117.0	0.0
1977	AUG	12	9:07	19:05	NO. 2 FUEL OIL	0.10	10.0	159.5	16.0	114.0	0.0
1977	AUG	15	13:42	18:38	NO. 2 FUEL OIL	0.10	4.9	88.8	18.0	112.0	0.0
1977	AUG	16	8:43	12:03	NO. 2 FUEL OIL	0.10	3.3	56.7	17.0	120.0	0.0
1977	AUG	18	13:28	21:33	NO. 2 FUEL OIL	0.10	8.1	88.9	11.0	111.0	0.0
1977	AUG	23	8:50	9:46	NO. 2 FUEL OIL	0.10	0.9	9.3	10.0	119.0	0.0
1977	AUG	24	11:05	11:08	NO. 2 FUEL OIL	0.10	0.0	0.1	2.0	220.0	0.0
1977	AUG	29	14:20	17:17	NO. 2 FUEL OIL	0.10	2.9	32.4	11.0	140.0	0.0
1977	AUG	31	9:20	17:31	NO. 2 FUEL OIL	0.10	8.2	114.6	14.0	121.0	0.0
1977	SEP	14	13:10	17:05	NO. 2 FUEL OIL	0.10	3.9	43.1	11.0	109.0	0.0
1977	SEP	15	10:25	17:15	NO. 2 FUEL OIL	0.10	6.8	75.2	11.0	115.0	0.0

NEG = NEGLIGIBLE

SOUTH COAST AIR BASIN

UTILITY: CITY OF PASADENA

ELECTRIC GENERATING STATION: CITY OF PASADENA, GLENARM STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)	AVERAGE STATION LOAD (MW)	AVERAGE SYSTEM LOAD (MW)
1977	SEP	30	7:54	10:58	NO. 2 FUEL OIL	0.10	3.1	42.9	14.0	98.0	0.0
1977	OCT	3	13:03	17:40	NO. 2 FUEL OIL	0.10	4.6	69.2	15.0	105.0	0.0
1977	OCT	14	14:58	16:28	NO. 2 FUEL OIL	0.10	1.5	30.0	20.0	112.0	0.0
1977	OCT	18	16:01	16:05	NO. 2 FUEL OIL	0.10	0.1	0.1	2.0	97.0	0.0
1977	OCT	20	14:11	16:27	NO. 2 FUEL OIL	0.10	2.3	34.0	15.0	89.0	0.0
1977	OCT	26	9:21	10:51	NATURAL GAS	0.10	1.5	19.5	13.0	920.0	0.0
1977	NOV	10	10:08	11:19	NO. 2 FUEL OIL	0.10	1.2	13.0	11.0	104.0	0.0
1977	NOV	23	9:45	11:51	NO. 2 FUEL OIL	0.10	2.1	23.1	11.0	103.0	0.0
1977	DEC	5	8:43	11:08	NO. 2 FUEL OIL	0.10	2.4	29.0	12.0	75.0	0.0
1977	DEC	7	8:55	14:06	NO. 2 FUEL OIL	0.10	5.2	57.0	11.0	87.0	0.0
1977	DEC	12	9:41	12:25	NO. 2 FUEL OIL	0.10	2.7	27.3	10.0	56.0	0.0
1977	DEC	15	19:06	23:05	NO. 2 FUEL OIL	0.10	4.0	39.8	10.0	68.0	0.0
1977	DEC	19	10:58	14:06	NO. 2 FUEL OIL	0.10	3.1	47.0	15.0	68.0	0.0
1977	DEC	28	10:45	10:49	NO. 2 FUEL OIL	0.10	0.1	0.1	2.0	36.0	0.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING

UTILITY: CITY OF PASADENA

STATION: CITY OF PASADENA, GLENARM STATION

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7:00 TO 8:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8:00 TO 9:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9:00 TO 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.7	0.0	0.0	0.0	1.7
10:00 TO 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.6	5.5	0.0	1.3	15.0
11:00 TO 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.5	6.0	0.5	4.3	0.0	19.3
12:00 TO 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.5	6.0	0.0	20.0	62.4	96.3
13:00 TO 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7.9	17.3	0.0	21.7	31.7	70.7
14:00 TO 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	30.1	9.7	17.0	0.0	63.5
15:00 TO 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.8	47.8	89.9	175.8	25.7	363.5
16:00 TO 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24.3	35.0	172.2	173.5	10.7	414.2
17:00 TO 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22.8	10.5	180.4	37.0	12.2	245.0
18:00 TO 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.0	0.0	90.3	0.0	12.0	102.3
19:00 TO 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.4	2.4
20:00 TO 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
21:00 TO 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22:00 TO 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	81.7	156.1	548.4	449.3	158.5	1394.0

GAS TURBINE PEAKING UNIT DAILY OPERATIONS

UTILITY: CITY OF PASADENA

STATION: CITY OF PASADENA, GLENARM STATION

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	13.1	0.0	0.0	0.0	0.0	5.8	18.9
1:00 TO 2:00	0.0	0.0	0.0	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.9
2:00 TO 3:00	0.0	0.0	0.0	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.2
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	2.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.8
6:00 TO 7:00	0.0	3.0	10.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.0
7:00 TO 8:00	0.0	11.5	10.0	0.0	0.0	18.2	0.0	0.2	0.0	0.0	4.6	0.3	44.9
8:00 TO 9:00	28.8	24.8	72.2	0.0	11.4	79.4	0.0	19.2	1.5	30.2	21.0	5.0	293.5
9:00 TO 10:00	60.7	114.6	145.7	3.9	11.2	130.3	7.4	53.0	15.0	42.8	23.2	5.3	613.1
10:00 TO 11:00	48.2	135.2	159.2	3.9	7.5	145.3	34.3	72.4	15.7	35.2	15.5	7.6	680.0
11:00 TO 12:00	44.7	143.4	153.7	36.0	26.8	195.2	79.5	65.0	38.7	37.8	16.5	25.4	862.7
12:00 TO 13:00	58.3	137.2	135.8	53.6	45.0	209.0	91.2	81.8	35.5	58.0	29.4	36.1	970.9
13:00 TO 14:00	68.8	117.1	137.9	33.7	54.9	208.5	147.6	98.9	35.0	82.7	43.1	35.0	1063.2
14:00 TO 15:00	136.5	69.8	145.8	28.8	61.5	216.3	182.0	114.9	38.2	77.9	53.7	32.8	1158.3
15:00 TO 16:00	73.3	55.7	96.5	25.0	46.7	206.1	173.1	123.7	40.7	77.7	44.8	20.0	983.4
16:00 TO 17:00	28.3	43.3	87.8	17.7	34.7	192.3	154.0	106.4	29.0	66.4	57.5	20.3	837.8
17:00 TO 18:00	0.0	60.0	53.4	12.0	33.0	142.4	121.0	71.6	19.7	41.6	59.2	20.9	634.9
18:00 TO 19:00	0.0	41.2	58.8	21.2	33.0	99.0	58.7	19.9	0.0	4.5	60.0	22.8	419.2
19:00 TO 20:00	0.0	42.0	59.2	27.0	19.8	71.4	65.2	0.0	0.0	0.0	60.0	29.7	374.2
20:00 TO 21:00	0.0	33.2	29.1	8.2	11.6	47.3	51.3	0.0	0.0	0.0	38.2	28.0	247.0
21:00 TO 22:00	0.0	27.0	6.2	0.0	0.0	34.8	36.0	0.0	0.0	0.0	22.0	36.4	162.4
22:00 TO 23:00	0.0	3.1	0.0	0.0	0.0	15.3	29.8	0.0	0.0	0.0	13.8	45.7	107.6
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	25.0	0.0	0.0	0.0	0.7	32.9	58.7
TOTAL	547.6	1062.2	1364.5	274.2	397.1	2010.8	1269.3	826.8	269.0	554.9	563.2	410.1	9549.8

GAS TURBINE PEAKING UNIT DAILY OPERATING PATTERN

UTILITY: CITY OF PASADENA

STATION: CITY OF PASADENA, GLENARM STATION

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	10.0	0.0	0.0	0.0	0.0	0.0	10.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	4.7	0.0	0.0	0.0	0.0	0.0	4.7
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24.5	0.0	24.5
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	40.0	0.0	40.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.3	0.0	13.3
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	15.7	0.0	3.7	0.0	10.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	30.2
7:00 TO 8:00	24.2	36.3	5.0	0.0	17.5	0.0	0.0	0.0	1.4	0.0	0.0	0.0	84.4
8:00 TO 9:00	64.0	55.1	8.1	23.0	0.0	12.3	43.1	16.4	14.0	0.0	0.0	8.4	244.5
9:00 TO 10:00	84.6	64.6	9.0	19.7	0.0	54.8	265.9	111.4	14.0	8.4	4.2	59.2	695.8
10:00 TO 11:00	88.9	61.4	12.0	55.7	5.7	120.6	410.2	131.2	19.9	11.0	20.7	66.8	1004.5
11:00 TO 12:00	105.0	54.4	1.9	64.9	20.3	162.8	444.5	155.7	11.0	0.8	22.6	70.6	1114.5
12:00 TO 13:00	107.4	37.0	0.0	59.0	26.1	205.0	498.8	173.6	11.0	0.0	12.0	63.2	1193.0
13:00 TO 14:00	102.0	37.0	8.3	59.0	19.4	228.3	536.5	185.1	20.2	14.2	12.0	54.4	1276.4
14:00 TO 15:00	105.6	30.1	11.4	59.0	34.7	249.4	573.6	211.0	22.0	27.9	14.6	14.7	1354.0
15:00 TO 16:00	141.7	27.0	32.0	58.2	26.9	248.1	578.0	233.0	22.0	50.0	23.0	12.0	1452.0
16:00 TO 17:00	154.2	27.3	45.4	47.0	1.6	234.9	570.4	212.7	22.0	31.2	13.5	5.8	1366.0
17:00 TO 18:00	152.2	21.8	23.7	18.5	0.0	163.8	509.7	164.6	3.7	10.0	12.0	0.0	1080.0
18:00 TO 19:00	139.4	30.2	37.3	0.0	0.0	115.7	356.6	114.1	0.0	10.8	12.0	0.0	816.1
19:00 TO 20:00	120.6	34.1	37.0	0.0	0.0	70.6	185.7	43.5	0.0	12.0	7.0	9.0	519.4
20:00 TO 21:00	94.6	27.2	29.1	0.0	0.0	52.0	146.0	28.0	0.0	12.0	0.0	10.0	398.9
21:00 TO 22:00	74.5	20.0	19.1	0.0	0.0	52.0	125.4	6.6	0.0	12.0	0.0	10.0	319.6
22:00 TO 23:00	54.4	5.0	0.0	0.0	0.0	16.9	91.3	0.0	0.0	11.2	0.0	10.0	188.7
23:00 TO 24:00	17.3	0.0	0.0	0.0	0.0	0.0	40.9	0.0	0.0	0.0	0.0	0.8	59.0
TOTAL	1646.3	568.5	283.1	464.1	163.1	1987.1	5391.2	1787.1	161.2	211.7	231.4	394.9	13289.8

APPENDIX H

HISTORICAL OPERATING DATA FROM SAN DIEGO GAS AND ELECTRIC COMPANY

Combined Fuel A is defined as a mixture of natural gas with No. 2 fuel oil.

Combined Fuel B is defined as a mixture of natural gas with diesel fuel.

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E DIVISION STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	21	10:15	11:35	DIESEL	0.30	1.3		
1975	JAN	21	14:46	14:50	DIESEL	0.30	0.1	28.0	20.0
1975	MAR	7	11:30	15:00	DIESEL	0.30	3.5	70.0	20.0
1975	JUN	27	13:32	14:18	DIESEL	0.30	0.8		
1975	JUN	27	15:17	15:33	DIESEL	0.30	0.3	20.7	20.0
1975	JUL	8	10:06	10:32	DIESEL	0.30	0.4		
1975	JUL	8	11:06	11:16	DIESEL	0.30	0.2	12.0	20.0
1975	AUG	4	9:25	10:50	DIESEL	0.30	1.4	28.3	20.0
1975	SEP	25	10:37	13:45	DIESEL	0.30	3.1	62.7	20.0
1975	NOV	13	10:56	11:23	DIESEL	0.30	0.5	9.0	20.0
1975	DEC	10	12:57	14:00	DIESEL	0.30	1.0	21.0	20.0
1976	JAN	6	7:53	10:03	DIESEL	0.26	2.2	43.3	20.0
1976	JAN	7	17:36	18:08	DIESEL	0.26	0.5	10.7	20.0
1976	JAN	11	7:33	7:59	DIESEL	0.26	0.4	8.7	20.0
1976	JAN	16	17:19	19:30	DIESEL	0.26	2.2	43.7	20.0
1976	JAN	21	4:17	5:50	DIESEL	0.26	1.5	31.0	20.0
1976	FEB	5	17:11	21:20	DIESEL	0.26	4.1	83.0	20.0
1976	FEB	6	17:33	19:05	DIESEL	0.26	1.5	30.7	20.0
1976	FEB	8	13:34	16:36	DIESEL	0.26	3.0	60.7	20.0
1976	FEB	9	9:32	13:03	DIESEL	0.26	3.5	70.3	20.0
1976	FEB	11	6:48	8:44	DIESEL	0.26	1.9	38.7	20.0
1976	FEB	13	9:26	12:24	DIESEL	0.26	3.0	59.3	20.0
1976	FEB	14	17:18	18:56	DIESEL	0.26	1.6	32.7	20.0
1976	FEB	17	17:06	20:10	DIESEL	0.26	3.1	61.3	20.0
1976	FEB	22	8:28	11:23	DIESEL	0.26	2.9	58.3	20.0
1976	FEB	25	9:23	10:45	DIESEL	0.26	1.4	27.3	20.0
1976	FEB	29	17:58	20:45	DIESEL	0.26	2.8	55.7	20.0
1976	MAR	1	17:30	21:23	DIESEL	0.26	3.9	77.7	20.0
1976	MAR	2	17:53	20:47	DIESEL	0.26	2.9	58.0	20.0
1976	MAR	3	17:56	19:40	DIESEL	0.26	1.7	34.7	20.0
1976	MAR	4	7:54	15:07	DIESEL	0.26	7.2		
1976	MAR	4	17:47	21:13	DIESEL	0.26	3.4	213.0	20.0
1976	MAR	6	9:00	12:02	DIESEL	0.26	3.0	60.7	20.0
1976	MAR	14	4:47	7:31	DIESEL	0.26	2.7	54.7	20.0
1976	MAR	15	5:42	9:01	DIESEL	0.26	3.3	66.3	20.0
1976	MAR	30	12:55	13:50	DIESEL	0.26	0.9	18.3	20.0
1976	APR	1	10:17	12:05	DIESEL	0.26	1.8	36.0	20.0
1976	APR	7	3:28	4:22	DIESEL	0.26	0.9	18.0	20.0
1976	APR	15	18:32	21:05	DIESEL	0.26	2.5	51.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E DIVISION STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	APR	19	18:25	20:30	DIESEL	0.26	2.1	41.7	20.0
1976	MAY	19	16:35	17:59	DIESEL	0.26	1.4		
1976	MAY	19	18:41	18:48	DIESEL	0.26	0.1		
1976	MAY	19	22:08	22:14	DIESEL	0.26	0.1	32.3	20.0
1976	MAY	21	13:22	13:29	DIESEL	0.26	0.1	2.3	20.0
1976	JUN	8	14:41	14:59	DIESEL	0.26	0.3	6.0	20.0
1976	JUN	17	9:52	10:55	DIESEL	0.26	1.0	21.0	20.0
1976	JUN	28	11:35	17:52	DIESEL	0.26	6.3	125.7	20.0
1976	JUL	4	16:49	16:57	DIESEL	0.26	0.1	2.7	20.0
1976	JUL	23	13:21	16:09	DIESEL	0.26	2.8		
1976	JUL	23	20:15	21:41	DIESEL	0.26	1.4	84.7	20.0
1976	AUG	2	10:58	12:27	DIESEL	0.26	1.5	29.7	20.0
1976	AUG	3	11:27	11:59	DIESEL	0.26	0.5	10.7	20.0
1976	SEP	4	14:20	15:35	DIESEL	0.26	1.3	25.0	20.0
1976	SEP	16	0:54	1:18	DIESEL	0.26	0.4	8.0	20.0
1976	SEP	21	9:18	9:49	DIESEL	0.26	0.5		
1976	SEP	21	14:36	14:49	DIESEL	0.26	0.2	14.7	20.0
1976	SEP	28	13:25	14:42	DIESEL	0.26	1.3	25.7	20.0
1976	OCT	22	8:50	8:56	DIESEL	0.26	0.1		
1976	OCT	22	9:13	10:35	DIESEL	0.26	1.4	29.3	20.0
1976	OCT	23	15:07	15:29	DIESEL	0.26	0.4	7.3	20.0
1976	OCT	28	18:22	19:23	DIESEL	0.26	1.0	20.3	20.0
1976	OCT	31	8:03	8:48	DIESEL	0.26	0.8	15.0	20.0
1976	NOV	8	11:44	14:02	DIESEL	0.26	2.3	46.0	20.0
1976	NOV	11	16:31	19:38	DIESEL	0.26	3.1	62.3	20.0
1976	NOV	12	16:41	18:20	DIESEL	0.26	1.6	33.0	20.0
1976	NOV	15	17:10	17:28	DIESEL	0.26	0.3	6.0	20.0
1976	NOV	16	17:17	18:32	DIESEL	0.26	1.3	25.0	20.0
1976	NOV	18	16:31	20:05	DIESEL	0.26	3.6	71.3	20.0
1976	NOV	19	16:32	19:03	DIESEL	0.26	2.5	50.3	20.0
1976	NOV	20	9:33	14:08	DIESEL	0.26	4.6	91.7	20.0
1976	NOV	22	16:56	19:04	DIESEL	0.26	2.1	42.7	20.0
1976	NOV	23	17:52	22:07	DIESEL	0.26	4.3	85.0	20.0
1976	DEC	8	9:23	9:58	DIESEL	0.26	0.6	11.7	20.0
1976	DEC	9	17:22	18:37	DIESEL	0.26	1.3	25.0	20.0
1977	JAN	18	20:56	21:38	DIESEL	0.29	0.7	14.0	20.0
1977	JAN	20	17:30	18:19	DIESEL	0.29	0.8	16.3	20.0
1977	APR	13	11:18	13:46	DIESEL	0.29	2.5	49.3	20.0
1977	APR	18	18:36	19:38	DIESEL	0.29	1.0	20.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E DIVISION STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	MAY	5	10:49	12:24	DIESEL	0.29	1.6	31.7	20.0
1977	MAY	6	7:38	9:49	DIESEL	0.29	2.2	43.7	20.0
1977	MAY	19	10:19	14:25	DIESEL	0.29	4.1		
1977	MAY	19	14:25	14:53	DIESEL	0.29	0.5	91.3	20.0
1977	MAY	27	8:59	10:30	DIESEL	0.29	1.5	30.3	20.0
1977	JUL	22	13:34	13:59	DIESEL	0.29	0.4	8.3	20.0
1977	JUL	25	9:05	11:00	DIESEL	0.29	1.9		
1977	JUL	25	11:48	17:23	DIESEL	0.29	5.6	150.0	20.0
1977	JUL	26	8:58	13:56	DIESEL	0.29	5.0		
1977	JUL	26	15:08	15:28	DIESEL	0.29	0.3	106.0	20.0
1977	JUL	27	9:15	11:55	DIESEL	0.29	2.7	53.3	20.0
1977	JUL	29	13:32	14:07	DIESEL	0.29	0.6	11.7	20.0
1977	AUG	2	17:25	18:44	DIESEL	0.29	1.3	26.3	20.0
1977	AUG	4	15:20	15:39	DIESEL	0.29	0.3		
1977	AUG	4	16:05	16:11	DIESEL	0.29	0.1	8.3	20.0
1977	AUG	9	13:32	13:40	DIESEL	0.29	0.1	2.7	20.0
1977	AUG	25	10:15	12:20	DIESEL	0.29	2.1	41.7	20.0
1977	SEP	14	12:40	13:18	DIESEL	0.29	0.6		
1977	SEP	14	13:36	13:56	DIESEL	0.29	0.3	19.3	20.0
1977	OCT	4	14:15	20:53	DIESEL	0.29	6.6	132.7	20.0
1977	OCT	16	8:58	9:12	DIESEL	0.29	0.2	4.7	20.0
1977	OCT	18	8:05	11:32	DIESEL	0.29	3.4	69.0	20.0
1977	OCT	19	17:15	18:13	DIESEL	0.29	1.0	19.3	20.0
1977	OCT	21	17:31	18:11	DIESEL	0.29	0.7	13.3	20.0
1977	OCT	22	8:30	11:32	DIESEL	0.29	3.0		
1977	OCT	22	12:34	13:45	DIESEL	0.29	1.2		
1977	OCT	22	17:13	18:32	DIESEL	0.29	1.3	110.7	20.0
1977	OCT	28	11:44	12:36	DIESEL	0.29	0.9	17.3	20.0
1977	OCT	30	16:55	22:05	DIESEL	0.29	5.2	103.3	20.0
1977	DEC	2	8:37	11:00	DIESEL	0.29	2.4	47.7	20.0
1977	DEC	6	16:59	18:57	DIESEL	0.29	2.0	39.3	20.0
1977	DEC	12	17:18	17:53	DIESEL	0.29	0.6	11.7	20.0
1977	DEC	17	9:56	10:48	DIESEL	0.29	0.9	17.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E EL CAJON STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	2	8:07	8:28	DIESEL	0.30	0.3		
1975	JAN	2	15:30	19:32	DIESEL	0.30	4.0	92.0	21.0
1975	JAN	3	9:05	9:07	DIESEL	0.30	0.0		
1975	JAN	3	10:21	10:35	DIESEL	0.30	0.2		
1975	JAN	3	13:12	13:20	DIESEL	0.30	0.1	8.4	21.0
1975	JAN	4	9:14	11:58	DIESEL	0.30	2.7	57.4	21.0
1975	JAN	7	17:19	18:22	DIESEL	0.30	1.0	22.0	21.0
1975	JAN	8	10:10	11:38	DIESEL	0.30	1.5	30.8	21.0
1975	JAN	9	17:41	18:35	DIESEL	0.30	0.9	18.9	21.0
1975	JAN	20	8:30	11:15	DIESEL	0.30	2.8	57.8	21.0
1975	JAN	29	17:13	20:43	DIESEL	0.30	3.5	73.5	21.0
1975	FEB	12	10:31	10:44	DIESEL	0.30	0.2		
1975	FEB	12	11:13	11:52	DIESEL	0.30	0.6	18.2	21.0
1975	MAR	21	14:32	15:08	DIESEL	0.30	0.6	12.6	21.0
1975	MAR	24	12:35	15:35	DIESEL	0.30	3.0	63.0	21.0
1975	MAR	25	12:48	16:08	DIESEL	0.30	3.3		
1975	MAR	25	19:20	21:19	DIESEL	0.30	2.0	111.6	21.0
1975	MAR	26	9:00	11:07	DIESEL	0.30	2.1		
1975	MAR	26	11:07	12:12	DIESEL	0.30	1.1	67.2	21.0
1975	MAR	27	12:41	15:52	DIESEL	0.30	3.2	66.8	21.0
1975	MAR	28	14:21	14:32	DIESEL	0.30	0.2		
1975	MAR	28	14:39	15:20	DIESEL	0.30	0.7	18.2	21.0
1975	MAR	29	19:34	20:36	DIESEL	0.30	1.0	21.7	21.0
1975	MAR	31	18:22	21:15	DIESEL	0.30	2.9	60.5	21.0
1975	APR	1	18:35	21:15	DIESEL	0.30	2.7	56.0	21.0
1975	APR	2	8:14	8:30	DIESEL	0.30	0.3	5.6	21.0
1975	APR	3	9:12	10:25	DIESEL	0.30	1.2	25.5	21.0
1975	APR	4	8:10	9:29	DIESEL	0.30	1.3		
1975	APR	4	9:29	14:42	DIESEL	0.30	5.2		
1975	APR	4	14:42	17:06	DIESEL	0.30	2.4	187.6	21.0
1975	APR	7	8:17	8:40	DIESEL	0.30	0.4		
1975	APR	7	9:28	10:08	DIESEL	0.30	0.7		
1975	APR	7	19:32	20:43	DIESEL	0.30	1.2	46.9	21.0
1975	APR	8	8:58	14:27	DIESEL	0.30	5.5	115.1	21.0
1975	APR	14	10:03	13:25	DIESEL	0.30	3.4	70.7	21.0
1975	APR	16	6:42	13:05	DIESEL	0.30	6.4		
1975	APR	16	18:15	23:04	DIESEL	0.30	4.8	235.2	21.0
1975	APR	17	11:18	11:36	DIESEL	0.30	0.3		
1975	APR	17	19:43	21:25	DIESEL	0.30	1.7	42.0	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E EL CAJON STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	APR	18	8:18	12:05	DIESEL	0.30	3.8		
1975	APR	18	19:04	21:02	DIESEL	0.30	2.0	120.7	21.0
1975	APR	24	11:46	12:21	DIESEL	0.30	0.6	12.3	21.0
1975	APR	28	19:48	21:17	DIESEL	0.30	1.5	31.1	21.0
1975	MAY	2	11:12	15:05	DIESEL	0.30	3.9	81.5	21.0
1975	MAY	5	10:00	14:00	DIESEL	0.30	4.0	84.0	21.0
1975	MAY	27	15:03	17:27	DIESEL	0.30	2.4	50.4	21.0
1975	MAY	29	13:28	16:00	DIESEL	0.30	2.5	53.2	21.0
1975	JUN	7	20:32	20:42	DIESEL	0.30	0.2		
1975	JUN	7	21:24	21:37	DIESEL	0.30	0.2	8.0	21.0
1975	JUN	10	10:23	12:00	DIESEL	0.30	1.6	33.9	21.0
1975	JUN	15	12:32	13:06	DIESEL	0.30	0.6	11.9	21.0
1975	JUN	17	12:43	12:54	DIESEL	0.30	0.2		
1975	JUN	17	13:08	13:59	DIESEL	0.30	0.8	21.7	21.0
1975	JUN	19	19:33	22:12	DIESEL	0.30	2.6	55.6	21.0
1975	JUN	23	13:21	16:11	DIESEL	0.30	2.8	59.5	21.0
1975	JUL	10	14:57	16:12	DIESEL	0.30	1.3	26.3	21.0
1975	JUL	11	9:21	16:55	DIESEL	0.30	7.6	158.9	21.0
1975	JUL	16	14:38	15:57	DIESEL	0.30	1.3	27.6	21.0
1975	JUL	17	12:16	13:16	DIESEL	0.30	1.0	21.0	21.0
1975	JUL	18	8:05	9:02	DIESEL	0.30	1.0		
1975	JUL	18	10:23	12:46	DIESEL	0.30	2.4	70.0	21.0
1975	JUL	19	12:07	16:12	DIESEL	0.30	4.1		
1975	JUL	19	20:25	21:12	DIESEL	0.30	0.8	102.2	21.0
1975	JUL	21	8:54	10:04	DIESEL	0.30	1.2	24.5	21.0
1975	JUL	30	12:37	14:18	DIESEL	0.30	1.7	35.3	21.0
1975	AUG	5	16:52	17:17	DIESEL	0.30	0.4		
1975	AUG	5	18:25	19:07	DIESEL	0.30	0.7	23.4	21.0
1975	AUG	11	13:45	14:25	DIESEL	0.30	0.7	14.0	21.0
1975	AUG	19	8:29	8:45	DIESEL	0.30	0.3	5.6	21.0
1975	SEP	18	9:50	11:22	DIESEL	0.30	1.5		
1975	SEP	18	13:33	14:01	DIESEL	0.30	0.5		
1975	SEP	18	14:01	16:50	DIESEL	0.30	2.8		
1975	SEP	18	17:36	21:14	DIESEL	0.30	3.6	177.4	21.0
1975	SEP	19	10:10	14:02	DIESEL	0.30	3.9		
1975	SEP	19	18:00	18:28	DIESEL	0.30	0.5	91.0	21.0
1975	SEP	20	8:36	12:59	DIESEL	0.30	4.4		
1975	SEP	20	14:57	15:09	DIESEL	0.30	0.2	96.2	21.0
1975	SEP	21	13:05	21:13	DIESEL	0.30	8.1	170.8	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E EL CAJON STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	SEP	22	11:44	21:11	DIESEL	0.30	9.4	198.4	21.0
1975	SEP	23	10:06	21:25	DIESEL	0.30	11.3	237.6	21.0
1975	SEP	24	7:02	17:01	DIESEL	0.30	10.0	209.6	21.0
1975	SEP	25	6:46	17:01	DIESEL	0.30	10.3	215.3	21.0
1975	SEP	26	7:20	16:37	DIESEL	0.30	9.3	194.9	21.0
1975	SEP	27	8:31	16:53	DIESEL	0.30	8.4	175.7	21.0
1975	OCT	1	6:55	16:45	DIESEL	0.30	9.8	206.5	21.0
1975	OCT	2	6:33	16:47	DIESEL	0.30	10.2		
1975	OCT	2	18:45	21:26	DIESEL	0.30	2.7	271.2	21.0
1975	OCT	3	6:15	17:39	DIESEL	0.30	11.4	239.4	21.0
1975	OCT	6	8:13	8:40	DIESEL	0.30	0.4		
1975	OCT	6	10:09	19:43	DIESEL	0.30	9.6	210.3	21.0
1975	OCT	7	8:57	14:08	DIESEL	0.30	5.2	108.8	21.0
1975	OCT	8	7:06	14:13	DIESEL	0.30	7.1	149.4	21.0
1975	OCT	14	7:32	10:48	DIESEL	0.30	3.3	68.6	21.0
1975	OCT	15	7:21	15:08	DIESEL	0.30	7.8	163.4	21.0
1975	OCT	20	18:30	19:47	DIESEL	0.30	1.3	26.9	21.0
1975	OCT	27	11:16	11:45	DIESEL	0.30	0.5	10.1	21.0
1975	OCT	28	8:30	9:10	DIESEL	0.30	0.7		
1975	OCT	28	9:30	9:51	DIESEL	0.30	0.3	21.3	21.0
1975	OCT	31	17:03	19:15	DIESEL	0.30	2.2	46.2	21.0
1975	NOV	5	10:40	11:30	DIESEL	0.30	0.8		
1975	NOV	5	13:57	14:00	DIESEL	0.30	0.1		
1975	NOV	5	14:10	14:20	DIESEL	0.30	0.2	22.0	21.0
1975	NOV	6	17:01	19:58	DIESEL	0.30	2.9	61.9	21.0
1975	NOV	7	14:28	14:30	DIESEL	0.30	0.0		
1975	NOV	7	15:14	15:20	DIESEL	0.30	0.1	2.8	21.0
1975	NOV	10	10:00	11:10	DIESEL	0.30	1.2		
1975	NOV	10	13:46	14:10	DIESEL	0.30	0.4		
1975	NOV	10	17:11	18:30	DIESEL	0.30	1.3	60.5	21.0
1975	NOV	11	10:18	11:13	DIESEL	0.30	0.9		
1975	NOV	11	17:10	18:12	DIESEL	0.30	1.0	40.9	21.0
1975	NOV	13	13:25	14:15	DIESEL	0.30	0.8	17.5	21.0
1975	NOV	14	13:00	15:25	DIESEL	0.30	2.4		
1975	NOV	14	17:08	19:09	DIESEL	0.30	2.0	93.1	21.0
1975	NOV	17	7:38	12:35	DIESEL	0.30	4.9		
1975	NOV	17	12:35	13:46	DIESEL	0.30	1.2	128.8	21.0
1975	NOV	20	7:40	12:25	DIESEL	0.30	4.8		
1975	NOV	20	16:35	19:54	DIESEL	0.30	3.3	169.4	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E EL CAJON STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	NOV	21	16:29	18:40	DIESEL	0.30	2.2	45.8	21.0
1975	NOV	29	16:41	19:02	DIESEL	0.30	2.3	49.3	21.0
1975	NOV	30	16:19	20:35	DIESEL	0.30	4.3	89.6	21.0
1975	DEC	1	12:41	14:22	DIESEL	0.30	1.7		
1975	DEC	1	17:03	18:59	DIESEL	0.30	1.9	75.9	21.0
1975	DEC	2	17:16	18:07	DIESEL	0.30	0.9	17.8	21.0
1975	DEC	3	17:09	20:09	DIESEL	0.30	3.0	63.0	21.0
1975	DEC	4	8:20	10:41	DIESEL	0.30	2.3		
1975	DEC	4	17:04	17:58	DIESEL	0.30	0.9	68.2	21.0
1975	DEC	5	7:12	10:14	DIESEL	0.30	3.0		
1975	DEC	5	17:30	18:05	DIESEL	0.30	0.6	75.9	21.0
1975	DEC	6	17:23	18:30	DIESEL	0.30	1.1	23.4	21.0
1975	DEC	7	16:37	18:57	DIESEL	0.30	2.3	49.0	21.0
1975	DEC	10	16:07	18:33	DIESEL	0.30	2.4	51.1	21.0
1975	DEC	11	17:20	18:52	DIESEL	0.30	1.5	32.2	21.0
1975	DEC	12	17:03	19:01	DIESEL	0.30	2.0	41.3	21.0
1975	DEC	15	9:22	10:13	DIESEL	0.30	0.9		
1975	DEC	15	16:54	18:34	DIESEL	0.30	1.7	52.8	21.0
1975	DEC	30	16:56	20:20	DIESEL	0.30	3.4	71.4	21.0
1976	JAN	12	17:36	19:04	DIESEL	0.26	1.5	30.8	21.0
1976	JAN	21	4:17	6:09	DIESEL	0.26	1.9	39.2	21.0
1976	JAN	24	17:09	18:50	DIESEL	0.26	1.7	35.3	21.0
1976	JAN	25	17:34	21:04	DIESEL	0.26	3.5	73.5	21.0
1976	JAN	26	6:31	8:48	DIESEL	0.26	2.3	47.9	21.0
1976	JAN	30	17:20	20:02	DIESEL	0.26	2.7	56.7	21.0
1976	JAN	31	17:22	17:52	DIESEL	0.26	0.5	10.5	21.0
1976	MAR	1	12:56	15:00	DIESEL	0.26	2.1		
1976	MAR	1	15:00	21:05	DIESEL	0.26	6.1	171.1	21.0
1976	MAR	2	9:13	13:20	DIESEL	0.26	4.1	86.4	21.0
1976	MAR	4	8:07	15:00	DIESEL	0.26	6.9	144.5	21.0
1976	MAR	5	17:58	19:42	DIESEL	0.26	1.7	36.4	21.0
1976	MAR	15	6:09	8:51	DIESEL	0.26	2.7	56.7	21.0
1976	MAR	24	10:17	10:29	DIESEL	0.26	0.2		
1976	MAR	24	10:41	10:42	DIESEL	0.26	0.0	4.5	21.0
1976	MAR	26	13:05	14:47	DIESEL	0.26	1.7	35.7	21.0
1976	APR	7	3:28	4:22	DIESEL	0.26	0.9	18.9	21.0
1976	APR	19	18:19	19:55	DIESEL	0.26	1.6	33.6	21.0
1976	APR	21	10:19	11:05	DIESEL	0.26	0.8		
1976	APR	21	11:30	12:14	DIESEL	0.26	0.7	31.5	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E EL CAJON STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	MAY	11	10:12	17:06	DIESEL	0.26	6.9	144.9	21.0
1976	MAY	12	12:51	16:35	DIESEL	0.26	3.7	78.4	21.0
1976	MAY	17	17:43	19:18	DIESEL	0.26	1.6	33.2	21.0
1976	MAY	18	20:08	22:25	DIESEL	0.26	2.3	47.9	21.0
1976	JUN	1	11:34	16:08	DIESEL	0.26	4.6		
1976	JUN	1	20:20	21:05	DIESEL	0.26	0.8	111.6	21.0
1976	JUN	4	12:59	14:17	DIESEL	0.26	1.3		
1976	JUN	4	14:17	14:40	DIESEL	0.26	0.4	35.3	21.0
1976	JUN	5	9:28	11:18	DIESEL	0.26	1.8	38.5	21.0
1976	JUN	7	10:32	11:31	DIESEL	0.26	1.0		
1976	JUN	7	11:42	12:00	DIESEL	0.26	0.3	26.9	21.0
1976	JUN	8	14:41	14:54	DIESEL	0.26	0.2	4.5	21.0
1976	JUN	17	11:00	11:08	DIESEL	0.26	0.1		
1976	JUN	17	11:22	11:50	DIESEL	0.26	0.5		
1976	JUN	17	13:29	14:00	DIESEL	0.26	0.5	23.4	21.0
1976	JUN	19	20:05	21:31	DIESEL	0.26	1.4	30.1	21.0
1976	JUN	23	11:35	18:45	DIESEL	0.26	7.2	150.5	21.0
1976	JUN	24	10:46	13:40	DIESEL	0.26	2.9		
1976	JUN	24	14:58	15:12	DIESEL	0.26	0.2	65.8	21.0
1976	JUN	26	9:48	10:04	DIESEL	0.26	0.3	5.6	21.0
1976	JUN	27	13:38	15:25	DIESEL	0.26	1.8		
1976	JUN	27	17:34	17:49	DIESEL	0.26	0.3	42.7	21.0
1976	JUN	28	8:50	12:30	DIESEL	0.26	3.7		
1976	JUN	28	12:45	14:22	DIESEL	0.26	1.6		
1976	JUN	28	15:30	18:29	DIESEL	0.26	3.0	173.6	21.0
1976	JUL	4	16:49	17:03	DIESEL	0.26	0.2	4.9	21.0
1976	JUL	5	11:08	17:55	DIESEL	0.26	6.8	142.4	21.0
1976	JUL	6	9:58	12:15	DIESEL	0.26	2.3		
1976	JUL	6	13:10	15:24	DIESEL	0.26	2.2		
1976	JUL	6	16:26	16:36	DIESEL	0.26	0.2	98.3	21.0
1976	JUL	14	12:07	12:14	DIESEL	0.26	0.1		
1976	JUL	14	14:52	15:53	DIESEL	0.26	1.0	23.8	21.0
1976	JUL	28	10:16	16:31	DIESEL	0.26	6.3	131.3	21.0
1976	JUL	30	10:51	11:34	DIESEL	0.26	0.7	15.1	21.0
1976	JUL	31	9:30	15:30	DIESEL	0.26	6.0	126.0	21.0
1976	AUG	1	9:24	11:41	DIESEL	0.26	2.3	47.9	21.0
1976	AUG	2	10:58	12:44	DIESEL	0.26	1.8	37.1	21.0
1976	AUG	4	11:27	13:33	DIESEL	0.26	2.1	44.1	21.0
1976	AUG	10	10:41	11:35	DIESEL	0.26	0.9	18.9	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E EL CAJON STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	AUG	20	10:33	13:51	DIESEL	0.26	3.3	69.3	21.0
1976	AUG	23	13:11	17:26	DIESEL	0.26	4.3	89.3	21.0
1976	AUG	30	8:45	15:29	DIESEL	0.26	6.7	141.4	21.0
1976	AUG	31	9:22	12:42	DIESEL	0.26	3.3		
1976	AUG	31	14:57	16:33	DIESEL	0.26	1.6	103.6	21.0
1976	SEP	4	14:20	16:02	DIESEL	0.26	1.7	35.7	21.0
1976	SEP	5	19:42	20:03	DIESEL	0.26	0.4	7.4	21.0
1976	SEP	8	19:20	21:10	DIESEL	0.26	1.8	38.5	21.0
1976	SEP	9	19:04	21:23	DIESEL	0.26	2.3	48.6	21.0
1976	SEP	10	0:54	1:17	DIESEL	0.26	0.4	8.1	21.0
1976	SEP	14	19:11	19:14	DIESEL	0.26	0.0	1.0	21.0
1976	SEP	25	19:56	21:14	DIESEL	0.26	1.3	27.3	21.0
1976	OCT	9	16:43	20:39	DIESEL	0.26	3.9	82.6	21.0
1976	OCT	22	14:40	15:24	DIESEL	0.26	0.7	15.4	21.0
1976	NOV	2	11:55	15:57	DIESEL	0.26	4.0		
1976	NOV	2	17:22	19:04	DIESEL	0.26	1.7	120.4	21.0
1976	NOV	5	11:38	15:03	DIESEL	0.26	3.4	71.7	21.0
1976	NOV	8	12:49	18:13	DIESEL	0.26	5.4	113.4	21.0
1976	NOV	10	10:05	13:27	DIESEL	0.26	3.4	70.7	21.0
1976	NOV	11	6:18	6:41	DIESEL	0.26	0.4	8.0	21.0
1976	NOV	14	16:02	16:27	DIESEL	0.26	0.4	8.7	21.0
1976	NOV	18	16:40	20:05	DIESEL	0.26	3.4	71.7	21.0
1976	NOV	19	17:00	18:25	DIESEL	0.26	1.4	29.7	21.0
1976	NOV	22	16:31	18:43	DIESEL	0.26	2.2	46.2	21.0
1976	NOV	23	17:52	22:32	DIESEL	0.26	4.7	98.0	21.0
1976	DEC	4	16:41	20:01	DIESEL	0.26	3.3	70.0	21.0
1976	DEC	5	16:58	18:33	DIESEL	0.26	1.6	33.2	21.0
1976	DEC	30	17:29	19:10	DIESEL	0.26	1.7	35.3	21.0
1977	JAN	3	17:30	18:44	DIESEL	0.29	1.2	25.9	21.0
1977	JAN	6	10:03	10:57	DIESEL	0.29	0.9	18.9	21.0
1977	JAN	18	20:55	23:43	DIESEL	0.29	2.8	58.8	21.0
1977	JAN	19	17:45	18:30	DIESEL	0.29	0.8	15.8	21.0
1977	FEB	7	12:10	14:10	DIESEL	0.29	2.0	42.0	21.0
1977	FEB	11	13:20	13:48	DIESEL	0.29	0.5	9.8	21.0
1977	FEB	20	3:21	3:58	DIESEL	0.29	0.6		
1977	FEB	20	3:58	5:59	DIESEL	0.29	2.0	55.3	21.0
1977	FEB	22	13:29	13:50	DIESEL	0.29	0.3	7.3	21.0
1977	FEB	24	14:47	16:05	DIESEL	0.29	1.3	27.3	21.0
1977	MAR	10	13:57	14:24	DIESEL	0.29	0.5	9.5	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E EL CAJON STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	MAR	21	14:00	14:58	DIESEL	0.29	1.0	20.3	21.0
1977	APR	18	18:43	19:19	DIESEL	0.29	0.6	12.6	21.0
1977	APR	26	13:25	14:05	DIESEL	0.29	0.7	14.0	21.0
1977	APR	27	8:52	10:24	DIESEL	0.29	1.5		
1977	APR	27	14:48	15:26	DIESEL	0.29	0.6	45.5	21.0
1977	MAY	6	23:27	23:59	DIESEL	0.29	0.5	11.2	21.0
1977	MAY	11	10:30	11:15	DIESEL	0.29	0.8	15.8	21.0
1977	MAY	17	10:11	15:14	DIESEL	0.29	5.0	106.0	21.0
1977	JUN	23	10:47	14:07	DIESEL	0.29	3.3		
1977	JUN	23	14:20	14:37	DIESEL	0.29	0.3	75.9	21.0
1977	JUL	11	11:41	12:27	DIESEL	0.29	0.8	16.1	21.0
1977	JUL	12	12:50	13:25	DIESEL	0.29	0.6	12.3	21.0
1977	JUL	17	20:16	22:12	DIESEL	0.29	1.9	40.6	21.0
1977	JUL	18	10:36	18:09	DIESEL	0.29	7.5	158.5	21.0
1977	JUL	21	11:30	17:47	DIESEL	0.29	6.3	131.9	21.0
1977	JUL	22	9:02	18:30	DIESEL	0.29	9.5	198.8	21.0
1977	JUL	25	12:43	22:03	DIESEL	0.29	9.3	196.0	21.0
1977	JUL	26	8:46	15:22	DIESEL	0.29	6.6		
1977	JUL	26	16:30	18:06	DIESEL	0.29	1.6		
1977	JUL	26	19:57	21:47	DIESEL	0.29	1.8	210.7	21.0
1977	JUL	29	10:01	22:26	DIESEL	0.29	12.4	260.7	21.0
1977	JUL	31	11:26	13:46	DIESEL	0.29	2.3	49.0	21.0
1977	AUG	3	12:19	19:15	DIESEL	0.29	6.9	145.6	21.0
1977	AUG	4	13:27	15:46	DIESEL	0.29	2.3	48.6	21.0
1977	AUG	5	15:20	15:39	DIESEL	0.29	0.3		
1977	AUG	5	16:05	16:11	DIESEL	0.29	0.1	8.7	21.0
1977	AUG	8	14:30	14:50	DIESEL	0.29	0.3	7.0	21.0
1977	AUG	19	8:23	11:28	DIESEL	0.29	3.1	64.7	21.0
1977	AUG	20	12:08	18:16	DIESEL	0.29	6.1	128.8	21.0
1977	AUG	23	10:35	12:57	DIESEL	0.29	2.4	49.7	21.0
1977	AUG	28	19:48	21:02	DIESEL	0.29	1.2	25.9	21.0
1977	AUG	29	12:08	16:55	DIESEL	0.29	4.8	100.4	21.0
1977	SEP	5	13:37	18:10	DIESEL	0.29	4.5	95.5	21.0
1977	SEP	6	12:14	14:58	DIESEL	0.29	2.7		
1977	SEP	6	15:44	16:10	DIESEL	0.29	0.4	66.5	21.0
1977	SEP	16	9:10	13:17	DIESEL	0.29	4.1	86.4	21.0
1977	OCT	6	10:57	15:18	DIESEL	0.29	4.3	91.3	21.0
1977	OCT	7	13:42	20:15	DIESEL	0.29	6.5	137.5	21.0
1977	OCT	21	8:58	14:14	DIESEL	0.29	5.3	110.6	21.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E EL CAJON STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	OCT	24	10:39	13:04	DIESEL	0.29	2.4	50.7	21.0
1977	OCT	31	17:50	18:26	DIESEL	0.29	0.6	12.6	21.0
1977	NOV	1	19:39	19:55	DIESEL	0.29	0.3	5.6	21.0
1977	NOV	2	17:27	18:55	DIESEL	0.29	1.5	30.8	21.0
1977	NOV	3	17:01	20:45	DIESEL	0.29	3.7	78.4	21.0
1977	NOV	4	9:45	10:50	DIESEL	0.29	1.1	22.7	21.0
1977	NOV	5	17:17	19:17	DIESEL	0.29	2.0	42.0	21.0
1977	NOV	7	17:25	18:29	DIESEL	0.29	1.1	22.4	21.0
1977	NOV	30	16:55	21:49	DIESEL	0.29	4.9	102.9	21.0
1977	DEC	7	17:16	19:02	DIESEL	0.29	1.8	37.1	21.0
1977	DEC	31	17:31	17:44	DIESEL	0.29	0.2		
1977	DEC	31	19:30	19:43	DIESEL	0.29	0.2	9.1	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E ENCINA STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	14	15:30	15:40	COMBINED FUEL A	0.30	0.2	3.3	20.0
1975	JAN	15	13:35	15:22	COMBINED FUEL A	0.30	1.8	35.7	20.0
1975	JAN	23	15:12	15:22	COMBINED FUEL A	0.30	0.2	3.3	20.0
1975	JAN	24	13:36	14:19	COMBINED FUEL A	0.30	0.7	14.3	20.0
1975	MAR	13	18:21	22:00	COMBINED FUEL A	0.30	3.6		
1975	MAR	13	22:15	22:20	COMBINED FUEL A	0.30	0.1	74.7	20.0
1975	MAR	14	10:32	11:08	COMBINED FUEL A	0.30	0.6		
1975	MAR	14	12:27	13:23	COMBINED FUEL A	0.30	0.9	30.7	20.0
1975	MAR	17	11:06	12:25	COMBINED FUEL A	0.30	1.3	26.3	20.0
1975	MAR	22	19:39	20:24	COMBINED FUEL A	0.30	0.8	15.0	20.0
1975	MAR	27	8:03	14:00	COMBINED FUEL A	0.30	5.9	119.0	20.0
1975	MAR	31	9:28	16:36	COMBINED FUEL A	0.30	7.1	142.7	20.0
1975	APR	2	10:22	11:53	COMBINED FUEL A	0.30	1.5		
1975	APR	2	14:19	14:59	COMBINED FUEL A	0.30	0.7	43.7	20.0
1975	APR	4	14:39	17:10	COMBINED FUEL A	0.30	2.5		
1975	APR	4	17:36	17:43	COMBINED FUEL A	0.30	0.1	52.7	20.0
1975	APR	7	19:25	20:48	COMBINED FUEL A	0.30	1.4	27.7	20.0
1975	APR	8	9:08	14:31	COMBINED FUEL A	0.30	5.4	107.7	20.0
1975	APR	12	8:20	12:22	COMBINED FUEL A	0.30	4.0	80.7	20.0
1975	APR	14	16:05	16:38	COMBINED FUEL A	0.30	0.5		
1975	APR	14	17:10	17:17	COMBINED FUEL A	0.30	0.1	13.3	20.0
1975	APR	16	6:42	22:46	COMBINED FUEL A	0.30	16.1	321.3	20.0
1975	APR	17	16:20	16:55	COMBINED FUEL A	0.30	0.6		
1975	APR	17	16:59	17:22	COMBINED FUEL A	0.30	0.4	19.3	20.0
1975	APR	18	16:06	16:18	COMBINED FUEL A	0.30	0.2	4.0	20.0
1975	APR	25	16:08	16:22	COMBINED FUEL A	0.30	0.2	4.7	20.0
1975	APR	26	15:26	18:04	COMBINED FUEL A	0.30	2.6	52.7	20.0
1975	APR	28	13:00	13:15	COMBINED FUEL A	0.30	0.3		
1975	APR	28	13:24	14:10	COMBINED FUEL A	0.30	0.8	20.3	20.0
1975	APR	29	19:35	22:35	COMBINED FUEL A	0.30	3.0	60.0	20.0
1975	MAY	7	10:16	11:38	COMBINED FUEL A	0.30	1.4		
1975	MAY	7	15:12	15:25	COMBINED FUEL A	0.30	0.2	31.7	20.0
1975	MAY	16	5:32	6:02	COMBINED FUEL A	0.30	0.5	10.0	20.0
1975	MAY	23	15:52	15:56	COMBINED FUEL A	0.30	0.1	1.3	20.0
1975	MAY	28	14:50	14:54	COMBINED FUEL A	0.30	0.1	1.3	20.0
1975	JUN	1	12:10	13:40	COMBINED FUEL A	0.30	1.5	30.0	20.0
1975	JUN	4	8:40	9:55	COMBINED FUEL A	0.30	1.3	25.0	20.0
1975	JUN	7	20:37	21:23	COMBINED FUEL A	0.30	0.8	15.3	20.0
1975	JUN	17	8:08	8:11	COMBINED FUEL A	0.30	0.0	1.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E ENCINA STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JUL	2	10:30	11:35	COMBINED FUEL A	0.30	1.1	21.7	20.0
1975	JUL	19	20:03	21:47	COMBINED FUEL A	0.30	1.7	34.7	20.0
1975	JUL	20	16:11	18:05	COMBINED FUEL A	0.30	1.9		
1975	JUL	20	20:10	21:45	COMBINED FUEL A	0.30	1.6	69.7	20.0
1975	JUL	21	8:53	11:34	COMBINED FUEL A	0.30	2.7	53.7	20.0
1975	JUL	25	20:10	21:07	COMBINED FUEL A	0.30	1.0	19.0	20.0
1975	JUL	26	10:30	14:10	COMBINED FUEL A	0.30	3.7	73.3	20.0
1975	JUL	27	10:24	16:50	COMBINED FUEL A	0.30	6.4		
1975	JUL	27	20:05	22:00	COMBINED FUEL A	0.30	1.9	167.0	20.0
1975	JUL	28	9:50	11:44	COMBINED FUEL A	0.30	1.9		
1975	JUL	28	11:45	17:52	COMBINED FUEL A	0.30	6.1	160.3	20.0
1975	AUG	4	11:46	17:42	COMBINED FUEL A	0.30	5.9	118.7	20.0
1975	AUG	5	12:00	18:29	COMBINED FUEL A	0.30	6.5	129.7	20.0
1975	AUG	6	8:25	9:36	COMBINED FUEL A	0.30	1.2	23.7	20.0
1975	AUG	7	9:57	10:48	COMBINED FUEL A	0.30	0.9	17.0	20.0
1975	AUG	20	9:30	12:36	COMBINED FUEL A	0.30	3.1	62.0	20.0
1975	AUG	23	10:17	18:56	COMBINED FUEL A	0.30	8.6	173.0	20.0
1975	AUG	24	10:02	15:05	COMBINED FUEL A	0.30	5.0	101.0	20.0
1975	SEP	4	9:52	18:10	COMBINED FUEL A	0.30	8.3	166.0	20.0
1975	SEP	6	9:05	9:25	COMBINED FUEL A	0.30	0.3		
1975	SEP	6	9:31	9:42	COMBINED FUEL A	0.30	0.2	10.3	20.0
1975	SEP	14	9:06	18:29	COMBINED FUEL A	0.30	9.4		
1975	SEP	14	19:19	20:26	COMBINED FUEL A	0.30	1.1	210.0	20.0
1975	SEP	17	9:30	21:21	COMBINED FUEL A	0.30	11.8	237.0	20.0
1975	SEP	22	12:40	20:04	COMBINED FUEL A	0.30	7.4	148.0	20.0
1975	SEP	23	12:58	21:11	COMBINED FUEL A	0.30	8.2	164.3	20.0
1975	OCT	1	15:01	16:55	COMBINED FUEL A	0.30	1.9	38.0	20.0
1975	OCT	3	10:53	18:06	COMBINED FUEL A	0.30	7.2	144.3	20.0
1975	OCT	6	9:13	9:42	COMBINED FUEL A	0.30	0.5		
1975	OCT	6	10:25	11:53	COMBINED FUEL A	0.30	1.5	39.0	20.0
1975	OCT	20	18:20	20:10	COMBINED FUEL A	0.30	1.8	36.7	20.0
1975	OCT	21	18:29	20:11	COMBINED FUEL A	0.30	1.7	34.0	20.0
1975	OCT	22	17:46	20:05	COMBINED FUEL A	0.30	2.3	46.3	20.0
1975	OCT	23	18:23	20:06	COMBINED FUEL A	0.30	1.7	34.3	20.0
1975	OCT	24	9:48	19:42	COMBINED FUEL A	0.30	9.9	198.0	20.0
1975	NOV	5	9:05	11:10	COMBINED FUEL A	0.30	2.1	41.7	20.0
1975	NOV	6	17:04	19:15	COMBINED FUEL A	0.30	2.2	43.7	20.0
1975	NOV	7	17:38	18:32	COMBINED FUEL A	0.30	0.9	18.0	20.0
1975	NOV	10	17:09	19:04	COMBINED FUEL A	0.30	1.9	38.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E ENCINA STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	NOV	14	10:42	12:13	COMBINED FUEL A	0.30	1.5		
1975	NOV	14	16:54	20:10	COMBINED FUEL A	0.30	3.3	95.7	20.0
1975	NOV	16	17:30	18:11	COMBINED FUEL A	0.30	0.7	13.7	20.0
1975	NOV	17	7:03	13:07	COMBINED FUEL A	0.30	6.1		
1975	NOV	17	17:06	18:35	COMBINED FUEL A	0.30	1.5	151.0	20.0
1975	NOV	21	17:25	18:35	COMBINED FUEL A	0.30	1.2	23.3	20.0
1975	NOV	30	16:40	19:40	COMBINED FUEL A	0.30	3.0	60.0	20.0
1975	DEC	1	17:04	18:13	COMBINED FUEL A	0.30	1.1	23.0	20.0
1975	DEC	3	16:30	20:32	COMBINED FUEL A	0.30	4.0	80.7	20.0
1975	DEC	4	17:12	18:41	COMBINED FUEL A	0.30	1.5	29.7	20.0
1975	DEC	5	7:32	9:36	COMBINED FUEL A	0.30	2.1	41.3	20.0
1975	DEC	7	16:43	20:30	COMBINED FUEL A	0.30	3.8	75.7	20.0
1975	DEC	10	8:57	10:26	COMBINED FUEL A	0.30	1.5		
1975	DEC	10	12:19	14:21	COMBINED FUEL A	0.30	2.0		
1975	DEC	10	16:10	18:50	COMBINED FUEL A	0.30	2.7	123.7	20.0
1975	DEC	11	17:35	19:00	COMBINED FUEL A	0.30	1.4	28.3	20.0
1975	DEC	16	13:19	17:52	COMBINED FUEL A	0.30	4.5	91.0	20.0
1975	DEC	26	17:05	19:50	COMBINED FUEL A	0.30	2.8	55.0	20.0
1975	DEC	30	17:27	20:15	COMBINED FUEL A	0.30	2.8	56.0	20.0
1976	JAN	18	17:17	18:27	COMBINED FUEL A	0.26	1.2	23.3	20.0
1976	JAN	28	8:53	8:58	COMBINED FUEL A	0.26	0.1		
1976	JAN	28	9:08	9:11	COMBINED FUEL A	0.26	0.0		
1976	JAN	28	9:29	9:38	COMBINED FUEL A	0.26	0.1		
1976	JAN	28	11:08	11:16	COMBINED FUEL A	0.26	0.1		
1976	JAN	28	11:46	11:56	COMBINED FUEL A	0.26	0.2		
1976	JAN	28	12:57	14:51	COMBINED FUEL A	0.26	1.9	49.7	20.0
1976	JAN	29	8:38	12:00	COMBINED FUEL A	0.26	3.4		
1976	JAN	29	13:28	13:50	COMBINED FUEL A	0.26	0.4		
1976	JAN	29	14:04	14:45	COMBINED FUEL A	0.26	0.7	88.3	20.0
1976	JAN	30	9:05	9:33	COMBINED FUEL A	0.26	0.5		
1976	JAN	30	9:46	10:00	COMBINED FUEL A	0.26	0.2		
1976	JAN	30	12:55	13:09	COMBINED FUEL A	0.26	0.2		
1976	JAN	30	17:20	20:06	COMBINED FUEL A	0.26	2.8	74.0	20.0
1976	JAN	31	17:20	17:58	COMBINED FUEL A	0.26	0.6	12.7	20.0
1976	FEB	2	12:54	14:37	COMBINED FUEL A	0.26	1.7	34.3	20.0
1976	FEB	3	8:04	8:18	COMBINED FUEL A	0.26	0.2		
1976	FEB	3	8:26	11:42	COMBINED FUEL A	0.26	3.3		
1976	FEB	3	13:18	14:56	COMBINED FUEL A	0.26	1.6	102.7	20.0
1976	FEB	4	17:08	18:22	COMBINED FUEL A	0.26	1.2	24.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E ENCINA STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	FEB	5	15:15	21:42	COMBINED FUEL A	0.26	6.4	129.0	20.0
1976	FEB	10	7:29	13:58	COMBINED FUEL A	0.26	6.5	129.7	20.0
1976	APR	1	13:52	14:02	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	APR	19	10:25	11:53	COMBINED FUEL A	0.26	1.5		
1976	APR	19	12:12	12:43	COMBINED FUEL A	0.26	0.5	39.7	20.0
1976	MAY	12	15:24	17:09	COMBINED FUEL A	0.26	1.8	35.0	20.0
1976	JUN	5	9:27	11:19	COMBINED FUEL A	0.26	1.9	37.3	20.0
1976	JUN	8	14:40	14:58	COMBINED FUEL A	0.26	0.3	6.0	20.0
1976	JUN	26	11:22	14:00	COMBINED FUEL A	0.26	2.6	52.7	20.0
1976	JUN	28	10:22	20:20	COMBINED FUEL A	0.26	10.0	199.3	20.0
1976	JUL	4	16:51	17:00	COMBINED FUEL A	0.26	0.2	3.0	20.0
1976	JUL	5	10:40	18:10	COMBINED FUEL A	0.26	7.5	150.0	20.0
1976	JUL	6	11:47	17:08	COMBINED FUEL A	0.26	5.3	107.0	20.0
1976	JUL	15	11:21	14:25	COMBINED FUEL A	0.26	3.1	61.3	20.0
1976	AUG	1	9:27	10:23	COMBINED FUEL A	0.26	0.9		
1976	AUG	1	20:08	21:40	COMBINED FUEL A	0.26	1.5	49.3	20.0
1976	AUG	2	11:58	13:33	COMBINED FUEL A	0.26	1.6	31.7	20.0
1976	AUG	4	11:25	13:29	COMBINED FUEL A	0.26	2.1	41.3	20.0
1976	AUG	24	13:09	18:25	COMBINED FUEL A	0.26	5.3	105.3	20.0
1976	AUG	25	10:00	10:56	COMBINED FUEL A	0.26	0.9	18.7	20.0
1976	AUG	30	12:20	17:44	COMBINED FUEL A	0.26	5.4		
1976	AUG	30	19:34	20:06	COMBINED FUEL A	0.26	0.5	118.7	20.0
1976	AUG	31	12:58	14:58	COMBINED FUEL A	0.26	2.0		
1976	AUG	31	15:09	16:37	COMBINED FUEL A	0.26	1.5		
1976	AUG	31	17:41	18:32	COMBINED FUEL A	0.26	0.9	86.3	20.0
1976	SEP	1	11:05	15:49	COMBINED FUEL A	0.26	4.7	94.7	20.0
1976	SEP	3	12:39	15:32	COMBINED FUEL A	0.26	2.9	57.7	20.0
1976	SEP	4	14:27	16:11	COMBINED FUEL A	0.26	1.7	34.7	20.0
1976	SEP	10	0:54	1:18	COMBINED FUEL A	0.26	0.4	8.0	20.0
1976	SEP	23	10:35	11:37	COMBINED FUEL A	0.26	1.0		
1976	SEP	23	15:54	16:05	COMBINED FUEL A	0.26	0.2	24.3	20.0
1976	SEP	26	19:54	20:19	COMBINED FUEL A	0.26	0.4	8.3	20.0
1976	OCT	13	13:00	14:34	COMBINED FUEL A	0.26	1.6	31.3	20.0
1976	OCT	26	11:30	12:40	COMBINED FUEL A	0.26	1.2		
1976	OCT	26	13:11	13:27	COMBINED FUEL A	0.26	0.3	28.7	20.0
1976	NOV	4	17:32	18:36	COMBINED FUEL A	0.26	1.1	21.3	20.0
1976	NOV	18	12:47	13:30	COMBINED FUEL A	0.26	0.7	14.3	20.0
1976	NOV	21	16:10	18:52	COMBINED FUEL A	0.26	2.7	54.0	20.0
1976	NOV	23	17:40	21:36	COMBINED FUEL A	0.26	3.9	78.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E ENCINA STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	DEC	1	10:48	20:40	COMBINED FUEL A	0.26	9.9	197.3	20.0
1976	DEC	30	17:24	20:12	COMBINED FUEL A	0.26	2.8	56.0	20.0
1976	DEC	31	6:21	7:53	COMBINED FUEL A	0.26	1.5	30.7	20.0
1977	JAN	18	20:57	22:29	COMBINED FUEL A	0.29	1.5		
1977	JAN	18	23:30	24:00	COMBINED FUEL A	0.29	0.5	40.7	20.0
1977	FEB	1	17:39	18:30	COMBINED FUEL A	0.29	0.9	17.0	20.0
1977	FEB	10	12:56	13:24	COMBINED FUEL A	0.29	0.5		
1977	FEB	10	14:11	15:38	COMBINED FUEL A	0.29	1.4	38.3	20.0
1977	FEB	19	3:12	4:12	COMBINED FUEL A	0.29	1.0	20.0	20.0
1977	MAR	10	15:13	15:22	COMBINED FUEL A	0.29	0.1	3.0	20.0
1977	MAR	14	15:03	15:27	COMBINED FUEL A	0.29	0.4	8.0	20.0
1977	MAY	4	7:57	15:35	COMBINED FUEL A	0.29	7.6		
1977	MAY	4	16:08	16:16	COMBINED FUEL A	0.29	0.1	155.3	20.0
1977	MAY	5	10:47	11:39	COMBINED FUEL A	0.29	0.9	17.3	20.0
1977	MAY	6	7:35	12:32	COMBINED FUEL A	0.29	4.9	99.0	20.0
1977	MAY	25	10:40	12:55	COMBINED FUEL A	0.29	2.3	45.0	20.0
1977	JUN	10	3:35	5:01	COMBINED FUEL A	0.29	1.4	28.7	20.0
1977	JUL	16	14:01	14:35	COMBINED FUEL A	0.29	0.6	11.3	20.0
1977	JUL	17	11:46	18:21	COMBINED FUEL A	0.29	6.6	131.7	20.0
1977	JUL	24	16:48	17:10	COMBINED FUEL A	0.29	0.4	7.3	20.0
1977	JUL	25	13:40	17:21	COMBINED FUEL A	0.29	3.7	73.7	20.0
1977	JUL	29	13:31	16:16	COMBINED FUEL A	0.29	2.8	55.0	20.0
1977	JUL	31	12:05	14:05	COMBINED FUEL A	0.29	2.0	40.0	20.0
1977	AUG	3	17:12	19:02	COMBINED FUEL A	0.29	1.8	36.7	20.0
1977	AUG	4	9:16	9:50	COMBINED FUEL A	0.29	0.6	11.3	20.0
1977	AUG	30	12:18	12:29	COMBINED FUEL A	0.29	0.2	3.7	20.0
1977	SEP	20	11:25	15:25	COMBINED FUEL A	0.29	4.0	80.0	20.0
1977	OCT	7	11:46	17:10	COMBINED FUEL A	0.29	5.4	108.0	20.0
1977	OCT	21	21:10	21:37	COMBINED FUEL A	0.29	0.4	9.0	20.0
1977	OCT	26	9:20	9:50	COMBINED FUEL A	0.29	0.5	10.0	20.0
1977	NOV	5	6:48	19:47	COMBINED FUEL A	0.29	13.0	259.7	20.0
1977	NOV	23	3:36	4:43	COMBINED FUEL A	0.29	1.1		
1977	NOV	23	8:54	10:17	COMBINED FUEL A	0.29	1.4	50.0	20.0
1977	NOV	30	17:06	21:10	COMBINED FUEL A	0.29	4.1	81.3	20.0
1977	DEC	7	17:10	18:07	COMBINED FUEL A	0.29	1.0	19.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	3	9:07	11:30	COMBINED FUEL A	0.30	2.4	50.0	21.0
1975	JAN	4	10:29	12:18	COMBINED FUEL A	0.30	1.8	38.1	21.0
1975	JAN	6	13:09	15:00	COMBINED FUEL A	0.30	1.8	38.8	21.0
1975	JAN	9	17:33	18:29	COMBINED FUEL A	0.30	0.9	19.6	21.0
1975	JAN	22	9:03	9:56	COMBINED FUEL A	0.30	0.9		
1975	JAN	22	10:15	10:25	COMBINED FUEL A	0.30	0.2		
1975	JAN	22	13:50	14:01	COMBINED FUEL A	0.30	0.2	25.9	21.0
1975	FEB	7	13:00	13:48	COMBINED FUEL A	0.30	0.8		
1975	FEB	7	15:46	15:55	COMBINED FUEL A	0.30	0.1		
1975	FEB	7	16:11	16:28	COMBINED FUEL A	0.30	0.3	25.9	21.0
1975	FEB	10	9:55	11:45	COMBINED FUEL A	0.30	1.8		
1975	FEB	10	13:00	13:45	COMBINED FUEL A	0.30	0.8		
1975	FEB	10	15:00	15:10	COMBINED FUEL A	0.30	0.2	57.7	21.0
1975	FEB	17	17:58	19:37	COMBINED FUEL A	0.30	1.6	34.6	21.0
1975	FEB	25	8:46	9:57	COMBINED FUEL A	0.30	1.2		
1975	FEB	25	18:39	20:10	COMBINED FUEL A	0.30	1.5	56.7	21.0
1975	MAR	13	18:23	22:26	COMBINED FUEL A	0.30	4.0	85.0	21.0
1975	MAR	17	11:07	12:16	COMBINED FUEL A	0.30	1.1	24.1	21.0
1975	MAR	19	18:02	21:26	COMBINED FUEL A	0.30	3.4	71.4	21.0
1975	MAR	21	14:32	15:08	COMBINED FUEL A	0.30	0.6	12.6	21.0
1975	MAR	22	9:20	12:27	COMBINED FUEL A	0.30	3.1	65.4	21.0
1975	MAR	26	10:20	10:48	COMBINED FUEL A	0.30	0.5	9.8	21.0
1975	MAR	27	7:57	14:22	COMBINED FUEL A	0.30	6.4	134.7	21.0
1975	MAR	30	19:32	20:52	COMBINED FUEL A	0.30	1.3	28.0	21.0
1975	APR	2	19:49	20:40	COMBINED FUEL A	0.30	0.9	17.8	21.0
1975	APR	3	9:07	12:13	COMBINED FUEL A	0.30	3.1		
1975	APR	3	14:31	17:12	COMBINED FUEL A	0.30	2.7	121.4	21.0
1975	APR	6	19:38	21:01	COMBINED FUEL A	0.30	1.4	29.0	21.0
1975	APR	7	8:32	9:25	COMBINED FUEL A	0.30	0.9	18.5	21.0
1975	APR	8	14:19	20:54	COMBINED FUEL A	0.30	6.6	138.2	21.0
1975	APR	10	19:24	20:44	COMBINED FUEL A	0.30	1.3	28.0	21.0
1975	APR	16	6:42	22:59	COMBINED FUEL A	0.30	16.3	341.9	21.0
1975	APR	25	12:55	15:05	COMBINED FUEL A	0.30	2.2	45.5	21.0
1975	APR	26	16:00	17:18	COMBINED FUEL A	0.30	1.3	27.3	21.0
1975	APR	27	19:53	21:35	COMBINED FUEL A	0.30	1.7	35.7	21.0
1975	APR	29	18:06	22:35	COMBINED FUEL A	0.30	4.5	94.1	21.0
1975	MAY	2	19:49	20:48	COMBINED FUEL A	0.30	1.0	20.6	21.0
1975	MAY	4	9:07	12:13	COMBINED FUEL A	0.30	3.1		
1975	MAY	4	14:31	17:12	COMBINED FUEL A	0.30	2.7	121.4	21.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	MAY	6	19:38	21:01	COMBINED FUEL A	0.30	1.4	29.0	21.0
1975	MAY	7	8:32	9:25	COMBINED FUEL A	0.30	0.9	18.5	21.0
1975	MAY	8	14:19	20:54	COMBINED FUEL A	0.30	6.6	138.2	21.0
1975	MAY	10	19:24	20:41	COMBINED FUEL A	0.30	1.3	26.9	21.0
1975	MAY	16	6:42	22:59	COMBINED FUEL A	0.30	16.3	341.9	21.0
1975	MAY	25	12:55	15:05	COMBINED FUEL A	0.30	2.2	45.5	21.0
1975	MAY	26	16:00	17:18	COMBINED FUEL A	0.30	1.3	27.3	21.0
1975	MAY	27	19:53	21:35	COMBINED FUEL A	0.30	1.7	35.7	21.0
1975	MAY	29	18:06	22:35	COMBINED FUEL A	0.30	4.5	94.1	21.0
1975	JUN	1	11:28	14:11	COMBINED FUEL A	0.30	2.7	57.0	21.0
1975	JUN	24	13:21	16:11	COMBINED FUEL A	0.30	2.8	59.5	21.0
1975	JUL	11	9:43	17:09	COMBINED FUEL A	0.30	7.4	156.1	21.0
1975	JUL	14	11:01	16:08	COMBINED FUEL A	0.30	5.1	107.4	21.0
1975	JUL	15	10:50	15:58	COMBINED FUEL A	0.30	5.1	107.8	21.0
1975	JUL	16	10:12	11:25	COMBINED FUEL A	0.30	1.2		
1975	JUL	16	11:40	16:09	COMBINED FUEL A	0.30	4.5	119.7	21.0
1975	JUL	17	11:30	16:00	COMBINED FUEL A	0.30	4.5	94.5	21.0
1975	JUL	18	9:05	16:07	COMBINED FUEL A	0.30	7.0	147.7	21.0
1975	JUL	19	17:58	22:04	COMBINED FUEL A	0.30	4.1	86.1	21.0
1975	JUL	20	20:19	21:25	COMBINED FUEL A	0.30	1.1	23.1	21.0
1975	JUL	23	10:04	13:37	COMBINED FUEL A	0.30	3.5	74.5	21.0
1975	JUL	27	21:02	21:39	COMBINED FUEL A	0.30	0.6	12.9	21.0
1975	JUL	29	10:38	11:37	COMBINED FUEL A	0.30	1.0		
1975	JUL	29	14:46	16:12	COMBINED FUEL A	0.30	1.4	50.7	21.0
1975	JUL	30	9:48	10:37	COMBINED FUEL A	0.30	0.8	17.1	21.0
1975	AUG	19	19:39	22:22	COMBINED FUEL A	0.30	2.7	57.0	21.0
1975	AUG	22	19:45	21:09	COMBINED FUEL A	0.30	1.4	29.4	21.0
1975	AUG	23	12:05	18:58	COMBINED FUEL A	0.30	6.9	144.5	21.0
1975	AUG	29	13:59	15:29	COMBINED FUEL A	0.30	1.5	31.5	21.0
1975	SEP	3	19:23	20:54	COMBINED FUEL A	0.30	1.5	31.8	21.0
1975	SEP	4	19:46	21:01	COMBINED FUEL A	0.30	1.3	26.3	21.0
1975	SEP	5	10:53	12:15	COMBINED FUEL A	0.30	1.4	28.7	21.0
1975	SEP	6	7:47	11:56	COMBINED FUEL A	0.30	4.1	87.1	21.0
1975	SEP	8	18:15	18:27	COMBINED FUEL A	0.30	0.2		
1975	SEP	8	20:43	20:48	COMBINED FUEL A	0.30	0.1	5.9	21.0
1975	SEP	13	10:07	13:22	COMBINED FUEL A	0.30	3.3	68.3	21.0
1975	SEP	15	10:12	12:06	COMBINED FUEL A	0.30	1.9		
1975	SEP	15	19:26	20:55	COMBINED FUEL A	0.30	1.5		
1975	SEP	15	21:50	22:00	COMBINED FUEL A	0.30	0.2	74.5	21.0

NEG = NEGLIGIBLE

STEAM GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	SEP	16	9:12	18:02	COMBINED FUEL A	0.30	8.8	185.5	21.0
1975	SEP	17	9:52	17:59	COMBINED FUEL A	0.30	8.1	170.4	21.0
1975	SEP	18	9:48	22:18	COMBINED FUEL A	0.30	12.5	262.5	21.0
1975	SEP	19	11:16	18:23	COMBINED FUEL A	0.30	7.1	149.4	21.0
1975	SEP	20	9:31	16:40	COMBINED FUEL A	0.30	7.1	150.1	21.0
1975	SEP	21	19:07	21:20	COMBINED FUEL A	0.30	2.2	46.5	21.0
1975	SEP	23	10:04	18:56	COMBINED FUEL A	0.30	8.9	186.2	21.0
1975	SEP	25	9:40	11:30	COMBINED FUEL A	0.30	1.8	38.5	21.0
1975	SEP	30	18:58	20:12	COMBINED FUEL A	0.30	1.2	25.9	21.0
1975	OCT	2	12:32	21:33	COMBINED FUEL A	0.30	9.0	189.3	21.0
1975	OCT	3	11:21	16:57	COMBINED FUEL A	0.30	5.6		
1975	OCT	3	19:07	19:42	COMBINED FUEL A	0.30	0.6	129.8	21.0
1975	OCT	5	18:55	21:27	COMBINED FUEL A	0.30	2.5	53.2	21.0
1975	OCT	8	18:18	20:27	COMBINED FUEL A	0.30	2.1	45.1	21.0
1975	OCT	12	19:08	20:02	COMBINED FUEL A	0.30	0.9	18.9	21.0
1975	OCT	20	18:42	19:27	COMBINED FUEL A	0.30	0.8	15.8	21.0
1975	OCT	21	18:27	19:47	COMBINED FUEL A	0.30	1.3	28.0	21.0
1975	OCT	22	17:40	20:01	COMBINED FUEL A	0.30	2.3	49.3	21.0
1975	OCT	24	9:47	12:20	COMBINED FUEL A	0.30	2.5		
1975	OCT	24	13:15	14:31	COMBINED FUEL A	0.30	1.3		
1975	OCT	24	18:25	19:38	COMBINED FUEL A	0.30	1.2	105.7	21.0
1975	OCT	26	17:23	18:23	COMBINED FUEL A	0.30	1.0	21.0	21.0
1975	OCT	30	8:02	8:57	COMBINED FUEL A	0.30	0.9		
1975	OCT	30	17:36	18:55	COMBINED FUEL A	0.30	1.3	46.9	21.0
1975	NOV	1	17:31	20:03	COMBINED FUEL A	0.30	2.5	53.2	21.0
1975	NOV	2	17:33	19:03	COMBINED FUEL A	0.30	1.5	31.5	21.0
1975	NOV	3	17:16	19:15	COMBINED FUEL A	0.30	2.0	41.6	21.0
1975	NOV	4	17:10	18:17	COMBINED FUEL A	0.30	1.1	23.4	21.0
1975	NOV	14	13:18	14:07	COMBINED FUEL A	0.30	0.8		
1975	NOV	14	17:23	19:29	COMBINED FUEL A	0.30	2.1	61.2	21.0
1975	NOV	15	17:15	18:22	COMBINED FUEL A	0.30	1.1	23.4	21.0
1975	NOV	17	7:10	13:35	COMBINED FUEL A	0.30	6.4	134.7	21.0
1975	NOV	18	17:22	18:20	COMBINED FUEL A	0.30	1.0	20.3	21.0
1975	NOV	19	6:45	8:00	COMBINED FUEL A	0.30	1.3		
1975	NOV	19	17:21	18:18	COMBINED FUEL A	0.30	1.0	46.2	21.0
1975	NOV	20	7:30	8:10	COMBINED FUEL A	0.30	0.7	14.0	21.0
1975	NOV	26	17:00	18:05	COMBINED FUEL A	0.30	1.1	22.7	21.0
1975	NOV	29	17:17	18:51	COMBINED FUEL A	0.30	1.6	32.9	21.0
1975	NOV	30	16:19	19:48	COMBINED FUEL A	0.30	3.5	73.1	21.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	DEC	1	17:03	18:22	COMBINED FUEL A	0.30	1.3	27.6	21.0
1975	DEC	2	17:16	18:02	COMBINED FUEL A	0.30	0.8	16.1	21.0
1975	DEC	3	10:15	13:46	COMBINED FUEL A	0.30	3.5		
1975	DEC	3	17:04	19:00	COMBINED FUEL A	0.30	1.9	114.4	21.0
1975	DEC	4	8:13	9:42	COMBINED FUEL A	0.30	1.5	31.1	21.0
1975	DEC	5	7:35	10:22	COMBINED FUEL A	0.30	2.8	58.4	21.0
1975	DEC	7	17:05	18:46	COMBINED FUEL A	0.30	1.7	35.3	21.0
1975	DEC	10	8:06	11:22	COMBINED FUEL A	0.30	3.3		
1975	DEC	10	16:07	19:25	COMBINED FUEL A	0.30	3.3	137.9	21.0
1975	DEC	11	8:31	9:11	COMBINED FUEL A	0.30	0.7		
1975	DEC	11	13:01	14:01	COMBINED FUEL A	0.30	1.0		
1975	DEC	11	17:15	19:25	COMBINED FUEL A	0.30	2.2	80.5	21.0
1975	DEC	12	11:22	11:40	COMBINED FUEL A	0.30	0.3		
1975	DEC	12	17:03	18:26	COMBINED FUEL A	0.30	1.4	35.3	21.0
1975	DEC	13	9:04	11:10	COMBINED FUEL A	0.30	2.1		
1975	DEC	13	16:46	18:59	COMBINED FUEL A	0.30	2.2	90.6	21.0
1975	DEC	15	17:03	19:28	COMBINED FUEL A	0.30	2.4	50.7	21.0
1975	DEC	16	13:52	17:35	COMBINED FUEL A	0.30	3.7	78.0	21.0
1975	DEC	17	9:16	9:45	COMBINED FUEL A	0.30	0.5	10.1	21.0
1975	DEC	20	9:36	9:43	COMBINED FUEL A	0.30	0.1		
1975	DEC	20	10:06	13:03	COMBINED FUEL A	0.30	2.9	64.4	21.0
1975	DEC	22	17:28	18:52	COMBINED FUEL A	0.30	1.4	29.4	21.0
1975	DEC	25	17:21	18:51	COMBINED FUEL A	0.30	1.5	31.5	21.0
1975	DEC	28	10:20	18:51	COMBINED FUEL A	0.30	8.5	178.8	21.0
1975	DEC	29	10:20	12:24	COMBINED FUEL A	0.30	2.1	43.4	21.0
1975	DEC	30	17:03	19:20	COMBINED FUEL A	0.30	2.3	47.9	21.0
1976	JAN	1	10:16	11:47	COMBINED FUEL A	0.26	1.5	31.8	21.0
1976	JAN	15	8:29	10:10	COMBINED FUEL A	0.26	1.7		
1976	JAN	15	13:20	14:38	COMBINED FUEL A	0.26	1.3	62.6	21.0
1976	JAN	16	7:47	11:15	COMBINED FUEL A	0.26	3.5		
1976	JAN	16	13:40	14:10	COMBINED FUEL A	0.26	0.5	83.3	21.0
1976	JAN	21	4:17	6:18	COMBINED FUEL A	0.26	2.0	42.3	21.0
1976	JAN	24	17:09	19:27	COMBINED FUEL A	0.26	2.3	48.3	21.0
1976	JAN	25	17:39	20:49	COMBINED FUEL A	0.26	3.2	66.5	21.0
1976	JAN	26	6:10	8:56	COMBINED FUEL A	0.26	2.8	58.1	21.0
1976	JAN	30	17:30	20:10	COMBINED FUEL A	0.26	2.7	56.0	21.0
1976	FEB	3	8:07	15:53	COMBINED FUEL A	0.26	7.8		
1976	FEB	3	17:37	19:12	COMBINED FUEL A	0.26	1.6		
1976	FEB	3	21:01	21:18	COMBINED FUEL A	0.26	0.3	202.3	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	FEB	4	21:50	22:21	COMBINED FUEL A	0.26	0.5	10.9	21.0
1976	FEB	5	17:17	21:13	COMBINED FUEL A	0.26	3.9	82.6	21.0
1976	FEB	6	17:54	18:18	COMBINED FUEL A	0.26	0.4	8.4	21.0
1976	FEB	20	8:51	11:21	COMBINED FUEL A	0.26	2.5	52.5	21.0
1976	FEB	21	18:15	18:18	COMBINED FUEL A	0.26	0.0		
1976	FEB	21	19:42	19:48	COMBINED FUEL A	0.26	0.1	3.1	21.0
1976	FEB	23	11:01	14:00	COMBINED FUEL A	0.26	3.0	62.6	21.0
1976	FEB	25	8:53	11:52	COMBINED FUEL A	0.26	3.0	62.6	21.0
1976	FEB	28	18:03	19:39	COMBINED FUEL A	0.26	1.6	33.6	21.0
1976	MAR	1	15:43	21:13	COMBINED FUEL A	0.26	5.5	115.5	21.0
1976	MAR	2	18:20	19:05	COMBINED FUEL A	0.26	0.8	15.8	21.0
1976	MAR	3	18:03	19:28	COMBINED FUEL A	0.26	1.4	29.7	21.0
1976	MAR	4	6:52	14:55	COMBINED FUEL A	0.26	8.0		
1976	MAR	4	18:19	19:38	COMBINED FUEL A	0.26	1.3	196.7	21.0
1976	MAR	5	18:01	19:15	COMBINED FUEL A	0.26	1.2	25.9	21.0
1976	MAR	6	8:45	10:47	COMBINED FUEL A	0.26	2.0	42.7	21.0
1976	MAR	8	18:10	19:37	COMBINED FUEL A	0.26	1.4	30.4	21.0
1976	MAR	9	18:18	19:51	COMBINED FUEL A	0.26	1.5	32.5	21.0
1976	MAR	15	5:47	9:09	COMBINED FUEL A	0.26	3.4	70.7	21.0
1976	MAR	22	11:16	12:12	COMBINED FUEL A	0.26	0.9		
1976	MAR	22	13:44	15:37	COMBINED FUEL A	0.26	1.9	59.1	21.0
1976	MAR	23	9:35	16:10	COMBINED FUEL A	0.26	6.6	138.2	21.0
1976	MAR	25	8:27	15:55	COMBINED FUEL A	0.26	7.5	156.8	21.0
1976	MAR	26	7:48	15:12	COMBINED FUEL A	0.26	7.4	155.4	21.0
1976	MAR	28	8:27	10:32	COMBINED FUEL A	0.26	2.1	43.7	21.0
1976	MAR	31	9:19	9:21	COMBINED FUEL A	0.26	0.0		
1976	MAR	31	10:31	14:39	COMBINED FUEL A	0.26	4.1	87.5	21.0
1976	APR	5	18:42	21:44	COMBINED FUEL A	0.26	3.0	63.7	21.0
1976	APR	6	3:28	4:23	COMBINED FUEL A	0.26	0.9	19.3	21.0
1976	APR	7	18:45	19:36	COMBINED FUEL A	0.26	0.9	17.8	21.0
1976	APR	12	18:45	20:05	COMBINED FUEL A	0.26	1.3	28.0	21.0
1976	APR	15	17:40	20:48	COMBINED FUEL A	0.26	3.1	65.8	21.0
1976	APR	16	18:46	19:31	COMBINED FUEL A	0.26	0.8	15.8	21.0
1976	APR	17	9:35	9:38	COMBINED FUEL A	0.26	0.0		
1976	APR	17	12:14	12:27	COMBINED FUEL A	0.26	0.2	5.6	21.0
1976	APR	18	18:43	21:16	COMBINED FUEL A	0.26	2.5	53.5	21.0
1976	APR	19	18:43	20:15	COMBINED FUEL A	0.26	1.5	32.2	21.0
1976	JUN	16	13:45	15:26	COMBINED FUEL A	0.26	1.7	35.3	21.0
1976	JUN	18	12:02	14:00	COMBINED FUEL A	0.26	2.0		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JUN	18	14:30	15:19	COMBINED FUEL A	0.26	0.8	58.4	21.0
1976	JUN	19	20:10	21:23	COMBINED FUEL A	0.26	1.2	25.5	21.0
1976	JUN	22	14:07	16:30	COMBINED FUEL A	0.26	2.4	50.0	21.0
1976	JUN	23	13:07	18:18	COMBINED FUEL A	0.26	5.2	108.8	21.0
1976	JUN	24	10:42	18:48	COMBINED FUEL A	0.26	8.1	170.1	21.0
1976	JUN	26	9:50	18:56	COMBINED FUEL A	0.26	9.1	191.1	21.0
1976	JUN	27	12:41	12:51	COMBINED FUEL A	0.26	0.2		
1976	JUN	27	14:55	16:41	COMBINED FUEL A	0.26	1.8		
1976	JUN	27	18:52	19:05	COMBINED FUEL A	0.26	0.2	45.1	21.0
1976	JUN	28	9:09	12:37	COMBINED FUEL A	0.26	3.5		
1976	JUN	28	13:18	18:16	COMBINED FUEL A	0.26	5.0	177.1	21.0
1976	JUN	30	17:23	18:20	COMBINED FUEL A	0.26	1.0	19.9	21.0
1976	JUL	4	16:49	16:57	COMBINED FUEL A	0.26	0.1	2.8	21.0
1976	JUL	5	16:25	17:39	COMBINED FUEL A	0.26	1.2	25.9	21.0
1976	JUL	6	9:55	9:57	COMBINED FUEL A	0.26	0.0	0.7	21.0
1976	JUL	7	9:55	10:10	COMBINED FUEL A	0.26	0.3	5.3	21.0
1976	JUL	13	12:35	14:37	COMBINED FUEL A	0.26	2.0	42.7	21.0
1976	JUL	14	12:14	17:47	COMBINED FUEL A	0.26	5.5	116.5	21.0
1976	JUL	17	20:31	20:55	COMBINED FUEL A	0.26	0.4	8.4	21.0
1976	JUL	19	12:33	20:30	COMBINED FUEL A	0.26	7.9	166.9	21.0
1976	JUL	23	12:38	17:19	COMBINED FUEL A	0.26	4.7	98.3	21.0
1976	JUL	26	8:27	12:21	COMBINED FUEL A	0.26	3.9	81.9	21.0
1976	JUL	27	8:02	14:44	COMBINED FUEL A	0.26	6.7		
1976	JUL	27	20:10	20:43	COMBINED FUEL A	0.26	0.5	152.2	21.0
1976	AUG	1	9:23	13:44	COMBINED FUEL A	0.26	4.3		
1976	AUG	1	17:04	19:01	COMBINED FUEL A	0.26	1.9		
1976	AUG	1	19:56	21:40	COMBINED FUEL A	0.26	1.7	168.7	21.0
1976	AUG	2	10:58	12:49	COMBINED FUEL A	0.26	1.8	38.8	21.0
1976	AUG	4	11:27	13:53	COMBINED FUEL A	0.26	2.4	51.1	21.0
1976	AUG	7	9:26	11:34	COMBINED FUEL A	0.26	2.1	44.8	21.0
1976	AUG	19	8:36	9:57	COMBINED FUEL A	0.26	1.3	28.3	21.0
1976	AUG	21	11:08	17:35	COMBINED FUEL A	0.26	6.4	135.4	21.0
1976	AUG	22	1:15	1:50	COMBINED FUEL A	0.26	0.6	12.2	21.0
1976	AUG	28	11:07	18:29	COMBINED FUEL A	0.26	7.4		
1976	AUG	28	19:31	20:43	COMBINED FUEL A	0.26	1.2	179.9	21.0
1976	AUG	29	10:42	22:26	COMBINED FUEL A	0.26	11.7	246.4	21.0
1976	AUG	31	12:55	14:26	COMBINED FUEL A	0.26	1.5		
1976	AUG	31	14:52	17:08	COMBINED FUEL A	0.26	2.3		
1976	AUG	31	19:55	21:07	COMBINED FUEL A	0.26	1.2	104.6	21.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	SEP	1	19:43	20:16	COMBINED FUEL A	0.26	0.6	11.6	21.0
1976	SEP	2	11:44	17:16	COMBINED FUEL A	0.26	5.5	116.2	21.0
1976	SEP	3	13:27	14:42	COMBINED FUEL A	0.26	1.3	26.3	21.0
1976	SEP	4	14:20	15:55	COMBINED FUEL A	0.26	1.6	33.2	21.0
1976	SEP	5	19:14	21:11	COMBINED FUEL A	0.26	1.9	40.9	21.0
1976	SEP	6	19:32	21:03	COMBINED FUEL A	0.26	1.5	31.8	21.0
1976	SEP	8	13:05	14:06	COMBINED FUEL A	0.26	1.0		
1976	SEP	8	19:04	21:18	COMBINED FUEL A	0.26	2.2	68.2	21.0
1976	SEP	9	19:12	20:29	COMBINED FUEL A	0.26	1.3	26.9	21.0
1976	SEP	10	0:54	1:17	COMBINED FUEL A	0.26	0.4	8.1	21.0
1976	SEP	12	19:14	21:11	COMBINED FUEL A	0.26	1.9	40.9	21.0
1976	SEP	19	9:40	10:18	COMBINED FUEL A	0.26	0.6		
1976	SEP	19	14:25	14:36	COMBINED FUEL A	0.26	0.2	17.1	21.0
1976	SEP	23	10:29	14:21	COMBINED FUEL A	0.26	3.9	81.2	21.0
1976	SEP	25	19:56	21:28	COMBINED FUEL A	0.26	1.5	32.2	21.0
1976	SEP	30	19:05	20:21	COMBINED FUEL A	0.26	1.3	26.6	21.0
1976	OCT	1	18:50	19:35	COMBINED FUEL A	0.26	0.8	15.8	21.0
1976	OCT	3	18:48	19:36	COMBINED FUEL A	0.26	0.8	16.8	21.0
1976	OCT	4	18:50	19:55	COMBINED FUEL A	0.26	1.1	22.7	21.0
1976	OCT	5	12:46	13:36	COMBINED FUEL A	0.26	0.8	17.5	21.0
1976	OCT	6	19:02	20:07	COMBINED FUEL A	0.26	1.1	22.7	21.0
1976	OCT	7	9:23	10:00	COMBINED FUEL A	0.26	0.6		
1976	OCT	7	13:35	20:37	COMBINED FUEL A	0.26	7.0	160.6	21.0
1976	OCT	9	14:01	20:47	COMBINED FUEL A	0.26	6.8	142.1	21.0
1976	OCT	10	18:58	19:56	COMBINED FUEL A	0.26	1.0	20.3	21.0
1976	OCT	11	18:47	19:17	COMBINED FUEL A	0.26	0.5	10.5	21.0
1976	OCT	12	11:40	15:20	COMBINED FUEL A	0.26	3.7	77.0	21.0
1976	OCT	18	18:25	19:58	COMBINED FUEL A	0.26	1.5	32.5	21.0
1976	OCT	20	18:31	19:20	COMBINED FUEL A	0.26	0.8	17.1	21.0
1976	OCT	22	18:20	19:22	COMBINED FUEL A	0.26	1.0	21.7	21.0
1976	OCT	29	18:27	19:55	COMBINED FUEL A	0.26	1.5	30.8	21.0
1976	OCT	30	18:04	19:36	COMBINED FUEL A	0.26	1.5	32.2	21.0
1976	OCT	31	11:54	12:56	COMBINED FUEL A	0.26	1.0		
1976	OCT	31	17:31	18:06	COMBINED FUEL A	0.26	0.6	33.9	21.0
1976	NOV	1	12:24	14:26	COMBINED FUEL A	0.26	2.0	42.7	21.0
1976	NOV	2	13:18	16:00	COMBINED FUEL A	0.26	2.7		
1976	NOV	2	17:20	19:10	COMBINED FUEL A	0.26	1.8	95.2	21.0
1976	NOV	4	16:12	16:34	COMBINED FUEL A	0.26	0.4		
1976	NOV	4	17:00	19:23	COMBINED FUEL A	0.26	2.4	57.7	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	NOV	5	15:05	15:12	COMBINED FUEL A	0.26	0.1		
1976	NOV	5	22:15	22:40	COMBINED FUEL A	0.26	0.4	11.2	21.0
1976	NOV	7	17:11	18:48	COMBINED FUEL A	0.26	1.6	33.9	21.0
1976	NOV	8	17:27	20:18	COMBINED FUEL A	0.26	2.8	59.8	21.0
1976	NOV	9	17:08	19:08	COMBINED FUEL A	0.26	2.0	42.0	21.0
1976	NOV	10	17:02	18:18	COMBINED FUEL A	0.26	1.3	26.6	21.0
1976	NOV	11	17:05	18:28	COMBINED FUEL A	0.26	1.4	29.0	21.0
1976	NOV	12	15:33	16:40	COMBINED FUEL A	0.26	1.1		
1976	NOV	12	16:40	18:48	COMBINED FUEL A	0.26	2.1	68.2	21.0
1976	NOV	13	17:05	18:53	COMBINED FUEL A	0.26	1.8	37.8	21.0
1976	NOV	15	17:10	18:37	COMBINED FUEL A	0.26	1.4	30.4	21.0
1976	NOV	17	17:07	19:10	COMBINED FUEL A	0.26	2.0	43.0	21.0
1976	NOV	18	16:51	19:22	COMBINED FUEL A	0.26	2.5	52.8	21.0
1976	NOV	19	14:53	15:00	COMBINED FUEL A	0.26	0.1		
1976	NOV	19	15:25	15:35	COMBINED FUEL A	0.26	0.2		
1976	NOV	19	15:55	16:05	COMBINED FUEL A	0.26	0.2		
1976	NOV	19	16:43	17:31	COMBINED FUEL A	0.26	0.8	26.3	21.0
1976	NOV	20	10:13	13:00	COMBINED FUEL A	0.26	2.8	58.4	21.0
1976	NOV	21	16:16	18:38	COMBINED FUEL A	0.26	2.4	49.7	21.0
1976	NOV	22	17:15	18:29	COMBINED FUEL A	0.26	1.2	25.9	21.0
1976	NOV	23	17:45	20:50	COMBINED FUEL A	0.26	3.1	64.7	21.0
1976	DEC	3	7:22	7:38	COMBINED FUEL A	0.26	0.3	5.6	21.0
1976	DEC	4	16:41	19:27	COMBINED FUEL A	0.26	2.8	58.1	21.0
1976	DEC	5	16:58	19:00	COMBINED FUEL A	0.26	2.0	42.7	21.0
1976	DEC	7	10:34	10:44	COMBINED FUEL A	0.26	0.2		
1976	DEC	7	10:46	11:45	COMBINED FUEL A	0.26	1.0	24.1	21.0
1976	DEC	8	13:15	13:16	COMBINED FUEL A	0.26	0.0		
1976	DEC	8	15:49	16:00	COMBINED FUEL A	0.26	0.2		
1976	DEC	8	17:03	17:06	COMBINED FUEL A	0.26	0.0		
1976	DEC	8	18:06	18:10	COMBINED FUEL A	0.26	0.1		
1976	DEC	8	19:06	19:18	COMBINED FUEL A	0.26	0.2	10.8	21.0
1976	DEC	9	13:55	14:35	COMBINED FUEL A	0.26	0.7	14.0	21.0
1976	DEC	10	17:08	17:09	COMBINED FUEL A	0.26	0.0		
1976	DEC	10	18:10	21:05	COMBINED FUEL A	0.26	2.9	61.6	21.0
1976	DEC	11	17:00	18:54	COMBINED FUEL A	0.26	1.9	39.9	21.0
1976	DEC	16	17:30	18:27	COMBINED FUEL A	0.26	1.0	19.9	21.0
1976	DEC	17	9:45	10:10	COMBINED FUEL A	0.26	0.4	8.8	21.0
1976	DEC	18	17:10	19:11	COMBINED FUEL A	0.26	2.0	42.3	21.0
1976	DEC	19	17:15	18:52	COMBINED FUEL A	0.26	1.6	33.9	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	DEC	22	6:56	10:13	COMBINED FUEL A	0.26	3.3		
1976	DEC	22	17:18	18:40	COMBINED FUEL A	0.26	1.4	97.6	21.0
1976	DEC	27	17:24	19:19	COMBINED FUEL A	0.26	1.9	40.2	21.0
1976	DEC	28	11:27	13:46	COMBINED FUEL A	0.26	2.3		
1976	DEC	28	17:32	18:50	COMBINED FUEL A	0.26	1.3	75.9	21.0
1976	DEC	29	17:45	18:50	COMBINED FUEL A	0.26	1.1	22.7	21.0
1976	DEC	30	16:56	17:09	COMBINED FUEL A	0.26	0.2		
1976	DEC	30	21:27	21:56	COMBINED FUEL A	0.26	0.5	14.7	21.0
1976	DEC	31	9:45	13:13	COMBINED FUEL A	0.26	3.5		
1976	DEC	31	17:23	18:47	COMBINED FUEL A	0.26	1.4	102.2	21.0
1977	JAN	1	9:09	11:37	COMBINED FUEL A	0.29	2.5		
1977	JAN	1	17:34	18:42	COMBINED FUEL A	0.29	1.1	75.6	21.0
1977	JAN	2	17:19	18:22	COMBINED FUEL A	0.29	1.0	22.0	21.0
1977	JAN	3	11:18	12:03	COMBINED FUEL A	0.29	0.8	15.8	21.0
1977	JAN	4	17:19	17:22	COMBINED FUEL A	0.29	0.0		
1977	JAN	4	18:49	19:30	COMBINED FUEL A	0.29	0.7	21.3	29.0
1977	JAN	5	17:17	17:56	COMBINED FUEL A	0.29	0.6	18.8	29.0
1977	JAN	6	8:10	10:30	COMBINED FUEL A	0.29	2.3		
1977	JAN	6	12:34	14:27	COMBINED FUEL A	0.29	1.9		
1977	JAN	6	18:10	19:28	COMBINED FUEL A	0.29	1.3	115.8	21.0
1977	JAN	7	7:12	11:03	COMBINED FUEL A	0.29	3.8		
1977	JAN	7	14:02	14:51	COMBINED FUEL A	0.29	0.8		
1977	JAN	7	18:04	18:52	COMBINED FUEL A	0.29	0.8	114.8	21.0
1977	JAN	8	17:25	19:04	COMBINED FUEL A	0.29	1.6	47.8	29.0
1977	JAN	10	17:33	19:04	COMBINED FUEL A	0.29	1.5	44.0	29.0
1977	JAN	11	12:07	12:25	COMBINED FUEL A	0.29	0.3		
1977	JAN	11	17:33	18:25	COMBINED FUEL A	0.29	0.9	33.8	29.0
1977	JAN	12	17:27	18:35	COMBINED FUEL A	0.29	1.1	32.9	29.0
1977	JAN	18	20:53	23:42	COMBINED FUEL A	0.29	2.8	81.7	29.0
1977	JAN	20	17:43	18:50	COMBINED FUEL A	0.29	1.1	32.4	29.0
1977	JAN	24	9:05	11:30	COMBINED FUEL A	0.29	2.4		
1977	JAN	24	17:37	18:43	COMBINED FUEL A	0.29	1.1	102.0	29.0
1977	JAN	29	17:49	19:19	COMBINED FUEL A	0.29	1.5	31.5	21.0
1977	JAN	30	10:30	11:15	COMBINED FUEL A	0.29	0.8	15.8	21.0
1977	FEB	12	14:47	19:50	COMBINED FUEL A	0.29	5.0	146.4	29.0
1977	FEB	15	18:20	18:48	COMBINED FUEL A	0.29	0.5	13.5	29.0
1977	FEB	16	9:53	13:48	COMBINED FUEL A	0.29	3.9	113.6	29.0
1977	FEB	20	3:14	4:06	COMBINED FUEL A	0.29	0.9	25.1	29.0
1977	FEB	22	9:33	9:49	COMBINED FUEL A	0.29	0.3		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	FEB	22	18:03	19:17	COMBINED FUEL A	0.29	1.2	43.5	29.0
1977	FEB	23	17:52	18:57	COMBINED FUEL A	0.29	1.1	31.4	29.0
1977	FEB	24	13:07	15:59	COMBINED FUEL A	0.29	2.9		
1977	FEB	24	18:02	19:16	COMBINED FUEL A	0.29	1.2	118.9	29.0
1977	MAR	1	18:05	19:08	COMBINED FUEL A	0.29	1.0	22.0	21.0
1977	MAR	2	7:35	9:17	COMBINED FUEL A	0.29	1.7	35.7	21.0
1977	MAR	3	18:02	18:57	COMBINED FUEL A	0.29	0.9	19.2	21.0
1977	MAR	7	17:50	19:19	COMBINED FUEL A	0.29	1.5	31.1	21.0
1977	MAR	13	20:10	20:47	COMBINED FUEL A	0.29	0.6	12.9	21.0
1977	MAR	16	17:46	20:28	COMBINED FUEL A	0.29	2.7	56.7	21.0
1977	MAR	23	11:23	13:50	COMBINED FUEL A	0.29	2.4	51.4	21.0
1977	MAR	28	12:20	14:12	COMBINED FUEL A	0.29	1.9	39.2	21.0
1977	APR	1	7:57	8:37	COMBINED FUEL A	0.29	0.7		
1977	APR	1	10:48	11:06	COMBINED FUEL A	0.29	0.3		
1977	APR	1	11:24	14:45	COMBINED FUEL A	0.29	3.3	90.6	21.0
1977	APR	4	16:16	17:31	COMBINED FUEL A	0.29	1.3	26.3	21.0
1977	APR	8	13:56	14:25	COMBINED FUEL A	0.29	0.5	10.1	21.0
1977	APR	17	11:25	16:18	COMBINED FUEL A	0.29	4.9		
1977	APR	17	18:16	20:16	COMBINED FUEL A	0.29	2.0	144.5	21.0
1977	APR	19	10:02	11:21	COMBINED FUEL A	0.29	1.3	27.6	21.0
1977	APR	30	19:51	20:56	COMBINED FUEL A	0.29	1.1	22.7	21.0
1977	MAY	3	10:36	11:18	COMBINED FUEL A	0.29	0.7	14.7	21.0
1977	MAY	5	10:48	12:05	COMBINED FUEL A	0.29	1.3	26.9	21.0
1977	MAY	6	17:55	20:37	COMBINED FUEL A	0.29	2.7	56.7	21.0
1977	MAY	8	16:02	16:13	COMBINED FUEL A	0.29	0.2	3.8	21.0
1977	MAY	19	14:00	14:20	COMBINED FUEL A	0.29	0.3	7.0	21.0
1977	MAY	20	10:25	11:30	COMBINED FUEL A	0.29	1.1		
1977	MAY	20	11:30	14:15	COMBINED FUEL A	0.29	2.8	80.5	21.0
1977	MAY	24	20:29	21:05	COMBINED FUEL A	0.29	0.6	12.6	21.0
1977	MAY	31	9:34	10:21	COMBINED FUEL A	0.29	0.8		
1977	MAY	31	11:04	15:23	COMBINED FUEL A	0.29	4.3	107.1	21.0
1977	JUN	29	10:15	14:25	COMBINED FUEL A	0.29	4.2	87.5	21.0
1977	JUL	16	20:26	23:30	COMBINED FUEL A	0.29	3.1	64.4	21.0
1977	JUL	17	20:14	22:34	COMBINED FUEL A	0.29	2.3		
1977	JUL	17	23:12	24:00	COMBINED FUEL A	0.29	0.8	65.8	21.0
1977	JUL	18	0:00	0:12	COMBINED FUEL A	0.29	0.2		
1977	JUL	18	10:17	17:09	COMBINED FUEL A	0.29	6.9	148.4	21.0
1977	JUL	21	12:07	15:47	COMBINED FUEL A	0.29	3.7		
1977	JUL	21	20:15	21:16	COMBINED FUEL A	0.29	1.0	98.3	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JUL	22	13:10	14:36	COMBINED FUEL A	0.29	1.4	30.1	21.0
1977	JUL	25	9:25	11:03	COMBINED FUEL A	0.29	1.6		
1977	JUL	25	12:32	14:30	COMBINED FUEL A	0.29	2.0	75.6	21.0
1977	JUL	26	15:04	15:42	COMBINED FUEL A	0.29	0.6		
1977	JUL	26	20:12	21:12	COMBINED FUEL A	0.29	1.0	34.3	21.0
1977	JUL	27	9:15	11:55	COMBINED FUEL A	0.29	2.7	56.0	21.0
1977	JUL	29	13:32	18:55	COMBINED FUEL A	0.29	5.4	113.0	21.0
1977	JUL	30	10:31	10:43	COMBINED FUEL A	0.29	0.2		
1977	JUL	30	11:04	11:17	COMBINED FUEL A	0.29	0.2		
1977	JUL	30	18:08	18:19	COMBINED FUEL A	0.29	0.2	12.6	21.0
1977	AUG	1	8:29	9:17	COMBINED FUEL A	0.29	0.8	16.8	21.0
1977	AUG	2	13:09	14:15	COMBINED FUEL A	0.29	1.1		
1977	AUG	2	14:15	14:28	COMBINED FUEL A	0.29	0.2		
1977	AUG	2	15:40	16:00	COMBINED FUEL A	0.29	0.3	34.6	21.0
1977	AUG	3	17:25	18:47	COMBINED FUEL A	0.29	1.4	28.7	21.0
1977	AUG	5	15:20	15:39	COMBINED FUEL A	0.29	0.3	6.6	21.0
1977	AUG	9	19:42	20:26	COMBINED FUEL A	0.29	0.7	15.4	21.0
1977	AUG	15	19:43	21:15	COMBINED FUEL A	0.29	1.5	32.2	21.0
1977	AUG	19	8:23	11:29	COMBINED FUEL A	0.29	3.1		
1977	AUG	19	19:56	20:52	COMBINED FUEL A	0.29	0.9	84.7	21.0
1977	AUG	25	8:06	9:14	COMBINED FUEL A	0.29	1.1	23.8	21.0
1977	AUG	28	19:44	21:17	COMBINED FUEL A	0.29	1.5	32.5	21.0
1977	AUG	29	19:30	20:38	COMBINED FUEL A	0.29	1.1	23.8	21.0
1977	AUG	31	8:45	13:30	COMBINED FUEL A	0.29	4.8		
1977	AUG	31	14:28	14:40	COMBINED FUEL A	0.29	0.2		
1977	AUG	31	14:55	15:08	COMBINED FUEL A	0.29	0.2	108.5	21.0
1977	SEP	2	19:44	20:50	COMBINED FUEL A	0.29	1.1	23.1	21.0
1977	SEP	4	19:25	21:00	COMBINED FUEL A	0.29	1.6	33.2	21.0
1977	SEP	6	12:11	17:37	COMBINED FUEL A	0.29	5.4		
1977	SEP	6	19:37	21:15	COMBINED FUEL A	0.29	1.6	148.4	21.0
1977	SEP	7	12:58	19:13	COMBINED FUEL A	0.29	6.3	131.3	21.0
1977	SEP	10	8:55	13:25	COMBINED FUEL A	0.29	4.5	94.5	21.0
1977	SEP	16	19:20	20:25	COMBINED FUEL A	0.29	1.1	22.7	21.0
1977	SEP	18	19:40	20:29	COMBINED FUEL A	0.29	0.8	17.1	21.0
1977	SEP	20	12:15	15:14	COMBINED FUEL A	0.29	3.0	62.6	21.0
1977	SEP	23	19:09	20:16	COMBINED FUEL A	0.29	1.1	23.4	21.0
1977	SEP	24	18:56	20:40	COMBINED FUEL A	0.29	1.7	36.4	21.0
1977	OCT	2	19:00	19:30	COMBINED FUEL A	0.29	0.5	10.5	21.0
1977	OCT	3	18:00	18:30	COMBINED FUEL A	0.29	0.5	10.5	21.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDGE)

ELECTRIC GENERATING STATION: SDGE KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	OCT	7	15:15	16:02	COMBINED FUEL A	0.29	0.8		
1977	OCT	7	18:42	19:35	COMBINED FUEL A	0.29	0.9	35.0	21.0
1977	OCT	10	18:51	19:15	COMBINED FUEL A	0.29	0.4	8.4	21.0
1977	OCT	11	9:40	10:52	COMBINED FUEL A	0.29	1.2		
1977	OCT	11	14:50	15:13	COMBINED FUEL A	0.29	0.4	33.2	21.0
1977	OCT	15	18:30	19:38	COMBINED FUEL A	0.29	1.1	23.8	21.0
1977	OCT	16	18:30	19:25	COMBINED FUEL A	0.29	0.9	19.3	21.0
1977	OCT	17	8:43	11:21	COMBINED FUEL A	0.29	2.6	55.3	21.0
1977	OCT	20	18:07	19:24	COMBINED FUEL A	0.29	1.3	26.9	21.0
1977	OCT	24	10:23	13:13	COMBINED FUEL A	0.29	2.8	59.5	21.0
1977	OCT	25	18:49	19:09	COMBINED FUEL A	0.29	0.3	7.0	21.0
1977	OCT	31	17:55	18:20	COMBINED FUEL A	0.29	0.4	8.8	21.0
1977	NOV	1	17:35	19:45	COMBINED FUEL A	0.29	2.2	45.5	21.0
1977	NOV	2	17:26	18:58	COMBINED FUEL A	0.29	1.5	32.2	21.0
1977	NOV	3	17:15	18:20	COMBINED FUEL A	0.29	1.1	22.7	21.0
1977	NOV	7	17:11	18:45	COMBINED FUEL A	0.29	1.6	32.9	21.0
1977	NOV	8	17:27	18:15	COMBINED FUEL A	0.29	0.8	16.8	21.0
1977	NOV	9	17:08	19:21	COMBINED FUEL A	0.29	2.2	46.5	21.0
1977	NOV	10	17:16	18:30	COMBINED FUEL A	0.29	1.2	25.9	21.0
1977	NOV	14	17:24	18:23	COMBINED FUEL A	0.29	1.0	20.6	21.0
1977	NOV	16	17:21	18:21	COMBINED FUEL A	0.29	1.0	21.0	21.0
1977	NOV	17	17:04	18:22	COMBINED FUEL A	0.29	1.3	27.3	21.0
1977	NOV	18	7:14	8:20	COMBINED FUEL A	0.29	1.1	23.1	21.0
1977	NOV	19	17:15	18:31	COMBINED FUEL A	0.29	1.3	26.6	21.0
1977	NOV	20	17:05	19:38	COMBINED FUEL A	0.29	2.5	53.5	21.0
1977	NOV	21	17:18	18:11	COMBINED FUEL A	0.29	0.9	18.5	21.0
1977	NOV	23	16:53	19:37	COMBINED FUEL A	0.29	2.7	57.4	21.0
1977	NOV	28	17:02	18:35	COMBINED FUEL A	0.29	1.5	32.5	21.0
1977	NOV	30	8:46	24:00	COMBINED FUEL A	0.29	15.2	319.9	21.0
1977	DEC	1	16:56	18:39	COMBINED FUEL A	0.29	1.7	36.0	21.0
1977	DEC	3	17:20	18:27	COMBINED FUEL A	0.29	1.1	23.4	21.0
1977	DEC	7	17:18	19:27	COMBINED FUEL A	0.29	2.1	45.1	21.0
1977	DEC	10	13:05	13:35	COMBINED FUEL A	0.29	0.5		
1977	DEC	10	13:49	14:02	COMBINED FUEL A	0.29	0.2		
1977	DEC	10	17:31	18:10	COMBINED FUEL A	0.29	0.7	28.7	21.0
1977	DEC	12	17:14	17:53	COMBINED FUEL A	0.29	0.6	13.6	21.0
1977	DEC	16	17:01	19:12	COMBINED FUEL A	0.29	2.2	45.8	21.0
1977	DEC	19	17:02	19:14	COMBINED FUEL A	0.29	2.2	46.2	21.0
1977	DEC	20	17:19	18:52	COMBINED FUEL A	0.29	1.5	32.5	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	DEC	21	16:59	19:22	COMBINED FUEL A	0.29	2.4	50.0	21.0
1977	DEC	22	17:05	18:45	COMBINED FUEL A	0.29	1.7	35.0	21.0
1977	DEC	24	16:59	18:11	COMBINED FUEL A	0.29	1.2	25.2	21.0
1977	DEC	28	12:17	13:39	COMBINED FUEL A	0.29	1.4	28.7	21.0
1977	DEC	29	17:45	18:14	COMBINED FUEL A	0.29	0.5	10.1	21.0
1977	DEC	31	17:24	18:28	COMBINED FUEL A	0.29	1.1	22.4	21.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	9	15:08	16:20	COMBINED FUEL A	0.30	1.2	24.0	20.0
1975	JAN	17	9:45	11:25	COMBINED FUEL A	0.30	1.7	33.3	20.0
1975	FEB	24	12:05	15:12	COMBINED FUEL A	0.30	3.1	62.3	20.0
1975	FEB	27	7:56	8:50	COMBINED FUEL A	0.30	0.9		
1975	FEB	27	9:30	10:40	COMBINED FUEL A	0.30	1.2		
1975	FEB	27	11:20	12:45	COMBINED FUEL A	0.30	1.4	69.7	20.0
1975	MAR	4	10:08	10:32	COMBINED FUEL A	0.30	0.4	8.0	20.0
1975	MAR	10	8:13	10:59	COMBINED FUEL A	0.30	2.8	55.3	20.0
1975	MAR	13	18:09	19:24	COMBINED FUEL A	0.30	1.3	25.0	20.0
1975	MAR	20	11:54	12:48	COMBINED FUEL A	0.30	0.9	18.0	20.0
1975	MAR	21	0:56	2:03	COMBINED FUEL A	0.30	1.1		
1975	MAR	21	8:42	11:30	COMBINED FUEL A	0.30	2.8	78.3	20.0
1975	MAR	31	8:24	9:03	COMBINED FUEL A	0.30	0.7		
1975	MAR	31	9:18	9:21	COMBINED FUEL A	0.30	0.0	14.0	20.0
1975	APR	3	11:01	11:24	COMBINED FUEL A	0.30	0.4		
1975	APR	3	12:01	12:10	COMBINED FUEL A	0.30	0.1	10.7	20.0
1975	APR	4	14:36	16:24	COMBINED FUEL A	0.30	1.8	36.0	20.0
1975	APR	11	8:26	12:14	COMBINED FUEL A	0.30	3.8	76.0	20.0
1975	APR	17	10:14	10:45	COMBINED FUEL A	0.30	0.5	10.3	20.0
1975	APR	25	10:30	15:22	COMBINED FUEL A	0.30	4.9	97.3	20.0
1975	APR	28	10:48	12:35	COMBINED FUEL A	0.30	1.8	35.7	20.0
1975	APR	29	8:18	8:25	COMBINED FUEL A	0.30	0.1		
1975	APR	29	18:06	21:56	COMBINED FUEL A	0.30	3.8	79.0	20.0
1975	APR	30	12:57	13:43	COMBINED FUEL A	0.30	0.8		
1975	APR	30	14:25	14:40	COMBINED FUEL A	0.30	0.3	20.3	20.0
1975	MAY	3	11:01	11:24	COMBINED FUEL A	0.30	0.4	7.7	20.0
1975	MAY	4	12:01	12:10	COMBINED FUEL A	0.30	0.1	3.0	20.0
1975	MAY	11	14:36	16:24	COMBINED FUEL A	0.30	1.8	36.0	20.0
1975	MAY	17	8:26	12:14	COMBINED FUEL A	0.30	3.8	76.0	20.0
1975	MAY	25	10:14	10:45	COMBINED FUEL A	0.30	0.5		
1975	MAY	25	13:20	13:55	COMBINED FUEL A	0.30	0.6		
1975	MAY	25	14:46	15:22	COMBINED FUEL A	0.30	0.6	34.0	20.0
1975	MAY	28	10:48	12:35	COMBINED FUEL A	0.30	1.8	35.7	20.0
1975	MAY	29	8:18	8:25	COMBINED FUEL A	0.30	0.1		
1975	MAY	29	18:06	21:56	COMBINED FUEL A	0.30	3.8	79.0	20.0
1975	MAY	30	12:57	13:43	COMBINED FUEL A	0.30	0.8		
1975	MAY	30	14:25	14:40	COMBINED FUEL A	0.30	0.3	20.3	20.0
1975	JUN	2	10:20	12:10	COMBINED FUEL A	0.30	1.8	36.7	20.0
1975	JUN	11	12:42	13:52	COMBINED FUEL A	0.30	1.2	23.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JUN	15	8:07	8:10	COMBINED FUEL A	0.30	0.0	1.0	20.0
1975	JUN	17	8:07	8:10	COMBINED FUEL A	0.30	0.0	1.0	20.0
1975	JUN	19	7:50	10:58	COMBINED FUEL A	0.30	3.1		
1975	JUN	19	19:40	22:53	COMBINED FUEL A	0.30	3.2	127.0	20.0
1975	JUL	11	10:05	15:42	COMBINED FUEL A	0.30	5.6	112.3	20.0
1975	JUL	18	10:15	11:30	COMBINED FUEL A	0.30	1.3	25.0	20.0
1975	JUL	19	14:32	15:56	COMBINED FUEL A	0.30	1.4	28.0	20.0
1975	JUL	21	9:00	11:42	COMBINED FUEL A	0.30	2.7	54.0	20.0
1975	JUL	25	11:42	14:20	COMBINED FUEL A	0.30	2.6	52.7	20.0
1975	AUG	2	15:21	18:06	COMBINED FUEL A	0.30	2.8	55.0	20.0
1975	AUG	11	7:31	8:37	COMBINED FUEL A	0.30	1.1	22.0	20.0
1975	AUG	24	12:39	14:50	COMBINED FUEL A	0.30	2.2	43.7	20.0
1975	SEP	4	14:36	16:18	COMBINED FUEL A	0.30	1.7	34.0	20.0
1975	SEP	6	8:43	9:59	COMBINED FUEL A	0.30	1.3		
1975	SEP	6	22:25	22:34	COMBINED FUEL A	0.30	0.1	28.3	20.0
1975	SEP	8	18:34	19:45	COMBINED FUEL A	0.30	1.2	23.7	20.0
1975	SEP	15	9:45	18:27	COMBINED FUEL A	0.30	8.7	174.0	20.0
1975	SEP	16	9:32	24:00	COMBINED FUEL A	0.30	14.5	289.3	20.0
1975	SEP	17	0:00	0:03	COMBINED FUEL A	0.30	0.0		
1975	SEP	17	10:18	11:46	COMBINED FUEL A	0.30	1.5		
1975	SEP	17	13:12	15:15	COMBINED FUEL A	0.30	2.0	71.3	20.0
1975	SEP	18	10:43	18:41	COMBINED FUEL A	0.30	8.0	159.3	20.0
1975	SEP	19	8:18	9:48	COMBINED FUEL A	0.30	1.5	30.0	20.0
1975	SEP	20	10:12	11:08	COMBINED FUEL A	0.30	0.9	18.7	20.0
1975	SEP	23	12:15	19:29	COMBINED FUEL A	0.30	7.2	144.7	20.0
1975	OCT	2	12:51	18:05	COMBINED FUEL A	0.30	5.2	104.7	20.0
1975	OCT	3	12:49	17:32	COMBINED FUEL A	0.30	4.7	94.3	20.0
1975	OCT	10	8:59	19:37	COMBINED FUEL A	0.30	10.6	212.7	20.0
1975	OCT	29	11:28	12:15	COMBINED FUEL A	0.30	0.8	15.7	20.0
1975	OCT	31	8:07	8:12	COMBINED FUEL A	0.30	0.1		
1975	OCT	31	9:50	14:20	COMBINED FUEL A	0.30	4.5		
1975	OCT	31	17:08	19:55	COMBINED FUEL A	0.30	2.8	147.3	20.0
1975	DEC	1	15:20	16:17	COMBINED FUEL A	0.30	1.0	19.0	20.0
1975	DEC	5	7:48	11:19	COMBINED FUEL A	0.30	3.5		
1975	DEC	5	13:05	14:20	COMBINED FUEL A	0.30	1.3	95.3	20.0
1975	DEC	6	17:00	18:45	COMBINED FUEL A	0.30	1.8	35.0	20.0
1975	DEC	7	16:47	20:06	COMBINED FUEL A	0.30	3.3	66.3	20.0
1975	DEC	10	16:29	20:50	COMBINED FUEL A	0.30	4.3	87.0	20.0
1975	DEC	12	11:00	14:45	COMBINED FUEL A	0.30	3.8	75.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	DEC	16	14:51	15:15	COMBINED FUEL A	0.30	0.4		
1975	DEC	16	15:15	15:27	COMBINED FUEL A	0.30	0.2	12.0	20.0
1975	DEC	20	11:22	13:02	COMBINED FUEL A	0.30	1.7	33.3	20.0
1975	DEC	22	12:55	14:32	COMBINED FUEL A	0.30	1.6		
1975	DEC	22	15:03	15:22	COMBINED FUEL A	0.30	0.3	38.7	20.0
1975	DEC	23	10:15	10:48	COMBINED FUEL A	0.30	0.5		
1975	DEC	23	11:41	12:02	COMBINED FUEL A	0.30	0.4		
1975	DEC	23	13:57	14:25	COMBINED FUEL A	0.30	0.5		
1975	DEC	23	14:45	15:20	COMBINED FUEL A	0.30	0.6	39.0	20.0
1975	DEC	30	10:55	13:33	COMBINED FUEL A	0.30	2.6	52.7	20.0
1976	JAN	1	9:38	13:45	COMBINED FUEL A	0.26	4.1	82.3	20.0
1976	JAN	2	10:42	14:55	COMBINED FUEL A	0.26	4.2	84.3	20.0
1976	JAN	5	6:50	8:06	COMBINED FUEL A	0.26	1.3	25.3	20.0
1976	JAN	21	4:17	6:43	COMBINED FUEL A	0.26	2.4	48.7	20.0
1976	JAN	25	18:06	19:23	COMBINED FUEL A	0.26	1.3	25.7	20.0
1976	JAN	26	6:59	9:57	COMBINED FUEL A	0.26	3.0	59.3	20.0
1976	JAN	27	15:33	15:58	COMBINED FUEL A	0.26	0.4	8.3	20.0
1976	FEB	5	8:11	8:43	COMBINED FUEL A	0.26	0.5		
1976	FEB	5	11:21	11:38	COMBINED FUEL A	0.26	0.3		
1976	FEB	5	17:10	19:08	COMBINED FUEL A	0.26	2.0	55.7	20.0
1976	MAR	7	2:12	3:08	COMBINED FUEL A	0.26	0.9	18.7	20.0
1976	MAR	10	14:03	14:57	COMBINED FUEL A	0.26	0.9	18.0	20.0
1976	MAR	15	6:30	8:46	COMBINED FUEL A	0.26	2.3	45.3	20.0
1976	APR	6	19:00	20:50	COMBINED FUEL A	0.26	1.8	36.7	20.0
1976	APR	7	3:28	4:01	COMBINED FUEL A	0.26	0.6	11.0	20.0
1976	MAY	4	11:32	12:04	COMBINED FUEL A	0.26	0.5	10.7	20.0
1976	MAY	6	22:50	22:52	COMBINED FUEL A	0.26	0.0	0.7	20.0
1976	MAY	10	7:37	14:41	COMBINED FUEL A	0.26	7.1	141.3	20.0
1976	MAY	11	10:26	15:40	COMBINED FUEL A	0.26	5.2	104.7	20.0
1976	MAY	12	8:08	14:10	COMBINED FUEL A	0.26	6.0	120.7	20.0
1976	MAY	13	8:09	15:26	COMBINED FUEL A	0.26	7.3	145.7	20.0
1976	MAY	14	11:04	13:45	COMBINED FUEL A	0.26	2.7	53.7	20.0
1976	MAY	19	15:35	16:35	COMBINED FUEL A	0.26	1.0	20.0	20.0
1976	JUN	5	8:14	13:44	COMBINED FUEL A	0.26	5.5	110.0	20.0
1976	JUN	6	20:20	21:33	COMBINED FUEL A	0.26	1.2	24.3	20.0
1976	JUN	8	14:41	15:20	COMBINED FUEL A	0.26	0.7	13.0	20.0
1976	JUN	9	8:15	8:25	COMBINED FUEL A	0.26	0.2		
1976	JUN	9	8:38	9:07	COMBINED FUEL A	0.26	0.5		
1976	JUN	9	9:37	10:33	COMBINED FUEL A	0.26	0.9		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JUN	9	10:50	10:59	COMBINED FUEL A	0.26	0.1	34.7	20.0
1976	JUN	14	14:04	16:35	COMBINED FUEL A	0.26	2.5	50.3	20.0
1976	JUN	15	13:10	18:54	COMBINED FUEL A	0.26	5.7	114.7	20.0
1976	JUN	26	10:49	14:11	COMBINED FUEL A	0.26	3.4	67.3	20.0
1976	JUN	28	9:06	17:57	COMBINED FUEL A	0.26	8.8	177.0	20.0
1976	JUL	4	16:49	16:59	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	JUL	5	12:32	19:32	COMBINED FUEL A	0.26	7.0	140.0	20.0
1976	JUL	6	12:59	18:42	COMBINED FUEL A	0.26	5.7	114.3	20.0
1976	JUL	27	12:17	17:04	COMBINED FUEL A	0.26	4.8	95.7	20.0
1976	JUL	28	7:21	13:48	COMBINED FUEL A	0.26	6.4	129.0	20.0
1976	JUL	30	10:37	12:18	COMBINED FUEL A	0.26	1.7	33.7	20.0
1976	JUL	31	9:44	13:15	COMBINED FUEL A	0.26	3.5	70.3	20.0
1976	AUG	1	9:52	11:56	COMBINED FUEL A	0.26	2.1		
1976	AUG	1	20:07	21:21	COMBINED FUEL A	0.26	1.2	66.0	20.0
1976	AUG	2	7:22	14:32	COMBINED FUEL A	0.26	7.2	143.3	20.0
1976	AUG	4	17:50	18:15	COMBINED FUEL A	0.26	0.4	8.3	20.0
1976	AUG	12	13:48	16:38	COMBINED FUEL A	0.26	2.8	56.7	20.0
1976	AUG	24	13:48	16:38	COMBINED FUEL A	0.26	2.8	56.7	20.0
1976	AUG	25	10:00	11:37	COMBINED FUEL A	0.26	1.6	32.3	20.0
1976	AUG	27	14:50	16:56	COMBINED FUEL A	0.26	2.1	42.0	20.0
1976	AUG	29	19:40	20:45	COMBINED FUEL A	0.26	1.1	21.7	20.0
1976	AUG	30	9:07	17:54	COMBINED FUEL A	0.26	8.8	175.7	20.0
1976	AUG	31	9:53	11:00	COMBINED FUEL A	0.26	1.1	22.3	20.0
1976	SEP	1	11:12	15:58	COMBINED FUEL A	0.26	4.8	95.3	20.0
1976	SEP	2	12:38	17:11	COMBINED FUEL A	0.26	4.5	91.0	20.0
1976	SEP	3	11:06	11:34	COMBINED FUEL A	0.26	0.5	9.3	20.0
1976	SEP	4	14:20	16:20	COMBINED FUEL A	0.26	2.0	40.0	20.0
1976	SEP	7	12:32	14:33	COMBINED FUEL A	0.26	2.0	40.3	20.0
1976	SEP	8	11:46	15:48	COMBINED FUEL A	0.26	4.0	80.7	20.0
1976	SEP	10	0:54	1:22	COMBINED FUEL A	0.26	0.5	9.3	20.0
1976	SEP	25	19:56	22:30	COMBINED FUEL A	0.26	2.6	51.3	20.0
1976	OCT	5	12:45	16:00	COMBINED FUEL A	0.26	3.3	65.0	20.0
1976	OCT	6	14:25	15:00	COMBINED FUEL A	0.26	0.6	11.7	20.0
1976	OCT	9	19:56	20:49	COMBINED FUEL A	0.26	0.9	17.7	20.0
1976	OCT	17	14:25	18:05	COMBINED FUEL A	0.26	3.7	73.3	20.0
1976	OCT	19	11:04	12:36	COMBINED FUEL A	0.26	1.5	30.7	20.0
1976	OCT	20	11:04	12:36	COMBINED FUEL A	0.26	1.5		
1976	OCT	20	13:18	13:27	COMBINED FUEL A	0.26	0.1	33.7	20.0
1976	OCT	21	14:45	16:06	COMBINED FUEL A	0.26	1.3	27.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	OCT	26	10:37	11:07	COMBINED FUEL A	0.26	0.5	10.0	20.0
1976	NOV	2	15:55	16:28	COMBINED FUEL A	0.26	0.6	11.0	20.0
1976	NOV	3	8:32	10:55	COMBINED FUEL A	0.26	2.4		
1976	NOV	3	11:10	14:09	COMBINED FUEL A	0.26	3.0		
1976	NOV	3	14:09	16:13	COMBINED FUEL A	0.26	2.1	148.7	20.0
1976	NOV	7	17:41	19:52	COMBINED FUEL A	0.26	2.2	43.7	20.0
1976	NOV	8	10:35	18:50	COMBINED FUEL A	0.26	8.3	165.0	20.0
1976	NOV	17	14:09	15:06	COMBINED FUEL A	0.26	1.0		
1976	NOV	17	17:23	18:32	COMBINED FUEL A	0.26	1.1	42.0	20.0
1976	NOV	18	17:13	18:14	COMBINED FUEL A	0.26	1.0	20.3	20.0
1976	NOV	19	6:50	7:25	COMBINED FUEL A	0.26	0.6	11.7	20.0
1976	NOV	21	16:18	18:02	COMBINED FUEL A	0.26	1.7	34.7	20.0
1976	NOV	23	17:41	21:23	COMBINED FUEL A	0.26	3.7	74.0	20.0
1976	DEC	7	12:55	14:07	COMBINED FUEL A	0.26	1.2	24.0	20.0
1976	DEC	12	10:52	11:36	COMBINED FUEL A	0.26	0.7	14.7	20.0
1976	DEC	18	17:36	18:07	COMBINED FUEL A	0.26	0.5	10.3	20.0
1976	DEC	22	7:04	8:05	COMBINED FUEL A	0.26	1.0	20.3	20.0
1976	DEC	30	17:26	22:35	COMBINED FUEL A	0.26	5.1	103.0	20.0
1976	DEC	31	6:21	13:46	COMBINED FUEL A	0.26	7.4	148.3	20.0
1977	JAN	6	17:02	20:43	COMBINED FUEL A	0.29	3.7	73.7	20.0
1977	JAN	7	16:59	19:10	COMBINED FUEL A	0.29	2.2	43.7	20.0
1977	JAN	17	11:31	14:25	COMBINED FUEL A	0.29	2.9	58.0	20.0
1977	JAN	18	20:52	24:00	COMBINED FUEL A	0.29	3.1	62.7	20.0
1977	JAN	19	0:00	0:53	COMBINED FUEL A	0.29	0.9	17.7	20.0
1977	JAN	20	12:57	14:17	COMBINED FUEL A	0.29	1.3		
1977	JAN	20	14:46	15:37	COMBINED FUEL A	0.29	0.9	43.7	20.0
1977	FEB	16	11:57	13:35	COMBINED FUEL A	0.29	1.6	32.7	20.0
1977	MAR	18	15:00	15:30	COMBINED FUEL A	0.29	0.5	10.0	20.0
1977	MAR	23	12:35	13:17	COMBINED FUEL A	0.29	0.7	14.0	20.0
1977	APR	4	16:07	18:08	COMBINED FUEL A	0.29	2.0	40.3	20.0
1977	APR	5	8:42	15:25	COMBINED FUEL A	0.29	6.7	134.3	20.0
1977	APR	21	9:49	11:13	COMBINED FUEL A	0.29	1.4	28.0	20.0
1977	APR	30	20:40	20:47	COMBINED FUEL A	0.29	0.1	2.3	20.0
1977	MAY	3	15:02	15:22	COMBINED FUEL A	0.29	0.3	6.7	20.0
1977	MAY	4	11:23	11:40	COMBINED FUEL A	0.29	0.3	5.7	20.0
1977	MAY	5	10:47	11:58	COMBINED FUEL A	0.29	1.2	23.7	20.0
1977	MAY	6	7:34	13:14	COMBINED FUEL A	0.29	5.7	113.3	20.0
1977	MAY	23	9:23	12:50	COMBINED FUEL A	0.29	3.4	69.0	20.0
1977	MAY	31	11:00	12:00	COMBINED FUEL A	0.29	1.0	20.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JUN	8	13:25	15:45	COMBINED FUEL A	0.29	2.3	46.7	20.0
1977	JUN	9	9:23	10:07	COMBINED FUEL A	0.29	0.7	14.7	20.0
1977	JUL	15	11:42	16:48	COMBINED FUEL A	0.29	5.1	102.0	20.0
1977	JUL	17	15:59	22:57	COMBINED FUEL A	0.29	7.0		
1977	JUL	17	23:12	23:48	COMBINED FUEL A	0.29	0.6	151.3	20.0
1977	JUL	18	9:48	15:51	COMBINED FUEL A	0.29	6.0	121.0	20.0
1977	JUL	20	9:44	10:47	COMBINED FUEL A	0.29	1.0	21.0	20.0
1977	JUL	21	12:35	18:26	COMBINED FUEL A	0.29	5.8	117.0	20.0
1977	JUL	22	12:37	17:38	COMBINED FUEL A	0.29	5.0	100.3	20.0
1977	JUL	25	13:45	15:24	COMBINED FUEL A	0.29	1.6	33.0	20.0
1977	JUL	26	10:01	18:34	COMBINED FUEL A	0.29	8.5	171.0	20.0
1977	JUL	27	9:53	18:02	COMBINED FUEL A	0.29	8.1	163.0	20.0
1977	JUL	28	11:00	17:36	COMBINED FUEL A	0.29	6.6	132.0	20.0
1977	JUL	29	13:39	18:55	COMBINED FUEL A	0.29	5.3	105.3	20.0
1977	AUG	1	9:21	10:17	COMBINED FUEL A	0.29	0.9	18.7	20.0
1977	AUG	3	17:13	19:18	COMBINED FUEL A	0.29	2.1	41.7	20.0
1977	AUG	5	15:20	15:40	COMBINED FUEL A	0.29	0.3		
1977	AUG	5	16:05	16:11	COMBINED FUEL A	0.29	0.1	8.7	20.0
1977	AUG	7	20:08	20:10	COMBINED FUEL A	0.29	0.0	0.7	20.0
1977	AUG	9	15:37	16:57	COMBINED FUEL A	0.29	1.3	26.7	20.0
1977	AUG	17	13:47	14:20	COMBINED FUEL A	0.29	0.6	11.0	20.0
1977	AUG	30	11:40	12:05	COMBINED FUEL A	0.29	0.4	8.3	20.0
1977	SEP	10	6:04	6:38	COMBINED FUEL A	0.29	0.6		
1977	SEP	10	9:26	10:03	COMBINED FUEL A	0.29	0.6	23.7	20.0
1977	SEP	19	9:35	12:57	COMBINED FUEL A	0.29	3.4	67.3	20.0
1977	SEP	20	10:15	10:33	COMBINED FUEL A	0.29	0.3	6.0	20.0
1977	SEP	21	7:44	10:27	COMBINED FUEL A	0.29	2.7		
1977	SEP	21	10:44	11:10	COMBINED FUEL A	0.29	0.4	63.0	20.0
1977	SEP	26	10:30	14:32	COMBINED FUEL A	0.29	4.0	80.7	20.0
1977	OCT	3	20:44	22:02	COMBINED FUEL A	0.29	1.3	26.0	20.0
1977	OCT	10	8:28	10:26	COMBINED FUEL A	0.29	2.0	39.3	20.0
1977	OCT	20	11:46	14:05	COMBINED FUEL A	0.29	2.3	46.3	20.0
1977	OCT	22	18:46	19:16	COMBINED FUEL A	0.29	0.5	10.0	20.0
1977	OCT	31	17:49	20:50	COMBINED FUEL A	0.29	3.0	60.3	20.0
1977	NOV	2	11:00	13:03	COMBINED FUEL A	0.29	2.0		
1977	NOV	2	13:36	13:52	COMBINED FUEL A	0.29	0.3		
1977	NOV	2	14:04	14:30	COMBINED FUEL A	0.29	0.4	55.0	20.0
1977	NOV	30	9:42	20:11	COMBINED FUEL A	0.29	10.5	209.7	20.0
1977	DEC	7	16:55	19:32	COMBINED FUEL A	0.29	2.6	52.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	DEC	8	17:04	18:11	COMBINED FUEL A	0.29	1.1	22.3	20.0
1977	DEC	15	11:30	13:35	COMBINED FUEL A	0.29	2.1	41.7	20.0
1977	DEC	19	17:02	19:30	COMBINED FUEL A	0.29	2.5	49.3	20.0
1977	DEC	22	17:24	18:13	COMBINED FUEL A	0.29	0.8	16.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDGGE)

ELECTRIC GENERATING STATION: SDGGE KEARNY STATION

UNIT NUMBER: 2B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	15	15:35	15:55	COMBINED FUEL A	0.30	0.3	6.7	20.0
1975	JAN	16	13:53	15:41	COMBINED FUEL A	0.30	1.8	36.0	20.0
1975	JAN	17	15:35	15:52	COMBINED FUEL A	0.30	0.3	5.7	20.0
1975	JAN	20	7:58	9:58	COMBINED FUEL A	0.30	2.0		
1975	JAN	20	10:00	10:25	COMBINED FUEL A	0.30	0.4	48.3	20.0
1975	JAN	21	13:18	13:30	COMBINED FUEL A	0.30	0.2		
1975	JAN	21	13:45	14:20	COMBINED FUEL A	0.30	0.6	15.7	20.0
1975	JAN	22	13:00	14:37	COMBINED FUEL A	0.30	1.6		
1975	JAN	22	15:06	15:15	COMBINED FUEL A	0.30	0.1		
1975	JAN	22	15:43	15:50	COMBINED FUEL A	0.30	0.1	37.7	20.0
1975	JAN	23	8:37	9:10	COMBINED FUEL A	0.30	0.6		
1975	JAN	23	10:47	11:00	COMBINED FUEL A	0.30	0.2		
1975	JAN	23	12:40	13:10	COMBINED FUEL A	0.30	0.5	25.3	20.0
1975	FEB	8	10:14	11:47	COMBINED FUEL A	0.30	1.5	31.0	20.0
1975	FEB	11	17:29	20:02	COMBINED FUEL A	0.30	2.5	51.0	20.0
1975	FEB	14	8:52	11:15	COMBINED FUEL A	0.30	2.4	47.7	20.0
1975	FEB	16	17:46	21:18	COMBINED FUEL A	0.30	3.5	70.7	20.0
1975	FEB	26	18:48	20:46	COMBINED FUEL A	0.30	2.0	39.3	20.0
1975	MAR	6	11:05	12:06	COMBINED FUEL A	0.30	1.0	20.3	20.0
1975	MAR	10	8:13	10:54	COMBINED FUEL A	0.30	2.7	53.7	20.0
1975	MAR	13	18:09	21:15	COMBINED FUEL A	0.30	3.1	62.0	20.0
1975	MAR	18	19:18	20:49	COMBINED FUEL A	0.30	1.5	30.3	20.0
1975	MAR	21	0:56	2:03	COMBINED FUEL A	0.30	1.1		
1975	MAR	21	9:03	12:05	COMBINED FUEL A	0.30	3.0	83.0	20.0
1975	MAR	27	8:00	14:37	COMBINED FUEL A	0.30	6.6	132.3	20.0
1975	MAR	31	9:33	16:28	COMBINED FUEL A	0.30	6.9	138.3	20.0
1975	APR	1	10:58	11:21	COMBINED FUEL A	0.30	0.4	7.7	20.0
1975	APR	4	9:14	11:13	COMBINED FUEL A	0.30	2.0		
1975	APR	4	14:36	15:28	COMBINED FUEL A	0.30	0.9	57.0	20.0
1975	APR	8	10:46	20:12	COMBINED FUEL A	0.30	9.4	188.7	20.0
1975	APR	10	9:43	15:25	COMBINED FUEL A	0.30	5.7	114.0	20.0
1975	APR	15	15:12	15:59	COMBINED FUEL A	0.30	0.8	15.7	20.0
1975	APR	16	8:10	12:26	COMBINED FUEL A	0.30	4.3		
1975	APR	16	19:36	22:52	COMBINED FUEL A	0.30	3.3	150.7	20.0
1975	APR	17	8:09	12:32	COMBINED FUEL A	0.30	4.4	87.7	20.0
1975	APR	18	9:14	11:32	COMBINED FUEL A	0.30	2.3	46.0	20.0
1975	APR	21	8:42	14:30	COMBINED FUEL A	0.30	5.8		
1975	APR	21	14:30	21:09	COMBINED FUEL A	0.30	6.6	249.0	20.0
1975	APR	23	8:51	11:00	COMBINED FUEL A	0.30	2.1	43.0	20.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	APR	24	10:40	11:07	COMBINED FUEL A	0.30	0.5	9.0	20.0
1975	APR	29	18:06	21:43	COMBINED FUEL A	0.30	3.6	72.3	20.0
1975	MAY	1	10:58	11:21	COMBINED FUEL A	0.30	0.4	7.7	20.0
1975	MAY	4	9:14	11:13	COMBINED FUEL A	0.30	2.0		
1975	MAY	4	14:36	15:28	COMBINED FUEL A	0.30	0.9	57.0	20.0
1975	MAY	8	10:46	20:12	COMBINED FUEL A	0.30	9.4	188.7	20.0
1975	MAY	10	9:43	15:25	COMBINED FUEL A	0.30	5.7	114.0	20.0
1975	MAY	15	15:12	15:59	COMBINED FUEL A	0.30	0.8	15.7	20.0
1975	MAY	16	8:16	12:26	COMBINED FUEL A	0.30	4.2		
1975	MAY	16	19:36	22:52	COMBINED FUEL A	0.30	3.3	148.7	20.0
1975	MAY	17	8:09	12:32	COMBINED FUEL A	0.30	4.4	87.7	20.0
1975	MAY	18	9:14	11:32	COMBINED FUEL A	0.30	2.3	46.0	20.0
1975	MAY	21	8:42	14:30	COMBINED FUEL A	0.30	5.8		
1975	MAY	21	14:30	21:09	COMBINED FUEL A	0.30	6.6	249.0	20.0
1975	MAY	23	8:51	11:00	COMBINED FUEL A	0.30	2.1	43.0	20.0
1975	MAY	24	10:40	11:07	COMBINED FUEL A	0.30	0.5	9.0	20.0
1975	MAY	29	18:06	21:43	COMBINED FUEL A	0.30	3.6	72.3	20.0
1975	JUN	2	10:35	12:10	COMBINED FUEL A	0.30	1.6		
1975	JUN	2	13:35	15:40	COMBINED FUEL A	0.30	2.1	73.3	20.0
1975	JUN	3	10:20	12:10	COMBINED FUEL A	0.30	1.8		
1975	JUN	3	14:40	15:52	COMBINED FUEL A	0.30	1.2	60.7	20.0
1975	JUN	4	10:11	14:58	COMBINED FUEL A	0.30	4.8	95.7	20.0
1975	JUN	5	13:02	15:35	COMBINED FUEL A	0.30	2.5	51.0	20.0
1975	JUN	6	8:58	12:30	COMBINED FUEL A	0.30	3.5	70.7	20.0
1975	JUN	9	8:20	8:25	COMBINED FUEL A	0.30	0.1	1.7	20.0
1975	JUN	17	8:07	8:10	COMBINED FUEL A	0.30	0.0	1.0	20.0
1975	JUN	19	7:50	10:58	COMBINED FUEL A	0.30	3.1		
1975	JUN	19	19:40	22:53	COMBINED FUEL A	0.30	3.2	127.0	20.0
1975	JUN	30	9:10	10:25	COMBINED FUEL A	0.30	1.3		
1975	JUN	30	10:25	11:55	COMBINED FUEL A	0.30	1.5	55.0	20.0
1975	JUL	11	10:13	14:44	COMBINED FUEL A	0.30	4.5	90.3	20.0
1975	JUL	19	14:43	15:57	COMBINED FUEL A	0.30	1.2	24.7	20.0
1975	JUL	21	9:00	10:10	COMBINED FUEL A	0.30	1.2	23.3	20.0
1975	JUL	27	12:11	16:21	COMBINED FUEL A	0.30	4.2	83.3	20.0
1975	JUL	28	10:05	16:05	COMBINED FUEL A	0.30	6.0	120.0	20.0
1975	AUG	2	15:21	18:11	COMBINED FUEL A	0.30	2.8	56.7	20.0
1975	AUG	5	12:52	14:18	COMBINED FUEL A	0.30	1.4	28.7	20.0
1975	AUG	8	9:36	11:10	COMBINED FUEL A	0.30	1.6	31.3	20.0
1975	AUG	11	7:31	8:37	COMBINED FUEL A	0.30	1.1	22.0	20.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	AUG	19	19:14	21:20	COMBINED FUEL A	0.30	2.1	42.0	20.0
1975	AUG	21	10:40	13:17	COMBINED FUEL A	0.30	2.6	52.3	20.0
1975	AUG	23	13:36	18:48	COMBINED FUEL A	0.30	5.2	104.0	20.0
1975	AUG	24	11:02	14:50	COMBINED FUEL A	0.30	3.8	76.0	20.0
1975	AUG	29	14:21	15:35	COMBINED FUEL A	0.30	1.2	24.7	20.0
1975	SEP	3	13:43	17:42	COMBINED FUEL A	0.30	4.0		
1975	SEP	3	19:43	21:18	COMBINED FUEL A	0.30	1.6	111.3	20.0
1975	SEP	4	11:45	18:17	COMBINED FUEL A	0.30	6.5	130.7	20.0
1975	SEP	6	8:43	9:59	COMBINED FUEL A	0.30	1.3		
1975	SEP	6	22:25	23:40	COMBINED FUEL A	0.30	1.3	50.3	20.0
1975	SEP	8	18:34	19:45	COMBINED FUEL A	0.30	1.2	23.7	20.0
1975	SEP	14	10:54	13:34	COMBINED FUEL A	0.30	2.7	53.3	20.0
1975	SEP	15	9:45	12:50	COMBINED FUEL A	0.30	3.1	61.7	20.0
1975	SEP	16	9:32	24:00	COMBINED FUEL A	0.30	14.5	289.3	20.0
1975	SEP	17	0:00	0:18	COMBINED FUEL A	0.30	0.3		
1975	SEP	17	15:11	22:53	COMBINED FUEL A	0.30	7.7	160.0	20.0
1975	SEP	18	1:37	3:34	COMBINED FUEL A	0.30	1.9		
1975	SEP	18	11:28	14:05	COMBINED FUEL A	0.30	2.6	91.3	20.0
1975	SEP	19	8:18	9:13	COMBINED FUEL A	0.30	0.9	18.3	20.0
1975	SEP	20	11:47	14:29	COMBINED FUEL A	0.30	2.7	54.0	20.0
1975	SEP	21	19:04	20:26	COMBINED FUEL A	0.30	1.4	27.3	20.0
1975	SEP	23	12:30	20:13	COMBINED FUEL A	0.30	7.7	154.3	20.0
1975	OCT	2	9:42	11:58	COMBINED FUEL A	0.30	2.3		
1975	OCT	2	13:06	18:05	COMBINED FUEL A	0.30	5.0	145.0	20.0
1975	OCT	3	12:33	16:42	COMBINED FUEL A	0.30	4.1	83.0	20.0
1975	OCT	5	19:06	21:13	COMBINED FUEL A	0.30	2.1	42.3	20.0
1975	OCT	10	8:59	9:26	COMBINED FUEL A	0.30	0.5		
1975	OCT	10	11:05	19:37	COMBINED FUEL A	0.30	8.5	179.7	20.0
1975	OCT	30	8:21	8:59	COMBINED FUEL A	0.30	0.6	12.7	20.0
1975	OCT	31	8:07	14:10	COMBINED FUEL A	0.30	6.0		
1975	OCT	31	17:08	19:42	COMBINED FUEL A	0.30	2.6	172.3	20.0
1975	NOV	1	17:38	19:53	COMBINED FUEL A	0.30	2.3	45.0	20.0
1975	NOV	3	14:48	15:05	COMBINED FUEL A	0.30	0.3		
1975	NOV	3	17:20	19:07	COMBINED FUEL A	0.30	1.8	41.3	20.0
1975	NOV	14	17:48	19:19	COMBINED FUEL A	0.30	1.5	30.3	20.0
1975	NOV	20	16:35	20:28	COMBINED FUEL A	0.30	3.9	77.7	20.0
1975	NOV	21	8:00	10:14	COMBINED FUEL A	0.30	2.2		
1975	NOV	21	16:29	18:58	COMBINED FUEL A	0.30	2.5	94.3	20.0
1975	NOV	22	16:44	18:05	COMBINED FUEL A	0.30	1.3	27.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	NOV	30	17:09	19:30	COMBINED FUEL A	0.30	2.3	47.0	20.0
1975	DEC	3	17:23	18:09	COMBINED FUEL A	0.30	0.8	15.3	20.0
1975	DEC	4	8:35	9:27	COMBINED FUEL A	0.30	0.9	17.3	20.0
1975	DEC	5	7:48	11:12	COMBINED FUEL A	0.30	3.4	68.0	20.0
1975	DEC	6	17:00	19:03	COMBINED FUEL A	0.30	2.0	41.0	20.0
1975	DEC	7	16:47	19:57	COMBINED FUEL A	0.30	3.2	63.3	20.0
1975	DEC	10	8:34	10:22	COMBINED FUEL A	0.30	1.8		
1975	DEC	10	16:29	20:40	COMBINED FUEL A	0.30	4.2	119.7	20.0
1975	DEC	13	17:10	18:49	COMBINED FUEL A	0.30	1.6	33.0	20.0
1975	DEC	15	17:04	18:50	COMBINED FUEL A	0.30	1.8	35.3	20.0
1975	DEC	16	13:40	16:50	COMBINED FUEL A	0.30	3.2	63.3	20.0
1975	DEC	19	9:52	11:10	COMBINED FUEL A	0.30	1.3	26.0	20.0
1975	DEC	23	13:36	14:07	COMBINED FUEL A	0.30	0.5	10.3	20.0
1975	DEC	30	10:55	13:48	COMBINED FUEL A	0.30	2.9	57.7	20.0
1976	JAN	1	9:35	13:37	COMBINED FUEL A	0.26	4.0	80.7	20.0
1976	JAN	2	7:45	9:18	COMBINED FUEL A	0.26	1.5	31.0	20.0
1976	JAN	5	6:50	8:11	COMBINED FUEL A	0.26	1.3	27.0	20.0
1976	JAN	21	4:17	6:43	COMBINED FUEL A	0.26	2.4	48.7	20.0
1976	JAN	25	18:04	19:50	COMBINED FUEL A	0.26	1.8	35.3	20.0
1976	JAN	26	6:30	9:44	COMBINED FUEL A	0.26	3.2	64.7	20.0
1976	JAN	27	15:33	15:58	COMBINED FUEL A	0.26	0.4	8.3	20.0
1976	FEB	4	17:11	19:34	COMBINED FUEL A	0.26	2.4	47.7	20.0
1976	FEB	5	8:11	8:49	COMBINED FUEL A	0.26	0.6		
1976	FEB	5	17:10	20:03	COMBINED FUEL A	0.26	2.9	70.3	20.0
1976	FEB	17	13:37	14:33	COMBINED FUEL A	0.26	0.9	18.7	20.0
1976	MAR	1	17:37	19:48	COMBINED FUEL A	0.26	2.2	43.7	20.0
1976	MAR	7	2:12	3:14	COMBINED FUEL A	0.26	1.0		
1976	MAR	7	5:30	8:27	COMBINED FUEL A	0.26	2.9	79.7	20.0
1976	MAR	15	6:22	8:46	COMBINED FUEL A	0.26	2.4	48.0	20.0
1976	APR	23	14:15	15:40	COMBINED FUEL A	0.26	1.4	28.3	20.0
1976	APR	30	14:18	14:22	COMBINED FUEL A	0.26	0.1		
1976	APR	30	14:52	15:00	COMBINED FUEL A	0.26	0.1	4.0	20.0
1976	MAY	3	10:00	11:23	COMBINED FUEL A	0.26	1.4		
1976	MAY	3	12:10	15:28	COMBINED FUEL A	0.26	3.3	93.7	20.0
1976	MAY	4	9:15	12:05	COMBINED FUEL A	0.26	2.8		
1976	MAY	4	14:15	14:57	COMBINED FUEL A	0.26	0.7	70.7	20.0
1976	MAY	5	10:55	14:20	COMBINED FUEL A	0.26	3.4	68.3	20.0
1976	MAY	6	17:03	17:58	COMBINED FUEL A	0.26	0.9		
1976	MAY	6	22:50	22:52	COMBINED FUEL A	0.26	0.0	19.0	20.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 20

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	MAY	11	19:35	21:20	COMBINED FUEL A	0.26	1.8	35.0	20.0
1976	MAY	12	15:28	16:18	COMBINED FUEL A	0.26	0.8		
1976	MAY	12	19:56	21:35	COMBINED FUEL A	0.26	1.6	49.7	20.0
1976	MAY	20	15:00	15:45	COMBINED FUEL A	0.26	0.8	15.0	20.0
1976	MAY	21	14:23	15:49	COMBINED FUEL A	0.26	1.4	28.7	20.0
1976	JUN	3	11:45	14:23	COMBINED FUEL A	0.26	2.6		
1976	JUN	3	14:23	16:18	COMBINED FUEL A	0.26	1.9	91.0	20.0
1976	JUN	5	8:14	11:55	COMBINED FUEL A	0.26	3.7		
1976	JUN	5	15:54	17:58	COMBINED FUEL A	0.26	2.1	115.0	20.0
1976	JUN	6	20:05	21:25	COMBINED FUEL A	0.26	1.3	26.7	20.0
1976	JUN	7	9:16	9:55	COMBINED FUEL A	0.26	0.6	13.0	20.0
1976	JUN	8	14:41	15:16	COMBINED FUEL A	0.26	0.6	11.7	20.0
1976	JUN	14	10:34	12:09	COMBINED FUEL A	0.26	1.6		
1976	JUN	14	14:04	16:21	COMBINED FUEL A	0.26	2.3	77.3	20.0
1976	JUN	15	13:10	18:06	COMBINED FUEL A	0.26	4.9	98.7	20.0
1976	JUN	23	13:15	18:30	COMBINED FUEL A	0.26	5.3	105.0	20.0
1976	JUN	24	13:02	17:45	COMBINED FUEL A	0.26	4.7	94.3	20.0
1976	JUN	25	12:30	16:08	COMBINED FUEL A	0.26	3.6	72.7	20.0
1976	JUN	26	10:04	14:22	COMBINED FUEL A	0.26	4.3	86.0	20.0
1976	JUN	28	9:06	17:57	COMBINED FUEL A	0.26	8.8	177.0	20.0
1976	JUN	29	12:40	16:42	COMBINED FUEL A	0.26	4.0	80.7	20.0
1976	JUN	30	12:30	14:45	COMBINED FUEL A	0.26	2.3	45.0	20.0
1976	JUL	4	16:49	16:59	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	JUL	5	11:24	19:24	COMBINED FUEL A	0.26	8.0	160.0	20.0
1976	JUL	6	12:15	17:56	COMBINED FUEL A	0.26	5.7	113.7	20.0
1976	JUL	7	12:12	16:37	COMBINED FUEL A	0.26	4.4	88.3	20.0
1976	JUL	8	13:03	14:43	COMBINED FUEL A	0.26	1.7	33.3	20.0
1976	JUL	14	12:44	17:44	COMBINED FUEL A	0.26	5.0	100.0	20.0
1976	JUL	19	12:52	14:39	COMBINED FUEL A	0.26	1.8	35.7	20.0
1976	JUL	20	8:11	8:46	COMBINED FUEL A	0.26	0.6		
1976	JUL	20	9:12	15:14	COMBINED FUEL A	0.26	6.0	132.3	20.0
1976	JUL	21	8:34	15:16	COMBINED FUEL A	0.26	6.7	134.0	20.0
1976	JUL	22	8:00	14:45	COMBINED FUEL A	0.26	6.8	135.0	20.0
1976	JUL	23	7:45	14:35	COMBINED FUEL A	0.26	6.8	136.7	20.0
1976	JUL	27	12:12	16:08	COMBINED FUEL A	0.26	3.9	78.7	20.0
1976	JUL	28	9:24	15:38	COMBINED FUEL A	0.26	6.2	124.7	20.0
1976	JUL	30	7:57	15:09	COMBINED FUEL A	0.26	7.2	144.0	20.0
1976	JUL	31	9:44	12:53	COMBINED FUEL A	0.26	3.1		
1976	JUL	31	20:11	21:12	COMBINED FUEL A	0.26	1.0	83.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	AUG	1	8:58	10:28	COMBINED FUEL A	0.26	1.5	30.0	20.0
1976	AUG	2	7:48	13:46	COMBINED FUEL A	0.26	6.0	119.3	20.0
1976	AUG	4	11:27	14:37	COMBINED FUEL A	0.26	3.2	63.3	20.0
1976	AUG	5	13:07	14:42	COMBINED FUEL A	0.26	1.6	31.7	20.0
1976	AUG	23	14:35	16:08	COMBINED FUEL A	0.26	1.5	31.0	20.0
1976	AUG	24	13:09	16:46	COMBINED FUEL A	0.26	3.6	72.3	20.0
1976	AUG	25	10:00	11:30	COMBINED FUEL A	0.26	1.5	30.0	20.0
1976	AUG	27	14:50	16:56	COMBINED FUEL A	0.26	2.1	42.0	20.0
1976	AUG	28	11:16	13:40	COMBINED FUEL A	0.26	2.4	48.0	20.0
1976	AUG	29	11:14	21:49	COMBINED FUEL A	0.26	10.6	211.7	20.0
1976	AUG	30	9:07	17:11	COMBINED FUEL A	0.26	8.1	161.3	20.0
1976	AUG	31	9:53	17:09	COMBINED FUEL A	0.26	7.3	145.3	20.0
1976	SEP	2	12:10	17:11	COMBINED FUEL A	0.26	5.0	100.3	20.0
1976	SEP	3	13:22	13:47	COMBINED FUEL A	0.26	0.4	8.3	20.0
1976	SEP	4	9:48	10:58	COMBINED FUEL A	0.26	1.2	23.3	20.0
1976	SEP	5	19:18	21:03	COMBINED FUEL A	0.26	1.8	35.0	20.0
1976	SEP	7	12:32	14:20	COMBINED FUEL A	0.26	1.8	36.0	20.0
1976	SEP	8	11:46	16:44	COMBINED FUEL A	0.26	5.0	99.3	20.0
1976	SEP	10	0:54	1:22	COMBINED FUEL A	0.26	0.5	9.3	20.0
1976	SEP	25	19:56	22:35	COMBINED FUEL A	0.26	2.6	53.0	20.0
1976	SEP	30	18:54	20:13	COMBINED FUEL A	0.26	1.3	26.3	20.0
1976	OCT	5	12:45	14:43	COMBINED FUEL A	0.26	2.0	39.3	20.0
1976	OCT	9	18:48	20:08	COMBINED FUEL A	0.26	1.3	26.7	20.0
1976	OCT	17	19:56	20:49	COMBINED FUEL A	0.26	0.9	17.7	20.0
1976	OCT	26	10:37	11:46	COMBINED FUEL A	0.26	1.1		
1976	OCT	26	12:51	13:01	COMBINED FUEL A	0.26	0.2		
1976	OCT	26	13:27	14:36	COMBINED FUEL A	0.26	1.1	49.3	20.0
1976	OCT	30	18:38	19:34	COMBINED FUEL A	0.26	0.9	18.7	20.0
1976	NOV	2	13:26	18:38	COMBINED FUEL A	0.26	5.2	104.0	20.0
1976	NOV	3	8:32	10:49	COMBINED FUEL A	0.26	2.3	45.7	20.0
1976	NOV	5	13:03	15:36	COMBINED FUEL A	0.26	2.5	51.0	20.0
1976	NOV	6	12:15	12:25	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	NOV	7	17:16	19:56	COMBINED FUEL A	0.26	2.7	53.3	20.0
1976	NOV	8	10:35	18:54	COMBINED FUEL A	0.26	8.3	166.3	20.0
1976	NOV	9	17:03	19:11	COMBINED FUEL A	0.26	2.1	42.7	20.0
1976	NOV	10	17:01	18:32	COMBINED FUEL A	0.26	1.5	30.3	20.0
1976	NOV	12	10:40	10:50	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	NOV	15	16:45	18:39	COMBINED FUEL A	0.26	1.9	38.0	20.0
1976	NOV	17	17:18	17:22	COMBINED FUEL A	0.26	0.1	1.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	NOV	18	5:32	11:50	COMBINED FUEL A	0.26	2.3		
1976	NOV	18	17:15	18:29	COMBINED FUEL A	0.26	1.2	70.7	20.0
1976	NOV	19	6:50	7:30	COMBINED FUEL A	0.26	0.7		
1976	NOV	19	17:16	18:02	COMBINED FUEL A	0.36	0.8	28.7	20.0
1976	NOV	21	16:18	18:04	COMBINED FUEL A	0.36	1.8	35.3	20.0
1976	NOV	23	17:04	22:05	COMBINED FUEL A	0.36	5.0	100.3	20.0
1976	NOV	24	15:33	17:00	COMBINED FUEL A	0.36	1.4	29.0	20.0
1976	DEC	4	17:24	18:16	COMBINED FUEL A	0.36	0.9	17.3	20.0
1976	DEC	5	17:22	18:12	COMBINED FUEL A	0.36	0.8	16.7	20.0
1976	DEC	9	17:16	18:37	COMBINED FUEL A	0.36	1.3	27.0	20.0
1976	DEC	12	10:52	11:26	COMBINED FUEL A	0.36	0.6	11.3	20.0
1976	DEC	18	17:17	18:32	COMBINED FUEL A	0.36	1.3	25.0	20.0
1976	DEC	22	7:04	8:09	COMBINED FUEL A	0.36	1.1	21.7	20.0
1976	DEC	30	17:26	22:30	COMBINED FUEL A	0.36	5.1	101.3	20.0
1976	DEC	31	6:21	13:38	COMBINED FUEL A	0.36	7.3	145.7	20.0
1977	JAN	4	17:30	18:32	COMBINED FUEL A	0.29	1.0	20.7	20.0
1977	JAN	5	17:22	18:46	COMBINED FUEL A	0.29	1.4	28.0	20.0
1977	JAN	6	10:09	10:14	COMBINED FUEL A	0.29	0.1		
1977	JAN	6	17:02	20:28	COMBINED FUEL A	0.29	3.4	70.3	20.0
1977	JAN	7	16:59	19:15	COMBINED FUEL A	0.29	2.3	45.3	20.0
1977	JAN	8	17:33	18:37	COMBINED FUEL A	0.30	1.1	21.3	20.0
1977	JAN	10	17:14	19:08	COMBINED FUEL A	0.30	1.9	38.0	20.0
1977	JAN	18	20:52	24:00	COMBINED FUEL A	0.30	3.1	62.7	20.0
1977	JAN	19	0:00	0:21	COMBINED FUEL A	0.30	0.3	7.0	20.0
1977	JAN	21	17:46	18:53	COMBINED FUEL A	0.30	1.1	22.3	20.0
1977	JAN	31	17:35	19:24	COMBINED FUEL A	0.30	1.8	36.3	20.0
1977	FEB	1	17:47	19:03	COMBINED FUEL A	0.29	1.3	25.3	20.0
1977	FEB	7	18:04	19:00	COMBINED FUEL A	0.29	0.9	18.7	20.0
1977	FEB	12	17:05	19:33	COMBINED FUEL A	0.29	2.5	49.3	20.0
1977	FEB	20	3:24	3:58	COMBINED FUEL A	0.29	0.6	11.3	20.0
1977	FEB	24	14:48	16:04	COMBINED FUEL A	0.29	1.3	25.3	20.0
1977	MAR	7	18:19	19:15	COMBINED FUEL A	0.30	0.9	18.7	20.0
1977	MAR	14	10:01	11:53	COMBINED FUEL A	0.30	1.9	37.3	20.0
1977	MAR	16	17:50	20:08	COMBINED FUEL A	0.30	2.3	46.0	20.0
1977	MAR	28	12:36	14:05	COMBINED FUEL A	0.30	1.5	29.7	20.0
1977	MAR	29	11:41	15:49	COMBINED FUEL A	0.30	4.1	82.7	20.0
1977	APR	4	16:07	18:13	COMBINED FUEL A	0.30	2.1	42.0	20.0
1977	APR	5	10:47	11:36	COMBINED FUEL A	0.30	0.8	16.3	20.0
1977	APR	6	7:34	13:23	COMBINED FUEL A	0.30	5.8	116.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	APR	7	8:21	15:22	COMBINED FUEL A	0.30	7.0	140.3	20.0
1977	APR	18	11:25	15:30	COMBINED FUEL A	0.30	4.1	81.7	20.0
1977	APR	31	11:40	12:44	COMBINED FUEL A	0.30	1.1	21.3	20.0
1977	JUN	15	9:43	13:45	COMBINED FUEL A	0.30	4.0		
1977	JUN	15	14:02	14:40	COMBINED FUEL A	0.30	0.6	93.3	20.0
1977	JUN	20	12:54	13:06	COMBINED FUEL A	0.30	0.2	4.0	20.0
1977	JUL	11	9:27	10:28	COMBINED FUEL A	0.30	1.0		
1977	JUL	11	11:04	11:13	COMBINED FUEL A	0.30	0.1	23.3	20.0
1977	JUL	15	11:42	15:52	COMBINED FUEL A	0.30	4.2	83.3	20.0
1977	JUL	16	10:38	18:25	COMBINED FUEL A	0.29	7.8	155.7	20.0
1977	JUL	17	12:30	18:13	COMBINED FUEL A	0.29	5.7		
1977	JUL	17	20:02	23:41	COMBINED FUEL A	0.29	3.6	187.3	20.0
1977	JUL	18	9:36	16:37	COMBINED FUEL A	0.29	7.0	140.3	20.0
1977	JUL	19	13:32	16:51	COMBINED FUEL A	0.29	3.3	66.3	20.0
1977	JUL	20	10:33	11:55	COMBINED FUEL A	0.29	1.4	27.3	20.0
1977	JUL	21	13:17	18:33	COMBINED FUEL A	0.29	5.3	105.3	20.0
1977	JUL	22	11:52	17:16	COMBINED FUEL A	0.29	5.4	108.0	20.0
1977	JUL	25	13:21	15:52	COMBINED FUEL A	0.29	2.5	50.3	20.0
1977	JUL	26	9:51	18:34	COMBINED FUEL A	0.29	8.7	174.3	20.0
1977	JUL	27	9:45	17:55	COMBINED FUEL A	0.29	8.2	163.3	20.0
1977	JUL	28	10:35	17:25	COMBINED FUEL A	0.29	6.8	136.7	20.0
1977	JUL	29	10:52	18:55	COMBINED FUEL A	0.29	8.0	161.0	20.0
1977	AUG	1	10:12	11:10	COMBINED FUEL A	0.29	1.0	19.3	20.0
1977	AUG	3	17:13	17:18	COMBINED FUEL A	0.29	0.1		
1977	AUG	3	17:26	19:16	COMBINED FUEL A	0.29	1.8	38.3	20.0
1977	AUG	4	10:18	11:05	COMBINED FUEL A	0.29	0.8	15.7	20.0
1977	AUG	5	15:20	15:40	COMBINED FUEL A	0.29	0.3		
1977	AUG	5	16:05	16:11	COMBINED FUEL A	0.29	0.1	8.7	20.0
1977	AUG	9	15:37	16:04	COMBINED FUEL A	0.29	0.5	9.0	20.0
1977	AUG	18	8:45	11:30	COMBINED FUEL A	0.29	2.8	55.0	20.0
1977	AUG	22	8:58	9:22	COMBINED FUEL A	0.29	0.4		
1977	AUG	22	13:14	14:00	COMBINED FUEL A	0.29	0.8	23.3	20.0
1977	AUG	26	13:20	14:08	COMBINED FUEL A	0.29	0.8	16.0	20.0
1977	AUG	28	19:58	20:46	COMBINED FUEL A	0.29	0.8	16.0	20.0
1977	AUG	29	13:15	16:23	COMBINED FUEL A	0.29	3.1		
1977	AUG	29	19:35	20:28	COMBINED FUEL A	0.29	0.9	80.3	20.0
1977	SEP	7	14:58	19:13	COMBINED FUEL A	0.29	4.3	85.0	20.0
1977	SEP	10	6:04	6:43	COMBINED FUEL A	0.29	0.6		
1977	SEP	10	9:26	11:12	COMBINED FUEL A	0.29	1.8	48.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SEGGE KEARNY STATION

UNIT NUMBER: 28

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	SEP	19	9:35	12:57	COMBINED FUEL A	0.29	3.4	67.3	20.0
1977	SEP	21	13:00	14:31	COMBINED FUEL A	0.29	1.5		
1977	SEP	21	14:47	15:14	COMBINED FUEL A	0.29	0.5	39.3	20.0
1977	SEP	27	13:22	16:44	COMBINED FUEL A	0.29	3.4		
1977	SEP	27	10:04	12:30	COMBINED FUEL A	0.29	2.4	116.0	20.0
1977	OCT	3	20:44	22:02	COMBINED FUEL A	0.29	1.3	26.0	20.0
1977	OCT	6	18:45	22:17	COMBINED FUEL A	0.29	3.5	70.7	20.0
1977	OCT	7	10:01	15:40	COMBINED FUEL A	0.29	5.6	113.0	20.0
1977	OCT	10	8:28	10:26	COMBINED FUEL A	0.29	2.0	39.3	20.0
1977	OCT	12	18:42	19:32	COMBINED FUEL A	0.29	0.8	16.7	20.0
1977	OCT	24	11:44	12:36	COMBINED FUEL A	0.29	0.9	17.3	20.0
1977	OCT	27	11:25	13:06	COMBINED FUEL A	0.29	1.7		
1977	OCT	27	13:06	17:52	COMBINED FUEL A	0.29	4.8	129.0	20.0
1977	OCT	31	17:49	20:18	COMBINED FUEL A	0.29	2.5	49.7	20.0
1977	NOV	1	11:24	12:40	COMBINED FUEL A	0.29	1.3	25.3	20.0
1977	NOV	3	9:49	9:55	COMBINED FUEL A	0.29	0.1		
1977	NOV	3	10:08	10:17	COMBINED FUEL A	0.29	0.1		
1977	NOV	3	10:48	13:40	COMBINED FUEL A	0.29	2.9	62.3	20.0
1977	NOV	7	17:43	17:56	COMBINED FUEL A	0.29	0.2	4.3	20.0
1977	NOV	8	17:21	18:49	COMBINED FUEL A	0.29	1.5	29.3	20.0
1977	NOV	9	17:24	18:41	COMBINED FUEL A	0.29	1.3	25.7	20.0
1977	NOV	16	17:42	19:04	COMBINED FUEL A	0.29	1.4	27.3	20.0
1977	NOV	18	9:39	12:00	COMBINED FUEL A	0.29	2.3		
1977	NOV	18	15:29	16:07	COMBINED FUEL A	0.29	0.6	59.7	20.0
1977	NOV	20	17:13	19:21	COMBINED FUEL A	0.29	2.1	42.7	20.0
1977	NOV	22	17:04	18:58	COMBINED FUEL A	0.29	1.9	38.0	20.0
1977	NOV	29	9:05	12:46	COMBINED FUEL A	0.29	3.7		
1977	NOV	29	17:04	18:11	COMBINED FUEL A	0.29	1.1	96.0	20.0
1977	NOV	30	7:44	15:30	COMBINED FUEL A	0.29	7.8		
1977	NOV	30	15:47	20:15	COMBINED FUEL A	0.29	4.5	244.7	20.0
1977	DEC	7	17:06	19:46	COMBINED FUEL A	0.29	2.7	53.3	20.0
1977	DEC	8	17:04	18:16	COMBINED FUEL A	0.29	1.2	24.0	20.0
1977	DEC	16	14:15	15:12	COMBINED FUEL A	0.29	1.0	19.0	20.0
1977	DEC	19	7:35	11:10	COMBINED FUEL A	0.29	3.6		
1977	DEC	19	17:02	19:30	COMBINED FUEL A	0.29	2.5	121.0	20.0
1977	DEC	20	17:32	17:59	COMBINED FUEL A	0.29	0.4	9.0	20.0
1977	DEC	21	17:12	18:25	COMBINED FUEL A	0.29	1.2	24.3	20.0
1977	DEC	22	17:33	18:10	COMBINED FUEL A	0.29	0.6	12.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	23	12:07	14:50	COMBINED FUEL A	0.30	1.7	34.3	20.0
1975	FEB	11	17:29	19:36	COMBINED FUEL A	0.30	2.1	42.3	20.0
1975	FEB	14	10:16	11:03	COMBINED FUEL A	0.30	0.8	15.7	20.0
1975	FEB	17	17:46	21:12	COMBINED FUEL A	0.30	3.4	68.7	20.0
1975	FEB	27	19:14	21:07	COMBINED FUEL A	0.30	1.9	37.7	20.0
1975	MAR	4	10:03	10:32	COMBINED FUEL A	0.30	0.5	9.7	20.0
1975	MAR	10	8:13	11:48	COMBINED FUEL A	0.30	3.6	71.7	20.0
1975	MAR	13	13:35	14:18	COMBINED FUEL A	0.30	0.7		
1975	MAR	13	18:09	21:28	COMBINED FUEL A	0.30	3.3	80.7	20.0
1975	MAR	21	0:56	2:03	COMBINED FUEL A	0.30	1.1		
1975	MAR	21	14:10	15:03	COMBINED FUEL A	0.30	0.9	40.0	20.0
1975	MAR	27	8:23	14:15	COMBINED FUEL A	0.30	5.9	117.3	20.0
1975	APR	1	10:58	11:21	COMBINED FUEL A	0.30	0.4	7.7	20.0
1975	APR	4	14:36	16:18	COMBINED FUEL A	0.30	1.7	34.0	20.0
1975	APR	17	12:25	13:24	COMBINED FUEL A	0.30	1.0		
1975	APR	17	13:24	14:20	COMBINED FUEL A	0.30	0.9		
1975	APR	17	14:20	14:38	COMBINED FUEL A	0.30	0.3	44.3	20.0
1975	APR	18	9:41	14:46	COMBINED FUEL A	0.30	5.1	101.7	20.0
1975	APR	21	8:31	14:37	COMBINED FUEL A	0.30	6.1	122.0	20.0
1975	APR	22	8:45	15:55	COMBINED FUEL A	0.30	7.2	143.3	20.0
1975	APR	29	18:06	21:28	COMBINED FUEL A	0.30	3.4	67.3	20.0
1975	MAY	1	10:58	11:21	COMBINED FUEL A	0.30	0.4	7.7	20.0
1975	MAY	4	14:36	16:18	COMBINED FUEL A	0.30	1.7	34.0	20.0
1975	MAY	17	12:25	13:24	COMBINED FUEL A	0.30	1.0		
1975	MAY	17	13:24	14:20	COMBINED FUEL A	0.30	0.9		
1975	MAY	17	14:20	14:38	COMBINED FUEL A	0.30	0.3	44.3	20.0
1975	MAY	18	13:50	15:02	COMBINED FUEL A	0.30	1.2	24.0	20.0
1975	MAY	21	9:41	14:46	COMBINED FUEL A	0.30	5.1	101.7	20.0
1975	MAY	22	8:31	14:37	COMBINED FUEL A	0.30	6.1	122.0	20.0
1975	MAY	23	8:45	15:55	COMBINED FUEL A	0.30	7.2	143.3	20.0
1975	MAY	29	18:06	21:28	COMBINED FUEL A	0.30	3.4	67.3	20.0
1975	JUN	18	10:45	16:00	COMBINED FUEL A	0.30	5.3	105.0	20.0
1975	JUN	19	7:50	10:01	COMBINED FUEL A	0.30	2.2		
1975	JUN	19	10:02	12:16	COMBINED FUEL A	0.30	2.2		
1975	JUN	19	19:40	22:53	COMBINED FUEL A	0.30	3.2	152.7	20.0
1975	JUN	20	9:18	10:17	COMBINED FUEL A	0.30	1.0		
1975	JUN	20	11:20	13:33	COMBINED FUEL A	0.30	2.2	64.0	20.0
1975	JUL	3	15:15	15:35	COMBINED FUEL A	0.30	0.3	6.7	20.0
1975	JUL	9	8:45	9:10	COMBINED FUEL A	0.30	0.4		

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JUL	9	9:33	9:51	COMBINED FUEL A	0.30	0.3		
1975	JUL	9	10:13	10:40	COMBINED FUEL A	0.30	0.4		
1975	JUL	9	13:36	14:05	COMBINED FUEL A	0.30	0.5	33.0	20.0
1975	JUL	11	12:01	14:04	COMBINED FUEL A	0.30	2.0	41.0	20.0
1975	JUL	15	13:06	15:02	COMBINED FUEL A	0.30	1.9	38.7	20.0
1975	JUL	23	14:40	15:00	COMBINED FUEL A	0.30	0.3	6.7	20.0
1975	AUG	2	15:21	18:14	COMBINED FUEL A	0.30	2.9	57.7	20.0
1975	AUG	11	7:31	8:31	COMBINED FUEL A	0.30	1.0	20.0	20.0
1975	AUG	13	8:55	12:06	COMBINED FUEL A	0.30	3.2	63.7	20.0
1975	AUG	24	12:52	14:50	COMBINED FUEL A	0.30	2.0	39.3	20.0
1975	SEP	6	8:43	9:59	COMBINED FUEL A	0.30	1.3		
1975	SEP	6	22:25	22:34	COMBINED FUEL A	0.30	0.1	28.3	20.0
1975	SEP	8	18:34	19:45	COMBINED FUEL A	0.30	1.2	23.7	20.0
1975	SEP	15	9:45	16:27	COMBINED FUEL A	0.30	6.7	134.0	20.0
1975	SEP	16	9:32	24:00	COMBINED FUEL A	0.30	14.5	289.3	20.0
1975	SEP	17	0:00	0:18	COMBINED FUEL A	0.30	0.3		
1975	SEP	17	12:20	23:30	COMBINED FUEL A	0.30	11.2	229.3	20.0
1975	SEP	18	12:08	18:31	COMBINED FUEL A	0.30	6.4	127.7	20.0
1975	SEP	19	8:18	9:48	COMBINED FUEL A	0.30	1.5	30.0	20.0
1975	SEP	23	12:15	19:29	COMBINED FUEL A	0.30	7.2	144.7	20.0
1975	OCT	2	13:38	17:18	COMBINED FUEL A	0.30	3.7	73.3	20.0
1975	OCT	3	12:54	17:32	COMBINED FUEL A	0.30	4.6	92.7	20.0
1975	OCT	10	8:59	9:26	COMBINED FUEL A	0.30	0.5	9.0	20.0
1975	OCT	20	16:35	20:10	COMBINED FUEL A	0.30	3.6	71.7	20.0
1975	OCT	21	8:37	9:34	COMBINED FUEL A	0.30	1.0		
1975	OCT	21	16:29	19:20	COMBINED FUEL A	0.30	2.8	76.0	20.0
1975	OCT	22	10:09	12:20	COMBINED FUEL A	0.30	2.2		
1975	OCT	22	16:44	18:19	COMBINED FUEL A	0.30	1.6	75.3	20.0
1975	OCT	31	8:07	8:12	COMBINED FUEL A	0.30	0.1		
1975	OCT	31	9:50	12:39	COMBINED FUEL A	0.30	2.8		
1975	OCT	31	17:08	19:59	COMBINED FUEL A	0.30	2.8	115.0	20.0
1975	DEC	5	7:48	11:39	COMBINED FUEL A	0.30	3.8	77.0	20.0
1975	DEC	6	17:00	19:10	COMBINED FUEL A	0.30	2.2	43.3	20.0
1975	DEC	10	16:29	21:20	COMBINED FUEL A	0.30	4.8	97.0	20.0
1975	DEC	16	13:40	14:03	COMBINED FUEL A	0.30	0.4		
1975	DEC	16	14:30	16:56	COMBINED FUEL A	0.30	2.4	56.3	20.0
1975	DEC	20	11:22	13:02	COMBINED FUEL A	0.30	1.7	33.3	20.0
1975	DEC	30	10:55	13:55	COMBINED FUEL A	0.30	3.0	60.0	20.0
1976	JAN	1	9:39	13:28	COMBINED FUEL A	0.26	3.8	76.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JAN	5	6:50	8:20	COMBINED FUEL A	0.26	1.5	30.0	20.0
1976	JAN	21	4:17	6:43	COMBINED FUEL A	0.26	2.4	48.7	20.0
1976	JAN	25	18:06	19:23	COMBINED FUEL A	0.26	1.3	25.7	20.0
1976	JAN	26	6:59	9:37	COMBINED FUEL A	0.26	2.6	52.7	20.0
1976	JAN	27	15:33	15:58	COMBINED FUEL A	0.26	0.4	8.3	20.0
1976	FEB	3	9:28	12:28	COMBINED FUEL A	0.26	3.0	60.0	20.0
1976	FEB	5	8:11	9:41	COMBINED FUEL A	0.26	1.5		
1976	FEB	5	17:10	17:30	COMBINED FUEL A	0.26	0.3		
1976	FEB	5	20:45	21:13	COMBINED FUEL A	0.26	0.5	46.0	20.0
1976	MAR	7	2:12	3:15	COMBINED FUEL A	0.26	1.0	21.0	20.0
1976	MAR	15	6:30	8:38	COMBINED FUEL A	0.26	2.1	42.7	20.0
1976	APR	6	19:00	20:57	COMBINED FUEL A	0.26	1.9	39.0	20.0
1976	APR	7	3:28	4:01	COMBINED FUEL A	0.26	0.6	11.0	20.0
1976	APR	15	18:43	20:42	COMBINED FUEL A	0.26	2.0	39.7	20.0
1976	APR	30	15:46	15:52	COMBINED FUEL A	0.26	0.1		
1976	APR	30	16:01	16:18	COMBINED FUEL A	0.26	0.3	7.7	20.0
1976	MAY	4	11:32	12:04	COMBINED FUEL A	0.26	0.5	10.7	20.0
1976	MAY	6	22:50	22:52	COMBINED FUEL A	0.26	0.0	0.7	20.0
1976	MAY	12	15:25	16:10	COMBINED FUEL A	0.26	0.8	15.0	20.0
1976	MAY	14	19:21	21:09	COMBINED FUEL A	0.26	1.8	36.0	20.0
1976	MAY	20	12:48	13:45	COMBINED FUEL A	0.26	1.0	19.0	20.0
1976	MAY	21	14:23	15:54	COMBINED FUEL A	0.26	1.5	30.3	20.0
1976	JUN	5	8:14	13:08	COMBINED FUEL A	0.26	4.9	98.0	20.0
1976	JUN	6	20:32	21:20	COMBINED FUEL A	0.26	0.8	16.0	20.0
1976	JUN	7	9:10	9:55	COMBINED FUEL A	0.26	0.8	15.0	20.0
1976	JUN	8	14:41	15:24	COMBINED FUEL A	0.26	0.7	14.3	20.0
1976	JUN	14	14:04	16:29	COMBINED FUEL A	0.26	2.4	48.3	20.0
1976	JUN	15	13:10	18:54	COMBINED FUEL A	0.26	5.7	114.7	20.0
1976	JUN	26	10:49	14:16	COMBINED FUEL A	0.26	3.4	69.0	20.0
1976	JUN	28	9:06	15:20	COMBINED FUEL A	0.26	6.2		
1976	JUN	28	15:37	17:57	COMBINED FUEL A	0.26	2.3	171.3	20.0
1976	JUL	4	16:49	16:59	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	JUL	5	11:54	19:18	COMBINED FUEL A	0.26	7.4	148.0	20.0
1976	JUL	27	12:17	16:16	COMBINED FUEL A	0.26	4.0	79.7	20.0
1976	JUL	30	10:37	12:18	COMBINED FUEL A	0.26	1.7	33.7	20.0
1976	JUL	31	10:05	15:19	COMBINED FUEL A	0.26	5.2	104.7	20.0
1976	AUG	1	9:52	11:56	COMBINED FUEL A	0.26	2.1	41.3	20.0
1976	AUG	2	2:22	13:59	COMBINED FUEL A	0.26	11.6	232.3	20.0
1976	AUG	7	9:26	11:19	COMBINED FUEL A	0.26	1.9	37.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	AUG	20	7:36	12:00	COMBINED FUEL A	0.26	4.4		
1976	AUG	20	12:49	14:24	COMBINED FUEL A	0.26	1.6	119.7	20.0
1976	AUG	25	10:00	11:37	COMBINED FUEL A	0.26	1.6	32.3	20.0
1976	AUG	27	14:50	16:49	COMBINED FUEL A	0.26	2.0	39.7	20.0
1976	AUG	29	19:46	20:41	COMBINED FUEL A	0.26	0.9	18.3	20.0
1976	AUG	30	9:07	17:06	COMBINED FUEL A	0.26	8.0	159.7	20.0
1976	AUG	31	9:53	18:10	COMBINED FUEL A	0.26	8.3	165.7	20.0
1976	SEP	2	12:41	16:20	COMBINED FUEL A	0.26	3.6	73.0	20.0
1976	SEP	4	14:20	16:20	COMBINED FUEL A	0.26	2.0	40.0	20.0
1976	SEP	5	12:48	14:04	COMBINED FUEL A	0.26	1.3	25.3	20.0
1976	SEP	7	12:31	17:07	COMBINED FUEL A	0.26	4.6	92.0	20.0
1976	SEP	8	0:54	1:22	COMBINED FUEL A	0.26	0.5	9.3	20.0
1976	SEP	10	19:56	22:53	COMBINED FUEL A	0.26	2.9	59.0	20.0
1976	SEP	30	18:45	20:07	COMBINED FUEL A	0.26	1.4	27.3	20.0
1976	OCT	5	12:45	14:36	COMBINED FUEL A	0.26	1.8	37.0	20.0
1976	OCT	9	14:43	15:06	COMBINED FUEL A	0.26	0.4	7.7	20.0
1976	OCT	17	19:56	20:49	COMBINED FUEL A	0.26	0.9	17.7	20.0
1976	OCT	26	10:37	11:11	COMBINED FUEL A	0.26	0.6	11.3	20.0
1976	NOV	3	8:32	11:10	COMBINED FUEL A	0.26	2.6	52.7	20.0
1976	NOV	7	17:16	20:04	COMBINED FUEL A	0.26	2.8	56.0	20.0
1976	NOV	8	10:35	10:49	COMBINED FUEL A	0.26	0.2		
1976	NOV	8	10:59	19:01	COMBINED FUEL A	0.26	8.0	165.3	20.0
1976	NOV	9	17:11	18:52	COMBINED FUEL A	0.26	1.7	33.7	20.0
1976	NOV	18	17:01	18:37	COMBINED FUEL A	0.26	1.6	32.0	20.0
1976	NOV	19	6:50	7:31	COMBINED FUEL A	0.26	0.7	13.7	20.0
1976	NOV	21	16:18	18:04	COMBINED FUEL A	0.26	1.8	35.3	20.0
1976	NOV	23	10:39	14:52	COMBINED FUEL A	0.26	4.2		
1976	NOV	23	17:41	21:45	COMBINED FUEL A	0.26	4.1	165.7	20.0
1976	DEC	8	17:03	18:22	COMBINED FUEL A	0.26	1.3	26.3	20.0
1976	DEC	12	10:52	11:34	COMBINED FUEL A	0.26	0.7	14.0	20.0
1976	DEC	18	17:45	18:18	COMBINED FUEL A	0.26	0.6	11.0	20.0
1976	DEC	22	7:04	8:32	COMBINED FUEL A	0.26	1.5	29.3	20.0
1976	DEC	30	17:26	22:21	COMBINED FUEL A	0.26	4.9	98.3	20.0
1976	DEC	31	6:21	13:31	COMBINED FUEL A	0.26	7.2	143.3	20.0
1977	JAN	6	17:02	21:09	COMBINED FUEL A	0.29	4.1	82.3	20.0
1977	JAN	7	9:11	10:58	COMBINED FUEL A	0.29	1.8		
1977	JAN	7	11:33	11:49	COMBINED FUEL A	0.29	0.3		
1977	JAN	7	16:59	20:04	COMBINED FUEL A	0.29	3.1	102.7	20.0
1977	JAN	19	20:52	24:00	COMBINED FUEL A	0.29	3.1	62.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JAN	20	0:00	0:53	COMBINED FUEL A	0.29	0.9	17.7	20.0
1977	JAN	31	17:45	18:40	COMBINED FUEL A	0.29	0.9	18.3	20.0
1977	FEB	16	10:06	13:29	COMBINED FUEL A	0.29	3.4	67.7	20.0
1977	MAR	4	11:15	13:10	COMBINED FUEL A	0.29	1.9	38.3	20.0
1977	APR	4	16:07	18:29	COMBINED FUEL A	0.29	2.4	47.3	20.0
1977	APR	11	8:01	15:26	COMBINED FUEL A	0.29	7.4	148.3	20.0
1977	APR	18	9:47	10:17	COMBINED FUEL A	0.29	0.5		
1977	APR	18	13:15	15:12	COMBINED FUEL A	0.29	1.9	49.0	20.0
1977	APR	21	7:47	9:00	COMBINED FUEL A	0.26	1.2	24.3	20.0
1977	APR	25	13:50	14:05	COMBINED FUEL A	0.26	0.3	5.0	20.0
1977	MAY	3	10:49	11:16	COMBINED FUEL A	0.26	0.5	9.0	20.0
1977	MAY	4	9:49	10:04	COMBINED FUEL A	0.26	0.3		
1977	MAY	4	10:24	10:44	COMBINED FUEL A	0.26	0.3	11.7	20.0
1977	MAY	5	10:47	11:51	COMBINED FUEL A	0.26	1.1	21.3	20.0
1977	MAY	6	7:34	13:31	COMBINED FUEL A	0.26	5.9	119.0	20.0
1977	MAY	31	12:23	14:30	COMBINED FUEL A	0.26	2.1	42.3	20.0
1977	JUN	17	15:56	16:15	COMBINED FUEL A	0.26	0.3		
1977	JUN	17	9:17	15:39	COMBINED FUEL A	0.26	6.4	133.7	20.0
1977	JUL	15	11:42	12:29	COMBINED FUEL A	0.26	0.8		
1977	JUL	15	12:35	15:05	COMBINED FUEL A	0.26	2.5	65.7	20.0
1977	JUL	17	23:12	23:54	COMBINED FUEL A	0.26	0.7	14.0	20.0
1977	JUL	18	13:23	13:30	COMBINED FUEL A	0.26	0.1		
1977	JUL	18	14:50	15:26	COMBINED FUEL A	0.26	0.6	14.3	20.0
1977	JUL	20	11:39	12:43	COMBINED FUEL A	0.26	1.1	21.3	20.0
1977	JUL	22	10:07	17:54	COMBINED FUEL A	0.26	7.8	155.7	20.0
1977	JUL	25	13:45	16:32	COMBINED FUEL A	0.26	2.8	55.7	20.0
1977	JUL	26	9:55	18:48	COMBINED FUEL A	0.26	8.9	177.7	20.0
1977	JUL	27	9:53	17:31	COMBINED FUEL A	0.26	7.6	152.7	20.0
1977	JUL	28	11:50	17:17	COMBINED FUEL A	0.26	5.4	109.0	20.0
1977	JUL	29	14:07	18:45	COMBINED FUEL A	0.26	4.6	92.7	20.0
1977	AUG	1	11:02	12:05	COMBINED FUEL A	0.26	1.0	21.0	20.0
1977	AUG	3	17:13	19:18	COMBINED FUEL A	0.26	2.1	41.7	20.0
1977	AUG	5	15:20	15:40	COMBINED FUEL A	0.29	0.3		
1977	AUG	5	16:05	16:11	COMBINED FUEL A	0.29	0.1	8.7	20.0
1977	AUG	9	15:37	16:57	COMBINED FUEL A	0.29	1.3	26.7	20.0
1977	AUG	16	10:06	12:53	COMBINED FUEL A	0.29	2.8	55.7	20.0
1977	AUG	25	8:18	8:52	COMBINED FUEL A	0.29	0.6		
1977	AUG	25	14:38	15:18	COMBINED FUEL A	0.29	0.7	24.7	20.0
1977	SEP	10	6:04	6:48	COMBINED FUEL A	0.29	0.7		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	SEP	10	9:26	10:03	COMBINED FUEL A	0.29	0.6	27.0	20.0
1977	SEP	19	9:35	12:57	COMBINED FUEL A	0.29	3.4	67.3	20.0
1977	SEP	22	10:18	11:08	COMBINED FUEL A	0.29	0.8		
1977	SEP	22	11:37	12:00	COMBINED FUEL A	0.29	0.4		
1977	SEP	22	12:57	13:10	COMBINED FUEL A	0.29	0.2	28.7	20.0
1977	OCT	7	13:07	13:11	COMBINED FUEL A	0.29	0.1		
1977	OCT	7	13:43	14:10	COMBINED FUEL A	0.29	0.5	10.3	20.0
1977	OCT	10	8:28	10:26	COMBINED FUEL A	0.29	2.0	39.3	20.0
1977	OCT	19	11:10	14:18	COMBINED FUEL A	0.29	3.1	62.7	20.0
1977	OCT	31	12:58	15:45	COMBINED FUEL A	0.29	2.8		
1977	OCT	31	17:49	20:57	COMBINED FUEL A	0.29	3.1	118.3	20.0
1977	NOV	1	14:13	14:22	COMBINED FUEL A	0.29	0.1		
1977	NOV	1	15:28	15:50	COMBINED FUEL A	0.29	0.4	10.3	20.0
1977	NOV	8	17:34	18:20	COMBINED FUEL A	0.29	0.8	15.3	20.0
1977	NOV	20	17:37	18:44	COMBINED FUEL A	0.29	1.1	22.3	20.0
1977	NOV	30	9:05	20:30	COMBINED FUEL A	0.29	11.4	228.3	20.0
1977	DEC	1	16:56	18:28	COMBINED FUEL A	0.29	1.5	30.7	20.0
1977	DEC	7	16:56	20:10	COMBINED FUEL A	0.29	3.2	64.7	20.0
1977	DEC	8	17:04	18:31	COMBINED FUEL A	0.29	1.4	29.0	20.0
1977	DEC	29	14:18	16:10	COMBINED FUEL A	0.29	1.9	37.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 20

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	3	13:58	17:08	COMBINED FUEL A	0.30	3.2	64.0	20.0
1975	JAN	6	10:20	12:03	COMBINED FUEL A	0.30	1.7		
1975	JAN	6	14:20	14:55	COMBINED FUEL A	0.30	0.6	46.0	20.0
1975	JAN	30	17:50	18:39	COMBINED FUEL A	0.30	0.8	16.3	20.0
1975	FEB	8	9:39	11:15	COMBINED FUEL A	0.30	1.6	32.0	20.0
1975	FEB	11	17:29	19:07	COMBINED FUEL A	0.30	1.6	32.7	20.0
1975	FEB	14	8:55	11:10	COMBINED FUEL A	0.30	2.3	45.0	20.0
1975	FEB	17	17:46	21:04	COMBINED FUEL A	0.30	3.3	66.0	20.0
1975	FEB	20	10:27	11:10	COMBINED FUEL A	0.30	0.7	14.3	20.0
1975	FEB	26	19:01	21:16	COMBINED FUEL A	0.30	2.3	45.0	20.0
1975	MAR	10	8:13	10:42	COMBINED FUEL A	0.30	2.5	49.7	20.0
1975	MAR	13	18:09	21:33	COMBINED FUEL A	0.30	3.4	68.0	20.0
1975	MAR	21	0:56	2:03	COMBINED FUEL A	0.30	1.1	22.3	20.0
1975	MAR	27	8:23	14:08	COMBINED FUEL A	0.30	5.8	115.0	20.0
1975	MAR	31	10:17	13:40	COMBINED FUEL A	0.30	3.4	67.7	20.0
1975	APR	1	10:58	11:21	COMBINED FUEL A	0.30	0.4	7.7	20.0
1975	APR	4	9:15	11:34	COMBINED FUEL A	0.30	2.3		
1975	APR	4	14:36	16:12	COMBINED FUEL A	0.30	1.6	78.3	20.0
1975	APR	8	17:02	20:21	COMBINED FUEL A	0.30	3.3	66.3	20.0
1975	APR	15	15:12	16:14	COMBINED FUEL A	0.30	1.0	20.7	20.0
1975	APR	16	8:10	14:19	COMBINED FUEL A	0.30	6.1		
1975	APR	16	19:36	22:02	COMBINED FUEL A	0.30	2.4	171.7	20.0
1975	APR	24	10:40	11:07	COMBINED FUEL A	0.30	0.5	9.0	20.0
1975	APR	29	18:06	21:22	COMBINED FUEL A	0.30	3.3	65.3	20.0
1975	MAY	1	10:58	11:21	COMBINED FUEL A	0.30	0.4	7.7	20.0
1975	MAY	4	9:15	11:34	COMBINED FUEL A	0.30	2.3		
1975	MAY	4	14:36	16:12	COMBINED FUEL A	0.30	1.6	78.3	20.0
1975	MAY	8	17:02	20:21	COMBINED FUEL A	0.30	3.3	66.3	20.0
1975	MAY	15	15:12	16:14	COMBINED FUEL A	0.30	1.0	20.7	20.0
1975	MAY	16	8:10	14:19	COMBINED FUEL A	0.30	6.1		
1975	MAY	16	19:36	22:02	COMBINED FUEL A	0.30	2.4	171.7	20.0
1975	MAY	24	10:40	11:07	COMBINED FUEL A	0.30	0.5	9.0	20.0
1975	MAY	29	18:06	21:22	COMBINED FUEL A	0.30	3.3	65.3	20.0
1975	JUN	13	9:10	15:40	COMBINED FUEL A	0.30	6.5	130.0	20.0
1975	JUN	16	8:45	12:10	COMBINED FUEL A	0.30	3.4	68.3	20.0
1975	JUN	17	8:15	10:18	COMBINED FUEL A	0.30	2.0	41.0	20.0
1975	JUN	19	7:50	10:01	COMBINED FUEL A	0.30	2.2		
1975	JUN	19	19:40	22:41	COMBINED FUEL A	0.30	3.0	104.0	20.0
1975	JUL	11	11:06	14:30	COMBINED FUEL A	0.30	3.4	68.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JUL	21	10:20	12:04	COMBINED FUEL A	0.30	1.7	34.7	20.0
1975	JUL	27	12:33	15:46	COMBINED FUEL A	0.30	3.2	64.3	20.0
1975	JUL	28	10:05	16:00	COMBINED FUEL A	0.30	5.9	118.3	20.0
1975	AUG	2	15:21	18:20	COMBINED FUEL A	0.30	3.0	59.7	20.0
1975	AUG	4	13:47	15:46	COMBINED FUEL A	0.30	2.0		
1975	AUG	4	20:11	20:56	COMBINED FUEL A	0.30	0.8	54.7	20.0
1975	AUG	11	7:31	8:31	COMBINED FUEL A	0.30	1.0	20.0	20.0
1975	AUG	19	19:14	21:16	COMBINED FUEL A	0.30	2.0	40.7	20.0
1975	AUG	20	11:10	11:38	COMBINED FUEL A	0.30	0.5	9.3	20.0
1975	AUG	22	16:43	18:28	COMBINED FUEL A	0.30	1.8	35.0	20.0
1975	AUG	23	11:02	14:50	COMBINED FUEL A	0.30	3.8	76.0	20.0
1975	SEP	3	13:43	17:18	COMBINED FUEL A	0.30	3.6		
1975	SEP	3	19:39	21:23	COMBINED FUEL A	0.30	1.7	106.3	20.0
1975	SEP	4	13:05	18:20	COMBINED FUEL A	0.30	5.3	105.0	20.0
1975	SEP	6	8:43	9:59	COMBINED FUEL A	0.30	1.3		
1975	SEP	6	22:25	23:25	COMBINED FUEL A	0.30	1.0	45.3	20.0
1975	SEP	8	10:48	12:51	COMBINED FUEL A	0.30	2.0		
1975	SEP	8	18:34	19:45	COMBINED FUEL A	0.30	1.2	64.7	20.0
1975	SEP	14	8:38	9:00	COMBINED FUEL A	0.30	0.4	7.3	20.0
1975	SEP	15	9:17	10:45	COMBINED FUEL A	0.30	1.5	29.3	20.0
1975	SEP	16	11:42	13:38	COMBINED FUEL A	0.30	1.9	38.7	20.0
1975	SEP	17	0:00	0:24	COMBINED FUEL A	0.30	0.4		
1975	SEP	17	12:20	23:01	COMBINED FUEL A	0.30	10.7	221.7	20.0
1975	SEP	18	1:37	3:34	COMBINED FUEL A	0.30	1.9		
1975	SEP	18	11:36	14:05	COMBINED FUEL A	0.30	2.5	88.7	20.0
1975	SEP	19	8:18	9:23	COMBINED FUEL A	0.30	1.1	21.7	20.0
1975	SEP	21	19:37	20:39	COMBINED FUEL A	0.30	1.0	20.7	20.0
1975	SEP	23	11:56	19:29	COMBINED FUEL A	0.30	7.5	151.0	20.0
1975	OCT	2	13:32	17:13	COMBINED FUEL A	0.30	3.7		
1975	OCT	2	19:06	21:06	COMBINED FUEL A	0.30	2.0	113.7	20.0
1975	OCT	3	12:46	13:37	COMBINED FUEL A	0.30	0.9		
1975	OCT	3	17:48	17:58	COMBINED FUEL A	0.30	0.2	20.3	20.0
1975	OCT	5	19:06	21:23	COMBINED FUEL A	0.30	2.3	45.7	20.0
1975	OCT	10	8:59	9:26	COMBINED FUEL A	0.30	0.5	9.0	20.0
1975	OCT	30	8:21	8:59	COMBINED FUEL A	0.30	0.6	12.7	20.0
1975	OCT	31	8:07	14:06	COMBINED FUEL A	0.30	6.0		
1975	OCT	31	17:08	19:50	COMBINED FUEL A	0.30	2.7	173.7	20.0
1975	NOV	3	17:31	18:31	COMBINED FUEL A	0.30	1.0	20.0	20.0
1975	NOV	5	8:35	13:45	COMBINED FUEL A	0.30	5.2	103.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 20

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	NOV	12	10:30	12:05	COMBINED FUEL A	0.30	1.6	31.7	20.0
1975	NOV	20	16:35	20:52	COMBINED FUEL A	0.30	4.3	85.7	20.0
1975	NOV	21	8:00	9:39	COMBINED FUEL A	0.30	1.6		
1975	NOV	21	16:29	19:30	COMBINED FUEL A	0.30	3.0	93.3	20.0
1975	NOV	22	16:44	17:34	COMBINED FUEL A	0.30	0.8	16.7	20.0
1975	NOV	30	17:09	19:13	COMBINED FUEL A	0.30	2.1	41.3	20.0
1975	DEC	5	7:48	11:26	COMBINED FUEL A	0.30	3.6	72.7	20.0
1975	DEC	6	17:00	19:10	COMBINED FUEL A	0.30	2.2	43.3	20.0
1975	DEC	7	16:47	19:24	COMBINED FUEL A	0.30	2.6	52.3	20.0
1975	DEC	10	16:29	20:35	COMBINED FUEL A	0.30	4.1	82.0	20.0
1975	DEC	13	17:15	18:39	COMBINED FUEL A	0.30	1.4	28.0	20.0
1975	DEC	16	13:40	16:51	COMBINED FUEL A	0.30	3.2	63.7	20.0
1975	DEC	19	9:52	11:17	COMBINED FUEL A	0.30	1.4	28.3	20.0
1975	DEC	20	11:22	13:02	COMBINED FUEL A	0.30	1.7	33.3	20.0
1975	DEC	30	10:55	13:59	COMBINED FUEL A	0.30	3.1	61.3	20.0
1976	JAN	1	9:37	12:52	COMBINED FUEL A	0.26	3.3	65.0	20.0
1976	JAN	2	7:45	10:41	COMBINED FUEL A	0.20	2.9	58.7	20.0
1976	JAN	5	6:50	8:30	COMBINED FUEL A	0.26	1.7	33.3	20.0
1976	JAN	21	4:17	6:43	COMBINED FUEL A	0.26	2.4	48.7	20.0
1976	JAN	25	18:04	19:50	COMBINED FUEL A	0.26	1.8	35.3	20.0
1976	JAN	26	6:50	9:32	COMBINED FUEL A	0.26	2.7	54.0	20.0
1976	JAN	27	15:33	15:58	COMBINED FUEL A	0.26	0.4	8.3	20.0
1976	FEB	4	17:24	19:05	COMBINED FUEL A	0.26	1.7	33.7	20.0
1976	FEB	5	8:11	9:52	COMBINED FUEL A	0.26	1.7		
1976	FEB	5	17:10	20:22	COMBINED FUEL A	0.26	3.2	97.7	20.0
1976	FEB	17	11:35	13:38	COMBINED FUEL A	0.26	2.0	41.0	20.0
1976	FEB	18	11:01	11:58	COMBINED FUEL A	0.26	0.9	19.0	20.0
1976	MAR	1	17:47	20:13	COMBINED FUEL A	0.26	2.4	48.7	20.0
1976	MAR	7	2:12	6:15	COMBINED FUEL A	0.26	4.0	81.0	20.0
1976	MAR	15	6:28	8:32	COMBINED FUEL A	0.26	2.1	41.3	20.0
1976	APR	6	19:00	20:57	COMBINED FUEL A	0.26	1.9	39.0	20.0
1976	APR	7	3:28	4:01	COMBINED FUEL A	0.26	0.6	11.0	20.0
1976	APR	15	9:37	10:58	COMBINED FUEL A	0.26	1.3	27.0	20.0
1976	APR	18	18:43	20:38	COMBINED FUEL A	0.26	1.9	38.3	20.0
1976	APR	24	19:30	21:02	COMBINED FUEL A	0.26	1.5	30.7	20.0
1976	APR	30	14:24	15:41	COMBINED FUEL A	0.26	1.3	25.7	20.0
1976	MAY	3	20:04	20:50	COMBINED FUEL A	0.26	0.8	15.3	20.0
1976	MAY	4	11:32	12:04	COMBINED FUEL A	0.26	0.5	10.7	20.0
1976	MAY	6	17:02	18:07	COMBINED FUEL A	0.26	1.1		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 20

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	MAY	6	22:50	22:52	COMBINED FUEL A	0.26	0.0	22.3	20.0
1976	MAY	11	19:35	21:36	COMBINED FUEL A	0.26	2.0	40.3	20.0
1976	MAY	12	14:07	16:10	COMBINED FUEL A	0.26	2.0		
1976	MAY	12	19:21	21:35	COMBINED FUEL A	0.26	2.2	85.7	20.0
1976	MAY	20	15:05	15:48	COMBINED FUEL A	0.26	0.7	14.3	20.0
1976	MAY	23	15:21	16:20	COMBINED FUEL A	0.26	1.0	19.7	20.0
1976	JUN	5	8:14	11:55	COMBINED FUEL A	0.26	3.7	73.7	20.0
1976	JUN	6	20:09	21:15	COMBINED FUEL A	0.26	1.1	22.0	20.0
1976	JUN	7	9:10	9:55	COMBINED FUEL A	0.26	0.8	15.0	20.0
1976	JUN	8	14:41	15:24	COMBINED FUEL A	0.26	0.7	14.3	20.0
1976	JUN	14	14:04	16:17	COMBINED FUEL A	0.26	2.2	44.3	20.0
1976	JUN	15	13:10	18:01	COMBINED FUEL A	0.26	4.8	97.0	20.0
1976	JUN	16	14:02	14:10	COMBINED FUEL A	0.26	0.1	2.7	20.0
1976	JUN	18	13:32	13:45	COMBINED FUEL A	0.26	0.2	4.3	20.0
1976	JUN	23	13:29	18:12	COMBINED FUEL A	0.26	4.7	94.3	20.0
1976	JUN	24	12:46	17:10	COMBINED FUEL A	0.26	4.4	88.0	20.0
1976	JUN	25	12:47	16:00	COMBINED FUEL A	0.26	3.2	64.3	20.0
1976	JUN	26	10:05	16:21	COMBINED FUEL A	0.26	6.3	125.3	20.0
1976	JUN	28	9:06	17:57	COMBINED FUEL A	0.26	8.8	177.0	20.0
1976	JUN	30	12:35	16:56	COMBINED FUEL A	0.26	4.3	87.0	20.0
1976	JUL	4	16:49	16:59	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	JUL	5	11:24	19:13	COMBINED FUEL A	0.26	7.8	156.3	20.0
1976	JUL	6	12:41	17:51	COMBINED FUEL A	0.26	5.2	103.3	20.0
1976	JUL	7	12:12	16:37	COMBINED FUEL A	0.26	4.4	88.3	20.0
1976	JUL	14	14:18	17:02	COMBINED FUEL A	0.26	2.7	54.7	20.0
1976	JUL	27	12:17	16:28	COMBINED FUEL A	0.26	4.2	83.7	20.0
1976	JUL	28	10:10	15:26	COMBINED FUEL A	0.26	5.3	105.3	20.0
1976	JUL	30	7:57	13:41	COMBINED FUEL A	0.26	5.7	114.7	20.0
1976	JUL	31	10:05	12:53	COMBINED FUEL A	0.26	2.8		
1976	JUL	31	14:33	15:25	COMBINED FUEL A	0.26	0.9		
1976	JUL	31	20:11	21:16	COMBINED FUEL A	0.26	1.1	95.0	20.0
1976	AUG	1	8:58	10:28	COMBINED FUEL A	0.26	1.5	30.0	20.0
1976	AUG	2	7:48	13:55	COMBINED FUEL A	0.26	6.1	122.3	20.0
1976	AUG	4	11:27	14:44	COMBINED FUEL A	0.26	3.3	65.7	20.0
1976	AUG	7	9:26	11:19	COMBINED FUEL A	0.26	1.9	37.7	20.0
1976	AUG	24	13:21	16:05	COMBINED FUEL A	0.26	2.7	54.7	20.0
1976	AUG	25	10:00	11:30	COMBINED FUEL A	0.26	1.5	30.0	20.0
1976	AUG	27	14:50	16:43	COMBINED FUEL A	0.26	1.9	37.7	20.0
1976	AUG	28	11:16	17:37	COMBINED FUEL A	0.26	6.3		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	AUG	28	19:46	20:33	COMBINED FUEL A	0.26	0.8	142.7	20.0
1976	AUG	29	11:14	22:17	COMBINED FUEL A	0.26	11.0	221.0	20.0
1976	AUG	30	9:07	16:37	COMBINED FUEL A	0.26	7.5	150.0	20.0
1976	AUG	31	9:53	14:30	COMBINED FUEL A	0.26	4.6		
1976	AUG	31	15:02	17:24	COMBINED FUEL A	0.26	2.4	139.7	20.0
1976	SEP	2	12:12	16:14	COMBINED FUEL A	0.26	4.0	80.7	20.0
1976	SEP	4	14:20	16:10	COMBINED FUEL A	0.26	1.8	36.7	20.0
1976	SEP	5	19:18	20:37	COMBINED FUEL A	0.26	1.3	26.3	20.0
1976	SEP	6	9:18	10:04	COMBINED FUEL A	0.26	0.8	15.3	20.0
1976	SEP	7	13:13	13:56	COMBINED FUEL A	0.26	0.7	14.3	20.0
1976	SEP	8	12:41	14:29	COMBINED FUEL A	0.26	1.8	36.0	20.0
1976	SEP	10	0:54	1:22	COMBINED FUEL A	0.26	0.5	9.3	20.0
1976	SEP	22	14:05	14:13	COMBINED FUEL A	0.26	0.1	2.7	20.0
1976	SEP	25	19:56	23:00	COMBINED FUEL A	0.26	3.1	61.3	20.0
1976	SEP	30	19:23	20:07	COMBINED FUEL A	0.26	0.7	14.7	20.0
1976	OCT	25	14:00	15:10	COMBINED FUEL A	0.26	1.2		
1976	OCT	25	15:57	16:50	COMBINED FUEL A	0.26	0.9	41.0	20.0
1976	OCT	26	7:57	15:00	COMBINED FUEL A	0.26	7.0	141.0	20.0
1976	OCT	27	9:25	14:45	COMBINED FUEL A	0.26	5.3	106.7	20.0
1976	OCT	28	8:54	15:25	COMBINED FUEL A	0.26	6.5	130.3	20.0
1976	OCT	29	10:15	10:45	COMBINED FUEL A	0.26	0.5		
1976	OCT	29	11:11	13:18	COMBINED FUEL A	0.26	2.1	52.3	20.0
1976	NOV	1	13:12	15:37	COMBINED FUEL A	0.26	2.4	48.3	20.0
1976	NOV	2	13:35	18:45	COMBINED FUEL A	0.26	5.2	103.3	20.0
1976	NOV	3	8:32	10:41	COMBINED FUEL A	0.26	2.1	43.0	20.0
1976	NOV	5	13:08	15:36	COMBINED FUEL A	0.26	2.5	49.3	20.0
1976	NOV	7	17:16	20:10	COMBINED FUEL A	0.26	2.9	58.0	20.0
1976	NOV	8	10:35	19:07	COMBINED FUEL A	0.26	8.5	170.7	20.0
1976	NOV	9	17:03	19:24	COMBINED FUEL A	0.26	2.3	47.0	20.0
1976	NOV	10	17:01	18:39	COMBINED FUEL A	0.26	1.6	32.7	20.0
1976	NOV	15	16:45	18:47	COMBINED FUEL A	0.26	2.0	40.7	20.0
1976	NOV	17	17:18	19:04	COMBINED FUEL A	0.26	1.8	35.3	20.0
1976	NOV	18	17:09	19:05	COMBINED FUEL A	0.26	1.9	38.7	20.0
1976	NOV	19	6:50	7:38	COMBINED FUEL A	0.26	0.8	16.0	20.0
1976	NOV	21	16:18	18:02	COMBINED FUEL A	0.26	1.7	34.7	20.0
1976	NOV	23	17:04	22:22	COMBINED FUEL A	0.26	5.3	106.0	20.0
1976	DEC	4	17:33	18:03	COMBINED FUEL A	0.26	0.5	10.0	20.0
1976	DEC	8	17:03	18:29	COMBINED FUEL A	0.26	1.4	28.7	20.0
1976	DEC	9	17:27	18:31	COMBINED FUEL A	0.26	1.1	21.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	DEC	12	10:52	11:26	COMBINED FUEL A	0.26	0.6	11.3	20.0
1976	DEC	18	17:17	18:42	COMBINED FUEL A	0.26	1.4	28.3	20.0
1976	DEC	22	7:04	8:40	COMBINED FUEL A	0.26	1.6	32.0	20.0
1976	DEC	30	17:26	22:14	COMBINED FUEL A	0.26	4.8	96.0	20.0
1976	DEC	31	6:21	8:10	COMBINED FUEL A	0.26	1.8		
1976	DEC	31	10:50	13:09	COMBINED FUEL A	0.26	2.3	82.7	20.0
1977	JAN	4	17:47	18:56	COMBINED FUEL A	0.29	1.1	23.0	20.0
1977	JAN	5	17:22	18:41	COMBINED FUEL A	0.29	1.3	26.3	20.0
1977	JAN	6	17:02	20:10	COMBINED FUEL A	0.29	3.1	62.7	20.0
1977	JAN	7	11:57	12:09	COMBINED FUEL A	0.29	0.2		
1977	JAN	7	16:59	20:04	COMBINED FUEL A	0.29	3.1	65.7	20.0
1977	JAN	10	17:14	19:32	COMBINED FUEL A	0.29	2.3	46.0	20.0
1977	JAN	18	20:52	24:00	COMBINED FUEL A	0.29	3.1	62.7	20.0
1977	JAN	19	0:00	0:47	COMBINED FUEL A	0.29	0.8	15.7	20.0
1977	JAN	26	11:23	14:11	COMBINED FUEL A	0.29	2.8	56.0	20.0
1977	JAN	31	17:32	19:07	COMBINED FUEL A	0.29	1.6	31.7	20.0
1977	FEB	12	17:05	19:05	COMBINED FUEL A	0.29	2.0	40.0	20.0
1977	FEB	15	11:57	12:36	COMBINED FUEL A	0.29	0.7	13.0	20.0
1977	FEB	16	10:50	13:21	COMBINED FUEL A	0.29	2.5	50.3	20.0
1977	MAR	7	18:07	19:11	COMBINED FUEL A	0.29	1.1	21.3	20.0
1977	MAR	16	17:55	20:03	COMBINED FUEL A	0.29	2.1	42.7	20.0
1977	APR	4	16:07	18:20	COMBINED FUEL A	0.29	2.2	44.3	20.0
1977	APR	13	8:05	14:55	COMBINED FUEL A	0.29	6.8	136.7	20.0
1977	APR	18	11:25	13:56	COMBINED FUEL A	0.29	2.5	50.3	20.0
1977	APR	21	9:15	10:25	COMBINED FUEL A	0.29	1.2	23.3	20.0
1977	MAY	5	10:47	11:46	COMBINED FUEL A	0.29	1.0	19.7	20.0
1977	MAY	6	7:37	13:43	COMBINED FUEL A	0.29	6.1	122.0	20.0
1977	JUN	2	9:38	10:45	COMBINED FUEL A	0.29	1.1	22.3	20.0
1977	JUL	15	11:42	17:16	COMBINED FUEL A	0.29	5.6	111.3	20.0
1977	JUL	16	11:33	18:01	COMBINED FUEL A	0.29	6.5	129.3	20.0
1977	JUL	17	14:36	18:37	COMBINED FUEL A	0.29	4.0		
1977	JUL	17	23:12	23:58	COMBINED FUEL A	0.29	0.8	95.7	20.0
1977	JUL	18	9:42	16:33	COMBINED FUEL A	0.29	6.8	137.0	20.0
1977	JUL	20	12:28	15:36	COMBINED FUEL A	0.29	3.1	62.7	20.0
1977	JUL	21	20:18	21:20	COMBINED FUEL A	0.29	1.0	20.7	20.0
1977	JUL	22	11:27	17:28	COMBINED FUEL A	0.29	6.0	120.3	20.0
1977	JUL	25	13:06	17:07	COMBINED FUEL A	0.29	4.0	80.3	20.0
1977	JUL	26	9:36	18:48	COMBINED FUEL A	0.29	9.2	184.0	20.0
1977	JUL	27	9:38	17:26	COMBINED FUEL A	0.29	7.8	156.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JUL	28	10:37	14:07	COMBINED FUEL A	0.29	3.5	70.0	20.0
1977	JUL	29	9:10	9:22	COMBINED FUEL A	0.29	0.2		
1977	JUL	29	10:52	18:42	COMBINED FUEL A	0.29	7.8	160.7	20.0
1977	AUG	1	11:57	12:52	COMBINED FUEL A	0.29	0.9	18.3	20.0
1977	AUG	3	17:13	17:18	COMBINED FUEL A	0.29	0.1		
1977	AUG	3	17:26	19:16	COMBINED FUEL A	0.29	1.8	38.3	20.0
1977	AUG	5	15:20	15:40	COMBINED FUEL A	0.29	0.3		
1977	AUG	5	16:05	16:11	COMBINED FUEL A	0.29	0.1	8.7	20.0
1977	AUG	9	13:01	14:48	COMBINED FUEL A	0.29	1.8		
1977	AUG	9	15:37	16:57	COMBINED FUEL A	0.29	1.3	62.3	20.0
1977	AUG	24	12:33	14:41	COMBINED FUEL A	0.29	2.1	42.7	20.0
1977	AUG	25	8:18	8:52	COMBINED FUEL A	0.29	0.6	11.3	20.0
1977	AUG	26	9:25	9:35	COMBINED FUEL A	0.29	0.2	3.3	20.0
1977	AUG	28	20:06	20:41	COMBINED FUEL A	0.29	0.6	11.7	20.0
1977	AUG	31	12:48	13:43	COMBINED FUEL A	0.29	0.9	18.3	20.0
1977	SEP	10	6:04	6:55	COMBINED FUEL A	0.29	0.8		
1977	SEP	10	9:26	11:12	COMBINED FUEL A	0.29	1.8	52.3	20.0
1977	SEP	19	9:35	12:57	COMBINED FUEL A	0.29	3.4	67.3	20.0
1977	SEP	29	8:00	11:30	COMBINED FUEL A	0.29	3.5	70.0	20.0
1977	OCT	3	20:44	22:02	COMBINED FUEL A	0.29	1.3	26.0	20.0
1977	OCT	4	12:33	13:24	COMBINED FUEL A	0.29	0.9		
1977	OCT	4	13:41	14:17	COMBINED FUEL A	0.29	0.6		
1977	OCT	4	15:33	15:55	COMBINED FUEL A	0.29	0.4	36.3	20.0
1977	OCT	5	18:44	19:29	COMBINED FUEL A	0.29	0.8	15.0	20.0
1977	OCT	6	18:50	22:16	COMBINED FUEL A	0.29	3.4	68.7	20.0
1977	OCT	7	12:11	15:04	COMBINED FUEL A	0.29	2.9	57.7	20.0
1977	OCT	10	8:28	10:26	COMBINED FUEL A	0.29	2.0	39.3	20.0
1977	OCT	31	17:49	20:23	COMBINED FUEL A	0.29	2.6	51.3	20.0
1977	NOV	8	11:15	11:44	COMBINED FUEL A	0.29	0.5		
1977	NOV	8	12:28	12:37	COMBINED FUEL A	0.29	0.1		
1977	NOV	8	17:21	18:55	COMBINED FUEL A	0.29	1.6	44.0	20.0
1977	NOV	9	17:26	17:35	COMBINED FUEL A	0.29	0.1	3.0	20.0
1977	NOV	19	17:23	18:13	COMBINED FUEL A	0.29	0.8	16.7	20.0
1977	NOV	20	17:13	19:08	COMBINED FUEL A	0.29	1.9	38.3	20.0
1977	NOV	22	17:06	18:58	COMBINED FUEL A	0.29	1.9	37.3	20.0
1977	NOV	29	17:04	18:14	COMBINED FUEL A	0.29	1.2	23.3	20.0
1977	NOV	30	8:08	20:40	COMBINED FUEL A	0.29	12.5	250.7	20.0
1977	DEC	1	17:16	18:32	COMBINED FUEL A	0.29	1.3	25.3	20.0
1977	DEC	7	17:08	20:17	COMBINED FUEL A	0.29	3.1	63.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 2D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	DEC	8	17:04	19:10	COMBINED FUEL A	0.29	2.1	42.0	20.0
1977	DEC	16	17:16	18:28	COMBINED FUEL A	0.29	1.2	24.0	20.0
1977	DEC	19	17:02	18:50	COMBINED FUEL A	0.29	1.8	36.0	20.0
1977	DEC	20	17:32	18:52	COMBINED FUEL A	0.29	1.3	26.7	20.0
1977	DEC	21	17:28	18:05	COMBINED FUEL A	0.29	0.6	12.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	3	9:43	11:43	COMBINED FUEL A	0.30	2.0	40.0	20.0
1975	JAN	16	9:56	10:22	COMBINED FUEL A	0.30	0.4	8.7	20.0
1975	JAN	27	9:48	10:53	COMBINED FUEL A	0.30	1.1	21.7	20.0
1975	JAN	30	17:50	20:25	COMBINED FUEL A	0.30	2.6	51.7	20.0
1975	FEB	5	10:16	10:34	COMBINED FUEL A	0.30	0.3	6.0	20.0
1975	FEB	8	8:57	12:54	COMBINED FUEL A	0.30	3.9	79.0	20.0
1975	FEB	17	18:22	20:05	COMBINED FUEL A	0.30	1.7	34.3	20.0
1975	FEB	19	10:25	13:40	COMBINED FUEL A	0.30	3.3	65.0	20.0
1975	MAR	13	18:23	21:36	COMBINED FUEL A	0.30	3.2	64.3	20.0
1975	MAR	20	19:22	21:34	COMBINED FUEL A	0.30	2.2	44.0	20.0
1975	MAR	21	0:56	1:46	COMBINED FUEL A	0.30	0.8	16.7	20.0
1975	MAR	22	9:23	12:17	COMBINED FUEL A	0.30	2.9	58.0	20.0
1975	MAR	27	8:28	12:48	COMBINED FUEL A	0.30	4.3	86.7	20.0
1975	MAR	29	19:19	21:24	COMBINED FUEL A	0.30	2.1	41.7	20.0
1975	APR	4	14:36	16:48	COMBINED FUEL A	0.30	2.2	44.0	20.0
1975	APR	8	17:51	20:47	COMBINED FUEL A	0.30	2.9	58.7	20.0
1975	APR	29	19:17	22:01	COMBINED FUEL A	0.30	2.7	54.7	20.0
1975	MAY	4	14:36	16:48	COMBINED FUEL A	0.30	2.2	44.0	20.0
1975	MAY	8	17:51	20:47	COMBINED FUEL A	0.30	2.9	58.7	20.0
1975	MAY	29	19:17	22:01	COMBINED FUEL A	0.30	2.7	54.7	20.0
1975	JUN	17	8:07	8:10	COMBINED FUEL A	0.30	0.0	1.0	20.0
1975	JUN	19	8:15	21:38	COMBINED FUEL A	0.30	13.4	267.7	20.0
1975	JUN	23	10:40	12:40	COMBINED FUEL A	0.30	2.0		
1975	JUN	23	12:50	14:45	COMBINED FUEL A	0.30	1.9	78.3	20.0
1975	JUL	11	11:14	14:22	COMBINED FUEL A	0.30	3.1	62.7	20.0
1975	JUL	27	21:01	21:05	COMBINED FUEL A	0.30	0.1	1.3	20.0
1975	AUG	2	15:21	18:21	COMBINED FUEL A	0.30	3.0	60.0	20.0
1975	AUG	6	11:52	12:01	COMBINED FUEL A	0.30	0.2	3.0	20.0
1975	AUG	11	7:33	9:00	COMBINED FUEL A	0.30	1.4	29.0	20.0
1975	AUG	12	7:12	7:51	COMBINED FUEL A	0.30	0.6	13.0	20.0
1975	AUG	13	12:41	14:47	COMBINED FUEL A	0.30	2.1	42.0	20.0
1975	AUG	18	10:12	10:55	COMBINED FUEL A	0.30	0.7		
1975	AUG	18	13:24	13:55	COMBINED FUEL A	0.30	0.5	24.7	20.0
1975	SEP	4	14:53	20:42	COMBINED FUEL A	0.30	5.8	116.3	20.0
1975	SEP	6	9:06	12:23	COMBINED FUEL A	0.30	3.3		
1975	SEP	6	22:25	23:01	COMBINED FUEL A	0.30	0.6	77.7	20.0
1975	SEP	8	18:22	20:07	COMBINED FUEL A	0.30	1.8	35.0	20.0
1975	SEP	15	9:45	12:19	COMBINED FUEL A	0.30	2.6	51.3	20.0
1975	SEP	16	10:09	23:18	COMBINED FUEL A	0.30	13.1	263.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	SEP	17	10:06	11:20	COMBINED FUEL A	0.30	1.2		
1975	SEP	17	12:45	21:38	COMBINED FUEL A	0.30	8.9	202.3	20.0
1975	SEP	19	12:09	12:37	COMBINED FUEL A	0.30	0.5	9.3	20.0
1975	SEP	20	10:12	18:08	COMBINED FUEL A	0.30	7.9	158.7	20.0
1975	SEP	22	9:48	11:20	COMBINED FUEL A	0.30	1.5		
1975	SEP	22	11:55	12:15	COMBINED FUEL A	0.30	0.3	37.3	20.0
1975	SEP	23	10:33	20:23	COMBINED FUEL A	0.30	9.8		
1975	SEP	23	22:11	22:33	COMBINED FUEL A	0.30	0.4	204.0	20.0
1975	SEP	24	19:14	20:18	COMBINED FUEL A	0.30	1.1	21.3	20.0
1975	SEP	25	9:34	12:35	COMBINED FUEL A	0.30	3.0	60.3	20.0
1975	SEP	30	15:48	15:59	COMBINED FUEL A	0.30	0.2	3.7	20.0
1975	OCT	3	13:22	17:55	COMBINED FUEL A	0.30	4.5	91.0	20.0
1975	OCT	10	8:59	20:03	COMBINED FUEL A	0.30	11.1	221.3	20.0
1975	OCT	12	19:06	20:32	COMBINED FUEL A	0.30	1.4	28.7	20.0
1975	OCT	15	12:49	13:06	COMBINED FUEL A	0.30	0.3	5.7	20.0
1975	OCT	20	10:23	12:23	COMBINED FUEL A	0.30	2.0		
1975	OCT	20	12:55	14:57	COMBINED FUEL A	0.30	2.0	80.7	20.0
1975	OCT	21	10:51	11:50	COMBINED FUEL A	0.30	1.0		
1975	OCT	21	13:56	15:05	COMBINED FUEL A	0.30	1.1	42.7	20.0
1975	OCT	22	9:11	10:29	COMBINED FUEL A	0.30	1.3		
1975	OCT	22	11:21	15:10	COMBINED FUEL A	0.30	3.8	102.3	20.0
1975	OCT	23	9:43	12:09	COMBINED FUEL A	0.30	2.4		
1975	OCT	23	14:30	15:32	COMBINED FUEL A	0.30	1.0	69.3	20.0
1975	OCT	24	10:39	14:07	COMBINED FUEL A	0.30	3.5	69.3	20.0
1975	NOV	14	16:55	19:54	COMBINED FUEL A	0.30	3.0	59.7	20.0
1975	NOV	17	9:15	13:16	COMBINED FUEL A	0.30	4.0	80.3	20.0
1975	NOV	19	10:45	13:05	COMBINED FUEL A	0.30	2.3		
1975	NOV	19	13:50	14:07	COMBINED FUEL A	0.30	0.3		
1975	NOV	19	14:50	15:36	COMBINED FUEL A	0.30	0.8	67.7	20.0
1975	NOV	20	17:10	17:11	COMBINED FUEL A	0.30	0.0	0.3	20.0
1975	NOV	21	16:48	19:41	COMBINED FUEL A	0.30	2.9	57.7	20.0
1975	NOV	22	17:06	18:40	COMBINED FUEL A	0.30	1.6	31.3	20.0
1975	NOV	29	17:07	19:31	COMBINED FUEL A	0.30	2.4	48.0	20.0
1975	DEC	3	17:02	19:36	COMBINED FUEL A	0.30	2.6	51.3	20.0
1975	DEC	4	12:55	14:25	COMBINED FUEL A	0.30	1.5	30.0	20.0
1975	DEC	6	16:47	19:17	COMBINED FUEL A	0.30	2.5	50.0	20.0
1975	DEC	10	16:59	21:41	COMBINED FUEL A	0.30	4.7	94.0	20.0
1975	DEC	16	13:40	17:08	COMBINED FUEL A	0.30	3.5	69.3	20.0
1975	DEC	19	23:36	24:00	COMBINED FUEL A	0.30	0.4	8.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	DEC	20	0:00	0:30	COMBINED FUEL A	0.30	0.5	10.0	20.0
1976	JAN	6	8:05	9:49	COMBINED FUEL A	0.26	1.7	34.7	20.0
1976	JAN	21	4:17	12:09	COMBINED FUEL A	0.26	7.9	157.3	20.0
1976	JAN	25	18:06	18:39	COMBINED FUEL A	0.26	0.5	11.0	20.0
1976	FEB	5	8:08	10:28	COMBINED FUEL A	0.26	2.3		
1976	FEB	5	17:10	21:35	COMBINED FUEL A	0.26	4.4	135.0	20.0
1976	MAR	3	13:03	14:30	COMBINED FUEL A	0.26	1.4	29.0	20.0
1976	MAR	7	2:12	8:20	COMBINED FUEL A	0.26	6.1	122.7	20.0
1976	MAR	15	6:42	8:21	COMBINED FUEL A	0.26	1.6	33.0	20.0
1976	MAR	28	8:37	10:06	COMBINED FUEL A	0.26	1.5	29.7	20.0
1976	APR	6	18:42	19:27	COMBINED FUEL A	0.26	0.8	15.0	20.0
1976	APR	7	3:28	3:41	COMBINED FUEL A	0.26	0.2	4.3	20.0
1976	APR	15	18:12	20:16	COMBINED FUEL A	0.26	2.1	41.3	20.0
1976	MAY	4	11:32	11:52	COMBINED FUEL A	0.26	0.3	6.7	20.0
1976	MAY	12	13:30	13:53	COMBINED FUEL A	0.26	0.4	7.7	20.0
1976	JUL	20	10:55	15:15	COMBINED FUEL A	0.26	4.3	86.7	20.0
1976	JUL	21	10:30	14:42	COMBINED FUEL A	0.26	4.2	84.0	20.0
1976	JUL	27	12:31	13:23	COMBINED FUEL A	0.26	0.9	17.3	20.0
1976	JUL	28	8:08	16:11	COMBINED FUEL A	0.26	8.0	161.0	20.0
1976	JUL	30	10:37	11:34	COMBINED FUEL A	0.26	1.0	19.0	20.0
1976	AUG	1	8:58	11:32	COMBINED FUEL A	0.26	2.6	51.3	20.0
1976	AUG	2	10:58	12:34	COMBINED FUEL A	0.26	1.6	32.0	20.0
1976	AUG	4	11:27	14:32	COMBINED FUEL A	0.26	3.1	61.7	20.0
1976	AUG	17	14:02	17:09	COMBINED FUEL A	0.26	3.1	62.3	20.0
1976	AUG	24	8:10	14:37	COMBINED FUEL A	0.26	6.4	129.0	20.0
1976	AUG	25	8:47	10:25	COMBINED FUEL A	0.26	1.6		
1976	AUG	25	11:04	15:14	COMBINED FUEL A	0.26	4.2	116.0	20.0
1976	AUG	26	8:28	14:07	COMBINED FUEL A	0.26	5.6	113.0	20.0
1976	AUG	27	8:15	14:22	COMBINED FUEL A	0.26	6.1		
1976	AUG	27	14:50	16:43	COMBINED FUEL A	0.26	1.9	160.0	20.0
1976	AUG	30	9:43	15:36	COMBINED FUEL A	0.26	5.9	117.7	20.0
1976	SEP	4	14:20	16:43	COMBINED FUEL A	0.26	2.4	47.7	20.0
1976	SEP	8	19:35	21:00	COMBINED FUEL A	0.26	1.4	28.3	20.0
1976	SEP	9	19:33	19:56	COMBINED FUEL A	0.26	0.4	7.7	20.0
1976	SEP	12	19:28	22:24	COMBINED FUEL A	0.26	2.9	58.7	20.0
1976	SEP	16	0:54	1:25	COMBINED FUEL A	0.26	0.5	10.3	20.0
1976	SEP	25	19:56	21:47	COMBINED FUEL A	0.26	1.8	37.0	20.0
1976	OCT	5	12:24	14:27	COMBINED FUEL A	0.26	2.0	41.0	20.0
1976	OCT	6	11:59	14:57	COMBINED FUEL A	0.26	3.0	59.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	OCT	7	14:12	14:30	COMBINED FUEL A	0.26	0.3	6.0	20.0
1976	OCT	8	18:52	20:16	COMBINED FUEL A	0.26	1.4	28.0	20.0
1976	OCT	9	18:52	20:16	COMBINED FUEL A	0.26	1.4	28.0	20.0
1976	OCT	17	19:48	21:16	COMBINED FUEL A	0.26	1.5	29.3	20.0
1976	OCT	24	15:10	15:20	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	NOV	4	12:51	15:46	COMBINED FUEL A	0.26	2.9		
1976	NOV	4	17:12	18:41	COMBINED FUEL A	0.26	1.5	88.0	20.0
1976	NOV	9	17:16	18:20	COMBINED FUEL A	0.26	1.1	21.3	20.0
1976	NOV	18	17:21	17:57	COMBINED FUEL A	0.26	0.6	12.0	20.0
1976	NOV	21	16:36	17:26	COMBINED FUEL A	0.26	0.8	16.7	20.0
1976	NOV	23	17:41	21:31	COMBINED FUEL A	0.26	3.8	76.7	20.0
1976	DEC	30	17:26	22:08	COMBINED FUEL A	0.26	4.7	94.0	20.0
1977	JAN	6	16:39	19:32	COMBINED FUEL A	0.29	2.9	57.7	20.0
1977	JAN	7	9:15	9:40	COMBINED FUEL A	0.29	0.4		
1977	JAN	7	13:42	14:44	COMBINED FUEL A	0.29	1.0	29.0	20.0
1977	JAN	12	13:58	14:15	COMBINED FUEL A	0.29	0.3	5.7	20.0
1977	JAN	19	15:20	15:58	COMBINED FUEL A	0.29	0.6	12.7	20.0
1977	JAN	25	9:30	12:20	COMBINED FUEL A	0.29	2.8	56.7	20.0
1977	APR	4	16:07	18:41	COMBINED FUEL A	0.29	2.6	51.3	20.0
1977	APR	15	8:06	14:35	COMBINED FUEL A	0.29	6.5	129.7	20.0
1977	MAY	3	10:34	11:02	COMBINED FUEL A	0.29	0.5		
1977	MAY	3	13:03	13:27	COMBINED FUEL A	0.29	0.4	17.3	20.0
1977	MAY	4	13:40	14:08	COMBINED FUEL A	0.29	0.5	9.3	20.0
1977	MAY	5	10:47	11:36	COMBINED FUEL A	0.29	0.8	16.3	20.0
1977	MAY	6	7:34	14:21	COMBINED FUEL A	0.29	6.8	135.7	20.0
1977	MAY	23	13:15	14:47	COMBINED FUEL A	0.29	1.5	30.7	20.0
1977	JUN	16	9:14	10:13	COMBINED FUEL A	0.29	1.0	19.7	20.0
1977	JUN	23	13:44	14:04	COMBINED FUEL A	0.29	0.3	6.7	20.0
1977	JUL	8	8:51	12:52	COMBINED FUEL A	0.29	4.0		
1977	JUL	8	13:14	13:20	COMBINED FUEL A	0.29	0.1	82.3	20.0
1977	JUL	11	9:34	9:46	COMBINED FUEL A	0.29	0.2		
1977	JUL	11	11:40	11:43	COMBINED FUEL A	0.29	0.0	5.0	20.0
1977	JUL	15	10:02	17:30	COMBINED FUEL A	0.29	7.5	149.3	20.0
1977	JUL	16	21:36	24:00	COMBINED FUEL A	0.29	2.4	48.0	20.0
1977	JUL	17	0:00	0:45	COMBINED FUEL A	0.29	0.8		
1977	JUL	17	23:12	24:00	COMBINED FUEL A	0.29	0.8	31.0	20.0
1977	JUL	18	0:00	0:05	COMBINED FUEL A	0.29	0.1		
1977	JUL	18	8:47	22:26	COMBINED FUEL A	0.29	13.6	274.7	20.0
1977	JUL	22	10:07	18:03	COMBINED FUEL A	0.29	7.9	158.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JUL	25	10:03	17:47	COMBINED FUEL A	0.29	7.7	154.7	20.0
1977	JUL	26	9:35	14:47	COMBINED FUEL A	0.29	5.2		
1977	JUL	26	15:02	20:58	COMBINED FUEL A	0.29	5.9	222.7	20.0
1977	JUL	27	9:04	12:03	COMBINED FUEL A	0.29	3.0	59.7	20.0
1977	JUL	29	13:32	18:36	COMBINED FUEL A	0.29	5.1	101.3	20.0
1977	AUG	3	11:53	18:55	COMBINED FUEL A	0.29	7.0	140.7	20.0
1977	AUG	5	15:20	15:42	COMBINED FUEL A	0.29	0.4		
1977	AUG	5	16:05	16:12	COMBINED FUEL A	0.29	0.1	9.7	20.0
1977	AUG	9	15:37	17:29	COMBINED FUEL A	0.29	1.9	37.3	20.0
1977	AUG	19	8:50	16:40	COMBINED FUEL A	0.29	7.8	156.7	20.0
1977	AUG	23	10:32	12:07	COMBINED FUEL A	0.29	1.6		
1977	AUG	23	12:53	14:20	COMBINED FUEL A	0.29	1.4	60.7	20.0
1977	AUG	24	9:54	10:26	COMBINED FUEL A	0.29	0.5	10.7	20.0
1977	AUG	25	8:06	8:52	COMBINED FUEL A	0.29	0.8	15.3	20.0
1977	SEP	7	13:16	21:48	COMBINED FUEL A	0.29	8.5	170.7	20.0
1977	SEP	10	6:04	7:47	COMBINED FUEL A	0.29	1.7	34.3	20.0
1977	SEP	19	9:04	12:38	COMBINED FUEL A	0.29	3.6	71.3	20.0
1977	SEP	27	9:20	16:08	COMBINED FUEL A	0.29	6.8	136.0	20.0
1977	OCT	3	20:44	21:52	COMBINED FUEL A	0.29	1.1	22.7	20.0
1977	OCT	4	18:48	21:20	COMBINED FUEL A	0.29	2.5	50.7	20.0
1977	OCT	7	10:58	17:06	COMBINED FUEL A	0.29	6.1	122.7	20.0
1977	OCT	10	8:28	10:20	COMBINED FUEL A	0.29	1.9	37.3	20.0
1977	OCT	17	8:39	13:29	COMBINED FUEL A	0.29	4.8	96.7	20.0
1977	OCT	25	7:42	8:33	COMBINED FUEL A	0.29	0.9		
1977	OCT	25	8:53	9:00	COMBINED FUEL A	0.29	0.1	19.3	20.0
1977	OCT	31	17:49	19:50	COMBINED FUEL A	0.29	2.0	40.3	20.0
1977	NOV	1	17:19	19:32	COMBINED FUEL A	0.29	2.2	44.3	20.0
1977	NOV	9	17:35	18:44	COMBINED FUEL A	0.29	1.1	23.0	20.0
1977	NOV	30	13:17	21:18	COMBINED FUEL A	0.29	8.0	160.3	20.0
1977	DEC	4	16:48	18:48	COMBINED FUEL A	0.29	2.0	40.0	20.0
1977	DEC	6	17:28	19:09	COMBINED FUEL A	0.29	1.7	33.7	20.0
1977	DEC	19	17:24	19:10	COMBINED FUEL A	0.29	1.8	35.3	20.0
1977	DEC	27	17:14	17:27	COMBINED FUEL A	0.29	0.2	4.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	3	9:20	12:01	COMBINED FUEL A	0.30	2.7	53.7	20.0
1975	JAN	27	9:48	11:03	COMBINED FUEL A	0.30	1.3	25.0	20.0
1975	JAN	30	17:31	20:15	COMBINED FUEL A	0.30	2.7	54.7	20.0
1975	FEB	8	8:47	12:11	COMBINED FUEL A	0.30	3.4	68.0	20.0
1975	FEB	26	9:25	12:40	COMBINED FUEL A	0.30	3.3	65.0	20.0
1975	MAR	6	11:05	12:06	COMBINED FUEL A	0.30	1.0	20.3	20.0
1975	MAR	13	18:23	21:43	COMBINED FUEL A	0.30	3.3	66.7	20.0
1975	MAR	17	11:24	12:09	COMBINED FUEL A	0.30	0.8	15.0	20.0
1975	MAR	21	0:56	1:46	COMBINED FUEL A	0.30	0.8	16.7	20.0
1975	MAR	22	9:23	12:13	COMBINED FUEL A	0.30	2.8	56.7	20.0
1975	MAR	27	8:28	12:08	COMBINED FUEL A	0.30	3.7	73.3	20.0
1975	MAR	29	19:19	21:13	COMBINED FUEL A	0.30	1.9	38.0	20.0
1975	APR	4	14:36	16:42	COMBINED FUEL A	0.30	2.1	42.0	20.0
1975	APR	8	9:56	14:41	COMBINED FUEL A	0.30	4.8		
1975	APR	8	17:33	20:28	COMBINED FUEL A	0.30	2.9	153.3	20.0
1975	APR	16	8:10	12:10	COMBINED FUEL A	0.30	4.0		
1975	APR	16	19:36	21:51	COMBINED FUEL A	0.30	2.3	125.0	20.0
1975	APR	22	19:51	21:06	COMBINED FUEL A	0.30	1.3	25.0	20.0
1975	APR	24	10:40	11:07	COMBINED FUEL A	0.30	0.5	9.0	20.0
1975	APR	29	19:17	22:22	COMBINED FUEL A	0.30	3.1	61.7	20.0
1975	MAY	4	14:36	16:42	COMBINED FUEL A	0.30	2.1	42.0	20.0
1975	MAY	8	9:56	14:41	COMBINED FUEL A	0.30	4.8		
1975	MAY	8	17:33	20:28	COMBINED FUEL A	0.30	2.9	153.3	20.0
1975	MAY	16	8:10	12:10	COMBINED FUEL A	0.30	4.0		
1975	MAY	16	19:36	21:51	COMBINED FUEL A	0.30	2.3	125.0	20.0
1975	MAY	22	19:51	21:06	COMBINED FUEL A	0.30	1.3	25.0	20.0
1975	MAY	24	10:40	11:07	COMBINED FUEL A	0.30	0.5	9.0	20.0
1975	MAY	29	19:17	22:22	COMBINED FUEL A	0.30	3.1	61.7	20.0
1975	JUN	17	8:07	8:10	COMBINED FUEL A	0.30	0.0	1.0	20.0
1975	JUN	19	8:15	17:13	COMBINED FUEL A	0.30	9.0		
1975	JUN	19	19:50	21:38	COMBINED FUEL A	0.30	1.8	215.3	20.0
1975	JUN	24	14:08	14:25	COMBINED FUEL A	0.30	0.3		
1975	JUN	24	14:25	15:10	COMBINED FUEL A	0.30	0.8		
1975	JUN	24	15:10	15:28	COMBINED FUEL A	0.30	0.3	26.7	20.0
1975	JUL	7	8:09	10:55	COMBINED FUEL A	0.30	2.8	55.3	20.0
1975	JUL	11	11:19	14:20	COMBINED FUEL A	0.30	3.0	60.3	20.0
1975	JUL	25	20:15	21:05	COMBINED FUEL A	0.30	0.8	16.7	20.0
1975	JUL	26	12:02	13:06	COMBINED FUEL A	0.30	1.1	21.3	20.0
1975	JUL	27	11:56	18:42	COMBINED FUEL A	0.30	6.8		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JUL	27	21:01	21:27	COMBINED FUEL A	0.30	0.4	144.0	20.0
1975	JUL	28	12:23	13:10	COMBINED FUEL A	0.30	0.8	15.7	20.0
1975	AUG	2	15:21	18:24	COMBINED FUEL A	0.30	3.0	61.0	20.0
1975	AUG	4	12:41	17:58	COMBINED FUEL A	0.30	5.3	105.7	20.0
1975	AUG	6	11:52	21:47	COMBINED FUEL A	0.30	9.9	198.3	20.0
1975	AUG	11	7:33	9:00	COMBINED FUEL A	0.30	1.4	29.0	20.0
1975	AUG	12	7:12	7:58	COMBINED FUEL A	0.30	0.8	15.3	20.0
1975	AUG	14	9:53	11:43	COMBINED FUEL A	0.30	1.8	36.7	20.0
1975	AUG	20	9:37	12:00	COMBINED FUEL A	0.30	2.4	47.7	20.0
1975	AUG	22	16:52	18:01	COMBINED FUEL A	0.30	1.1	23.0	20.0
1975	AUG	23	10:55	15:27	COMBINED FUEL A	0.30	4.5	90.7	20.0
1975	SEP	3	13:48	16:38	COMBINED FUEL A	0.30	2.8	56.7	20.0
1975	SEP	4	13:05	20:49	COMBINED FUEL A	0.30	7.7	154.7	20.0
1975	SEP	6	9:06	23:01	COMBINED FUEL A	0.30	13.9	278.3	20.0
1975	SEP	8	18:19	20:16	COMBINED FUEL A	0.30	1.9	39.0	20.0
1975	SEP	15	9:45	12:20	COMBINED FUEL A	0.30	2.6	51.7	20.0
1975	SEP	16	10:30	23:23	COMBINED FUEL A	0.30	12.9	257.7	20.0
1975	SEP	17	8:56	10:48	COMBINED FUEL A	0.30	1.9		
1975	SEP	17	13:49	20:57	COMBINED FUEL A	0.30	7.1	180.0	20.0
1975	SEP	18	1:37	3:34	COMBINED FUEL A	0.30	1.9		
1975	SEP	18	8:08	10:20	COMBINED FUEL A	0.30	2.2		
1975	SEP	18	13:02	14:56	COMBINED FUEL A	0.30	1.9		
1975	SEP	18	16:51	17:55	COMBINED FUEL A	0.30	1.1	142.3	20.0
1975	SEP	19	9:30	12:05	COMBINED FUEL A	0.30	2.6	51.7	20.0
1975	SEP	20	9:31	11:10	COMBINED FUEL A	0.30	1.6		
1975	SEP	20	12:39	18:15	COMBINED FUEL A	0.30	5.6	145.0	20.0
1975	SEP	22	15:06	21:25	COMBINED FUEL A	0.30	6.3	126.3	20.0
1975	SEP	23	10:16	20:21	COMBINED FUEL A	0.30	10.1	201.7	20.0
1975	SEP	24	19:14	20:18	COMBINED FUEL A	0.30	1.1	21.3	20.0
1975	SEP	25	9:34	12:26	COMBINED FUEL A	0.30	2.9	57.3	20.0
1975	OCT	2	18:54	21:20	COMBINED FUEL A	0.30	2.4	48.7	20.0
1975	OCT	3	13:11	17:43	COMBINED FUEL A	0.30	4.5	90.7	20.0
1975	OCT	8	9:58	11:33	COMBINED FUEL A	0.30	1.6	31.7	20.0
1975	OCT	10	8:59	15:58	COMBINED FUEL A	0.30	7.0	139.7	20.0
1975	OCT	12	18:58	20:51	COMBINED FUEL A	0.30	1.9	37.7	20.0
1975	OCT	27	13:25	14:15	COMBINED FUEL A	0.30	0.8	16.7	20.0
1975	OCT	28	11:20	11:25	COMBINED FUEL A	0.30	0.1		
1975	OCT	28	13:19	14:48	COMBINED FUEL A	0.30	1.5		
1975	OCT	28	15:18	15:32	COMBINED FUEL A	0.30	0.2	36.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 38

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	OCT	31	9:57	10:50	COMBINED FUEL A	0.30	0.9		
1975	OCT	31	11:36	12:15	COMBINED FUEL A	0.30	0.7		
1975	OCT	31	13:12	13:50	COMBINED FUEL A	0.30	0.6	43.3	20.0
1975	NOV	3	8:44	8:50	COMBINED FUEL A	0.30	0.1		
1975	NOV	3	11:03	11:30	COMBINED FUEL A	0.30	0.4		
1975	NOV	3	13:57	14:55	COMBINED FUEL A	0.30	1.0	30.3	20.0
1975	NOV	4	9:40	13:47	COMBINED FUEL A	0.30	4.1	82.3	20.0
1975	NOV	14	16:55	19:54	COMBINED FUEL A	0.30	3.0	59.7	20.0
1975	NOV	20	7:44	12:16	COMBINED FUEL A	0.30	4.5		
1975	NOV	20	16:54	19:33	COMBINED FUEL A	0.30	2.6	143.7	20.0
1975	NOV	21	8:40	9:26	COMBINED FUEL A	0.30	0.8		
1975	NOV	21	16:48	20:04	COMBINED FUEL A	0.30	3.3	80.7	20.0
1975	NOV	22	17:06	18:51	COMBINED FUEL A	0.30	1.8	35.0	20.0
1975	NOV	29	17:07	19:18	COMBINED FUEL A	0.30	2.2	43.7	20.0
1975	DEC	3	17:02	19:13	COMBINED FUEL A	0.30	2.2	43.7	20.0
1975	DEC	6	16:47	19:24	COMBINED FUEL A	0.30	2.6	52.3	20.0
1975	DEC	7	16:47	19:57	COMBINED FUEL A	0.30	3.2	63.3	20.0
1975	DEC	10	17:10	21:20	COMBINED FUEL A	0.30	4.2	83.3	20.0
1975	DEC	11	10:30	12:10	COMBINED FUEL A	0.30	1.7	33.3	20.0
1975	DEC	13	9:37	12:24	COMBINED FUEL A	0.30	2.8	55.7	20.0
1975	DEC	16	13:40	17:08	COMBINED FUEL A	0.30	3.5	69.3	20.0
1975	DEC	19	23:36	24:00	COMBINED FUEL A	0.30	0.4	8.0	20.0
1975	DEC	20	0:00	0:30	COMBINED FUEL A	0.30	0.5	10.0	20.0
1975	DEC	30	17:32	19:48	COMBINED FUEL A	0.30	2.3	45.3	20.0
1976	JAN	6	8:26	9:06	COMBINED FUEL A	0.26	0.7	13.3	20.0
1976	JAN	21	4:17	12:26	COMBINED FUEL A	0.26	8.1	163.0	20.0
1976	JAN	24	17:33	18:58	COMBINED FUEL A	0.26	1.4	28.3	20.0
1976	JAN	25	18:04	19:59	COMBINED FUEL A	0.26	1.9	38.3	20.0
1976	JAN	30	17:54	19:08	COMBINED FUEL A	0.26	1.2	24.7	20.0
1976	FEB	3	8:15	11:30	COMBINED FUEL A	0.26	3.3	65.0	20.0
1976	FEB	5	8:08	10:39	COMBINED FUEL A	0.26	2.5		
1976	FEB	5	17:10	21:44	COMBINED FUEL A	0.26	4.6	141.7	20.0
1976	FEB	10	8:07	10:10	COMBINED FUEL A	0.26	2.0	41.0	20.0
1976	FEB	29	19:08	20:06	COMBINED FUEL A	0.26	1.0	19.3	20.0
1976	MAR	4	8:08	13:04	COMBINED FUEL A	0.26	4.9	98.7	20.0
1976	MAR	7	2:12	8:15	COMBINED FUEL A	0.26	6.0	121.0	20.0
1976	MAR	15	6:38	8:16	COMBINED FUEL A	0.26	1.6	32.7	20.0
1976	APR	6	18:52	19:27	COMBINED FUEL A	0.26	0.6	11.7	20.0
1976	APR	7	3:28	3:48	COMBINED FUEL A	0.26	0.3	6.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	APR	15	18:12	20:25	COMBINED FUEL A	0.26	2.2	44.3	20.0
1976	APR	18	18:52	21:07	COMBINED FUEL A	0.26	2.3	45.0	20.0
1976	MAY	1	20:12	21:16	COMBINED FUEL A	0.26	1.1	21.3	20.0
1976	MAY	4	11:32	11:52	COMBINED FUEL A	0.26	0.3	6.7	20.0
1976	MAY	11	13:06	18:10	COMBINED FUEL A	0.26	5.1		
1976	MAY	11	19:50	21:08	COMBINED FUEL A	0.26	1.3	127.3	20.0
1976	MAY	12	20:04	20:30	COMBINED FUEL A	0.26	0.4	8.7	20.0
1976	MAY	21	15:00	16:28	COMBINED FUEL A	0.26	1.5	29.3	20.0
1976	JUN	3	13:34	15:07	COMBINED FUEL A	0.26	1.5	31.0	20.0
1976	JUN	5	9:07	11:41	COMBINED FUEL A	0.26	2.6	51.3	20.0
1976	JUN	7	9:10	10:06	COMBINED FUEL A	0.26	0.9	18.7	20.0
1976	JUN	8	14:41	15:26	COMBINED FUEL A	0.26	0.8	15.0	20.0
1976	JUN	12	17:46	18:20	COMBINED FUEL A	0.26	0.6	11.3	20.0
1976	JUN	14	14:04	16:10	COMBINED FUEL A	0.26	2.1	42.0	20.0
1976	JUN	15	13:10	17:38	COMBINED FUEL A	0.26	4.5	89.3	20.0
1976	JUN	22	14:10	14:50	COMBINED FUEL A	0.26	0.7	13.3	20.0
1976	JUN	23	13:33	14:25	COMBINED FUEL A	0.26	0.9	17.3	20.0
1976	JUN	24	10:43	17:52	COMBINED FUEL A	0.26	7.1	143.0	20.0
1976	JUN	25	12:30	16:08	COMBINED FUEL A	0.26	3.6	72.7	20.0
1976	JUN	26	10:34	14:04	COMBINED FUEL A	0.26	3.5	70.0	20.0
1976	JUN	27	16:05	18:09	COMBINED FUEL A	0.26	2.1	41.3	20.0
1976	JUN	28	10:11	17:20	COMBINED FUEL A	0.26	7.1	143.0	20.0
1976	JUL	4	16:49	16:59	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	JUL	6	11:13	17:12	COMBINED FUEL A	0.26	6.0	119.7	20.0
1976	JUL	7	11:59	17:15	COMBINED FUEL A	0.26	5.3	105.3	20.0
1976	JUL	27	12:26	15:05	COMBINED FUEL A	0.26	2.6	53.0	20.0
1976	JUL	28	9:24	15:38	COMBINED FUEL A	0.26	6.2	124.7	20.0
1976	JUL	30	10:37	11:34	COMBINED FUEL A	0.26	1.0	19.0	20.0
1976	JUL	31	10:57	12:26	COMBINED FUEL A	0.26	1.5		
1976	JUL	31	17:03	18:26	COMBINED FUEL A	0.26	1.4	57.3	20.0
1976	AUG	1	8:35	10:33	COMBINED FUEL A	0.26	2.0		
1976	AUG	1	10:38	11:22	COMBINED FUEL A	0.26	0.7	54.0	20.0
1976	AUG	2	10:19	12:34	COMBINED FUEL A	0.26	2.3	45.0	20.0
1976	AUG	4	11:27	14:37	COMBINED FUEL A	0.26	3.2	63.3	20.0
1976	AUG	5	13:07	14:42	COMBINED FUEL A	0.26	1.6	31.7	20.0
1976	AUG	7	9:26	11:19	COMBINED FUEL A	0.26	1.9	37.7	20.0
1976	AUG	25	10:00	11:45	COMBINED FUEL A	0.26	1.8	35.0	20.0
1976	AUG	27	14:50	16:35	COMBINED FUEL A	0.26	1.8	35.0	20.0
1976	AUG	29	11:33	21:15	COMBINED FUEL A	0.26	9.7	194.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	SEP	1	11:12	15:58	COMBINED FUEL A	0.26	4.8	95.3	20.0
1976	SEP	4	14:20	16:43	COMBINED FUEL A	0.26	2.4	47.7	20.0
1976	SEP	8	9:22	9:45	COMBINED FUEL A	0.26	0.4	7.7	20.0
1976	SEP	10	0:54	1:26	COMBINED FUEL A	0.26	0.5	10.7	20.0
1976	SEP	12	19:17	22:31	COMBINED FUEL A	0.26	3.2	64.7	20.0
1976	SEP	22	9:53	15:00	COMBINED FUEL A	0.26	5.1	102.3	20.0
1976	SEP	25	19:56	21:55	COMBINED FUEL A	0.26	2.0	39.7	20.0
1976	OCT	1	2:30	10:35	COMBINED FUEL A	0.26	8.1		
1976	OCT	1	11:07	12:02	COMBINED FUEL A	0.26	0.9		
1976	OCT	1	12:50	14:43	COMBINED FUEL A	0.26	1.9	217.7	20.0
1976	OCT	3	19:11	19:43	COMBINED FUEL A	0.26	0.5	10.7	20.0
1976	OCT	5	12:44	14:19	COMBINED FUEL A	0.26	1.6	31.7	20.0
1976	OCT	7	18:50	20:10	COMBINED FUEL A	0.26	1.3	26.7	20.0
1976	OCT	9	17:08	20:24	COMBINED FUEL A	0.26	3.3	65.3	20.0
1976	OCT	17	19:48	21:20	COMBINED FUEL A	0.26	1.5	30.7	20.0
1976	OCT	18	18:40	19:24	COMBINED FUEL A	0.26	0.7	14.7	20.0
1976	OCT	24	15:16	15:20	COMBINED FUEL A	0.26	0.1		
1976	OCT	24	15:46	16:35	COMBINED FUEL A	0.26	0.8	17.7	20.0
1976	OCT	30	18:51	19:21	COMBINED FUEL A	0.26	0.5	10.0	20.0
1976	NOV	2	14:33	16:29	COMBINED FUEL A	0.26	1.9	38.7	20.0
1976	NOV	4	17:12	18:51	COMBINED FUEL A	0.26	1.6	33.0	20.0
1976	NOV	5	13:10	14:04	COMBINED FUEL A	0.26	0.9	18.0	20.0
1976	NOV	29	11:26	13:00	COMBINED FUEL A	0.26	1.6		
1976	NOV	29	13:08	15:07	COMBINED FUEL A	0.26	2.0	71.0	20.0
1976	NOV	30	13:02	16:03	COMBINED FUEL A	0.26	3.0	60.3	20.0
1976	DEC	30	17:26	21:58	COMBINED FUEL A	0.26	4.5	90.7	20.0
1977	JAN	6	16:39	19:40	COMBINED FUEL A	0.29	3.0	60.3	20.0
1977	JAN	7	9:46	10:13	COMBINED FUEL A	0.29	0.5	9.0	20.0
1977	JAN	28	9:16	12:03	COMBINED FUEL A	0.29	2.8	55.7	20.0
1977	MAR	2	18:15	19:30	COMBINED FUEL A	0.29	1.3	25.0	20.0
1977	MAR	16	17:55	19:21	COMBINED FUEL A	0.29	1.4	28.7	20.0
1977	APR	18	11:50	13:12	COMBINED FUEL A	0.29	1.4	27.3	20.0
1977	APR	21	7:57	14:33	COMBINED FUEL A	0.29	6.6	132.0	20.0
1977	APR	30	19:33	20:17	COMBINED FUEL A	0.29	0.7	14.7	20.0
1977	MAY	3	10:34	11:02	COMBINED FUEL A	0.29	0.5		
1977	MAY	3	14:05	14:27	COMBINED FUEL A	0.29	0.4	16.7	20.0
1977	MAY	4	15:01	15:19	COMBINED FUEL A	0.29	0.3	6.0	20.0
1977	MAY	5	10:47	11:16	COMBINED FUEL A	0.29	0.5	9.7	20.0
1977	MAY	6	7:37	13:51	COMBINED FUEL A	0.29	6.2	124.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	MAY	17	9:20	12:05	COMBINED FUEL A	0.29	2.8	55.0	20.0
1977	JUN	2	11:59	14:05	COMBINED FUEL A	0.29	2.1	42.0	20.0
1977	JUN	16	9:14	10:13	COMBINED FUEL A	0.29	1.0	19.7	20.0
1977	JUN	28	9:14	13:27	COMBINED FUEL A	0.29	4.2	84.3	20.0
1977	JUL	1	10:22	13:11	COMBINED FUEL A	0.29	2.8	56.3	20.0
1977	JUL	13	12:51	13:28	COMBINED FUEL A	0.29	0.6	12.3	20.0
1977	JUL	14	9:15	11:55	COMBINED FUEL A	0.29	2.7	53.3	20.0
1977	JUL	15	9:38	15:36	COMBINED FUEL A	0.29	6.0	119.3	20.0
1977	JUL	16	10:02	13:54	COMBINED FUEL A	0.29	3.9		
1977	JUL	16	21:36	24:00	COMBINED FUEL A	0.29	2.4	125.3	20.0
1977	JUL	17	0:00	1:12	COMBINED FUEL A	0.29	1.2		
1977	JUL	17	23:12	24:00	COMBINED FUEL A	0.29	0.8	40.0	20.0
1977	JUL	18	0:00	0:05	COMBINED FUEL A	0.29	0.1		
1977	JUL	18	8:42	22:31	COMBINED FUEL A	0.29	13.8	278.0	20.0
1977	JUL	19	11:39	16:09	COMBINED FUEL A	0.29	4.5	90.0	20.0
1977	JUL	22	9:26	16:16	COMBINED FUEL A	0.29	6.8	136.7	20.0
1977	JUL	25	9:35	17:59	COMBINED FUEL A	0.29	8.4	168.0	20.0
1977	JUL	26	9:05	14:47	COMBINED FUEL A	0.29	5.7		
1977	JUL	26	15:02	21:11	COMBINED FUEL A	0.29	6.1	237.0	20.0
1977	JUL	27	8:48	12:03	COMBINED FUEL A	0.29	3.3		
1977	JUL	27	14:40	16:47	COMBINED FUEL A	0.29	2.1	107.3	20.0
1977	JUL	28	14:07	16:42	COMBINED FUEL A	0.29	2.6	51.7	20.0
1977	JUL	29	13:32	15:36	COMBINED FUEL A	0.29	2.1	41.3	20.0
1977	JUL	30	16:17	16:55	COMBINED FUEL A	0.29	0.6	12.7	20.0
1977	AUG	3	11:13	18:50	COMBINED FUEL A	0.29	7.6	152.3	20.0
1977	AUG	5	15:20	15:42	COMBINED FUEL A	0.29	0.4		
1977	AUG	5	16:05	16:12	COMBINED FUEL A	0.29	0.1	9.7	20.0
1977	AUG	9	15:37	18:32	COMBINED FUEL A	0.29	2.9	58.3	20.0
1977	AUG	19	8:28	11:47	COMBINED FUEL A	0.29	3.3		
1977	AUG	19	13:30	16:52	COMBINED FUEL A	0.29	3.4	133.7	20.0
1977	AUG	20	11:18	18:04	COMBINED FUEL A	0.29	6.8	135.3	20.0
1977	AUG	25	8:06	8:52	COMBINED FUEL A	0.29	0.8	15.3	20.0
1977	SEP	7	13:00	20:38	COMBINED FUEL A	0.29	7.6	152.7	20.0
1977	SEP	10	6:04	7:57	COMBINED FUEL A	0.29	1.9	37.7	20.0
1977	SEP	19	9:04	9:30	COMBINED FUEL A	0.29	0.4		
1977	SEP	19	10:57	11:06	COMBINED FUEL A	0.29	0.2	11.7	20.0
1977	OCT	3	19:00	20:00	COMBINED FUEL A	0.29	1.0		
1977	OCT	3	20:44	21:51	COMBINED FUEL A	0.29	1.1	42.3	20.0
1977	OCT	4	18:36	21:05	COMBINED FUEL A	0.29	2.5	49.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	OCT	6	18:40	22:24	COMBINED FUEL A	0.29	3.7	74.7	20.0
1977	OCT	7	9:31	16:25	COMBINED FUEL A	0.29	6.9		
1977	OCT	7	18:33	19:45	COMBINED FUEL A	0.29	1.2	162.0	20.0
1977	OCT	10	8:28	10:20	COMBINED FUEL A	0.29	1.9	37.3	20.0
1977	OCT	15	18:47	18:53	COMBINED FUEL A	0.29	0.1	2.0	20.0
1977	OCT	16	18:26	19:46	COMBINED FUEL A	0.29	1.3	26.7	20.0
1977	OCT	17	8:39	12:12	COMBINED FUEL A	0.29	3.5	71.0	20.0
1977	OCT	20	10:23	10:50	COMBINED FUEL A	0.29	0.4		
1977	OCT	20	11:10	15:23	COMBINED FUEL A	0.29	4.2	93.3	20.0
1977	OCT	23	10:11	10:59	COMBINED FUEL A	0.29	0.8	16.0	20.0
1977	OCT	31	17:49	19:50	COMBINED FUEL A	0.29	2.0	40.3	20.0
1977	NOV	1	17:15	19:21	COMBINED FUEL A	0.29	2.1	42.0	20.0
1977	NOV	2	17:32	18:14	COMBINED FUEL A	0.29	0.7	14.0	20.0
1977	NOV	3	17:19	18:45	COMBINED FUEL A	0.29	1.4	28.7	20.0
1977	NOV	5	17:27	18:57	COMBINED FUEL A	0.29	1.5	30.0	20.0
1977	NOV	8	17:13	19:04	COMBINED FUEL A	0.29	1.8	37.0	20.0
1977	NOV	9	17:13	19:04	COMBINED FUEL A	0.29	1.8	37.0	20.0
1977	NOV	17	17:12	18:15	COMBINED FUEL A	0.29	1.0	21.0	20.0
1977	NOV	18	17:29	18:04	COMBINED FUEL A	0.29	0.6	11.7	20.0
1977	NOV	20	17:10	19:57	COMBINED FUEL A	0.29	2.8	55.7	20.0
1977	NOV	21	17:04	19:16	COMBINED FUEL A	0.29	2.2	44.0	20.0
1977	NOV	22	16:52	19:42	COMBINED FUEL A	0.29	2.8	56.7	20.0
1977	NOV	28	17:21	17:56	COMBINED FUEL A	0.29	0.6	11.7	20.0
1977	NOV	29	16:53	18:28	COMBINED FUEL A	0.29	1.6	31.7	20.0
1977	NOV	30	10:52	21:25	COMBINED FUEL A	0.29	10.5	211.0	20.0
1977	DEC	3	17:23	18:13	COMBINED FUEL A	0.29	0.8	16.7	20.0
1977	DEC	4	16:48	18:58	COMBINED FUEL A	0.29	2.2	43.3	20.0
1977	DEC	6	8:37	12:03	COMBINED FUEL A	0.29	3.4		
1977	DEC	6	17:19	18:26	COMBINED FUEL A	0.29	1.1	91.0	20.0
1977	DEC	19	17:02	18:20	COMBINED FUEL A	0.29	1.3	26.0	20.0
1977	DEC	24	17:15	18:03	COMBINED FUEL A	0.29	0.8	16.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	17	13:10	15:30	COMBINED FUEL A	0.30	2.3	46.7	20.0
1975	JAN	20	10:55	14:00	COMBINED FUEL A	0.30	3.1	61.7	20.0
1975	JAN	21	9:35	14:45	COMBINED FUEL A	0.30	5.2		
1975	JAN	21	14:49	15:20	COMBINED FUEL A	0.30	0.5	113.7	20.0
1975	JAN	23	10:20	14:22	COMBINED FUEL A	0.30	4.0	80.7	20.0
1975	JAN	27	9:48	10:43	COMBINED FUEL A	0.30	0.9	18.3	20.0
1975	JAN	30	17:33	17:59	COMBINED FUEL A	0.30	0.4		
1975	JAN	30	18:24	19:41	COMBINED FUEL A	0.30	1.3	34.3	20.0
1975	FEB	5	10:08	10:34	COMBINED FUEL A	0.30	0.4	8.7	20.0
1975	FEB	8	9:05	11:47	COMBINED FUEL A	0.30	2.7	54.0	20.0
1975	MAR	13	13:35	14:25	COMBINED FUEL A	0.30	0.8		
1975	MAR	13	18:23	21:53	COMBINED FUEL A	0.30	3.5	86.7	20.0
1975	MAR	21	0:56	1:46	COMBINED FUEL A	0.30	0.8	16.7	20.0
1975	MAR	22	9:27	12:02	COMBINED FUEL A	0.30	2.6	51.7	20.0
1975	MAR	27	8:28	12:21	COMBINED FUEL A	0.30	3.9	77.7	20.0
1975	MAR	29	19:19	21:07	COMBINED FUEL A	0.30	1.8	36.0	20.0
1975	APR	1	11:21	11:49	COMBINED FUEL A	0.30	0.5	9.3	20.0
1975	APR	4	14:36	16:37	COMBINED FUEL A	0.30	2.0	40.3	20.0
1975	APR	15	8:40	10:15	COMBINED FUEL A	0.30	1.6		
1975	APR	15	10:30	11:30	COMBINED FUEL A	0.30	1.0	51.7	20.0
1975	APR	29	19:17	19:18	COMBINED FUEL A	0.30	0.0		
1975	APR	29	19:56	22:28	COMBINED FUEL A	0.30	2.5	51.0	20.0
1975	MAY	27	15:37	17:21	COMBINED FUEL A	0.30	1.7	34.7	20.0
1975	MAY	28	9:03	10:09	COMBINED FUEL A	0.30	1.1	22.0	20.0
1975	JUN	17	8:07	8:10	COMBINED FUEL A	0.30	0.0	1.0	20.0
1975	JUN	19	8:15	16:09	COMBINED FUEL A	0.30	7.9		
1975	JUN	19	19:50	21:38	COMBINED FUEL A	0.30	1.8	194.0	20.0
1975	JUN	23	9:22	11:26	COMBINED FUEL A	0.30	2.1	41.3	20.0
1975	JUN	25	13:48	14:33	COMBINED FUEL A	0.30	0.8	15.0	20.0
1975	JUN	26	9:28	12:10	COMBINED FUEL A	0.30	2.7	54.0	20.0
1975	JUN	30	8:06	9:47	COMBINED FUEL A	0.30	1.7		
1975	JUN	30	11:12	12:00	COMBINED FUEL A	0.30	0.8		
1975	JUN	30	12:40	15:47	COMBINED FUEL A	0.30	3.1	112.0	20.0
1975	JUL	1	8:06	10:10	COMBINED FUEL A	0.30	2.1	41.3	20.0
1975	JUL	10	10:35	11:57	COMBINED FUEL A	0.30	1.4	27.3	20.0
1975	JUL	11	12:11	14:11	COMBINED FUEL A	0.30	2.0	40.0	20.0
1975	JUL	15	15:32	15:50	COMBINED FUEL A	0.30	0.3	6.0	20.0
1975	JUL	17	12:12	12:25	COMBINED FUEL A	0.30	0.2	4.3	20.0
1975	JUL	27	21:01	21:05	COMBINED FUEL A	0.30	0.1	1.3	20.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	AUG	2	15:47	16:01	COMBINED FUEL A	0.30	0.2	4.7	20.0
1975	AUG	6	11:52	12:01	COMBINED FUEL A	0.30	0.2	3.0	20.0
1975	AUG	11	7:33	8:46	COMBINED FUEL A	0.30	1.2	24.3	20.0
1975	AUG	12	7:12	8:26	COMBINED FUEL A	0.30	1.2	24.7	20.0
1975	AUG	27	11:16	12:53	COMBINED FUEL A	0.30	1.6	32.3	20.0
1975	SEP	6	9:31	12:10	COMBINED FUEL A	0.30	2.6	53.0	20.0
1975	SEP	8	22:25	23:01	COMBINED FUEL A	0.30	0.6	12.0	20.0
1975	SEP	9	11:09	12:17	COMBINED FUEL A	0.30	1.1	22.7	20.0
1975	SEP	15	9:45	12:19	COMBINED FUEL A	0.30	2.6	51.3	20.0
1975	SEP	16	10:09	23:28	COMBINED FUEL A	0.30	13.3	266.3	20.0
1975	SEP	17	10:15	11:12	COMBINED FUEL A	0.30	1.0		
1975	SEP	17	13:11	21:28	COMBINED FUEL A	0.30	8.3	184.7	20.0
1975	SEP	23	10:33	20:16	COMBINED FUEL A	0.30	9.7	194.3	20.0
1975	SEP	24	19:14	20:11	COMBINED FUEL A	0.30	1.0	19.0	20.0
1975	SEP	25	9:34	12:20	COMBINED FUEL A	0.30	2.8	55.3	20.0
1975	SEP	29	9:05	11:03	COMBINED FUEL A	0.30	2.0	39.3	20.0
1975	OCT	7	13:58	14:32	COMBINED FUEL A	0.30	0.6	11.3	20.0
1975	OCT	15	9:13	12:47	COMBINED FUEL A	0.30	3.6		
1975	OCT	15	13:08	13:41	COMBINED FUEL A	0.30	0.5		
1975	OCT	15	14:07	14:40	COMBINED FUEL A	0.30	0.5	93.3	20.0
1975	NOV	14	16:55	19:54	COMBINED FUEL A	0.30	3.0	59.7	20.0
1975	NOV	17	7:48	7:52	COMBINED FUEL A	0.30	0.1		
1975	NOV	17	8:46	12:53	COMBINED FUEL A	0.30	4.1	83.7	20.0
1975	NOV	21	16:48	20:19	COMBINED FUEL A	0.30	3.5	70.3	20.0
1975	NOV	26	8:11	11:06	COMBINED FUEL A	0.30	2.9	58.3	20.0
1975	NOV	29	17:07	19:31	COMBINED FUEL A	0.30	2.4	48.0	20.0
1975	DEC	3	17:02	20:02	COMBINED FUEL A	0.30	3.0	60.0	20.0
1975	DEC	5	16:47	19:26	COMBINED FUEL A	0.30	2.6	53.0	20.0
1975	DEC	10	16:59	21:35	COMBINED FUEL A	0.30	4.6	92.0	20.0
1975	DEC	16	13:40	17:08	COMBINED FUEL A	0.30	3.5	69.3	20.0
1975	DEC	19	23:36	24:00	COMBINED FUEL A	0.30	0.4	8.0	20.0
1975	DEC	20	0:00	0:30	COMBINED FUEL A	0.30	0.5	10.0	20.0
1975	DEC	30	13:25	14:47	COMBINED FUEL A	0.30	1.4	27.3	20.0
1976	JAN	21	4:17	13:04	COMBINED FUEL A	0.26	8.8	175.7	20.0
1976	JAN	25	18:06	18:51	COMBINED FUEL A	0.26	0.8	15.0	20.0
1976	JAN	27	9:49	11:15	COMBINED FUEL A	0.26	1.4	28.7	20.0
1976	FEB	5	8:08	10:49	COMBINED FUEL A	0.26	2.7		
1976	FEB	5	17:10	21:52	COMBINED FUEL A	0.26	4.7	147.7	20.0
1976	MAR	7	2:12	8:11	COMBINED FUEL A	0.26	6.0	119.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	FEB	4	8:25	11:09	COMBINED FUEL A	0.30	2.7	54.7	20.0
1977	APR	11	13:01	13:41	COMBINED FUEL A	0.30	0.7	13.3	20.0
1977	APR	12	11:34	15:18	COMBINED FUEL A	0.30	3.7	74.7	20.0
1977	APR	13	8:07	15:27	COMBINED FUEL A	0.30	7.3	146.7	20.0
1977	APR	15	13:56	15:30	COMBINED FUEL A	0.30	1.6	31.3	20.0
1977	APR	18	12:08	13:22	COMBINED FUEL A	0.30	1.2	24.7	20.0
1977	APR	19	7:55	14:54	COMBINED FUEL A	0.30	7.0	139.7	20.0
1977	APR	20	9:00	9:50	COMBINED FUEL A	0.30	0.8	16.7	20.0
1977	APR	21	10:30	11:02	COMBINED FUEL A	0.30	0.5	10.7	20.0
1977	APR	22	9:00	15:11	COMBINED FUEL A	0.30	6.2	123.7	20.0
1977	APR	27	14:20	15:30	COMBINED FUEL A	0.30	1.2	23.3	20.0
1977	APR	28	13:13	15:13	COMBINED FUEL A	0.30	2.0	40.0	20.0
1977	MAY	3	10:34	11:02	COMBINED FUEL A	0.30	0.5	9.3	20.0
1977	MAY	6	7:37	14:14	COMBINED FUEL A	0.30	6.6	132.3	20.0
1977	MAY	27	15:00	15:43	COMBINED FUEL A	0.30	0.7	14.3	20.0
1977	JUN	2	12:41	14:07	COMBINED FUEL A	0.30	1.4	28.7	20.0
1977	JUN	6	10:12	12:05	COMBINED FUEL A	0.30	1.9	37.7	20.0
1977	JUN	16	9:14	10:13	COMBINED FUEL A	0.30	1.0	19.7	20.0
1977	JUL	1	8:52	12:19	COMBINED FUEL A	0.30	3.4		
1977	JUL	1	12:34	13:03	COMBINED FUEL A	0.30	0.5	78.7	20.0
1977	JUL	11	9:34	9:46	COMBINED FUEL A	0.30	0.2	4.0	20.0
1977	JUL	15	10:45	15:34	COMBINED FUEL A	0.30	4.8	96.3	20.0
1977	JUL	16	21:36	24:00	COMBINED FUEL A	0.30	2.4	48.0	20.0
1977	JUL	17	0:00	1:18	COMBINED FUEL A	0.30	1.3		
1977	JUL	17	23:12	24:00	COMBINED FUEL A	0.30	0.8	42.0	20.0
1977	JUL	18	0:00	0:05	COMBINED FUEL A	0.30	0.1		
1977	JUL	18	8:47	22:34	COMBINED FUEL A	0.30	13.8	277.3	20.0
1977	JUL	21	12:40	17:59	COMBINED FUEL A	0.30	5.3	106.3	20.0
1977	JUL	22	9:44	18:24	COMBINED FUEL A	0.30	8.7	173.3	20.0
1977	JUL	25	10:15	18:13	COMBINED FUEL A	0.30	8.0	159.3	20.0
1977	JUL	26	9:19	14:47	COMBINED FUEL A	0.30	5.5		
1977	JUL	26	15:02	19:41	COMBINED FUEL A	0.30	4.6		
1977	JUL	26	20:22	21:24	COMBINED FUEL A	0.30	1.0	223.0	20.0
1977	JUL	27	9:04	12:03	COMBINED FUEL A	0.30	3.0	59.7	20.0
1977	JUL	29	13:32	18:30	COMBINED FUEL A	0.30	5.0	99.3	20.0
1977	AUG	3	17:28	18:55	COMBINED FUEL A	0.30	1.4	29.0	20.0
1977	AUG	5	15:20	15:42	COMBINED FUEL A	0.30	0.4		
1977	AUG	5	16:05	16:12	COMBINED FUEL A	0.30	0.1	9.7	20.0
1977	AUG	9	15:37	18:32	COMBINED FUEL A	0.30	2.9	58.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3C

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERICD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	AUG	16	13:10	13:20	COMBINED FUEL A	0.30	0.2		
1977	AUG	16	13:52	14:15	COMBINED FUEL A	0.30	0.4	11.0	20.0
1977	AUG	19	8:50	17:05	COMBINED FUEL A	0.30	8.3	165.0	20.0
1977	AUG	25	8:06	8:52	COMBINED FUEL A	0.30	0.8	15.3	20.0
1977	SEP	7	14:47	21:55	COMBINED FUEL A	0.30	7.1	142.7	20.0
1977	SEP	10	6:04	8:03	COMBINED FUEL A	0.30	2.0	39.7	20.0
1977	SEP	19	9:04	12:38	COMBINED FUEL A	0.29	3.6	71.3	20.0
1977	SEP	29	11:16	13:00	COMBINED FUEL A	0.29	1.7		
1977	SEP	29	14:02	16:18	COMBINED FUEL A	0.29	2.3	80.0	20.0
1977	OCT	3	20:44	21:51	COMBINED FUEL A	0.29	1.1	22.3	20.0
1977	OCT	4	18:48	21:11	COMBINED FUEL A	0.29	2.4	47.7	20.0
1977	OCT	7	12:57	16:55	COMBINED FUEL A	0.29	4.0	79.3	20.0
1977	OCT	10	8:28	10:20	COMBINED FUEL A	0.29	1.9	37.3	20.0
1977	OCT	11	11:39	12:51	COMBINED FUEL A	0.29	1.2		
1977	OCT	11	15:33	16:27	COMBINED FUEL A	0.29	0.9	42.0	20.0
1977	OCT	17	8:39	13:05	COMBINED FUEL A	0.29	4.4	88.7	20.0
1977	OCT	19	13:32	15:45	COMBINED FUEL A	0.29	2.2	44.3	20.0
1977	OCT	20	18:37	18:49	COMBINED FUEL A	0.29	0.2	4.0	20.0
1977	OCT	25	10:43	11:07	COMBINED FUEL A	0.29	0.4		
1977	OCT	25	11:30	11:57	COMBINED FUEL A	0.29	0.4		
1977	OCT	25	12:49	13:21	COMBINED FUEL A	0.29	0.5		
1977	OCT	25	13:40	14:00	COMBINED FUEL A	0.29	0.3	34.3	20.0
1977	OCT	26	9:15	11:18	COMBINED FUEL A	0.29	2.0	41.0	20.0
1977	OCT	31	17:49	19:45	COMBINED FUEL A	0.29	1.9	38.7	20.0
1977	NOV	1	17:23	19:34	COMBINED FUEL A	0.29	2.2	43.7	20.0
1977	NOV	3	12:40	14:38	COMBINED FUEL A	0.29	2.0		
1977	NOV	3	17:20	18:27	COMBINED FUEL A	0.29	1.1	61.7	20.0
1977	NOV	9	17:43	18:36	COMBINED FUEL A	0.29	0.9	17.7	20.0
1977	NOV	30	8:16	21:42	COMBINED FUEL A	0.29	13.4	268.7	20.0
1977	DEC	4	16:48	19:05	COMBINED FUEL A	0.29	2.3	45.7	20.0
1977	DEC	19	17:24	18:50	COMBINED FUEL A	0.29	1.4	28.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	3	9:13	11:39	COMBINED FUEL A	0.30	2.4		
1975	JAN	3	14:10	14:40	COMBINED FUEL A	0.30	0.5	58.7	20.0
1975	JAN	17	14:50	15:30	COMBINED FUEL A	0.30	0.7	13.3	20.0
1975	JAN	21	13:44	14:15	COMBINED FUEL A	0.30	0.5	10.3	20.0
1975	JAN	22	13:00	14:11	COMBINED FUEL A	0.30	1.2		
1975	JAN	22	15:00	16:50	COMBINED FUEL A	0.30	1.8	60.3	20.0
1975	JAN	27	9:48	10:58	COMBINED FUEL A	0.30	1.2	23.3	20.0
1975	JAN	30	17:31	18:06	COMBINED FUEL A	0.30	0.6		
1975	JAN	30	19:05	19:39	COMBINED FUEL A	0.30	0.6	23.0	20.0
1975	FEB	8	8:49	11:52	COMBINED FUEL A	0.30	3.0	61.0	20.0
1975	MAR	21	0:56	1:46	COMBINED FUEL A	0.30	0.8		
1975	MAR	21	12:26	15:31	COMBINED FUEL A	0.30	3.1	78.3	20.0
1975	MAR	27	8:28	12:02	COMBINED FUEL A	0.30	3.6	71.3	20.0
1975	MAR	29	19:19	21:02	COMBINED FUEL A	0.30	1.7	34.3	20.0
1975	APR	4	14:36	16:32	COMBINED FUEL A	0.30	1.9	38.7	20.0
1975	APR	8	9:56	14:36	COMBINED FUEL A	0.30	4.7	93.3	20.0
1975	APR	16	19:36	22:59	COMBINED FUEL A	0.30	3.4	67.7	20.0
1975	APR	22	8:50	14:20	COMBINED FUEL A	0.30	5.5		
1975	APR	22	20:03	21:12	COMBINED FUEL A	0.30	1.1	133.0	20.0
1975	APR	23	8:57	13:58	COMBINED FUEL A	0.30	5.0	100.3	20.0
1975	APR	29	19:17	19:18	COMBINED FUEL A	0.30	0.0	0.3	20.0
1975	MAY	27	15:31	17:21	COMBINED FUEL A	0.30	1.8	36.7	20.0
1975	MAY	28	9:03	9:32	COMBINED FUEL A	0.30	0.5	9.7	20.0
1975	JUN	17	8:07	8:10	COMBINED FUEL A	0.30	0.0	1.0	20.0
1975	JUN	19	8:15	15:24	COMBINED FUEL A	0.30	7.1		
1975	JUN	19	19:50	21:38	COMBINED FUEL A	0.30	1.8	179.0	20.0
1975	JUN	25	14:55	15:50	COMBINED FUEL A	0.30	0.9	18.3	20.0
1975	JUN	26	13:15	14:30	COMBINED FUEL A	0.30	1.3	25.0	20.0
1975	JUN	30	9:30	14:55	COMBINED FUEL A	0.30	5.4	108.3	20.0
1975	JUL	2	11:01	15:45	COMBINED FUEL A	0.30	4.7	94.7	20.0
1975	JUL	3	8:02	11:20	COMBINED FUEL A	0.30	3.3		
1975	JUL	3	12:33	14:20	COMBINED FUEL A	0.30	1.8	101.7	20.0
1975	JUL	7	9:20	10:53	COMBINED FUEL A	0.30	1.5	31.0	20.0
1975	JUL	11	13:08	13:50	COMBINED FUEL A	0.30	0.7	14.0	20.0
1975	JUL	14	11:26	12:45	COMBINED FUEL A	0.30	1.3	26.3	20.0
1975	JUL	22	10:20	15:00	COMBINED FUEL A	0.30	4.7	93.3	20.0
1975	JUL	26	11:56	15:00	COMBINED FUEL A	0.30	3.1		
1975	JUL	26	21:01	21:05	COMBINED FUEL A	0.30	0.1	62.7	20.0
1975	JUL	28	10:18	16:18	COMBINED FUEL A	0.30	6.0	120.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	AUG	2	15:47	18:28	COMBINED FUEL A	0.30	2.7	53.7	20.0
1975	AUG	4	12:56	18:05	COMBINED FUEL A	0.30	5.1	103.0	20.0
1975	AUG	6	11:52	18:51	COMBINED FUEL A	0.30	7.0	139.7	20.0
1975	AUG	11	7:33	8:46	COMBINED FUEL A	0.30	1.2	24.3	20.0
1975	AUG	12	7:12	8:31	COMBINED FUEL A	0.30	1.3	26.3	20.0
1975	AUG	24	10:55	15:17	COMBINED FUEL A	0.30	4.4	87.3	20.0
1975	SEP	3	14:05	16:12	COMBINED FUEL A	0.30	2.1	42.3	20.0
1975	SEP	4	13:22	20:54	COMBINED FUEL A	0.30	7.5	150.7	20.0
1975	SEP	6	9:21	12:05	COMBINED FUEL A	0.30	2.7		
1975	SEP	6	22:25	23:01	COMBINED FUEL A	0.30	0.6	66.7	20.0
1975	SEP	8	18:19	20:30	COMBINED FUEL A	0.30	2.2	43.7	20.0
1975	SEP	9	13:55	14:33	COMBINED FUEL A	0.30	0.6	12.7	20.0
1975	SEP	15	9:45	12:19	COMBINED FUEL A	0.30	2.6	51.3	20.0
1975	SEP	16	10:40	23:33	COMBINED FUEL A	0.30	12.9	257.7	20.0
1975	SEP	17	10:06	11:20	COMBINED FUEL A	0.30	1.2		
1975	SEP	17	13:02	20:28	COMBINED FUEL A	0.30	7.4	173.3	20.0
1975	SEP	18	13:20	18:24	COMBINED FUEL A	0.30	5.1	101.3	20.0
1975	SEP	19	11:16	16:05	COMBINED FUEL A	0.30	4.8	96.3	20.0
1975	SEP	23	10:33	11:56	COMBINED FUEL A	0.30	1.4		
1975	SEP	23	12:35	20:12	COMBINED FUEL A	0.30	7.6	180.0	20.0
1975	SEP	24	19:14	20:11	COMBINED FUEL A	0.30	1.0	19.0	20.0
1975	SEP	25	9:34	12:15	COMBINED FUEL A	0.30	2.7	53.7	20.0
1975	OCT	2	18:54	21:20	COMBINED FUEL A	0.30	2.4	48.7	20.0
1975	OCT	3	13:32	17:43	COMBINED FUEL A	0.30	4.2	83.7	20.0
1975	OCT	10	8:59	15:37	COMBINED FUEL A	0.30	6.6	132.7	20.0
1975	OCT	12	19:05	21:07	COMBINED FUEL A	0.30	2.0	40.7	20.0
1975	OCT	20	10:25	11:33	COMBINED FUEL A	0.30	1.1		
1975	OCT	20	12:40	14:20	COMBINED FUEL A	0.30	1.7	56.0	20.0
1975	NOV	14	16:55	19:44	COMBINED FUEL A	0.30	2.8	56.3	20.0
1975	NOV	17	7:48	7:52	COMBINED FUEL A	0.30	0.1		
1975	NOV	17	8:08	12:45	COMBINED FUEL A	0.30	4.6	93.7	20.0
1975	NOV	20	8:05	12:07	COMBINED FUEL A	0.30	4.0		
1975	NOV	20	16:54	19:33	COMBINED FUEL A	0.30	2.6	133.7	20.0
1975	NOV	21	8:52	9:07	COMBINED FUEL A	0.30	0.3		
1975	NOV	21	16:54	19:33	COMBINED FUEL A	0.30	2.6	58.0	20.0
1975	NOV	29	17:07	19:47	COMBINED FUEL A	0.30	2.7	53.3	20.0
1975	DEC	3	16:30	19:57	COMBINED FUEL A	0.30	3.4	69.0	20.0
1975	DEC	5	7:48	11:26	COMBINED FUEL A	0.30	3.6	72.7	20.0
1975	DEC	6	16:47	19:31	COMBINED FUEL A	0.30	2.7	54.7	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 30

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	DEC	10	17:10	21:15	COMBINED FUEL A	0.30	4.1	81.7	20.0
1975	DEC	13	10:27	12:32	COMBINED FUEL A	0.30	2.1	41.7	20.0
1975	DEC	16	13:40	17:08	COMBINED FUEL A	0.30	3.5	69.3	20.0
1975	DEC	19	23:36	24:00	COMBINED FUEL A	0.30	0.4	8.0	20.0
1975	DEC	20	0:00	0:30	COMBINED FUEL A	0.30	0.5	10.0	20.0
1975	DEC	26	17:05	19:20	COMBINED FUEL A	0.30	2.3	45.0	20.0
1975	DEC	30	17:34	19:56	COMBINED FUEL A	0.30	2.4	47.3	20.0
1976	JAN	10	17:51	18:29	COMBINED FUEL A	0.26	0.6	12.7	20.0
1976	JAN	21	4:17	13:38	COMBINED FUEL A	0.26	9.3	187.0	20.0
1976	JAN	25	17:34	20:26	COMBINED FUEL A	0.26	2.9	57.3	20.0
1976	JAN	26	7:19	9:09	COMBINED FUEL A	0.26	1.8	36.7	20.0
1976	FEB	3	8:15	10:56	COMBINED FUEL A	0.26	2.7	53.7	20.0
1976	FEB	4	9:19	11:12	COMBINED FUEL A	0.26	1.9	37.7	20.0
1976	FEB	5	8:08	10:54	COMBINED FUEL A	0.26	2.8		
1976	FEB	5	17:10	22:03	COMBINED FUEL A	0.26	4.9	153.0	20.0
1976	FEB	6	15:25	16:12	COMBINED FUEL A	0.26	0.8	15.7	20.0
1976	FEB	29	12:55	12:59	COMBINED FUEL A	0.26	0.1	1.3	20.0
1976	MAR	4	8:39	9:26	COMBINED FUEL A	0.26	0.8		
1976	MAR	4	10:45	11:26	COMBINED FUEL A	0.26	0.7	29.3	20.0
1976	MAR	7	2:12	3:15	COMBINED FUEL A	0.26	1.0	21.0	20.0
1976	MAR	26	12:57	13:31	COMBINED FUEL A	0.26	0.6		
1976	MAR	26	13:45	14:47	COMBINED FUEL A	0.26	1.0	32.0	20.0
1976	APR	6	18:52	19:27	COMBINED FUEL A	0.26	0.6	11.7	20.0
1976	APR	7	3:28	4:01	COMBINED FUEL A	0.26	0.6	11.0	20.0
1976	APR	15	18:12	20:35	COMBINED FUEL A	0.26	2.4	47.7	20.0
1976	APR	18	18:54	21:07	COMBINED FUEL A	0.26	2.2	44.3	20.0
1976	MAY	4	11:32	11:52	COMBINED FUEL A	0.26	0.3	6.7	20.0
1976	MAY	11	9:00	13:50	COMBINED FUEL A	0.26	4.8		
1976	MAY	11	20:17	21:03	COMBINED FUEL A	0.26	0.8	112.0	20.0
1976	MAY	12	12:10	17:21	COMBINED FUEL A	0.26	5.2		
1976	MAY	12	20:14	20:34	COMBINED FUEL A	0.26	0.3	110.3	20.0
1976	MAY	22	16:20	16:55	COMBINED FUEL A	0.26	0.6	11.7	20.0
1976	JUN	5	9:07	11:49	COMBINED FUEL A	0.26	2.7	54.0	20.0
1976	JUN	7	9:10	10:06	COMBINED FUEL A	0.26	0.9	18.7	20.0
1976	JUN	8	14:41	15:30	COMBINED FUEL A	0.26	0.8	16.3	20.0
1976	JUN	12	20:30	21:42	COMBINED FUEL A	0.26	1.2	24.0	20.0
1976	JUN	14	14:04	14:33	COMBINED FUEL A	0.26	0.5	9.7	20.0
1976	JUN	15	13:10	17:47	COMBINED FUEL A	0.26	4.6	92.3	20.0
1976	JUN	22	8:45	13:00	COMBINED FUEL A	0.26	4.3	85.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JUN	23	14:00	15:12	COMBINED FUEL A	0.26	1.2		
1976	JUN	23	15:12	16:10	COMBINED FUEL A	0.26	1.0	43.3	20.0
1976	JUN	24	11:17	16:12	COMBINED FUEL A	0.26	4.9	98.3	20.0
1976	JUN	25	12:47	16:00	COMBINED FUEL A	0.26	3.2	64.3	20.0
1976	JUN	26	10:35	18:05	COMBINED FUEL A	0.26	7.5	150.0	20.0
1976	JUN	27	16:41	18:04	COMBINED FUEL A	0.26	1.4	27.7	20.0
1976	JUN	28	10:51	17:35	COMBINED FUEL A	0.26	6.7	134.7	20.0
1976	JUN	30	12:38	14:34	COMBINED FUEL A	0.26	1.9	38.7	20.0
1976	JUL	4	16:49	16:59	COMBINED FUEL A	0.26	0.2	3.3	20.0
1976	JUL	6	11:13	13:59	COMBINED FUEL A	0.26	2.8	55.3	20.0
1976	JUL	7	13:38	17:10	COMBINED FUEL A	0.26	3.5	70.7	20.0
1976	JUL	8	12:49	16:04	COMBINED FUEL A	0.26	3.3	65.0	20.0
1976	JUL	27	12:26	15:11	COMBINED FUEL A	0.26	2.8	55.0	20.0
1976	JUL	28	10:10	15:26	COMBINED FUEL A	0.26	5.3	105.3	20.0
1976	JUL	30	10:37	11:34	COMBINED FUEL A	0.26	1.0	19.0	20.0
1976	AUG	1	8:35	10:33	COMBINED FUEL A	0.26	2.0	39.3	20.0
1976	AUG	2	10:19	12:34	COMBINED FUEL A	0.26	2.3	45.0	20.0
1976	AUG	4	11:27	14:44	COMBINED FUEL A	0.26	3.3	65.7	20.0
1976	AUG	10	19:29	19:43	COMBINED FUEL A	0.26	0.2	4.7	20.0
1976	AUG	25	10:00	11:45	COMBINED FUEL A	0.26	1.8	35.0	20.0
1976	AUG	27	14:50	16:25	COMBINED FUEL A	0.26	1.6	31.7	20.0
1976	AUG	29	11:33	12:55	COMBINED FUEL A	0.26	1.4		
1976	AUG	29	19:57	20:23	COMBINED FUEL A	0.26	0.4	36.0	20.0
1976	AUG	30	9:53	15:25	COMBINED FUEL A	0.26	5.5	110.7	20.0
1976	SEP	4	14:20	16:43	COMBINED FUEL A	0.26	2.4	47.7	20.0
1976	SEP	10	0:54	1:43	COMBINED FUEL A	0.26	0.8	16.3	20.0
1976	SEP	12	19:20	22:29	COMBINED FUEL A	0.26	3.1	63.0	20.0
1976	SEP	24	10:08	12:02	COMBINED FUEL A	0.26	1.9	38.0	20.0
1976	SEP	25	19:56	22:10	COMBINED FUEL A	0.26	2.2	44.7	20.0
1976	OCT	5	12:44	14:09	COMBINED FUEL A	0.26	1.4	28.3	20.0
1976	OCT	7	18:43	20:15	COMBINED FUEL A	0.26	1.5	30.7	20.0
1976	OCT	9	18:38	20:34	COMBINED FUEL A	0.26	1.9	38.7	20.0
1976	OCT	17	19:48	21:38	COMBINED FUEL A	0.26	1.8	36.7	20.0
1976	DEC	6	13:00	15:48	COMBINED FUEL A	0.26	2.8	56.0	20.0
1976	DEC	29	10:23	13:45	COMBINED FUEL A	0.26	3.4	67.3	20.0
1976	DEC	30	17:26	21:47	COMBINED FUEL A	0.26	4.3	87.0	20.0
1977	JAN	6	16:39	19:32	COMBINED FUEL A	0.29	2.9	57.7	20.0
1977	JAN	7	10:41	10:50	COMBINED FUEL A	0.29	0.1		
1977	JAN	7	13:15	13:35	COMBINED FUEL A	0.29	0.3		

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JAN	7	17:36	18:44	COMBINED FUEL A	0.29	1.1	32.3	20.0
1977	FEB	12	16:24	19:41	COMBINED FUEL A	0.29	3.3	65.7	20.0
1977	FEB	23	11:25	13:30	COMBINED FUEL A	0.29	2.1	41.7	20.0
1977	MAR	8	9:28	9:48	COMBINED FUEL A	0.29	0.3	6.7	20.0
1977	MAR	9	10:47	11:51	COMBINED FUEL A	0.29	1.1	21.3	20.0
1977	APR	3	10:34	11:02	COMBINED FUEL A	0.29	0.5	9.3	20.0
1977	APR	4	16:07	18:41	COMBINED FUEL A	0.29	2.6	51.3	20.0
1977	APR	5	10:47	11:26	COMBINED FUEL A	0.29	0.7	13.0	20.0
1977	APR	6	7:34	14:03	COMBINED FUEL A	0.29	6.5	129.7	20.0
1977	APR	14	14:42	15:30	COMBINED FUEL A	0.29	0.8	16.0	20.0
1977	APR	17	12:13	15:00	COMBINED FUEL A	0.29	2.8	55.7	20.0
1977	APR	18	8:27	9:02	COMBINED FUEL A	0.29	0.6		
1977	APR	18	14:53	15:33	COMBINED FUEL A	0.29	0.7	25.0	20.0
1977	APR	25	10:12	14:55	COMBINED FUEL A	0.29	4.7	94.3	20.0
1977	APR	30	19:46	19:51	COMBINED FUEL A	0.29	0.1	1.7	20.0
1977	JUN	2	13:26	14:44	COMBINED FUEL A	0.29	1.3	26.0	20.0
1977	JUL	6	13:51	15:52	COMBINED FUEL A	0.29	2.0	40.3	20.0
1977	JUL	7	9:05	9:32	COMBINED FUEL A	0.29	0.4		
1977	JUL	7	10:00	13:57	COMBINED FUEL A	0.29	3.9		
1977	JUL	7	14:21	14:28	COMBINED FUEL A	0.29	0.1	90.3	20.0
1977	JUL	13	14:13	14:30	COMBINED FUEL A	0.29	0.3	5.7	20.0
1977	JUL	14	12:40	13:26	COMBINED FUEL A	0.29	0.8		
1977	JUL	14	14:58	15:20	COMBINED FUEL A	0.29	0.4	22.7	20.0
1977	JUL	15	11:05	15:27	COMBINED FUEL A	0.29	4.4		
1977	JUL	15	15:53	16:55	COMBINED FUEL A	0.29	1.0	108.0	20.0
1977	JUL	16	10:32	17:29	COMBINED FUEL A	0.29	6.9		
1977	JUL	16	21:36	24:00	COMBINED FUEL A	0.29	2.4	187.0	20.0
1977	JUL	17	0:00	1:25	COMBINED FUEL A	0.29	1.4		
1977	JUL	17	23:12	24:00	COMBINED FUEL A	0.29	0.8	44.3	20.0
1977	JUL	18	0:00	0:05	COMBINED FUEL A	0.29	0.1		
1977	JUL	18	8:42	22:34	COMBINED FUEL A	0.29	13.9	279.0	20.0
1977	JUL	19	10:28	15:39	COMBINED FUEL A	0.29	5.2	103.7	20.0
1977	JUL	20	15:33	15:36	COMBINED FUEL A	0.29	0.0	1.0	20.0
1977	JUL	22	9:25	15:38	COMBINED FUEL A	0.29	6.2	124.3	20.0
1977	JUL	25	9:35	21:16	COMBINED FUEL A	0.29	11.7	233.7	20.0
1977	JUL	26	9:13	14:47	COMBINED FUEL A	0.29	5.6		
1977	JUL	26	15:02	19:31	COMBINED FUEL A	0.29	4.5		
1977	JUL	26	20:22	21:34	COMBINED FUEL A	0.29	1.2	225.0	20.0
1977	JUL	27	8:48	16:25	COMBINED FUEL A	0.29	7.6	152.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JUL	28	9:55	10:42	COMBINED FUEL A	0.29	0.8		
1977	JUL	28	12:15	16:25	COMBINED FUEL A	0.29	4.2	99.0	20.0
1977	JUL	29	13:32	17:30	COMBINED FUEL A	0.29	4.0	79.3	20.0
1977	AUG	3	11:33	18:50	COMBINED FUEL A	0.29	7.3	145.7	20.0
1977	AUG	5	15:20	15:42	COMBINED FUEL A	0.29	0.4		
1977	AUG	5	16:05	16:12	COMBINED FUEL A	0.29	0.1	9.7	20.0
1977	AUG	9	15:37	18:32	COMBINED FUEL A	0.29	2.9	58.3	20.0
1977	AUG	19	8:28	17:17	COMBINED FUEL A	0.29	8.8	176.3	20.0
1977	AUG	20	11:42	18:10	COMBINED FUEL A	0.29	6.5	129.3	20.0
1977	AUG	25	8:06	8:52	COMBINED FUEL A	0.29	0.8	15.3	20.0
1977	AUG	29	13:35	14:20	COMBINED FUEL A	0.29	0.8		
1977	AUG	29	14:21	14:35	COMBINED FUEL A	0.29	0.2	19.7	20.0
1977	SEP	4	19:43	20:33	COMBINED FUEL A	0.29	0.8	16.7	20.0
1977	SEP	7	13:00	20:25	COMBINED FUEL A	0.29	7.4	148.3	20.0
1977	SEP	10	6:04	8:10	COMBINED FUEL A	0.29	2.1	42.0	20.0
1977	SEP	19	9:04	12:38	COMBINED FUEL A	0.29	3.6	71.3	20.0
1977	OCT	3	18:55	20:05	COMBINED FUEL A	0.29	1.2		
1977	OCT	3	20:44	21:51	COMBINED FUEL A	0.29	1.1	45.7	20.0
1977	OCT	4	18:36	20:58	COMBINED FUEL A	0.29	2.4	47.3	20.0
1977	OCT	6	18:40	22:22	COMBINED FUEL A	0.29	3.7	74.0	20.0
1977	OCT	7	9:56	16:56	COMBINED FUEL A	0.29	7.0		
1977	OCT	7	18:35	19:35	COMBINED FUEL A	0.29	1.0	160.0	20.0
1977	OCT	10	8:28	10:20	COMBINED FUEL A	0.29	1.9	37.3	20.0
1977	OCT	12	10:14	10:57	COMBINED FUEL A	0.29	0.7		
1977	OCT	12	13:15	14:10	COMBINED FUEL A	0.29	0.9		
1977	OCT	12	14:25	14:57	COMBINED FUEL A	0.29	0.5	43.3	20.0
1977	OCT	15	18:36	19:22	COMBINED FUEL A	0.29	0.8	15.3	20.0
1977	OCT	16	18:26	21:01	COMBINED FUEL A	0.29	2.6	51.7	20.0
1977	OCT	17	8:39	12:45	COMBINED FUEL A	0.29	4.1	82.0	20.0
1977	OCT	20	18:28	19:14	COMBINED FUEL A	0.29	0.8	15.3	20.0
1977	OCT	21	9:24	11:03	COMBINED FUEL A	0.29	1.6		
1977	OCT	21	14:24	16:45	COMBINED FUEL A	0.29	2.3	80.0	20.0
1977	OCT	25	11:22	11:44	COMBINED FUEL A	0.29	0.4	7.3	20.0
1977	OCT	31	17:49	19:18	COMBINED FUEL A	0.29	1.5	29.7	20.0
1977	NOV	1	17:15	19:15	COMBINED FUEL A	0.29	2.0	40.0	20.0
1977	NOV	3	17:21	19:10	COMBINED FUEL A	0.29	1.8	36.3	20.0
1977	NOV	5	17:27	18:57	COMBINED FUEL A	0.29	1.5	30.0	20.0
1977	NOV	8	17:13	19:29	COMBINED FUEL A	0.29	2.3	45.3	20.0
1977	NOV	9	17:19	17:26	COMBINED FUEL A	0.29	0.1		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E KEARNY STATION

UNIT NUMBER: 3D

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	NOV	9	18:50	19:03	COMBINED FUEL A	0.29	0.2		
1977	NOV	9	21:09	21:20	COMBINED FUEL A	0.29	0.2		
1977	NOV	9	22:13	22:27	COMBINED FUEL A	0.29	0.2	15.0	20.0
1977	NOV	10	10:02	10:10	COMBINED FUEL A	0.29	0.1		
1977	NOV	10	11:34	12:01	COMBINED FUEL A	0.29	0.5		
1977	NOV	10	14:55	15:23	COMBINED FUEL A	0.29	0.5	21.0	20.0
1977	NOV	17	17:16	18:08	COMBINED FUEL A	0.29	0.9	17.3	20.0
1977	NOV	20	17:10	19:47	COMBINED FUEL A	0.29	2.6	52.3	20.0
1977	NOV	21	17:09	19:45	COMBINED FUEL A	0.29	2.6	52.0	20.0
1977	NOV	22	16:52	19:29	COMBINED FUEL A	0.29	2.6	52.3	20.0
1977	NOV	28	17:21	18:07	COMBINED FUEL A	0.29	0.8	15.3	20.0
1977	NOV	29	14:14	14:35	COMBINED FUEL A	0.29	0.3		
1977	NOV	29	16:53	18:21	COMBINED FUEL A	0.29	1.5	36.3	20.0
1977	NOV	30	7:40	21:37	COMBINED FUEL A	0.29	13.9	279.0	20.0
1977	DEC	4	16:48	19:11	COMBINED FUEL A	0.29	2.4	47.7	20.0
1977	DEC	6	9:01	13:29	COMBINED FUEL A	0.29	4.5		
1977	DEC	6	17:19	18:49	COMBINED FUEL A	0.29	1.5	119.3	20.0
1977	DEC	7	17:41	20:30	COMBINED FUEL A	0.29	2.8	56.3	20.0
1977	DEC	16	17:01	19:27	COMBINED FUEL A	0.29	2.4	48.7	20.0
1977	DEC	19	17:02	18:15	COMBINED FUEL A	0.29	1.2	24.3	20.0
1977	DEC	20	17:19	18:52	COMBINED FUEL A	0.29	1.5	31.0	20.0
1977	DEC	21	15:56	19:29	COMBINED FUEL A	0.29	3.5	71.0	20.0
1977	DEC	22	17:05	19:02	COMBINED FUEL A	0.29	1.9	39.0	20.0
1977	DEC	27	17:15	17:27	COMBINED FUEL A	0.29	0.2	4.0	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	2	8:09	14:07	COMBINED FUEL B	0.30	6.0	137.2	23.0
1975	JAN	3	12:45	13:11	COMBINED FUEL B	0.30	0.4	10.0	23.0
1975	JAN	4	9:11	12:03	COMBINED FUEL B	0.30	2.9	65.9	23.0
1975	JAN	8	7:54	16:13	COMBINED FUEL B	0.30	8.3		
1975	JAN	8	17:09	19:17	COMBINED FUEL B	0.30	2.1	240.3	23.0
1975	JAN	9	10:30	11:24	COMBINED FUEL B	0.30	0.9	20.7	23.0
1975	JAN	11	12:31	14:21	COMBINED FUEL B	0.30	1.8	42.2	23.0
1975	JAN	12	20:45	22:19	COMBINED FUEL B	0.30	1.6	36.0	23.0
1975	JAN	16	8:53	9:13	COMBINED FUEL B	0.30	0.3	7.7	23.0
1975	JAN	17	11:45	11:53	COMBINED FUEL B	0.30	0.1	3.1	23.0
1975	JAN	23	8:27	9:08	COMBINED FUEL B	0.30	0.7	15.7	23.0
1975	JAN	24	9:30	10:25	COMBINED FUEL B	0.30	0.9		
1975	JAN	24	10:45	11:00	COMBINED FUEL B	0.30	0.3	26.8	23.0
1975	FEB	12	11:30	11:55	COMBINED FUEL B	0.30	0.4	9.6	23.0
1975	FEB	13	8:05	9:45	COMBINED FUEL B	0.30	1.7		
1975	FEB	13	11:10	11:20	COMBINED FUEL B	0.30	0.2		
1975	FEB	13	11:40	12:05	COMBINED FUEL B	0.30	0.4		
1975	FEB	13	14:37	14:41	COMBINED FUEL B	0.30	0.1	53.3	23.0
1975	FEB	14	7:55	9:35	COMBINED FUEL B	0.30	1.7	38.3	23.0
1975	FEB	17	17:42	20:35	COMBINED FUEL B	0.30	2.9	66.3	23.0
1975	FEB	26	8:39	10:40	COMBINED FUEL B	0.30	2.0		
1975	FEB	26	13:57	15:25	COMBINED FUEL B	0.30	1.5		
1975	FEB	26	18:29	20:34	COMBINED FUEL B	0.30	2.1	128.0	23.0
1975	MAR	6	10:09	10:17	COMBINED FUEL B	0.30	0.1	3.1	23.0
1975	MAR	8	9:41	12:28	COMBINED FUEL B	0.30	2.8	64.0	23.0
1975	MAR	9	19:07	20:40	COMBINED FUEL B	0.30	1.5	35.6	23.0
1975	MAR	10	8:06	16:10	COMBINED FUEL B	0.30	8.1		
1975	MAR	10	18:12	20:20	COMBINED FUEL B	0.30	2.1	234.6	23.0
1975	MAR	20	9:12	10:30	COMBINED FUEL B	0.30	1.3	29.9	23.0
1975	MAR	21	6:16	6:31	COMBINED FUEL B	0.30	0.3	5.8	23.0
1975	MAR	22	8:54	12:57	COMBINED FUEL B	0.30	4.0	93.1	23.0
1975	MAR	31	10:18	16:18	COMBINED FUEL B	0.30	6.0	138.0	23.0
1975	APR	1	10:05	10:16	COMBINED FUEL B	0.30	0.2		
1975	APR	1	11:00	11:09	COMBINED FUEL B	0.30	0.1	7.7	23.0
1975	APR	4	14:37	14:43	COMBINED FUEL B	0.30	0.1		
1975	APR	4	15:41	15:52	COMBINED FUEL B	0.30	0.2	6.5	23.0
1975	APR	8	16:52	18:55	COMBINED FUEL B	0.30	2.0	47.1	23.0
1975	APR	9	9:16	11:26	COMBINED FUEL B	0.30	2.2	49.8	23.0
1975	APR	11	7:40	10:05	COMBINED FUEL B	0.30	2.4	55.6	23.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	APR	17	13:04	13:20	COMBINED FUEL B	0.30	0.3		
1975	APR	17	19:16	22:18	COMBINED FUEL B	0.30	3.0	75.9	23.0
1975	APR	21	20:08	21:52	COMBINED FUEL B	0.30	1.7	39.9	23.0
1975	APR	23	14:15	20:55	COMBINED FUEL B	0.30	6.7	153.3	23.0
1975	APR	24	9:48	10:05	COMBINED FUEL B	0.30	0.3	6.5	23.0
1975	APR	26	17:06	17:46	COMBINED FUEL B	0.30	0.7	15.3	23.0
1975	APR	27	20:01	21:14	COMBINED FUEL B	0.30	1.2	28.0	23.0
1975	APR	29	18:04	23:49	COMBINED FUEL B	0.30	5.8	132.3	23.0
1975	APR	30	19:33	20:21	COMBINED FUEL B	0.30	0.8	18.4	23.0
1975	MAY	2	12:05	14:01	COMBINED FUEL B	0.30	1.9	44.5	23.0
1975	MAY	15	12:35	14:15	COMBINED FUEL B	0.30	1.7	38.3	23.0
1975	MAY	20	12:50	13:52	COMBINED FUEL B	0.30	1.0	23.8	23.0
1975	MAY	22	9:03	11:25	COMBINED FUEL B	0.30	2.4	54.4	23.0
1975	MAY	27	9:49	17:20	COMBINED FUEL B	0.30	7.5	172.9	23.0
1975	MAY	28	11:07	14:05	COMBINED FUEL B	0.30	3.0	68.2	23.0
1975	JUN	19	20:21	21:19	COMBINED FUEL B	0.30	1.0	22.2	23.0
1975	JUL	11	9:21	15:53	COMBINED FUEL B	0.30	6.5	150.3	23.0
1975	JUL	23	13:04	14:25	COMBINED FUEL B	0.30	1.3	31.0	23.0
1975	JUL	27	11:38	18:55	COMBINED FUEL B	0.30	7.3		
1975	JUL	27	20:08	22:06	COMBINED FUEL B	0.30	2.0	212.7	23.0
1975	JUL	28	10:27	16:31	COMBINED FUEL B	0.30	6.1	139.5	23.0
1975	JUL	29	10:26	15:31	COMBINED FUEL B	0.30	5.1	116.9	23.0
1975	JUL	30	9:48	10:58	COMBINED FUEL B	0.30	1.2	26.8	23.0
1975	AUG	4	16:51	18:25	COMBINED FUEL B	0.30	1.6		
1975	AUG	4	20:01	21:03	COMBINED FUEL B	0.30	1.0	59.8	23.0
1975	AUG	6	12:14	22:06	COMBINED FUEL B	0.30	9.9	226.9	23.0
1975	AUG	7	12:02	17:47	COMBINED FUEL B	0.30	5.8	132.3	23.0
1975	AUG	15	20:06	21:05	COMBINED FUEL B	0.30	1.0	22.6	23.0
1975	AUG	16	8:43	9:30	COMBINED FUEL B	0.30	0.8	18.0	23.0
1975	AUG	19	2:33	3:58	COMBINED FUEL B	0.30	1.4		
1975	AUG	19	8:37	11:48	COMBINED FUEL B	0.30	3.2		
1975	AUG	19	14:27	17:16	COMBINED FUEL B	0.30	2.8	170.6	23.0
1975	AUG	23	11:45	19:11	COMBINED FUEL B	0.30	7.4	171.0	23.0
1975	SEP	6	9:00	11:03	COMBINED FUEL B	0.30	2.0	41.0	20.0
1975	SEP	8	18:10	19:14	COMBINED FUEL B	0.30	1.1	21.3	20.0
1975	SEP	9	11:13	12:42	COMBINED FUEL B	0.30	1.5	29.7	20.0
1975	SEP	12	10:43	12:18	COMBINED FUEL B	0.30	1.6	31.7	20.0
1975	SEP	15	10:17	15:31	COMBINED FUEL B	0.30	5.2	104.7	20.0
1975	SEP	16	11:09	18:19	COMBINED FUEL B	0.30	7.2	143.3	20.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	SEP	17	10:28	18:45	COMBINED FUEL B	0.30	8.3	165.7	20.0
1975	SEP	18	9:20	21:55	COMBINED FUEL B	0.30	12.6	251.7	20.0
1975	SEP	19	8:26	9:53	COMBINED FUEL B	0.30	1.4		
1975	SEP	19	11:16	17:08	COMBINED FUEL B	0.30	5.9	146.3	20.0
1975	SEP	20	9:38	20:48	COMBINED FUEL B	0.30	11.2	223.3	20.0
1975	SEP	21	18:42	21:45	COMBINED FUEL B	0.30	3.0	61.0	20.0
1975	SEP	22	14:22	20:53	COMBINED FUEL B	0.30	6.5	130.3	20.0
1975	SEP	23	9:37	21:15	COMBINED FUEL B	0.30	11.6	232.7	20.0
1975	SEP	24	13:45	18:24	COMBINED FUEL B	0.30	4.6	93.0	20.0
1975	SEP	29	10:20	12:05	COMBINED FUEL B	0.30	1.8	35.0	20.0
1975	SEP	30	7:24	7:54	COMBINED FUEL B	0.30	0.5		
1975	SEP	30	10:40	11:20	COMBINED FUEL B	0.30	0.7	23.3	20.0
1975	OCT	1	19:10	20:31	COMBINED FUEL B	0.30	1.3	27.0	20.0
1975	OCT	2	18:47	20:28	COMBINED FUEL B	0.30	1.7	33.7	20.0
1975	OCT	3	12:11	14:08	COMBINED FUEL B	0.30	1.9		
1975	OCT	3	14:09	16:14	COMBINED FUEL B	0.30	2.1		
1975	OCT	3	18:59	19:53	COMBINED FUEL B	0.30	0.9	98.7	20.0
1975	OCT	5	18:43	21:02	COMBINED FUEL B	0.30	2.3	46.3	20.0
1975	OCT	22	18:21	19:02	COMBINED FUEL B	0.30	0.7	15.7	23.0
1975	OCT	24	18:26	20:04	COMBINED FUEL B	0.30	1.6	37.6	23.0
1975	OCT	26	17:17	18:48	COMBINED FUEL B	0.30	1.5	34.9	23.0
1975	OCT	30	7:26	10:47	COMBINED FUEL B	0.30	3.3	77.0	23.0
1975	OCT	31	17:07	19:10	COMBINED FUEL B	0.30	2.0	47.1	23.0
1975	NOV	1	17:25	20:11	COMBINED FUEL B	0.30	2.8	63.6	23.0
1975	NOV	6	7:45	10:07	COMBINED FUEL B	0.30	2.4	54.4	23.0
1975	NOV	10	17:21	18:16	COMBINED FUEL B	0.30	0.9	21.1	23.0
1975	NOV	11	10:08	11:08	COMBINED FUEL B	0.30	1.0		
1975	NOV	11	17:10	18:33	COMBINED FUEL B	0.30	1.4	54.8	23.0
1975	NOV	17	7:08	12:34	COMBINED FUEL B	0.30	5.4	125.0	23.0
1975	NOV	19	6:24	8:29	COMBINED FUEL B	0.30	2.1	47.9	23.0
1975	NOV	20	0:42	8:20	COMBINED FUEL B	0.30	7.6		
1975	NOV	20	16:54	18:32	COMBINED FUEL B	0.30	1.6	213.1	23.0
1975	NOV	21	16:48	18:33	COMBINED FUEL B	0.30	1.8	40.3	23.0
1975	NOV	22	16:43	19:42	COMBINED FUEL B	0.30	3.0	68.6	23.0
1975	NOV	28	9:50	12:17	COMBINED FUEL B	0.30	2.4		
1975	NOV	28	17:04	18:45	COMBINED FUEL B	0.30	1.7	95.1	23.0
1975	NOV	29	17:03	21:25	COMBINED FUEL B	0.30	4.4	100.4	23.0
1975	NOV	30	16:40	23:33	COMBINED FUEL B	0.30	6.9	158.3	23.0
1975	DEC	3	17:06	20:39	COMBINED FUEL B	0.30	3.5	81.6	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	DEC	5	10:35	12:02	COMBINED FUEL B	0.30	1.4	33.3	23.0
1975	DEC	6	16:56	19:37	COMBINED FUEL B	0.30	2.7	61.7	23.0
1975	DEC	7	17:03	17:40	COMBINED FUEL B	0.30	0.6	14.2	23.0
1975	DEC	10	16:15	20:26	COMBINED FUEL B	0.30	4.2	96.2	23.0
1975	DEC	11	12:54	15:54	COMBINED FUEL B	0.30	3.0		
1975	DEC	11	17:10	20:14	COMBINED FUEL B	0.30	3.1	139.5	23.0
1975	DEC	12	16:58	19:15	COMBINED FUEL B	0.30	2.3	52.5	23.0
1975	DEC	15	16:58	19:24	COMBINED FUEL B	0.30	2.4	56.0	23.0
1975	DEC	18	13:18	14:55	COMBINED FUEL B	0.30	1.6	37.2	23.0
1975	DEC	19	9:10	9:52	COMBINED FUEL B	0.30	0.7		
1975	DEC	19	11:18	11:40	COMBINED FUEL B	0.30	0.4		
1975	DEC	19	13:20	13:55	COMBINED FUEL B	0.30	0.6		
1975	DEC	19	23:16	24:00	COMBINED FUEL B	0.30	0.7	54.8	23.0
1975	DEC	20	0:00	0:16	COMBINED FUEL B	0.30	0.3		
1975	DEC	20	9:25	13:04	COMBINED FUEL B	0.30	3.6	90.1	23.0
1975	DEC	26	17:21	18:31	COMBINED FUEL B	0.30	1.2	26.8	23.0
1975	DEC	29	10:33	11:14	COMBINED FUEL B	0.30	0.7	15.7	23.0
1975	DEC	30	17:07	18:51	COMBINED FUEL B	0.30	1.7	39.9	23.0
1976	JAN	1	17:29	22:21	COMBINED FUEL B	0.26	4.9	111.9	23.0
1976	JAN	2	8:07	8:17	COMBINED FUEL B	0.26	0.2	3.8	23.0
1976	JAN	3	8:53	11:35	COMBINED FUEL B	0.26	2.7	62.1	23.0
1976	JAN	7	14:57	15:22	COMBINED FUEL B	0.26	0.4	9.6	23.0
1976	JAN	16	22:32	23:11	COMBINED FUEL B	0.26	0.7	15.0	23.0
1976	JAN	21	4:17	6:23	COMBINED FUEL B	0.26	2.1	48.3	23.0
1976	JAN	24	17:20	18:05	COMBINED FUEL B	0.26	0.8		
1976	JAN	24	22:25	23:05	COMBINED FUEL B	0.26	0.7	32.6	23.0
1976	JAN	25	17:40	18:26	COMBINED FUEL B	0.26	0.8	17.6	23.0
1976	JAN	26	6:16	9:15	COMBINED FUEL B	0.26	3.0	68.6	23.0
1976	JAN	30	17:42	18:10	COMBINED FUEL B	0.26	0.5		
1976	JAN	30	18:44	21:03	COMBINED FUEL B	0.26	2.3	64.0	23.0
1976	FEB	5	17:14	18:55	COMBINED FUEL B	0.26	1.7		
1976	FEB	5	19:15	20:28	COMBINED FUEL B	0.26	1.2	66.7	23.0
1976	FEB	6	13:16	13:24	COMBINED FUEL B	0.26	0.1	3.1	23.0
1976	FEB	9	9:32	13:24	COMBINED FUEL B	0.26	3.9	88.9	23.0
1976	FEB	14	17:56	20:14	COMBINED FUEL B	0.26	2.3	52.9	23.0
1976	FEB	17	17:06	19:32	COMBINED FUEL B	0.26	2.4	56.0	23.0
1976	FEB	21	18:18	18:45	COMBINED FUEL B	0.26	0.4	10.3	23.0
1976	MAR	14	5:29	7:39	COMBINED FUEL B	0.26	2.2	49.8	23.0
1976	MAR	15	6:16	8:10	COMBINED FUEL B	0.26	1.9		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	MAR	15	8:10	13:27	COMBINED FUEL B	0.26	5.3	165.2	23.0
1976	MAR	16	8:29	8:50	COMBINED FUEL B	0.26	0.3		
1976	MAR	16	9:25	11:10	COMBINED FUEL B	0.26	1.8	48.3	23.0
1976	MAR	20	18:54	19:28	COMBINED FUEL B	0.26	0.6	13.0	23.0
1976	MAR	24	10:27	12:08	COMBINED FUEL B	0.26	1.7	38.7	23.0
1976	APR	6	14:15	15:28	COMBINED FUEL B	0.26	1.2		
1976	APR	6	19:15	19:35	COMBINED FUEL B	0.26	0.3	35.8	23.0
1976	APR	7	8:56	11:35	COMBINED FUEL B	0.26	2.6		
1976	APR	7	11:58	15:45	COMBINED FUEL B	0.26	3.8	148.0	23.0
1976	APR	8	7:32	13:55	COMBINED FUEL B	0.26	6.4	146.8	23.0
1976	APR	9	18:59	19:09	COMBINED FUEL B	0.26	0.2		
1976	APR	9	21:44	22:25	COMBINED FUEL B	0.26	0.7	19.5	23.0
1976	APR	15	18:07	18:12	COMBINED FUEL B	0.26	0.1		
1976	APR	15	19:19	19:33	COMBINED FUEL B	0.26	0.2	7.3	23.0
1976	APR	17	10:34	11:26	COMBINED FUEL B	0.26	0.9	19.9	23.0
1976	APR	19	18:35	21:03	COMBINED FUEL B	0.26	2.5	56.7	23.0
1976	MAY	3	19:45	21:02	COMBINED FUEL B	0.26	1.3	29.5	23.0
1976	MAY	4	11:32	12:15	COMBINED FUEL B	0.26	0.7		
1976	MAY	4	13:19	16:25	COMBINED FUEL B	0.26	3.1	87.8	23.0
1976	MAY	6	22:49	23:40	COMBINED FUEL B	0.26	0.9	19.5	23.0
1976	MAY	10	13:18	15:07	COMBINED FUEL B	0.26	1.8	41.8	23.0
1976	MAY	11	10:51	16:17	COMBINED FUEL B	0.26	5.4		
1976	MAY	11	20:03	21:15	COMBINED FUEL B	0.26	1.2	152.6	23.0
1976	MAY	12	3:46	4:52	COMBINED FUEL B	0.26	1.1		
1976	MAY	12	9:37	17:42	COMBINED FUEL B	0.26	8.1	211.2	23.0
1976	MAY	13	13:20	16:07	COMBINED FUEL B	0.26	2.8		
1976	MAY	13	18:21	20:02	COMBINED FUEL B	0.26	1.7	102.7	23.0
1976	MAY	17	16:12	16:38	COMBINED FUEL B	0.26	0.4	10.0	23.0
1976	MAY	18	12:26	18:41	COMBINED FUEL B	0.26	6.3		
1976	MAY	18	20:35	20:56	COMBINED FUEL B	0.26	0.3		
1976	MAY	18	21:43	22:00	COMBINED FUEL B	0.26	0.3		
1976	MAY	18	23:07	23:14	COMBINED FUEL B	0.26	0.1	161.0	23.0
1976	MAY	23	20:12	21:22	COMBINED FUEL B	0.26	1.2	26.8	23.0
1976	MAY	26	20:06	21:06	COMBINED FUEL B	0.26	1.0	23.0	23.0
1976	MAY	27	10:04	16:05	COMBINED FUEL B	0.26	6.0	138.4	23.0
1976	JUN	5	8:54	13:56	COMBINED FUEL B	0.26	5.0		
1976	JUN	5	20:15	21:51	COMBINED FUEL B	0.26	1.6	152.6	23.0
1976	JUN	7	9:10	9:31	COMBINED FUEL B	0.26	0.3		
1976	JUN	7	9:34	16:20	COMBINED FUEL B	0.26	6.8	163.7	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JUN	8	14:41	15:09	COMBINED FUEL B	0.26	0.5	10.7	23.0
1976	JUN	12	11:05	14:40	COMBINED FUEL B	0.26	3.6		
1976	JUN	12	17:47	21:56	COMBINED FUEL B	0.26	4.1	177.9	23.0
1976	JUN	14	14:39	15:05	COMBINED FUEL B	0.26	0.4	10.0	23.0
1976	JUN	15	12:36	16:38	COMBINED FUEL B	0.26	4.0		
1976	JUN	15	20:36	21:09	COMBINED FUEL B	0.26	0.6	105.4	23.0
1976	JUN	18	13:20	14:42	COMBINED FUEL B	0.26	1.4	31.4	23.0
1976	JUN	19	10:28	18:01	COMBINED FUEL B	0.26	7.5	173.6	23.0
1976	JUN	23	10:47	18:04	COMBINED FUEL B	0.26	7.3	167.5	23.0
1976	JUN	24	11:29	13:27	COMBINED FUEL B	0.26	2.0		
1976	JUN	24	13:27	14:04	COMBINED FUEL B	0.26	0.6		
1976	JUN	24	14:04	18:25	COMBINED FUEL B	0.26	4.3	159.5	23.0
1976	JUN	25	10:22	11:00	COMBINED FUEL B	0.26	0.6		
1976	JUN	25	11:06	17:38	COMBINED FUEL B	0.26	6.5	164.8	23.0
1976	JUN	26	9:41	19:48	COMBINED FUEL B	0.26	10.1		
1976	JUN	26	20:27	21:38	COMBINED FUEL B	0.26	1.2	259.9	23.0
1976	JUN	27	14:53	18:42	COMBINED FUEL B	0.26	3.8	87.8	23.0
1976	JUN	28	9:48	19:15	COMBINED FUEL B	0.26	9.4		
1976	JUN	28	20:50	21:20	COMBINED FUEL B	0.26	0.5	228.8	23.0
1976	JUL	4	16:49	17:02	COMBINED FUEL B	0.26	0.2	5.0	23.0
1976	JUL	5	10:09	18:40	COMBINED FUEL B	0.26	8.5	195.9	23.0
1976	JUL	6	10:15	17:46	COMBINED FUEL B	0.26	7.5	172.9	23.0
1976	JUL	7	14:13	17:31	COMBINED FUEL B	0.26	3.3	75.9	23.0
1976	JUL	17	16:23	17:16	COMBINED FUEL B	0.26	0.9	20.3	23.0
1976	JUL	23	11:48	17:13	COMBINED FUEL B	0.26	5.4	124.6	23.0
1976	JUL	24	10:47	16:09	COMBINED FUEL B	0.26	5.4	123.4	23.0
1976	JUL	26	14:58	15:30	COMBINED FUEL B	0.26	0.5	12.3	23.0
1976	JUL	27	12:15	18:27	COMBINED FUEL B	0.26	6.2		
1976	JUL	27	19:47	21:18	COMBINED FUEL B	0.26	1.5	177.5	23.0
1976	JUL	31	9:12	21:43	COMBINED FUEL B	0.26	12.5	287.9	23.0
1976	AUG	1	8:22	13:17	COMBINED FUEL B	0.26	4.9		
1976	AUG	1	19:47	21:57	COMBINED FUEL B	0.26	2.2	162.9	23.0
1976	AUG	2	10:57	12:29	COMBINED FUEL B	0.26	1.5	35.3	23.0
1976	AUG	6	8:04	8:11	COMBINED FUEL B	0.26	0.1	2.7	23.0
1976	AUG	11	10:37	11:56	COMBINED FUEL B	0.26	1.3	30.3	23.0
1976	AUG	24	19:55	20:37	COMBINED FUEL B	0.26	0.7	16.1	23.0
1976	AUG	25	10:00	10:55	COMBINED FUEL B	0.26	0.9	21.1	23.0
1976	AUG	27	14:55	16:14	COMBINED FUEL B	0.26	1.3	30.3	23.0
1976	AUG	30	8:52	14:16	COMBINED FUEL B	0.26	5.4	124.2	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	AUG	31	9:43	16:38	COMBINED FUEL B	0.26	6.9	159.1	23.0
1976	SEP	2	13:38	16:05	COMBINED FUEL B	0.26	2.4		
1976	SEP	2	19:24	20:24	COMBINED FUEL B	0.26	1.0	79.3	23.0
1976	SEP	4	14:20	15:48	COMBINED FUEL B	0.26	1.5	33.7	23.0
1976	SEP	5	19:30	20:21	COMBINED FUEL B	0.26	0.9	19.5	23.0
1976	SEP	6	19:37	20:27	COMBINED FUEL B	0.26	0.8	19.2	23.0
1976	SEP	8	13:24	13:51	COMBINED FUEL B	0.26	0.4		
1976	SEP	8	19:03	21:18	COMBINED FUEL B	0.26	2.3	62.1	23.0
1976	SEP	9	19:03	20:46	COMBINED FUEL B	0.26	1.7	39.5	23.0
1976	SEP	10	0:54	1:20	COMBINED FUEL B	0.26	0.4	10.0	23.0
1976	SEP	12	19:14	21:15	COMBINED FUEL B	0.26	2.0	46.4	23.0
1976	SEP	21	19:19	19:44	COMBINED FUEL B	0.26	0.4	9.6	23.0
1976	SEP	22	19:05	20:01	COMBINED FUEL B	0.26	0.9	21.5	23.0
1976	SEP	23	10:29	15:12	COMBINED FUEL B	0.26	4.7	108.5	23.0
1976	SEP	25	18:56	19:41	COMBINED FUEL B	0.26	0.8		
1976	SEP	25	19:56	21:32	COMBINED FUEL B	0.26	1.6	54.0	23.0
1976	OCT	5	12:46	13:13	COMBINED FUEL B	0.26	0.5	10.4	23.0
1976	OCT	6	15:25	20:30	COMBINED FUEL B	0.26	5.1	116.9	23.0
1976	OCT	7	13:33	15:41	COMBINED FUEL B	0.26	2.1	49.1	23.0
1976	OCT	8	13:05	20:52	COMBINED FUEL B	0.26	7.8	179.0	23.0
1976	OCT	9	18:45	20:02	COMBINED FUEL B	0.26	1.3	29.5	23.0
1976	OCT	10	18:42	20:03	COMBINED FUEL B	0.26	1.3	31.0	23.0
1976	OCT	16	18:42	20:03	COMBINED FUEL B	0.26	1.3	31.0	23.0
1976	OCT	25	18:24	19:35	COMBINED FUEL B	0.26	1.2	27.2	23.0
1976	OCT	28	18:11	20:20	COMBINED FUEL B	0.26	2.1	49.4	23.0
1976	OCT	30	14:27	14:36	COMBINED FUEL B	0.26	0.1	3.4	23.0
1976	NOV	2	17:14	20:09	COMBINED FUEL B	0.26	2.9	67.1	23.0
1976	NOV	3	17:20	18:43	COMBINED FUEL B	0.26	1.4	31.8	23.0
1976	NOV	4	16:55	19:27	COMBINED FUEL B	0.26	2.5	58.3	23.0
1976	NOV	7	17:10	17:23	COMBINED FUEL B	0.26	0.2		
1976	NOV	7	19:30	19:39	COMBINED FUEL B	0.26	0.1	8.4	23.0
1976	NOV	8	13:20	19:47	COMBINED FUEL B	0.26	6.4	148.3	23.0
1976	NOV	9	10:08	14:48	COMBINED FUEL B	0.26	4.7		
1976	NOV	9	17:38	18:00	COMBINED FUEL B	0.26	0.4	115.8	23.0
1976	NOV	10	17:07	17:57	COMBINED FUEL B	0.26	0.8	19.2	23.0
1976	NOV	11	16:54	18:48	COMBINED FUEL B	0.26	1.9	43.7	23.0
1976	NOV	17	12:31	14:18	COMBINED FUEL B	0.26	1.8		
1976	NOV	17	14:40	15:31	COMBINED FUEL B	0.26	0.9	60.6	23.0
1976	NOV	22	16:44	19:09	COMBINED FUEL B	0.26	2.4	55.6	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	NOV	23	17:52	22:37	COMBINED FUEL B	0.26	4.8	109.3	23.0
1976	DEC	4	17:01	19:00	COMBINED FUEL B	0.26	2.0	45.6	23.0
1976	DEC	5	16:58	19:53	COMBINED FUEL B	0.26	2.9	67.1	23.0
1976	DEC	22	6:55	6:57	COMBINED FUEL B	0.26	0.0		
1976	DEC	22	10:29	10:39	COMBINED FUEL B	0.26	0.2	4.6	23.0
1976	DEC	30	17:07	21:36	COMBINED FUEL B	0.26	4.5	103.1	23.0
1977	JAN	6	9:18	11:48	COMBINED FUEL B	0.29	2.5		
1977	JAN	6	17:10	19:06	COMBINED FUEL B	0.29	1.9	102.0	23.0
1977	JAN	8	8:19	9:35	COMBINED FUEL B	0.29	1.3	29.1	23.0
1977	JAN	18	20:57	23:27	COMBINED FUEL B	0.29	2.5	57.5	23.0
1977	JAN	19	17:30	18:45	COMBINED FUEL B	0.29	1.3	28.8	23.0
1977	FEB	1	10:29	13:01	COMBINED FUEL B	0.26	2.5	58.3	23.0
1977	FEB	7	7:20	8:19	COMBINED FUEL B	0.26	1.0	22.6	23.0
1977	FEB	20	3:21	4:20	COMBINED FUEL B	0.26	1.0	22.6	23.0
1977	FEB	22	18:15	18:59	COMBINED FUEL B	0.26	0.7	16.9	23.0
1977	FEB	23	17:55	18:46	COMBINED FUEL B	0.26	0.9	19.5	23.0
1977	FEB	24	18:07	21:10	COMBINED FUEL B	0.26	3.0	70.1	23.0
1977	MAR	1	18:07	19:35	COMBINED FUEL B	0.29	1.5	33.7	23.0
1977	MAR	3	8:57	10:12	COMBINED FUEL B	0.29	1.3	28.8	23.0
1977	MAR	16	10:22	12:58	COMBINED FUEL B	0.29	2.6		
1977	MAR	16	14:39	15:13	COMBINED FUEL B	0.29	0.6		
1977	MAR	16	18:26	18:58	COMBINED FUEL B	0.29	0.5	85.1	23.0
1977	MAR	17	18:21	20:10	COMBINED FUEL B	0.29	1.8	41.8	23.0
1977	APR	4	16:07	17:19	COMBINED FUEL B	0.29	1.2	27.6	23.0
1977	APR	12	9:35	10:29	COMBINED FUEL B	0.29	0.9		
1977	APR	12	13:26	13:50	COMBINED FUEL B	0.29	0.4		
1977	APR	12	15:27	15:46	COMBINED FUEL B	0.29	0.3	37.2	23.0
1977	APR	18	18:05	21:19	COMBINED FUEL B	0.29	3.2	74.4	23.0
1977	APR	22	16:32	17:15	COMBINED FUEL B	0.29	0.7	16.5	23.0
1977	APR	23	18:47	20:20	COMBINED FUEL B	0.29	1.5	35.6	23.0
1977	APR	28	10:45	15:25	COMBINED FUEL B	0.29	4.7	107.3	23.0
1977	MAY	5	10:48	12:15	COMBINED FUEL B	0.29	1.4	33.3	23.0
1977	MAY	6	7:38	7:50	COMBINED FUEL B	0.29	0.2		
1977	MAY	6	9:40	15:30	COMBINED FUEL B	0.29	5.8	138.8	23.0
1977	MAY	20	14:59	16:07	COMBINED FUEL B	0.29	1.1		
1977	MAY	20	20:22	21:36	COMBINED FUEL B	0.29	1.2	54.4	23.0
1977	MAY	27	9:10	18:16	COMBINED FUEL B	0.29	9.1	209.3	23.0
1977	MAY	31	13:30	16:39	COMBINED FUEL B	0.29	3.1	72.4	23.0
1977	JUN	10	14:20	14:48	COMBINED FUEL B	0.29	0.5		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JUN	10	14:48	17:02	COMBINED FUEL B	0.29	2.2	62.1	23.0
1977	JUN	13	10:25	12:32	COMBINED FUEL B	0.29	2.1		
1977	JUN	13	12:59	13:12	COMBINED FUEL B	0.29	0.2	53.7	23.0
1977	JUN	22	9:45	11:00	COMBINED FUEL B	0.29	1.3	28.8	23.0
1977	JUN	24	13:47	15:34	COMBINED FUEL B	0.29	1.8	41.0	23.0
1977	JUL	16	20:07	24:00	COMBINED FUEL B	0.29	3.9	89.3	23.0
1977	JUL	17	0:00	0:31	COMBINED FUEL B	0.29	0.5		
1977	JUL	17	20:21	21:22	COMBINED FUEL B	0.29	1.0		
1977	JUL	17	23:12	24:00	COMBINED FUEL B	0.29	0.8	53.7	23.0
1977	JUL	18	0:00	0:16	COMBINED FUEL B	0.29	0.3		
1977	JUL	18	10:00	17:30	COMBINED FUEL B	0.29	7.5	178.6	23.0
1977	JUL	21	10:50	18:16	COMBINED FUEL B	0.29	7.4	171.0	23.0
1977	JUL	22	9:02	15:32	COMBINED FUEL B	0.29	6.5	149.5	23.0
1977	JUL	25	9:02	18:32	COMBINED FUEL B	0.29	9.5		
1977	JUL	25	20:08	21:24	COMBINED FUEL B	0.29	1.3	247.6	23.0
1977	JUL	26	15:04	16:14	COMBINED FUEL B	0.29	1.2		
1977	JUL	26	19:58	22:03	COMBINED FUEL B	0.29	2.1	74.7	23.0
1977	JUL	29	13:39	16:35	COMBINED FUEL B	0.29	2.9	67.5	23.0
1977	AUG	1	10:50	11:00	COMBINED FUEL B	0.29	0.2		
1977	AUG	1	12:55	13:47	COMBINED FUEL B	0.29	0.9	23.8	23.0
1977	AUG	2	11:55	15:54	COMBINED FUEL B	0.29	4.0	91.6	23.0
1977	AUG	3	12:49	14:09	COMBINED FUEL B	0.29	1.3		
1977	AUG	3	17:13	18:42	COMBINED FUEL B	0.29	1.5	64.8	23.0
1977	AUG	4	12:38	16:01	COMBINED FUEL B	0.29	3.4	77.8	23.0
1977	AUG	5	15:20	15:39	COMBINED FUEL B	0.29	0.3		
1977	AUG	5	16:05	16:12	COMBINED FUEL B	0.29	0.1	10.0	23.0
1977	AUG	11	10:20	13:52	COMBINED FUEL B	0.29	3.5	81.3	23.0
1977	AUG	12	13:12	15:28	COMBINED FUEL B	0.29	2.3	52.1	23.0
1977	AUG	15	14:32	16:02	COMBINED FUEL B	0.29	1.5	34.5	23.0
1977	AUG	16	9:38	14:28	COMBINED FUEL B	0.29	4.8	111.2	23.0
1977	AUG	19	20:55	21:05	COMBINED FUEL B	0.29	0.2	3.8	23.0
1977	AUG	20	10:24	17:35	COMBINED FUEL B	0.29	7.2	165.2	23.0
1977	AUG	29	12:40	15:35	COMBINED FUEL B	0.29	2.9	67.1	23.0
1977	SEP	4	14:09	18:16	COMBINED FUEL B	0.29	4.1		
1977	SEP	4	19:28	21:26	COMBINED FUEL B	0.29	2.0	139.9	23.0
1977	SEP	6	12:52	19:07	COMBINED FUEL B	0.29	6.3	143.8	23.0
1977	SEP	7	12:53	13:55	COMBINED FUEL B	0.29	1.0	23.8	23.0
1977	SEP	8	10:48	18:30	COMBINED FUEL B	0.29	7.7	177.1	23.0
1977	SEP	10	6:04	6:28	COMBINED FUEL B	0.29	0.4		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	SEP	10	7:10	10:02	COMBINED FUEL B	0.29	2.9	75.1	23.0
1977	SEP	19	8:34	13:17	COMBINED FUEL B	0.29	4.7	108.5	23.0
1977	SEP	24	19:17	20:29	COMBINED FUEL B	0.29	1.2	27.6	23.0
1977	SEP	25	19:02	19:54	COMBINED FUEL B	0.29	0.9	19.9	23.0
1977	OCT	1	19:09	19:57	COMBINED FUEL B	0.29	0.8	18.4	23.0
1977	OCT	3	13:29	16:31	COMBINED FUEL B	0.29	3.0		
1977	OCT	3	18:53	20:35	COMBINED FUEL B	0.29	1.7	108.9	23.0
1977	OCT	4	18:32	20:26	COMBINED FUEL B	0.29	1.9	43.7	23.0
1977	OCT	5	13:19	16:10	COMBINED FUEL B	0.29	2.8		
1977	OCT	5	18:34	23:14	COMBINED FUEL B	0.29	4.7	172.9	23.0
1977	OCT	6	9:50	21:10	COMBINED FUEL B	0.29	11.3		
1977	OCT	6	22:34	22:43	COMBINED FUEL B	0.29	0.1	264.1	23.0
1977	OCT	7	10:12	20:45	COMBINED FUEL B	0.29	10.5	242.6	23.0
1977	OCT	10	8:43	10:00	COMBINED FUEL B	0.29	1.3	29.5	23.0
1977	OCT	15	18:19	20:17	COMBINED FUEL B	0.29	2.0	45.2	23.0
1977	OCT	16	18:40	20:25	COMBINED FUEL B	0.29	1.8	40.3	23.0
1977	OCT	17	8:39	11:15	COMBINED FUEL B	0.29	2.6	59.8	23.0
1977	OCT	18	18:29	19:20	COMBINED FUEL B	0.29	0.9	19.5	23.0
1977	OCT	19	18:37	19:16	COMBINED FUEL B	0.29	0.7	15.0	23.0
1977	OCT	20	18:15	20:08	COMBINED FUEL B	0.29	1.9	43.3	23.0
1977	OCT	23	10:04	10:53	COMBINED FUEL B	0.29	0.8	18.8	23.0
1977	OCT	26	18:20	20:01	COMBINED FUEL B	0.29	1.7	38.7	23.0
1977	OCT	30	17:27	18:38	COMBINED FUEL B	0.29	1.2	27.2	23.0
1977	OCT	31	17:21	18:57	COMBINED FUEL B	0.29	1.6	36.8	23.0
1977	NOV	1	17:10	20:05	COMBINED FUEL B	0.29	2.9	67.1	23.0
1977	NOV	2	17:20	19:10	COMBINED FUEL B	0.29	1.8	42.2	23.0
1977	NOV	3	17:12	19:35	COMBINED FUEL B	0.29	2.4	54.8	23.0
1977	NOV	5	16:59	19:25	COMBINED FUEL B	0.29	2.4	56.0	23.0
1977	NOV	7	17:11	20:06	COMBINED FUEL B	0.29	2.9	67.1	23.0
1977	NOV	8	17:06	17:27	COMBINED FUEL B	0.29	0.3		
1977	NOV	8	18:51	19:02	COMBINED FUEL B	0.29	0.2		
1977	NOV	8	19:48	19:59	COMBINED FUEL B	0.29	0.2	16.5	23.0
1977	NOV	9	17:03	19:42	COMBINED FUEL B	0.29	2.6	60.9	23.0
1977	NOV	10	17:10	18:15	COMBINED FUEL B	0.29	1.1	24.9	23.0
1977	NOV	12	17:27	18:12	COMBINED FUEL B	0.29	0.8	17.3	23.0
1977	NOV	14	17:37	17:51	COMBINED FUEL B	0.29	0.2	5.4	23.0
1977	NOV	15	17:03	18:15	COMBINED FUEL B	0.29	1.2	27.6	23.0
1977	NOV	17	17:04	18:53	COMBINED FUEL B	0.29	1.8	41.8	23.0
1977	NOV	18	17:03	17:14	COMBINED FUEL B	0.29	0.2		

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1A

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	NOV	18	18:36	18:46	COMBINED FUEL B	0.29	0.2	8.0	23.0
1977	NOV	19	17:06	17:14	COMBINED FUEL B	0.29	0.1		
1977	NOV	19	18:10	18:26	COMBINED FUEL B	0.29	0.3	9.2	23.0
1977	NOV	20	17:01	17:09	COMBINED FUEL B	0.29	0.1		
1977	NOV	20	17:11	17:36	COMBINED FUEL B	0.29	0.4	12.6	23.0
1977	NOV	21	10:45	13:05	COMBINED FUEL B	0.29	2.3		
1977	NOV	21	15:29	20:03	COMBINED FUEL B	0.29	4.6	158.7	23.0
1977	NOV	22	10:06	15:10	COMBINED FUEL B	0.29	5.1		
1977	NOV	22	16:42	16:52	COMBINED FUEL B	0.29	0.2		
1977	NOV	22	17:38	17:48	COMBINED FUEL B	0.29	0.2	124.2	23.0
1977	NOV	23	10:18	10:23	COMBINED FUEL B	0.29	0.1		
1977	NOV	23	10:40	11:47	COMBINED FUEL B	0.29	1.1		
1977	NOV	23	14:40	15:10	COMBINED FUEL B	0.29	0.5		
1977	NOV	23	17:02	19:00	COMBINED FUEL B	0.29	2.0	84.3	23.0
1977	NOV	25	17:11	18:15	COMBINED FUEL B	0.29	1.1	24.5	23.0
1977	NOV	28	17:02	19:04	COMBINED FUEL B	0.29	2.0	46.8	23.0
1977	NOV	29	17:15	19:10	COMBINED FUEL B	0.29	1.9	44.1	23.0
1977	NOV	30	17:02	17:16	COMBINED FUEL B	0.29	0.2		
1977	NOV	30	19:10	19:50	COMBINED FUEL B	0.29	0.7	20.7	23.0
1977	DEC	1	17:05	19:08	COMBINED FUEL B	0.29	2.0	47.1	23.0
1977	DEC	3	17:05	18:45	COMBINED FUEL B	0.29	1.7	38.3	23.0
1977	DEC	4	17:10	18:04	COMBINED FUEL B	0.29	0.9	20.7	23.0
1977	DEC	6	7:59	8:32	COMBINED FUEL B	0.29	0.6		
1977	DEC	6	10:05	14:26	COMBINED FUEL B	0.29	4.3		
1977	DEC	6	17:10	19:26	COMBINED FUEL B	0.29	2.3	164.8	23.0
1977	DEC	7	16:41	18:25	COMBINED FUEL B	0.29	1.7	39.9	23.0
1977	DEC	8	17:22	19:15	COMBINED FUEL B	0.29	1.9	43.3	23.0
1977	DEC	12	17:14	17:53	COMBINED FUEL B	0.29	0.6	14.9	23.0
1977	DEC	16	17:01	18:46	COMBINED FUEL B	0.29	1.8	40.3	23.0
1977	DEC	17	17:04	18:12	COMBINED FUEL B	0.29	1.1	26.1	23.0
1977	DEC	18	17:16	18:18	COMBINED FUEL B	0.29	1.0	23.8	23.0
1977	DEC	19	17:02	19:40	COMBINED FUEL B	0.29	2.6	60.6	23.0
1977	DEC	20	17:00	19:22	COMBINED FUEL B	0.29	2.4	54.4	23.0
1977	DEC	21	17:06	19:05	COMBINED FUEL B	0.29	2.0	45.6	23.0
1977	DEC	22	17:14	18:55	COMBINED FUEL B	0.29	1.7	38.7	23.0
1977	DEC	24	17:03	18:24	COMBINED FUEL B	0.29	1.3	31.0	23.0
1977	DEC	27	17:15	18:09	COMBINED FUEL B	0.29	0.9	20.7	23.0
1977	DEC	31	17:11	17:30	COMBINED FUEL B	0.29	0.3		
1977	DEC	31	18:26	18:33	COMBINED FUEL B	0.29	0.1	10.0	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	2	17:24	19:19	COMBINED FUEL B	0.30	1.9	44.1	23.0
1975	JAN	4	10:29	12:11	COMBINED FUEL B	0.30	1.7	39.1	23.0
1975	JAN	8	7:54	9:15	COMBINED FUEL B	0.30	1.3		
1975	JAN	8	12:00	16:21	COMBINED FUEL B	0.30	4.3	131.1	23.0
1975	JAN	9	10:30	11:40	COMBINED FUEL B	0.30	1.2		
1975	JAN	9	17:15	19:11	COMBINED FUEL B	0.30	1.9	71.3	23.0
1975	JAN	11	12:52	14:23	COMBINED FUEL B	0.30	1.5	34.9	23.0
1975	JAN	12	17:21	19:07	COMBINED FUEL B	0.30	1.8	40.6	23.0
1975	JAN	13	13:45	15:10	COMBINED FUEL B	0.30	1.4	32.6	23.0
1975	JAN	16	8:53	9:13	COMBINED FUEL B	0.30	0.3	7.7	23.0
1975	JAN	17	11:07	11:15	COMBINED FUEL B	0.30	0.1	3.1	23.0
1975	JAN	27	9:09	12:50	COMBINED FUEL B	0.30	3.7	84.7	23.0
1975	JAN	29	9:25	10:13	COMBINED FUEL B	0.30	0.8	18.4	23.0
1975	JAN	30	16:39	20:47	COMBINED FUEL B	0.30	4.1	95.1	23.0
1975	JAN	31	14:52	16:10	COMBINED FUEL B	0.30	1.3	29.9	23.0
1975	FEB	7	8:21	10:24	COMBINED FUEL B	0.30	2.0		
1975	FEB	7	10:39	10:52	COMBINED FUEL B	0.30	0.2		
1975	FEB	7	13:02	13:33	COMBINED FUEL B	0.30	0.5	64.0	23.0
1975	FEB	8	8:45	13:14	COMBINED FUEL B	0.30	4.5	103.1	23.0
1975	FEB	11	17:53	20:11	COMBINED FUEL B	0.30	2.3	52.9	23.0
1975	FEB	13	9:30	10:03	COMBINED FUEL B	0.30	0.6	12.6	23.0
1975	FEB	28	9:30	12:00	COMBINED FUEL B	0.30	2.5		
1975	FEB	28	13:10	14:05	COMBINED FUEL B	0.30	0.9	78.6	23.0
1975	MAR	8	10:15	12:19	COMBINED FUEL B	0.30	2.1	47.5	23.0
1975	MAR	10	8:08	15:28	COMBINED FUEL B	0.30	7.3		
1975	MAR	10	18:37	20:35	COMBINED FUEL B	0.30	2.0	213.9	23.0
1975	MAR	20	10:30	11:25	COMBINED FUEL B	0.30	0.9	21.1	23.0
1975	MAR	21	6:16	6:31	COMBINED FUEL B	0.30	0.3	5.8	23.0
1975	MAR	22	8:54	12:39	COMBINED FUEL B	0.30	3.8	86.3	23.0
1975	MAR	31	10:30	13:30	COMBINED FUEL B	0.30	3.0		
1975	MAR	31	18:28	20:34	COMBINED FUEL B	0.30	2.1	117.3	23.0
1975	APR	1	10:05	10:16	COMBINED FUEL B	0.30	0.2		
1975	APR	1	11:00	11:09	COMBINED FUEL B	0.30	0.1	7.7	23.0
1975	APR	4	14:31	14:43	COMBINED FUEL B	0.30	0.2		
1975	APR	4	15:41	15:52	COMBINED FUEL B	0.30	0.2	8.8	23.0
1975	APR	8	16:19	18:55	COMBINED FUEL B	0.30	2.6	59.8	23.0
1975	APR	9	8:56	10:19	COMBINED FUEL B	0.30	1.4	31.8	23.0
1975	APR	14	11:20	12:11	COMBINED FUEL B	0.30	0.9	19.5	23.0
1975	APR	15	15:17	15:54	COMBINED FUEL B	0.30	0.6	14.2	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	APR	16	6:42	22:52	COMBINED FUEL B	0.30	16.2	371.8	23.0
1975	APR	17	13:04	13:20	COMBINED FUEL B	0.30	0.3		
1975	APR	17	19:16	22:37	COMBINED FUEL B	0.30	3.3	83.2	23.0
1975	APR	21	19:01	21:27	COMBINED FUEL B	0.30	2.4	56.0	23.0
1975	APR	22	19:33	20:49	COMBINED FUEL B	0.30	1.3	29.1	23.0
1975	APR	23	14:15	19:04	COMBINED FUEL B	0.30	4.8	110.8	23.0
1975	APR	24	12:14	12:45	COMBINED FUEL B	0.30	0.5		
1975	APR	24	19:42	20:22	COMBINED FUEL B	0.30	0.7	27.2	23.0
1975	APR	26	15:21	17:42	COMBINED FUEL B	0.30	2.3	54.0	23.0
1975	APR	27	19:42	21:02	COMBINED FUEL B	0.30	1.3	30.7	23.0
1975	APR	29	18:06	22:46	COMBINED FUEL B	0.30	4.7	107.3	23.0
1975	MAY	2	12:06	12:20	COMBINED FUEL B	0.30	0.2		
1975	MAY	2	19:36	20:09	COMBINED FUEL B	0.30	0.6	18.0	23.0
1975	MAY	4	19:22	21:11	COMBINED FUEL B	0.30	1.8	41.8	23.0
1975	MAY	9	19:37	21:40	COMBINED FUEL B	0.30	2.0	47.1	23.0
1975	MAY	27	10:00	11:26	COMBINED FUEL B	0.30	1.4		
1975	MAY	27	14:35	17:20	COMBINED FUEL B	0.30	2.8	96.2	23.0
1975	MAY	28	8:56	9:48	COMBINED FUEL B	0.30	0.9	19.9	23.0
1975	JUN	5	11:40	14:02	COMBINED FUEL B	0.30	2.4	54.4	23.0
1975	JUN	19	20:21	21:19	COMBINED FUEL B	0.30	1.0	22.2	23.0
1975	JUL	11	9:21	16:25	COMBINED FUEL B	0.30	7.1	162.5	23.0
1975	JUL	21	9:00	10:01	COMBINED FUEL B	0.30	1.0	23.4	23.0
1975	JUL	24	12:40	13:46	COMBINED FUEL B	0.30	1.1	25.3	23.0
1975	JUL	27	11:03	19:02	COMBINED FUEL B	0.30	8.0	183.6	23.0
1975	JUL	28	10:38	17:28	COMBINED FUEL B	0.30	6.8	157.2	23.0
1975	JUL	29	10:26	14:12	COMBINED FUEL B	0.30	3.8	86.6	23.0
1975	JUL	30	9:40	9:48	COMBINED FUEL B	0.30	0.1		
1975	JUL	30	10:32	10:50	COMBINED FUEL B	0.30	0.3	10.0	23.0
1975	AUG	4	19:50	21:13	COMBINED FUEL B	0.30	1.4	31.8	23.0
1975	AUG	5	16:55	18:11	COMBINED FUEL B	0.30	1.3	29.1	23.0
1975	AUG	6	12:14	13:53	COMBINED FUEL B	0.30	1.6	37.9	23.0
1975	AUG	7	9:51	11:53	COMBINED FUEL B	0.30	2.0		
1975	AUG	7	12:00	13:30	COMBINED FUEL B	0.30	1.5		
1975	AUG	7	13:30	21:24	COMBINED FUEL B	0.30	7.9	263.0	23.0
1975	AUG	15	20:04	21:30	COMBINED FUEL B	0.30	1.4	33.0	23.0
1975	AUG	16	9:07	9:34	COMBINED FUEL B	0.30	0.4	10.3	23.0
1975	AUG	19	8:40	11:28	COMBINED FUEL B	0.30	2.8		
1975	AUG	19	17:54	22:15	COMBINED FUEL B	0.30	4.3	164.4	23.0
1975	AUG	23	10:21	19:03	COMBINED FUEL B	0.30	8.7	200.1	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	NOV	20	6:42	11:16	COMBINED FUEL B	0.30	4.6		
1975	NOV	20	16:54	18:48	COMBINED FUEL B	0.30	1.9	148.7	23.0
1975	NOV	21	8:00	8:19	COMBINED FUEL B	0.30	0.3	7.3	23.0
1975	NOV	22	16:43	19:17	COMBINED FUEL B	0.30	2.6	59.0	23.0
1975	NOV	28	8:51	13:35	COMBINED FUEL B	0.30	4.7		
1975	NOV	28	17:04	18:19	COMBINED FUEL B	0.30	1.3	137.6	23.0
1975	NOV	29	17:03	20:31	COMBINED FUEL B	0.30	3.5	79.7	23.0
1975	NOV	30	16:40	21:08	COMBINED FUEL B	0.30	4.5	102.7	23.0
1975	DEC	3	17:06	20:34	COMBINED FUEL B	0.30	3.5	79.7	23.0
1975	DEC	6	16:56	19:57	COMBINED FUEL B	0.30	3.0	69.4	23.0
1975	DEC	7	17:07	18:48	COMBINED FUEL B	0.30	1.7	38.7	23.0
1975	DEC	8	11:10	12:28	COMBINED FUEL B	0.30	1.3	29.9	23.0
1975	DEC	10	8:19	11:07	COMBINED FUEL B	0.30	2.8		
1975	DEC	10	16:15	19:52	COMBINED FUEL B	0.30	3.6	147.6	23.0
1975	DEC	11	12:54	20:20	COMBINED FUEL B	0.30	7.4	171.0	23.0
1975	DEC	12	7:55	9:02	COMBINED FUEL B	0.30	1.1		
1975	DEC	12	16:58	19:10	COMBINED FUEL B	0.30	2.2	76.3	23.0
1975	DEC	15	17:07	17:41	COMBINED FUEL B	0.30	0.6	13.0	23.0
1975	DEC	16	13:49	13:50	COMBINED FUEL B	0.30	0.0	0.4	23.0
1975	DEC	19	8:26	9:52	COMBINED FUEL B	0.30	1.4		
1975	DEC	19	11:18	11:40	COMBINED FUEL B	0.30	0.4		
1975	DEC	19	13:39	13:55	COMBINED FUEL B	0.30	0.3		
1975	DEC	19	23:16	24:00	COMBINED FUEL B	0.30	0.7	64.4	23.0
1975	DEC	20	0:00	0:16	COMBINED FUEL B	0.30	0.3		
1975	DEC	20	9:36	9:45	COMBINED FUEL B	0.30	0.1		
1975	DEC	20	10:05	13:09	COMBINED FUEL B	0.30	3.1	80.1	23.0
1975	DEC	23	8:58	10:50	COMBINED FUEL B	0.30	1.9	42.9	23.0
1975	DEC	26	17:55	18:06	COMBINED FUEL B	0.30	0.2	4.2	23.0
1975	DEC	30	17:22	18:30	COMBINED FUEL B	0.30	1.1	26.1	23.0
1976	JAN	1	17:24	22:15	COMBINED FUEL B	0.26	4.8	111.5	23.0
1976	JAN	2	8:07	8:17	COMBINED FUEL B	0.26	0.2		
1976	JAN	2	15:08	15:32	COMBINED FUEL B	0.26	0.4	13.0	23.0
1976	JAN	3	7:55	10:16	COMBINED FUEL B	0.26	2.3	54.0	23.0
1976	JAN	6	8:09	10:31	COMBINED FUEL B	0.26	2.4	54.4	23.0
1976	JAN	13	22:32	23:34	COMBINED FUEL B	0.26	1.0	23.8	23.0
1976	JAN	16	4:17	6:21	COMBINED FUEL B	0.26	2.1	47.5	23.0
1976	JAN	21	17:28	18:48	COMBINED FUEL B	0.26	1.3	30.7	23.0
1976	JAN	24	17:40	19:08	COMBINED FUEL B	0.26	1.5	33.7	23.0
1976	JAN	25	6:15	9:07	COMBINED FUEL B	0.26	2.9	65.9	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JAN	30	17:35	19:05	COMBINED FUEL B	0.26	1.5	34.5	23.0
1976	FEB	5	17:14	17:20	COMBINED FUEL B	0.26	0.1		
1976	FEB	5	18:50	21:07	COMBINED FUEL B	0.26	2.3	54.8	23.0
1976	FEB	6	14:09	14:18	COMBINED FUEL B	0.26	0.1	3.4	23.0
1976	FEB	11	7:43	8:38	COMBINED FUEL B	0.26	0.9	21.1	23.0
1976	FEB	14	18:02	19:41	COMBINED FUEL B	0.26	1.6	37.9	23.0
1976	FEB	21	18:18	18:53	COMBINED FUEL B	0.26	0.6	13.4	23.0
1976	MAR	1	17:54	21:18	COMBINED FUEL B	0.26	3.4	78.2	23.0
1976	MAR	2	18:07	19:25	COMBINED FUEL B	0.26	1.3	29.9	23.0
1976	MAR	3	18:15	20:25	COMBINED FUEL B	0.26	2.2	49.8	23.0
1976	MAR	4	18:08	20:40	COMBINED FUEL B	0.26	2.5	58.3	23.0
1976	MAR	17	12:46	14:22	COMBINED FUEL B	0.26	1.6	36.8	23.0
1976	MAR	18	8:26	10:00	COMBINED FUEL B	0.26	1.6		
1976	MAR	18	10:16	12:52	COMBINED FUEL B	0.26	2.6		
1976	MAR	18	13:18	14:43	COMBINED FUEL B	0.26	1.4	128.4	23.0
1976	MAR	19	8:12	9:01	COMBINED FUEL B	0.26	0.8	18.8	23.0
1976	MAR	26	13:11	14:24	COMBINED FUEL B	0.26	1.2	28.0	23.0
1976	APR	6	19:15	21:19	COMBINED FUEL B	0.26	2.1	47.5	23.0
1976	APR	8	18:34	19:53	COMBINED FUEL B	0.26	1.3	30.3	23.0
1976	APR	9	9:42	9:43	COMBINED FUEL B	0.26	0.0		
1976	APR	9	18:41	21:23	COMBINED FUEL B	0.26	2.7	62.5	23.0
1976	APR	13	18:53	19:55	COMBINED FUEL B	0.26	1.0	23.8	23.0
1976	APR	14	18:43	19:27	COMBINED FUEL B	0.26	0.7	16.9	23.0
1976	APR	15	15:09	18:12	COMBINED FUEL B	0.26	3.0		
1976	APR	15	19:19	19:33	COMBINED FUEL B	0.26	0.2	75.5	23.0
1976	APR	16	7:40	14:18	COMBINED FUEL B	0.26	6.6		
1976	APR	16	18:52	19:35	COMBINED FUEL B	0.26	0.7	169.0	23.0
1976	APR	17	9:38	13:00	COMBINED FUEL B	0.26	3.4	77.4	23.0
1976	APR	18	18:31	21:26	COMBINED FUEL B	0.26	2.9	67.1	23.0
1976	APR	19	18:41	20:37	COMBINED FUEL B	0.26	1.9	44.5	23.0
1976	APR	24	2:09	3:34	COMBINED FUEL B	0.26	1.4	32.6	23.0
1976	APR	27	12:45	15:55	COMBINED FUEL B	0.26	3.2	72.8	23.0
1976	APR	28	7:41	15:10	COMBINED FUEL B	0.26	7.5	172.1	23.0
1976	APR	29	7:38	14:30	COMBINED FUEL B	0.26	6.9	157.9	23.0
1976	MAY	3	9:33	12:19	COMBINED FUEL B	0.26	2.8	63.6	23.0
1976	MAY	4	11:32	14:19	COMBINED FUEL B	0.26	2.8	64.0	23.0
1976	MAY	6	17:01	23:26	COMBINED FUEL B	0.26	6.4	147.6	23.0
1976	MAY	10	13:11	13:33	COMBINED FUEL B	0.26	0.4		
1976	MAY	10	14:01	14:06	COMBINED FUEL B	0.26	0.1	10.3	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	MAY	11	9:04	18:06	COMBINED FUEL B	0.26	9.0	254.9	23.0
1976	MAY	11	19:39	21:42	COMBINED FUEL B	0.26	2.0		
1976	MAY	12	3:47	4:20	COMBINED FUEL B	0.26	0.6	261.8	23.0
1976	MAY	12	10:01	20:51	COMBINED FUEL B	0.26	10.8	37.6	23.0
1976	MAY	13	20:02	21:40	COMBINED FUEL B	0.26	1.6		
1976	MAY	18	15:35	16:03	COMBINED FUEL B	0.26	0.5	47.5	23.0
1976	MAY	18	20:05	21:41	COMBINED FUEL B	0.26	1.6	23.0	23.0
1976	MAY	24	20:08	21:08	COMBINED FUEL B	0.26	1.0	58.3	23.0
1976	MAY	25	7:32	10:04	COMBINED FUEL B	0.26	2.5	66.3	23.0
1976	MAY	26	13:17	16:10	COMBINED FUEL B	0.26	2.9	125.3	23.0
1976	JUN	1	11:20	16:47	COMBINED FUEL B	0.26	5.4	41.8	23.0
1976	JUN	2	12:15	14:04	COMBINED FUEL B	0.26	1.8	12.3	23.0
1976	JUN	3	20:26	20:58	COMBINED FUEL B	0.26	0.5	103.9	23.0
1976	JUN	4	10:55	15:26	COMBINED FUEL B	0.26	4.5	118.4	23.0
1976	JUN	7	9:10	14:19	COMBINED FUEL B	0.26	5.1		
1976	JUN	8	9:55	11:07	COMBINED FUEL B	0.26	1.2	46.0	23.0
1976	JUN	8	12:50	13:38	COMBINED FUEL B	0.26	0.8	24.9	23.0
1976	JUN	9	13:29	14:34	COMBINED FUEL B	0.26	1.1		
1976	JUN	12	10:15	13:05	COMBINED FUEL B	0.26	2.8	164.8	23.0
1976	JUN	12	17:29	21:49	COMBINED FUEL B	0.26	4.3	18.8	23.0
1976	JUN	13	20:59	21:48	COMBINED FUEL B	0.26	0.8	10.0	23.0
1976	JUN	14	14:39	15:05	COMBINED FUEL B	0.26	0.4	20.7	23.0
1976	JUN	15	13:12	14:06	COMBINED FUEL B	0.26	0.9	93.9	23.0
1976	JUN	16	8:45	12:50	COMBINED FUEL B	0.26	4.1	55.6	23.0
1976	JUN	17	12:05	14:30	COMBINED FUEL B	0.26	2.4	68.6	23.0
1976	JUN	19	11:43	14:42	COMBINED FUEL B	0.26	3.0	15.0	23.0
1976	JUN	23	16:31	17:10	COMBINED FUEL B	0.26	0.7	189.0	23.0
1976	JUN	24	10:07	18:20	COMBINED FUEL B	0.26	8.2	98.9	23.0
1976	JUN	25	12:07	16:25	COMBINED FUEL B	0.26	4.3		
1976	JUN	26	9:23	19:43	COMBINED FUEL B	0.26	10.3	260.7	23.0
1976	JUN	26	20:12	21:12	COMBINED FUEL B	0.26	1.0		
1976	JUN	27	11:33	18:20	COMBINED FUEL B	0.26	6.8	170.6	23.0
1976	JUN	27	21:02	21:40	COMBINED FUEL B	0.26	0.6	236.5	23.0
1976	JUN	28	8:51	19:08	COMBINED FUEL B	0.26	10.3	156.4	23.0
1976	JUN	29	11:48	18:36	COMBINED FUEL B	0.26	6.8	5.0	23.0
1976	JUL	4	16:49	17:02	COMBINED FUEL B	0.26	0.2	184.4	23.0
1976	JUL	5	10:21	18:22	COMBINED FUEL B	0.26	8.0		
1976	JUL	6	10:19	17:33	COMBINED FUEL B	0.26	7.2	174.8	23.0
1976	JUL	6	20:33	20:55	COMBINED FUEL B	0.26	0.4		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 18

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JUL	7	14:15	14:44	COMBINED FUEL B	0.26	0.5	11.1	23.0
1976	JUL	14	11:50	16:41	COMBINED FUEL B	0.26	4.8	111.5	23.0
1976	JUL	27	12:15	18:08	COMBINED FUEL B	0.26	5.9		
1976	JUL	27	20:03	21:04	COMBINED FUEL B	0.26	1.0	158.7	23.0
1976	JUL	28	14:14	14:52	COMBINED FUEL B	0.26	0.6	14.6	23.0
1976	JUL	29	14:02	14:30	COMBINED FUEL B	0.26	0.5	10.7	23.0
1976	JUL	30	11:13	11:19	COMBINED FUEL B	0.26	0.1	2.3	23.0
1976	JUL	31	9:11	18:20	COMBINED FUEL B	0.26	9.1	210.4	23.0
1976	AUG	1	9:18	9:24	COMBINED FUEL B	0.26	0.1	2.3	23.0
1976	AUG	4	13:21	13:39	COMBINED FUEL B	0.26	0.3	6.9	23.0
1976	AUG	8	9:26	12:20	COMBINED FUEL B	0.26	2.9	66.7	23.0
1976	AUG	9	20:14	21:15	COMBINED FUEL B	0.26	1.0	23.4	23.0
1976	AUG	19	9:19	10:51	COMBINED FUEL B	0.26	1.5		
1976	AUG	19	11:55	12:13	COMBINED FUEL B	0.26	0.3	42.2	23.0
1976	AUG	20	13:47	14:37	COMBINED FUEL B	0.26	0.8	19.2	23.0
1976	AUG	21	9:45	17:35	COMBINED FUEL B	0.26	7.8	180.2	23.0
1976	AUG	23	13:19	15:37	COMBINED FUEL B	0.26	2.3	52.9	23.0
1976	AUG	24	10:43	16:07	COMBINED FUEL B	0.26	5.4	124.2	23.0
1976	AUG	25	10:00	10:55	COMBINED FUEL B	0.26	0.9	21.1	23.0
1976	AUG	27	14:55	16:18	COMBINED FUEL B	0.26	1.4	31.8	23.0
1976	AUG	30	8:52	14:13	COMBINED FUEL B	0.26	5.3	123.0	23.0
1976	AUG	31	9:43	14:13	COMBINED FUEL B	0.26	4.5		
1976	AUG	31	19:35	20:33	COMBINED FUEL B	0.26	1.0	125.7	23.0
1976	SEP	2	13:14	16:10	COMBINED FUEL B	0.26	2.9		
1976	SEP	2	19:39	20:19	COMBINED FUEL B	0.26	0.7	82.8	23.0
1976	SEP	4	14:20	15:56	COMBINED FUEL B	0.26	1.6	36.8	23.0
1976	SEP	5	19:40	20:37	COMBINED FUEL B	0.26	1.0	21.8	23.0
1976	SEP	6	19:53	20:27	COMBINED FUEL B	0.26	0.6	13.0	23.0
1976	OCT	15	14:41	16:07	COMBINED FUEL B	0.26	1.4	33.0	23.0
1976	OCT	22	18:28	19:01	COMBINED FUEL B	0.26	0.6	12.6	23.0
1976	OCT	27	13:18	13:35	COMBINED FUEL B	0.26	0.3	6.5	23.0
1976	OCT	28	18:11	19:49	COMBINED FUEL B	0.26	1.6	37.6	23.0
1976	OCT	29	18:35	19:42	COMBINED FUEL B	0.26	1.1	25.7	23.0
1976	OCT	30	14:25	14:34	COMBINED FUEL B	0.26	0.1		
1976	OCT	30	15:16	17:20	COMBINED FUEL B	0.26	2.1		
1976	OCT	30	18:36	19:30	COMBINED FUEL B	0.26	0.9	71.7	23.0
1976	NOV	1	11:46	16:15	COMBINED FUEL B	0.26	4.5	103.1	23.0
1976	NOV	2	17:06	20:14	COMBINED FUEL B	0.26	3.1	72.1	23.0
1976	NOV	3	17:12	18:38	COMBINED FUEL B	0.26	1.4	33.0	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 18

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	NOV	4	12:47	19:51	COMBINED FUEL B	0.26	7.1	162.5	23.0
1976	NOV	5	12:10	14:21	COMBINED FUEL B	0.26	2.2	50.2	23.0
1976	NOV	7	17:00	17:23	COMBINED FUEL B	0.26	0.4		
1976	NOV	7	19:24	19:38	COMBINED FUEL B	0.26	0.2	14.2	23.0
1976	NOV	8	17:15	19:43	COMBINED FUEL B	0.26	2.5	56.7	23.0
1976	NOV	10	13:10	13:16	COMBINED FUEL B	0.26	0.1		
1976	NOV	10	16:09	16:36	COMBINED FUEL B	0.26	0.4		
1976	NOV	10	16:39	16:48	COMBINED FUEL B	0.26	0.1	16.1	23.0
1976	NOV	11	16:54	18:39	COMBINED FUEL B	0.26	1.8	40.3	23.0
1976	NOV	12	17:26	18:15	COMBINED FUEL B	0.26	0.8	18.8	23.0
1976	NOV	13	17:05	17:26	COMBINED FUEL B	0.26	0.3	8.0	23.0
1976	NOV	16	17:28	18:27	COMBINED FUEL B	0.26	1.0	22.6	23.0
1976	NOV	17	17:12	19:05	COMBINED FUEL B	0.26	1.9	43.3	23.0
1976	NOV	18	16:57	19:17	COMBINED FUEL B	0.26	2.3	53.7	23.0
1976	NOV	21	16:09	19:43	COMBINED FUEL B	0.26	3.6	82.0	23.0
1976	NOV	23	17:06	22:49	COMBINED FUEL B	0.26	5.7	131.5	23.0
1976	NOV	24	17:24	18:10	COMBINED FUEL B	0.26	0.8	17.6	23.0
1976	NOV	29	17:11	18:25	COMBINED FUEL B	0.26	1.2	28.4	23.0
1976	NOV	30	12:18	13:50	COMBINED FUEL B	0.26	1.5	35.3	23.0
1976	DEC	4	16:41	18:37	COMBINED FUEL B	0.26	1.9	44.5	23.0
1976	DEC	5	16:58	19:17	COMBINED FUEL B	0.26	2.3	53.3	23.0
1976	DEC	8	17:03	19:11	COMBINED FUEL B	0.26	2.1	49.1	23.0
1976	DEC	10	17:11	19:01	COMBINED FUEL B	0.26	1.8	42.2	23.0
1976	DEC	16	17:14	18:16	COMBINED FUEL B	0.26	1.0	23.8	23.0
1976	DEC	18	17:03	19:40	COMBINED FUEL B	0.26	2.6	60.2	23.0
1976	DEC	19	17:20	17:47	COMBINED FUEL B	0.26	0.4	10.3	23.0
1976	DEC	22	6:51	8:00	COMBINED FUEL B	0.26	1.1		
1976	DEC	22	10:29	10:39	COMBINED FUEL B	0.26	0.2		
1976	DEC	22	17:14	18:47	COMBINED FUEL B	0.26	1.5	65.9	23.0
1976	DEC	27	17:39	18:35	COMBINED FUEL B	0.26	0.9	21.5	23.0
1976	DEC	28	17:12	18:51	COMBINED FUEL B	0.26	1.6	37.9	23.0
1976	DEC	30	13:48	13:55	COMBINED FUEL B	0.26	0.1		
1976	DEC	30	17:09	21:31	COMBINED FUEL B	0.26	4.4	103.1	23.0
1976	DEC	31	9:05	13:26	COMBINED FUEL B	0.26	4.3	100.0	23.0
1977	JAN	1	9:06	9:53	COMBINED FUEL B	0.29	0.8		
1977	JAN	1	12:17	14:10	COMBINED FUEL B	0.29	1.9	61.3	23.0
1977	JAN	3	17:38	18:37	COMBINED FUEL B	0.29	1.0	22.6	23.0
1977	JAN	4	12:22	19:56	COMBINED FUEL B	0.29	7.6	174.0	23.0
1977	JAN	5	17:14	19:05	COMBINED FUEL B	0.29	1.8	42.5	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JAN	6	8:16	11:16	COMBINED FUEL B	0.29	3.0		
1977	JAN	6	15:17	18:39	COMBINED FUEL B	0.29	3.4	146.4	23.0
1977	JAN	7	18:05	19:04	COMBINED FUEL B	0.29	1.0	22.6	23.0
1977	JAN	8	8:16	8:53	COMBINED FUEL B	0.29	0.6	14.2	23.0
1977	JAN	12	17:19	19:41	COMBINED FUEL B	0.29	2.4	54.4	23.0
1977	JAN	18	20:51	23:22	COMBINED FUEL B	0.29	2.5	57.9	23.0
1977	JAN	26	12:43	14:51	COMBINED FUEL B	0.29	2.1	49.1	23.0
1977	FEB	8	7:12	8:31	COMBINED FUEL B	0.29	1.3	30.3	23.0
1977	FEB	11	12:07	12:29	COMBINED FUEL B	0.29	0.4	8.4	23.0
1977	FEB	20	3:19	4:20	COMBINED FUEL B	0.29	1.0	23.4	23.0
1977	FEB	24	13:10	15:58	COMBINED FUEL B	0.29	2.8		
1977	FEB	24	17:50	19:34	COMBINED FUEL B	0.29	1.7	104.3	23.0
1977	MAR	1	18:15	20:22	COMBINED FUEL B	0.29	2.1	48.7	23.0
1977	MAR	16	10:21	13:17	COMBINED FUEL B	0.29	2.9		
1977	MAR	16	18:11	19:07	COMBINED FUEL B	0.29	0.9	88.9	23.0
1977	MAR	17	18:23	19:30	COMBINED FUEL B	0.29	1.1	25.7	23.0
1977	MAR	28	13:22	14:13	COMBINED FUEL B	0.29	0.9	19.5	23.0
1977	MAR	29	7:51	13:18	COMBINED FUEL B	0.29	5.4	125.3	23.0
1977	APR	4	16:07	17:08	COMBINED FUEL B	0.29	1.0	23.4	23.0
1977	APR	11	12:29	14:20	COMBINED FUEL B	0.29	1.8	42.5	23.0
1977	APR	18	18:05	20:23	COMBINED FUEL B	0.29	2.3	52.9	23.0
1977	APR	21	18:45	20:13	COMBINED FUEL B	0.29	1.5	33.7	23.0
1977	APR	22	9:12	9:54	COMBINED FUEL B	0.29	0.7		
1977	APR	22	16:32	17:21	COMBINED FUEL B	0.29	0.8	34.9	23.0
1977	APR	23	18:24	20:02	COMBINED FUEL B	0.29	1.6	37.6	23.0
1977	APR	25	19:53	20:40	COMBINED FUEL B	0.29	0.8	18.0	23.0
1977	MAY	2	9:08	12:08	COMBINED FUEL B	0.29	3.0	69.0	23.0
1977	MAY	5	10:48	12:10	COMBINED FUEL B	0.29	1.4	31.4	23.0
1977	MAY	6	7:38	14:30	COMBINED FUEL B	0.29	6.9	157.9	23.0
1977	MAY	20	13:46	14:44	COMBINED FUEL B	0.29	1.0		
1977	MAY	20	20:18	21:03	COMBINED FUEL B	0.29	0.8	39.5	23.0
1977	MAY	27	10:20	16:27	COMBINED FUEL B	0.29	6.1	140.7	23.0
1977	JUN	1	10:29	15:44	COMBINED FUEL B	0.29	5.3	120.8	23.0
1977	JUN	8	8:20	9:19	COMBINED FUEL B	0.29	1.0	22.6	23.0
1977	JUN	16	9:08	9:32	COMBINED FUEL B	0.29	0.4	9.2	23.0
1977	JUN	22	11:10	12:45	COMBINED FUEL B	0.29	1.6	36.4	23.0
1977	JUL	1	10:10	13:39	COMBINED FUEL B	0.29	3.5	80.1	23.0
1977	JUL	2	23:40	24:00	COMBINED FUEL B	0.29	0.3	7.7	23.0
1977	JUL	3	0:00	0:14	COMBINED FUEL B	0.29	0.2	5.4	23.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JUL	10	20:55	21:27	COMBINED FUEL B	0.29	0.5	12.3	23.0
1977	JUL	17	23:12	24:00	COMBINED FUEL B	0.29	0.8	18.4	23.0
1977	JUL	18	0:00	0:16	COMBINED FUEL B	0.29	0.3		
1977	JUL	18	10:53	17:34	COMBINED FUEL B	0.29	6.7	159.8	23.0
1977	JUL	19	13:54	14:01	COMBINED FUEL B	0.29	0.1	2.7	23.0
1977	JUL	21	10:29	15:28	COMBINED FUEL B	0.29	5.0	114.6	23.0
1977	JUL	22	9:01	9:02	COMBINED FUEL B	0.29	0.0		
1977	JUL	22	20:00	20:49	COMBINED FUEL B	0.29	0.8	19.2	23.0
1977	JUL	25	8:55	11:10	COMBINED FUEL B	0.29	2.3		
1977	JUL	25	12:04	18:51	COMBINED FUEL B	0.29	6.8		
1977	JUL	25	19:52	24:00	COMBINED FUEL B	0.29	4.1	302.8	23.0
1977	JUL	26	11:55	13:47	COMBINED FUEL B	0.29	1.9		
1977	JUL	26	15:04	15:48	COMBINED FUEL B	0.29	0.7		
1977	JUL	26	19:58	21:58	COMBINED FUEL B	0.29	2.0	105.8	23.0
1977	JUL	28	13:19	16:05	COMBINED FUEL B	0.29	2.8	63.6	23.0
1977	JUL	29	10:34	16:58	COMBINED FUEL B	0.29	6.4	147.2	23.0
1977	JUL	31	12:23	13:45	COMBINED FUEL B	0.29	1.4	31.4	23.0
1977	AUG	2	11:13	16:20	COMBINED FUEL B	0.29	5.1	117.7	23.0
1977	AUG	3	17:13	17:18	COMBINED FUEL B	0.29	0.1		
1977	AUG	3	17:28	18:42	COMBINED FUEL B	0.29	1.2	30.3	23.0
1977	AUG	4	10:18	16:05	COMBINED FUEL B	0.29	5.8	133.0	23.0
1977	AUG	5	15:20	15:39	COMBINED FUEL B	0.29	0.3		
1977	AUG	5	16:05	16:12	COMBINED FUEL B	0.29	0.1	10.0	23.0
1977	AUG	7	20:08	20:18	COMBINED FUEL B	0.29	0.2	3.8	23.0
1977	AUG	9	19:42	20:25	COMBINED FUEL B	0.29	0.7	16.5	23.0
1977	AUG	11	10:05	12:50	COMBINED FUEL B	0.29	2.8		
1977	AUG	11	13:10	13:20	COMBINED FUEL B	0.29	0.2		
1977	AUG	11	16:04	16:27	COMBINED FUEL B	0.29	0.4	75.9	23.0
1977	AUG	16	10:20	11:11	COMBINED FUEL B	0.29	0.9	19.5	23.0
1977	AUG	19	8:16	11:56	COMBINED FUEL B	0.29	3.7		
1977	AUG	19	14:09	16:32	COMBINED FUEL B	0.29	2.4	139.1	23.0
1977	AUG	20	10:18	16:05	COMBINED FUEL B	0.29	5.8		
1977	AUG	20	20:10	20:45	COMBINED FUEL B	0.29	0.6	146.4	23.0
1977	AUG	25	8:03	8:51	COMBINED FUEL B	0.29	0.8	18.4	23.0
1977	SEP	2	19:54	20:07	COMBINED FUEL B	0.29	0.2	5.0	23.0
1977	SEP	3	19:50	20:48	COMBINED FUEL B	0.29	1.0	22.2	23.0
1977	SEP	4	17:08	18:18	COMBINED FUEL B	0.29	1.2		
1977	SEP	4	19:33	20:56	COMBINED FUEL B	0.29	1.4	58.6	23.0
1977	SEP	6	12:17	19:01	COMBINED FUEL B	0.29	6.7		

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	SEP	6	19:37	21:19	COMBINED FUEL B	0.29	1.7	194.0	23.0
1977	SEP	7	12:36	13:55	COMBINED FUEL B	0.29	1.3		
1977	SEP	7	16:01	16:10	COMBINED FUEL B	0.29	0.1	33.7	23.0
1977	SEP	8	11:05	13:24	COMBINED FUEL B	0.29	2.3		
1977	SEP	8	14:25	18:35	COMBINED FUEL B	0.29	4.2	149.1	23.0
1977	SEP	10	6:04	6:33	COMBINED FUEL B	0.29	0.5		
1977	SEP	10	8:55	10:02	COMBINED FUEL B	0.29	1.1		
1977	SEP	10	11:49	13:29	COMBINED FUEL B	0.29	1.7		
1977	SEP	10	19:22	20:27	COMBINED FUEL B	0.29	1.1	100.0	23.0
1977	SEP	11	19:30	20:45	COMBINED FUEL B	0.29	1.3	28.8	23.0
1977	SEP	13	13:15	15:31	COMBINED FUEL B	0.29	2.3		
1977	SEP	13	15:48	16:13	COMBINED FUEL B	0.29	0.4	61.7	23.0
1977	SEP	19	8:34	13:10	COMBINED FUEL B	0.29	4.6	105.8	23.0
1977	SEP	22	9:30	10:00	COMBINED FUEL B	0.29	0.5	11.5	23.0
1977	SEP	24	15:01	22:07	COMBINED FUEL B	0.29	3.1	71.3	23.0
1977	OCT	2	18:58	20:24	COMBINED FUEL B	0.29	1.4	33.0	23.0
1977	OCT	3	13:29	16:00	COMBINED FUEL B	0.29	2.5		
1977	OCT	3	18:53	20:19	COMBINED FUEL B	0.29	1.4		
1977	OCT	3	20:45	22:05	COMBINED FUEL B	0.29	1.3	121.5	23.0
1977	OCT	4	12:36	20:15	COMBINED FUEL B	0.29	7.6	175.9	23.0
1977	OCT	5	12:36	15:41	COMBINED FUEL B	0.29	3.1		
1977	OCT	5	17:03	23:18	COMBINED FUEL B	0.29	6.3	214.7	23.0
1977	OCT	6	9:49	22:29	COMBINED FUEL B	0.29	12.7	291.3	23.0
1977	OCT	7	9:25	20:24	COMBINED FUEL B	0.29	11.0	252.6	23.0
1977	OCT	10	8:43	9:04	COMBINED FUEL B	0.29	0.4	8.1	23.0
1977	OCT	15	18:19	20:00	COMBINED FUEL B	0.29	1.7	38.7	23.0
1977	OCT	16	18:35	19:41	COMBINED FUEL B	0.29	1.1	25.3	23.0
1977	OCT	17	8:39	8:43	COMBINED FUEL B	0.29	0.1		
1977	OCT	17	9:38	9:41	COMBINED FUEL B	0.29	0.0	2.7	23.0
1977	OCT	20	18:15	20:15	COMBINED FUEL B	0.29	2.0	46.0	23.0
1977	OCT	23	9:28	10:43	COMBINED FUEL B	0.29	1.3		
1977	OCT	23	18:48	19:20	COMBINED FUEL B	0.29	0.5	41.0	23.0
1977	OCT	25	13:15	14:45	COMBINED FUEL B	0.29	1.5		
1977	OCT	25	18:27	19:12	COMBINED FUEL B	0.29	0.8	51.8	23.0
1977	OCT	26	18:20	19:16	COMBINED FUEL B	0.29	0.9	21.5	23.0
1977	OCT	31	17:24	19:02	COMBINED FUEL B	0.29	1.6	37.6	23.0
1977	NOV	1	17:10	19:59	COMBINED FUEL B	0.29	2.8	64.8	23.0
1977	NOV	2	17:10	19:05	COMBINED FUEL B	0.29	1.9	44.1	23.0
1977	NOV	3	17:10	19:40	COMBINED FUEL B	0.29	2.5	57.5	23.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E).

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	NOV	5	16:59	19:31	COMBINED FUEL B	0.29	2.5	58.3	23.0
1977	NOV	7	17:17	19:23	COMBINED FUEL B	0.29	2.1	48.3	23.0
1977	NOV	8	17:06	19:50	COMBINED FUEL B	0.29	2.7	62.9	23.0
1977	NOV	9	17:03	19:35	COMBINED FUEL B	0.29	2.5	58.3	23.0
1977	NOV	10	17:10	18:52	COMBINED FUEL B	0.29	1.7	39.1	23.0
1977	NOV	13	16:51	17:31	COMBINED FUEL B	0.29	0.7	15.3	23.0
1977	NOV	15	17:03	18:25	COMBINED FUEL B	0.29	1.4	31.4	23.0
1977	NOV	17	17:04	19:08	COMBINED FUEL B	0.29	2.1	47.5	23.0
1977	NOV	18	17:03	18:29	COMBINED FUEL B	0.29	1.4	33.0	23.0
1977	NOV	19	17:06	17:14	COMBINED FUEL B	0.29	0.1		
1977	NOV	19	18:10	18:26	COMBINED FUEL B	0.29	0.3	9.2	23.0
1977	NOV	20	17:01	17:09	COMBINED FUEL B	0.29	0.1		
1977	NOV	20	17:17	17:38	COMBINED FUEL B	0.29	0.3	10.3	23.0
1977	NOV	21	11:05	13:14	COMBINED FUEL B	0.29	2.1		
1977	NOV	21	15:24	19:45	COMBINED FUEL B	0.29	4.3	149.5	23.0
1977	NOV	22	16:42	19:57	COMBINED FUEL B	0.29	3.3	74.8	23.0
1977	NOV	23	10:18	11:47	COMBINED FUEL B	0.29	1.5		
1977	NOV	23	17:02	18:02	COMBINED FUEL B	0.29	1.0		
1977	NOV	23	18:41	18:51	COMBINED FUEL B	0.29	0.2	60.9	23.0
1977	NOV	25	17:11	18:37	COMBINED FUEL B	0.29	1.4	33.0	23.0
1977	NOV	28	17:20	18:43	COMBINED FUEL B	0.29	1.4	31.8	23.0
1977	NOV	29	17:12	19:06	COMBINED FUEL B	0.29	1.5	43.7	23.0
1977	NOV	30	17:16	18:05	COMBINED FUEL B	0.29	0.8		
1977	NOV	30	19:22	19:45	COMBINED FUEL B	0.29	0.4	27.6	23.0
1977	DEC	1	16:54	18:50	COMBINED FUEL B	0.29	1.9	44.5	23.0
1977	DEC	3	17:13	18:35	COMBINED FUEL B	0.29	1.4	31.4	23.0
1977	DEC	4	17:10	18:00	COMBINED FUEL B	0.29	0.8	19.2	23.0
1977	DEC	6	8:32	14:14	COMBINED FUEL B	0.29	5.7		
1977	DEC	6	17:06	17:08	COMBINED FUEL B	0.29	0.0	131.9	23.0
1977	DEC	7	16:41	18:06	COMBINED FUEL B	0.29	1.4	32.6	23.0
1977	DEC	8	17:12	19:25	COMBINED FUEL B	0.29	2.2	51.0	23.0
1977	DEC	12	17:14	17:53	COMBINED FUEL B	0.29	0.6	14.9	23.0
1977	DEC	16	17:01	18:43	COMBINED FUEL B	0.29	1.7	39.1	23.0
1977	DEC	17	17:04	18:26	COMBINED FUEL B	0.29	1.4	31.4	23.0
1977	DEC	18	17:16	18:18	COMBINED FUEL B	0.29	1.0	23.8	23.0
1977	DEC	19	17:02	19:22	COMBINED FUEL B	0.29	2.3	53.7	23.0
1977	DEC	20	17:00	19:42	COMBINED FUEL B	0.29	2.7	62.1	23.0
1977	DEC	21	17:06	18:50	COMBINED FUEL B	0.29	1.7	39.9	23.0
1977	DEC	22	17:10	18:41	COMBINED FUEL B	0.29	1.5	34.9	23.0

NEG = NEGLIGIBLE

COMBINED PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E MIRAMAR STATION

UNIT NUMBER: 1B

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	DEC	23	17:30	18:30	COMBINED FUEL B	0.29	1.0	23.0	23.0
1977	DEC	24	17:09	18:46	COMBINED FUEL B	0.29	1.6	37.2	23.0
1977	DEC	27	17:15	18:40	COMBINED FUEL B	0.29	1.4	32.6	23.0
1977	DEC	31	17:22	18:15	COMBINED FUEL B	0.29	0.9	20.3	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NAVAL STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JUL	17	10:15	10:17	DIESEL	0.30	0.0		
1975	JUL	17	10:27	10:45	DIESEL	0.30	0.3		
1975	JUL	17	10:54	11:27	DIESEL	0.30	0.6		
1975	JUL	17	12:49	12:50	DIESEL	0.30	0.0		
1975	JUL	17	13:08	13:10	DIESEL	0.30	0.0		
1975	JUL	17	13:27	13:28	DIESEL	0.30	0.0		
1975	JUL	17	14:27	14:28	DIESEL	0.30	0.0		
1975	JUL	17	14:39	14:40	DIESEL	0.30	0.0		
1975	JUL	17	15:29	17:18	DIESEL	0.30	1.8	72.8	26.0
1975	JUL	18	13:14	13:15	DIESEL	0.30	0.0		
1975	JUL	18	13:35	13:37	DIESEL	0.30	0.0		
1975	JUL	18	14:08	16:28	DIESEL	0.30	2.3	62.0	26.0
1975	JUL	23	11:29	12:21	DIESEL	0.30	0.9		
1975	JUL	23	14:40	15:01	DIESEL	0.30	0.4		
1975	JUL	23	15:22	15:51	DIESEL	0.30	0.5	44.2	26.0
1975	JUL	24	14:18	14:58	DIESEL	0.30	0.7		
1975	JUL	24	15:08	15:47	DIESEL	0.30	0.6		
1975	JUL	24	16:03	16:08	DIESEL	0.30	0.1		
1975	JUL	24	16:12	16:18	DIESEL	0.30	0.1		
1975	JUL	24	16:30	16:37	DIESEL	0.30	0.1		
1975	JUL	24	16:42	16:54	DIESEL	0.30	0.2	47.2	26.0
1975	JUL	25	9:00	9:29	DIESEL	0.30	0.5		
1975	JUL	25	9:31	12:04	DIESEL	0.30	2.5		
1975	JUL	25	12:17	12:54	DIESEL	0.30	0.6		
1975	JUL	25	14:03	14:19	DIESEL	0.30	0.3		
1975	JUL	25	14:45	14:50	DIESEL	0.30	0.1		
1975	JUL	25	14:58	15:01	DIESEL	0.30	0.1	105.3	26.0
1975	AUG	5	11:20	11:50	DIESEL	0.30	0.5		
1975	AUG	5	13:21	13:39	DIESEL	0.30	0.3		
1975	AUG	5	13:39	13:46	DIESEL	0.30	0.1		
1975	AUG	5	13:47	15:32	DIESEL	0.30	1.8		
1975	AUG	5	15:36	15:39	DIESEL	0.30	0.0	70.6	26.0
1975	AUG	6	13:45	14:50	DIESEL	0.30	1.1		
1975	AUG	6	15:13	16:10	DIESEL	0.30	1.0		
1975	AUG	6	16:21	16:35	DIESEL	0.30	0.2		
1975	AUG	6	16:49	17:08	DIESEL	0.30	0.3	67.2	26.0
1975	AUG	7	8:59	9:46	DIESEL	0.30	0.8		
1975	AUG	7	9:57	10:00	DIESEL	0.30	0.1		
1975	AUG	7	10:09	10:41	DIESEL	0.30	0.5		

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NAVAL STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	AUG	7	10:45	11:24	DIESEL	0.30	0.7		
1975	AUG	7	14:33	14:43	DIESEL	0.30	0.2		
1975	AUG	7	14:46	14:55	DIESEL	0.30	0.1	60.7	26.0
1975	AUG	8	11:13	11:14	DIESEL	0.30	0.0		
1975	AUG	8	12:11	12:27	DIESEL	0.30	0.3		
1975	AUG	8	14:08	14:25	DIESEL	0.30	0.3		
1975	AUG	8	14:32	15:00	DIESEL	0.30	0.5		
1975	AUG	8	15:06	15:14	DIESEL	0.30	0.1		
1975	AUG	8	15:20	15:22	DIESEL	0.30	0.0		
1975	AUG	8	15:24	15:36	DIESEL	0.25	0.2		
1975	AUG	8	15:40	16:09	DIESEL	0.25	0.5		
1975	AUG	8	16:29	16:42	DIESEL	0.25	0.2	54.6	26.0
1975	AUG	11	11:04	11:16	DIESEL	0.25	0.2		
1975	AUG	11	11:27	11:45	DIESEL	0.25	0.3	13.0	26.0
1975	AUG	12	11:26	11:41	DIESEL	0.25	0.3	6.5	26.0
1975	AUG	13	10:20	10:21	DIESEL	0.25	0.0	0.4	26.0
1975	AUG	14	13:45	13:51	DIESEL	0.25	0.1		
1975	AUG	14	13:52	13:53	DIESEL	0.25	0.0		
1975	AUG	14	14:01	14:45	DIESEL	0.25	0.7	22.1	26.0
1975	AUG	16	10:17	11:53	DIESEL	0.25	1.6	41.6	26.0
1975	AUG	18	10:47	11:19	DIESEL	0.25	0.5		
1975	AUG	18	12:52	13:22	DIESEL	0.25	0.5	26.9	26.0
1975	AUG	28	8:56	9:52	DIESEL	0.25	0.9		
1975	AUG	28	12:01	12:19	DIESEL	0.25	0.3		
1975	AUG	28	12:21	12:40	DIESEL	0.25	0.3	40.3	26.0
1975	AUG	29	8:42	9:08	DIESEL	0.25	0.4		
1975	AUG	29	9:17	9:19	DIESEL	0.25	0.0	12.1	26.0
1975	SEP	2	10:18	10:25	DIESEL	0.25	0.1		
1975	SEP	2	10:30	10:34	DIESEL	0.25	0.1		
1975	SEP	2	15:02	15:07	DIESEL	0.25	0.1	6.9	26.0
1975	SEP	8	13:16	13:48	DIESEL	0.25	0.5		
1975	SEP	8	15:15	15:16	DIESEL	0.25	0.0		
1975	SEP	8	15:16	16:21	DIESEL	0.25	1.1	42.5	26.0
1975	SEP	9	11:08	12:12	DIESEL	0.30	1.1		
1975	SEP	9	14:44	15:36	DIESEL	0.30	0.9		
1975	SEP	9	15:41	15:55	DIESEL	0.30	0.2		
1975	SEP	9	16:10	16:16	DIESEL	0.30	0.1	58.9	26.0
1975	SEP	10	9:45	10:45	DIESEL	0.30	1.0		
1975	SEP	10	14:56	15:08	DIESEL	0.30	0.2	31.2	26.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NAVAL STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	SEP	12	8:30	10:59	DIESEL	0.30	2.5		
1975	SEP	12	13:04	15:07	DIESEL	0.30	2.0	117.9	26.0
1975	SEP	13	0:00	24:00	DIESEL	0.30	24.0	624.0	26.0
1975	SEP	14	0:00	0:40	DIESEL	0.30	0.7		
1975	SEP	14	8:21	12:17	DIESEL	0.30	3.9	119.6	26.0
1975	SEP	15	14:27	14:39	DIESEL	0.30	0.2	5.2	26.0
1975	SEP	16	14:42	14:44	DIESEL	0.30	0.0		
1975	SEP	16	14:46	14:50	DIESEL	0.30	0.1	2.6	26.0
1975	SEP	17	8:48	9:22	DIESEL	0.30	0.6		
1975	SEP	17	10:47	11:01	DIESEL	0.30	0.2		
1975	SEP	17	12:52	13:10	DIESEL	0.30	0.3	28.6	26.0
1975	SEP	18	9:29	10:25	DIESEL	0.30	0.9	24.3	26.0
1975	SEP	19	10:02	10:35	DIESEL	0.30	0.5		
1975	SEP	19	12:02	12:30	DIESEL	0.30	0.5	26.4	26.0
1975	OCT	3	10:44	11:40	DIESEL	0.30	0.9	24.3	26.0
1975	OCT	17	10:29	10:46	DIESEL	0.30	0.3	7.4	26.0
1975	NOV	11	8:48	10:07	DIESEL	0.30	1.3	34.2	26.0
1975	NOV	12	6:52	23:49	DIESEL	0.30	16.9	440.7	26.0
1975	NOV	24	14:10	15:37	DIESEL	0.30	1.4		
1975	NOV	24	19:08	19:25	DIESEL	0.30	0.3	45.1	26.0
1975	NOV	25	10:19	10:29	DIESEL	0.30	0.2		
1975	NOV	25	10:37	12:10	DIESEL	0.30	1.5	44.6	26.0
1975	DEC	4	16:54	23:56	DIESEL	0.30	7.0	182.9	26.0
1975	DEC	5	9:00	9:08	DIESEL	0.30	0.1	3.5	26.0
1975	DEC	26	17:55	18:15	DIESEL	0.30	0.3	8.7	26.0
1976	MAY	5	12:34	12:36	DIESEL	0.26	0.0		
1976	MAY	5	13:32	13:33	DIESEL	0.26	0.0		
1976	MAY	5	14:55	19:10	DIESEL	0.26	4.3	111.8	26.0
1976	MAY	6	14:26	19:02	DIESEL	0.26	4.6	119.6	26.0
1976	MAY	7	10:49	10:51	DIESEL	0.26	0.0		
1976	MAY	7	11:29	11:30	DIESEL	0.26	0.0		
1976	MAY	7	11:44	11:45	DIESEL	0.26	0.0		
1976	MAY	7	12:35	14:00	DIESEL	0.26	1.4	38.6	26.0
1976	MAY	10	9:17	9:18	DIESEL	0.26	0.0		
1976	MAY	10	11:50	11:52	DIESEL	0.26	0.0		
1976	MAY	10	12:00	12:01	DIESEL	0.26	0.0		
1976	MAY	10	12:31	13:35	DIESEL	0.26	1.1	29.5	26.0
1976	MAY	11	9:44	9:47	DIESEL	0.26	0.0		
1976	MAY	11	10:16	10:18	DIESEL	0.26	0.0		

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NAVAL STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	MAY	11	11:00	11:49	DIESEL	0.26	0.8		
1976	MAY	11	11:52	13:55	DIESEL	0.26	2.0	76.7	26.0
1976	MAY	12	14:00	14:01	DIESEL	0.26	0.0		
1976	MAY	12	14:22	14:30	DIESEL	0.26	0.1	3.9	26.0
1976	JUN	8	14:31	14:35	DIESEL	0.26	0.1		
1976	JUN	8	14:45	14:47	DIESEL	0.26	0.0	2.6	26.0
1976	JUN	9	8:00	12:29	DIESEL	0.26	4.5	116.6	26.0
1976	JUN	10	16:00	20:41	DIESEL	0.26	4.7	121.8	26.0
1976	JUN	12	19:31	20:31	DIESEL	0.26	1.0	26.0	26.0
1976	JUN	14	8:51	10:24	DIESEL	0.26	1.5		
1976	JUN	14	16:46	24:00	DIESEL	0.26	7.2	228.4	26.0
1976	JUN	16	0:00	15:18	DIESEL	0.26	15.3	397.8	26.0
1976	JUN	27	9:24	10:53	DIESEL	0.26	1.5	38.6	26.0
1976	JUN	28	8:15	9:58	DIESEL	0.26	1.7	44.6	26.0
1976	JUL	19	13:00	15:32	DIESEL	0.26	2.5	65.9	26.0
1976	JUL	20	9:11	11:19	DIESEL	0.26	2.1		
1976	JUL	20	11:23	11:25	DIESEL	0.26	0.0		
1976	JUL	20	16:50	16:51	DIESEL	0.26	0.0		
1976	JUL	20	17:41	18:45	DIESEL	0.26	1.1	84.5	26.0
1976	JUL	21	11:25	12:14	DIESEL	0.26	0.8	21.2	26.0
1976	AUG	4	11:28	12:55	DIESEL	0.26	1.4		
1976	AUG	4	14:25	17:20	DIESEL	0.26	2.9	113.5	26.0
1976	AUG	5	12:57	20:44	DIESEL	0.26	7.8	202.4	26.0
1976	AUG	6	11:40	13:56	DIESEL	0.26	2.3		
1976	AUG	6	16:36	17:54	DIESEL	0.26	1.3	92.7	26.0
1976	AUG	9	13:06	14:06	DIESEL	0.26	1.0	26.0	26.0
1976	AUG	12	8:16	14:07	DIESEL	0.26	5.8	152.1	26.0
1976	AUG	21	11:18	11:28	DIESEL	0.26	0.2		
1976	AUG	21	12:18	15:43	DIESEL	0.26	3.4	93.2	26.0
1976	AUG	23	11:12	11:13	DIESEL	0.26	0.0		
1976	AUG	23	11:18	16:18	DIESEL	0.26	5.0		
1976	AUG	23	16:30	17:32	DIESEL	0.26	1.0	157.3	26.0
1976	AUG	24	9:16	12:40	DIESEL	0.26	3.4		
1976	AUG	24	13:57	15:50	DIESEL	0.26	1.9		
1976	AUG	24	18:25	20:30	DIESEL	0.26	2.1	191.5	26.0
1976	AUG	25	20:14	20:55	DIESEL	0.26	0.7	17.8	26.0
1976	SEP	3	17:18	21:40	DIESEL	0.26	4.4	113.5	26.0
1976	SEP	4	14:28	15:57	DIESEL	0.26	1.5	38.6	26.0
1976	SEP	8	13:49	17:26	DIESEL	0.26	3.6	94.0	26.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NAVAL STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	SEP	16	14:30	17:32	DIESEL	0.26	3.0	78.9	26.0
1976	SEP	17	9:35	10:51	DIESEL	0.26	1.3	32.9	26.0
1976	SEP	22	11:06	11:50	DIESEL	0.26	0.7	19.1	26.0
1976	OCT	1	9:35	11:16	DIESEL	0.26	1.7	43.8	26.0
1976	OCT	6	13:00	13:22	DIESEL	0.26	0.4		
1976	OCT	6	14:05	15:20	DIESEL	0.26	1.3	42.0	26.0
1976	OCT	7	10:05	12:13	DIESEL	0.26	2.1		
1976	OCT	7	14:04	15:20	DIESEL	0.26	1.3	88.4	26.0
1976	OCT	8	9:45	17:05	DIESEL	0.26	7.3	190.7	26.0
1976	OCT	15	12:17	24:00	DIESEL	0.26	11.7	304.6	26.0
1976	OCT	16	0:00	1:23	DIESEL	0.26	1.4	36.0	26.0
1976	OCT	22	10:32	16:21	DIESEL	0.26	5.8	151.2	26.0
1976	NOV	16	9:23	24:00	DIESEL	0.26	14.6	380.0	26.0
1976	NOV	17	0:00	18:20	DIESEL	0.26	18.3	476.7	26.0
1976	NOV	23	17:59	18:41	DIESEL	0.26	0.7		
1976	NOV	23	18:46	18:50	DIESEL	0.26	0.1	19.9	26.0
1976	NOV	24	16:45	17:21	DIESEL	0.26	0.6		
1976	NOV	24	23:27	23:32	DIESEL	0.26	0.1	17.8	26.0
1976	NOV	25	0:48	3:04	DIESEL	0.26	2.3		
1976	NOV	25	4:00	4:35	DIESEL	0.26	0.6	74.1	26.0
1976	NOV	28	17:02	18:59	DIESEL	0.26	1.9	50.7	26.0
1976	NOV	29	15:22	24:00	DIESEL	0.26	8.6	224.5	26.0
1976	DEC	8	0:00	11:15	DIESEL	0.26	11.3		
1976	DEC	8	14:33	14:34	DIESEL	0.26	0.0		
1976	DEC	8	14:36	14:39	DIESEL	0.26	0.0	294.2	26.0
1976	DEC	14	16:20	16:24	DIESEL	0.26	0.1		
1976	DEC	14	16:40	24:00	DIESEL	0.26	7.3	192.4	26.0
1976	DEC	17	8:07	9:18	DIESEL	0.26	1.2	30.8	26.0
1976	DEC	21	7:00	7:07	DIESEL	0.26	0.1		
1976	DEC	21	18:20	18:22	DIESEL	0.26	0.0		
1976	DEC	21	22:36	22:38	DIESEL	0.26	0.0		
1976	DEC	21	23:42	23:47	DIESEL	0.26	0.1	6.9	26.0
1976	DEC	22	13:40	15:28	DIESEL	0.26	1.8		
1976	DEC	22	21:18	24:00	DIESEL	0.26	2.7	117.0	26.0
1976	DEC	23	2:29	13:12	DIESEL	0.26	10.7	278.6	26.0
1977	JAN	3	11:40	15:34	DIESEL	0.29	3.9	101.4	26.0
1977	JAN	4	7:23	15:38	DIESEL	0.29	8.3	214.5	26.0
1977	JAN	5	6:50	13:15	DIESEL	0.29	6.4	166.8	26.0
1977	JAN	6	0:00	5:03	DIESEL	0.29	5.0		

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NAVAL STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JAN	6	5:40	5:41	DIESEL	0.29	0.0		
1977	JAN	6	16:21	16:22	DIESEL	0.29	0.0		
1977	JAN	6	16:42	16:43	DIESEL	0.29	0.0		
1977	JAN	6	18:18	18:19	DIESEL	0.29	0.0		
1977	JAN	6	18:29	18:30	DIESEL	0.29	0.0		
1977	JAN	6	18:37	20:09	DIESEL	0.29	1.5	173.3	26.0
1977	JAN	13	9:16	11:45	DIESEL	0.29	2.5		
1977	JAN	13	11:50	13:47	DIESEL	0.29	1.9	115.3	26.0
1977	JAN	17	0:00	19:48	DIESEL	0.29	19.8	514.8	26.0
1977	JAN	18	13:31	24:00	DIESEL	0.29	10.5	272.6	26.0
1977	JAN	19	0:00	10:49	DIESEL	0.29	10.8		
1977	JAN	19	15:57	20:05	DIESEL	0.29	4.1	388.7	26.0
1977	JAN	20	0:00	0:59	DIESEL	0.29	1.0		
1977	JAN	20	11:23	24:00	DIESEL	0.29	12.6	353.6	26.0
1977	JAN	21	16:50	20:30	DIESEL	0.29	3.7	95.3	26.0
1977	JAN	23	16:50	19:47	DIESEL	0.29	2.9	76.7	26.0
1977	JAN	24	7:13	20:40	DIESEL	0.29	13.4	349.7	26.0
1977	JAN	25	8:43	24:00	DIESEL	0.29	15.3	397.4	26.0
1977	JAN	28	0:00	19:35	DIESEL	0.29	19.6	509.2	26.0
1977	JAN	29	17:15	18:58	DIESEL	0.29	1.7	44.6	26.0
1977	FEB	2	8:59	9:48	DIESEL	0.29	0.8	21.2	26.0
1977	FEB	3	7:31	13:46	DIESEL	0.29	6.3	162.5	26.0
1977	FEB	5	7:20	24:00	DIESEL	0.29	16.7	433.3	26.0
1977	FEB	6	13:55	15:40	DIESEL	0.29	1.8	45.5	26.0
1977	FEB	7	0:00	14:12	DIESEL	0.29	14.2	369.2	26.0
1977	FEB	8	12:55	13:24	DIESEL	0.29	0.5		
1977	FEB	8	17:10	21:37	DIESEL	0.29	4.4	128.3	26.0
1977	FEB	9	10:33	24:00	DIESEL	0.29	13.4	349.7	26.0
1977	FEB	12	15:49	19:41	DIESEL	0.29	3.9	100.5	26.0
1977	FEB	14	0:00	19:01	DIESEL	0.29	19.0	494.4	26.0
1977	FEB	17	17:34	18:49	DIESEL	0.29	1.3	32.5	26.0
1977	FEB	21	7:13	24:00	DIESEL	0.29	16.8	436.4	26.0
1977	FEB	22	0:00	3:54	DIESEL	0.29	3.9		
1977	FEB	22	16:50	19:42	DIESEL	0.29	2.9	175.9	26.0
1977	FEB	23	18:39	19:35	DIESEL	0.29	0.9	24.3	26.0
1977	FEB	25	14:01	14:10	DIESEL	0.29	0.1	3.9	26.0
1977	FEB	26	4:01	5:00	DIESEL	0.29	1.0		
1977	FEB	26	20:55	23:07	DIESEL	0.29	2.2	82.8	26.0
1977	MAR	1	2:05	2:25	DIESEL	0.29	0.3	8.7	26.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NAVAL STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	MAR	2	17:30	17:47	DIESEL	0.29	0.3	7.4	26.0
1977	MAR	4	13:17	13:48	DIESEL	0.29	0.5		
1977	MAR	4	14:03	15:15	DIESEL	0.29	1.2	44.6	26.0
1977	MAR	5	10:58	11:34	DIESEL	0.29	0.6	15.6	26.0
1977	MAR	7	3:40	5:23	DIESEL	0.29	1.7		
1977	MAR	7	7:43	9:28	DIESEL	0.29	1.8		
1977	MAR	7	12:15	13:15	DIESEL	0.29	1.0	116.1	26.0
1977	MAR	8	10:05	10:06	DIESEL	0.29	0.0		
1977	MAR	8	10:25	10:26	DIESEL	0.29	0.0		
1977	MAR	8	10:45	10:46	DIESEL	0.29	0.0		
1977	MAR	8	13:48	13:51	DIESEL	0.29	0.0	2.6	26.0
1977	MAR	10	20:05	24:00	DIESEL	0.29	3.9	101.8	26.0
1977	MAR	11	0:00	19:06	DIESEL	0.29	19.1	496.6	26.0
1977	MAR	15	13:05	14:09	DIESEL	0.29	1.1	27.7	26.0
1977	MAR	17	12:48	18:00	DIESEL	0.29	5.2	135.2	26.0
1977	MAR	18	8:40	12:47	DIESEL	0.29	4.1	107.0	26.0
1977	MAR	22	9:00	13:30	DIESEL	0.29	4.5	117.0	26.0
1977	MAR	23	8:17	9:42	DIESEL	0.29	1.4	36.8	26.0
1977	MAR	25	15:19	24:00	DIESEL	0.29	8.7	225.8	26.0
1977	MAR	28	0:00	12:05	DIESEL	0.29	12.1	314.2	26.0
1977	JUN	3	16:54	16:55	DIESEL	0.29	0.0		
1977	JUN	3	17:00	17:01	DIESEL	0.29	0.0		
1977	JUN	3	17:14	17:16	DIESEL	0.29	0.0		
1977	JUN	3	17:44	17:46	DIESEL	0.29	0.0		
1977	JUN	3	18:21	18:23	DIESEL	0.29	0.0		
1977	JUN	3	19:20	19:36	DIESEL	0.29	0.3	10.4	26.0
1977	JUN	4	9:04	19:40	DIESEL	0.29	10.6	275.6	26.0
1977	JUN	5	10:54	19:12	DIESEL	0.29	8.3	215.8	26.0
1977	JUN	6	8:59	9:17	DIESEL	0.29	0.3		
1977	JUN	6	10:17	11:37	DIESEL	0.29	1.3		
1977	JUN	6	13:24	17:46	DIESEL	0.29	4.4	156.0	26.0
1977	JUN	7	14:50	15:58	DIESEL	0.29	1.1	29.5	26.0
1977	JUN	8	8:07	15:15	DIESEL	0.29	7.1	185.5	26.0
1977	JUN	14	9:51	9:52	DIESEL	0.29	0.0		
1977	JUN	14	9:53	9:54	DIESEL	0.29	0.0		
1977	JUN	14	9:57	10:04	DIESEL	0.29	0.1		
1977	JUN	14	10:25	11:53	DIESEL	0.29	1.5	42.0	26.0
1977	JUN	22	13:30	13:58	DIESEL	0.29	0.5	12.1	26.0
1977	JUN	27	16:17	17:17	DIESEL	0.29	1.0	26.0	26.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NAVAL STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JUN	29	16:22	16:25	DIESEL	0.29	0.0		
1977	JUN	29	19:44	20:59	DIESEL	0.29	1.3	33.8	26.0
1977	JUL	21	6:48	16:40	DIESEL	0.29	9.9	256.5	26.0
1977	JUL	22	20:22	21:20	DIESEL	0.29	1.0	25.1	26.0
1977	JUL	25	13:42	22:00	DIESEL	0.29	8.3	215.8	26.0
1977	JUL	28	9:52	20:50	DIESEL	0.29	11.0	285.1	26.0
1977	JUL	29	10:06	19:00	DIESEL	0.29	8.9	231.4	26.0
1977	SEP	22	15:43	15:51	DIESEL	0.29	0.1		
1977	SEP	22	16:28	17:17	DIESEL	0.29	0.8		
1977	SEP	22	18:05	18:30	DIESEL	0.29	0.4	35.5	26.0
1977	SEP	23	9:13	9:58	DIESEL	0.29	0.8		
1977	SEP	23	13:27	13:29	DIESEL	0.29	0.0		
1977	SEP	23	13:45	13:47	DIESEL	0.29	0.0	21.2	26.0
1977	OCT	14	14:20	14:23	DIESEL	0.29	0.0		
1977	OCT	14	14:37	15:00	DIESEL	0.29	0.4	11.3	26.0
1977	OCT	17	16:40	16:41	DIESEL	0.29	0.0		
1977	OCT	17	16:44	16:46	DIESEL	0.29	0.0		
1977	OCT	17	16:56	17:07	DIESEL	0.29	0.2		
1977	OCT	17	18:03	23:57	DIESEL	0.29	5.9	159.5	26.0
1977	OCT	27	8:59	9:02	DIESEL	0.29	0.1		
1977	OCT	27	9:12	16:28	DIESEL	0.29	7.3	190.2	26.0
1977	OCT	28	15:04	15:07	DIESEL	0.29	0.0		
1977	OCT	28	15:11	16:42	DIESEL	0.29	1.5	40.7	26.0
1977	NOV	4	9:39	9:40	DIESEL	0.29	0.0		
1977	NOV	4	9:45	19:19	DIESEL	0.29	9.6	249.2	26.0
1977	NOV	5	3:44	3:46	DIESEL	0.29	0.0		
1977	NOV	5	3:54	24:00	DIESEL	0.29	20.1	523.5	26.0
1977	NOV	6	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	NOV	7	0:00	8:43	DIESEL	0.29	8.7		
1977	NOV	7	22:24	22:26	DIESEL	0.29	0.0	227.5	26.0
1977	NOV	9	11:30	11:44	DIESEL	0.29	0.2		
1977	NOV	9	12:33	16:09	DIESEL	0.29	3.6	99.7	26.0
1977	NOV	10	7:11	7:14	DIESEL	0.29	0.0	1.3	26.0
1977	NOV	11	7:15	24:00	DIESEL	0.29	16.8	435.5	26.0
1977	NOV	12	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	NOV	13	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	NOV	14	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	NOV	15	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	NOV	16	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NAVAL STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	NOV	17	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	NOV	18	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	NOV	19	0:00	14:42	DIESEL	0.29	14.7	382.2	26.0
1977	DEC	1	17:00	24:00	DIESEL	0.29	7.0	182.0	26.0
1977	DEC	2	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	3	0:00	3:30	DIESEL	0.29	3.5	91.0	26.0
1977	DEC	4	8:17	24:00	DIESEL	0.29	15.7	408.6	26.0
1977	DEC	5	0:00	20:37	DIESEL	0.29	20.6	536.0	26.0
1977	DEC	7	17:10	17:46	DIESEL	0.29	0.6		
1977	DEC	7	19:29	19:45	DIESEL	0.29	0.3	22.5	26.0
1977	DEC	8	9:17	24:00	DIESEL	0.29	14.7	382.6	26.0
1977	DEC	9	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	10	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	11	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	12	0:00	6:59	DIESEL	0.29	7.0	181.6	26.0
1977	DEC	17	12:12	12:19	DIESEL	0.29	0.1	3.0	26.0
1977	DEC	19	17:51	21:09	DIESEL	0.29	3.3	85.8	26.0
1977	DEC	20	16:51	19:15	DIESEL	0.29	2.4	62.4	26.0
1977	DEC	21	17:06	17:22	DIESEL	0.29	0.3		
1977	DEC	21	18:33	18:47	DIESEL	0.29	0.2	13.0	26.0
1977	DEC	22	10:30	24:00	DIESEL	0.29	13.5	351.0	26.0
1977	DEC	23	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	24	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	25	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	26	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	27	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	28	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	29	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	30	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0
1977	DEC	31	0:00	24:00	DIESEL	0.29	24.0	624.0	26.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	6	9:40	12:05	DIESEL	0.30	2.4		
1975	JAN	6	13:20	15:05	DIESEL	0.30	1.8	95.8	23.0
1975	JAN	16	12:18	12:41	DIESEL	0.30	0.4	8.8	23.0
1975	JAN	28	12:55	14:20	DIESEL	0.30	1.4		
1975	JAN	28	14:45	15:15	DIESEL	0.30	0.5	44.1	23.0
1975	JAN	30	14:10	14:42	DIESEL	0.30	0.5		
1975	JAN	30	15:17	15:30	DIESEL	0.30	0.2	17.2	23.0
1975	JAN	31	13:22	14:00	DIESEL	0.30	0.6		
1975	JAN	31	16:04	16:35	DIESEL	0.30	0.5	26.4	23.0
1975	FEB	4	10:15	12:05	DIESEL	0.30	1.8		
1975	FEB	4	12:50	13:45	DIESEL	0.30	0.9		
1975	FEB	4	14:07	14:35	DIESEL	0.30	0.5	74.0	23.0
1975	FEB	7	8:37	12:10	DIESEL	0.30	3.5	81.6	23.0
1975	MAR	1	14:56	23:48	DIESEL	0.30	8.9	203.9	23.0
1975	MAR	6	13:59	14:35	DIESEL	0.30	0.6	13.8	23.0
1975	MAR	12	15:08	15:38	DIESEL	0.30	0.5	11.5	23.0
1975	MAR	20	12:00	13:53	DIESEL	0.30	1.9		
1975	MAR	20	14:15	14:35	DIESEL	0.30	0.3	51.0	23.0
1975	APR	11	12:12	12:26	DIESEL	0.30	0.2	5.4	23.0
1975	APR	21	17:14	19:00	DIESEL	0.30	1.8	40.6	23.0
1975	MAY	8	10:45	11:13	DIESEL	0.30	0.5		
1975	MAY	8	11:32	11:48	DIESEL	0.30	0.3	16.9	23.0
1975	MAY	23	11:07	15:11	DIESEL	0.30	4.1	93.5	23.0
1975	JUL	1	11:15	13:00	DIESEL	0.30	1.8	40.3	23.0
1975	AUG	20	11:10	12:08	DIESEL	0.30	1.0	22.2	23.0
1975	AUG	25	9:40	10:39	DIESEL	0.30	1.0	22.6	23.0
1975	AUG	27	7:14	9:19	DIESEL	0.30	2.1	47.9	23.0
1975	SEP	11	6:11	15:47	DIESEL	0.30	9.6	220.8	23.0
1975	SEP	12	7:01	7:05	DIESEL	0.30	0.1		
1975	SEP	12	8:01	15:52	DIESEL	0.30	7.8	182.1	23.0
1975	SEP	16	12:14	15:40	DIESEL	0.30	3.4	79.0	23.0
1975	SEP	23	14:04	16:07	DIESEL	0.30	2.0		
1975	SEP	23	17:38	18:46	DIESEL	0.30	1.1	73.2	23.0
1975	OCT	23	6:42	14:46	DIESEL	0.30	8.1	185.5	23.0
1975	NOV	6	9:45	9:47	DIESEL	0.30	0.0		
1975	NOV	6	10:03	10:25	DIESEL	0.30	0.4	9.2	23.0
1975	DEC	2	9:15	9:17	DIESEL	0.30	0.0		
1975	DEC	2	9:20	9:22	DIESEL	0.30	0.0	1.5	23.0
1975	DEC	5	9:31	9:32	DIESEL	0.30	0.0		

NEG = NEGLIGIBLE

[illegible] HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	DEC	5	9:38	9:39	DIESEL	0.30	0.0		
1975	DEC	5	10:03	10:04	DIESEL	0.30	0.0		
1975	DEC	5	11:26	11:27	DIESEL	0.30	0.0		
1975	DEC	5	12:59	13:00	DIESEL	0.30	0.0		
1975	DEC	5	13:28	13:29	DIESEL	0.30	0.0		
1975	DEC	5	14:01	14:02	DIESEL	0.30	0.0		
1975	DEC	5	14:14	14:15	DIESEL	0.30	0.0	3.1	23.0
1975	DEC	8	10:56	10:57	DIESEL	0.30	0.0		
1975	DEC	8	12:45	12:55	DIESEL	0.30	0.2		
1975	DEC	8	14:45	14:47	DIESEL	0.30	0.0	5.0	23.0
1975	DEC	10	14:14	14:15	DIESEL	0.30	0.0	0.4	23.0
1975	DEC	15	13:44	13:45	DIESEL	0.30	0.0		
1975	DEC	15	14:15	14:16	DIESEL	0.30	0.0	0.8	23.0
1975	DEC	16	10:24	10:35	DIESEL	0.30	0.2	4.2	23.0
1976	JAN	6	17:55	19:03	DIESEL	0.26	1.1	26.1	23.0
1976	JAN	7	7:27	8:50	DIESEL	0.26	1.4	31.8	23.0
1976	JAN	8	7:04	12:14	DIESEL	0.26	5.2		
1976	JAN	8	12:55	15:04	DIESEL	0.26	2.1		
1976	JAN	8	15:07	23:57	DIESEL	0.26	8.8	371.4	23.0
1976	JAN	9	6:24	13:09	DIESEL	0.26	6.8	155.3	23.0
1976	JAN	10	17:30	19:01	DIESEL	0.26	1.5	34.9	23.0
1976	JAN	11	17:36	18:10	DIESEL	0.26	0.6	13.0	23.0
1976	JAN	12	10:45	12:00	DIESEL	0.26	1.3		
1976	JAN	12	14:32	14:52	DIESEL	0.26	0.3	36.4	23.0
1976	JAN	13	11:24	15:03	DIESEL	0.26	3.6	83.9	23.0
1976	JAN	15	9:25	11:24	DIESEL	0.26	2.0	45.6	23.0
1976	JAN	21	4:17	5:58	DIESEL	0.26	1.7	38.7	23.0
1976	FEB	5	17:11	21:45	DIESEL	0.26	4.6	105.0	23.0
1976	FEB	6	17:40	19:19	DIESEL	0.26	1.6	37.9	23.0
1976	FEB	8	13:48	16:44	DIESEL	0.26	2.9	67.5	23.0
1976	FEB	9	9:32	11:26	DIESEL	0.26	1.9	43.7	23.0
1976	FEB	13	7:32	14:12	DIESEL	0.26	6.7	153.3	23.0
1976	FEB	14	17:47	19:10	DIESEL	0.26	1.4	31.8	23.0
1976	FEB	17	17:05	19:33	DIESEL	0.26	2.5	56.7	23.0
1976	FEB	21	18:19	18:50	DIESEL	0.26	0.5	11.9	23.0
1976	MAR	1	18:02	20:20	DIESEL	0.26	2.3	52.9	23.0
1976	MAR	2	9:17	11:33	DIESEL	0.26	2.3		
1976	MAR	2	17:36	20:57	DIESEL	0.26	3.3	129.2	23.0
1976	MAR	3	17:47	21:16	DIESEL	0.26	3.5	80.1	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	MAR	4	7:34	14:06	DIESEL	0.26	6.5		
1976	MAR	4	18:01	20:41	DIESEL	0.26	2.7	211.6	23.0
1976	MAR	5	8:19	14:55	DIESEL	0.26	6.6	151.8	23.0
1976	MAR	6	9:35	10:36	DIESEL	0.26	1.0	23.4	23.0
1976	MAR	16	11:10	11:42	DIESEL	0.26	0.5	12.3	23.0
1976	APR	1	9:22	10:32	DIESEL	0.26	1.2		
1976	APR	1	10:32	11:44	DIESEL	0.26	1.2	54.4	23.0
1976	APR	7	3:28	4:23	DIESEL	0.26	0.9	21.1	23.0
1976	APR	27	7:58	20:01	DIESEL	0.26	12.0	277.1	23.0
1976	APR	28	7:25	9:55	DIESEL	0.26	2.5	57.5	23.0
1976	MAY	11	15:24	16:04	DIESEL	0.26	0.7	15.3	23.0
1976	MAY	15	16:30	16:31	DIESEL	0.26	0.0		
1976	MAY	15	17:02	17:33	DIESEL	0.26	0.5	12.3	23.0
1976	MAY	27	15:18	17:25	DIESEL	0.26	2.1		
1976	MAY	27	17:44	22:38	DIESEL	0.26	4.9	161.4	23.0
1976	MAY	28	6:21	9:37	DIESEL	0.26	3.3	75.1	23.0
1976	JUN	5	10:19	10:32	DIESEL	0.26	0.2	5.0	23.0
1976	JUN	8	14:41	14:57	DIESEL	0.26	0.3	6.1	23.0
1976	JUN	26	12:01	12:57	DIESEL	0.26	0.9	21.5	23.0
1976	JUN	28	12:17	17:11	DIESEL	0.26	4.9	112.7	23.0
1976	JUL	4	16:49	17:00	DIESEL	0.26	0.2	4.2	23.0
1976	AUG	2	10:58	12:29	DIESEL	0.26	1.5	34.9	23.0
1976	AUG	4	11:27	11:45	DIESEL	0.26	0.3	6.9	23.0
1976	AUG	18	13:50	14:15	DIESEL	0.26	0.4		
1976	AUG	18	15:55	16:05	DIESEL	0.26	0.2	13.4	23.0
1976	AUG	23	13:59	14:17	DIESEL	0.26	0.3	6.9	23.0
1976	SEP	4	14:20	15:31	DIESEL	0.26	1.2	27.2	23.0
1976	SEP	10	0:54	1:18	DIESEL	0.26	0.4	9.2	23.0
1976	SEP	14	9:36	10:06	DIESEL	0.26	0.5		
1976	SEP	14	14:23	14:34	DIESEL	0.26	0.2	15.7	23.0
1976	SEP	16	12:15	16:31	DIESEL	0.26	4.3	98.1	23.0
1976	OCT	4	9:33	10:24	DIESEL	0.26	0.9	19.5	23.0
1976	OCT	28	18:17	19:31	DIESEL	0.26	1.2	28.4	23.0
1976	NOV	20	12:40	13:50	DIESEL	0.26	1.2		
1976	NOV	20	16:01	16:40	DIESEL	0.26	0.6		
1976	NOV	20	17:52	18:04	DIESEL	0.26	0.2		
1976	NOV	20	18:10	18:11	DIESEL	0.26	0.0	46.8	23.0
1976	NOV	23	18:21	19:18	DIESEL	0.26	1.0		
1976	NOV	23	19:43	21:40	DIESEL	0.26	1.9	66.7	23.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	NOV	28	17:04	18:48	DIESEL	0.26	1.7	39.9	23.0
1976	DEC	9	11:13	11:37	DIESEL	0.26	0.4		
1976	DEC	9	17:07	18:40	DIESEL	0.26	1.5	44.8	23.0
1976	DEC	21	9:20	18:48	DIESEL	0.26	9.5	217.7	23.0
1976	DEC	26	17:38	20:24	DIESEL	0.26	2.8	63.6	23.0
1976	DEC	27	8:46	19:54	DIESEL	0.26	11.1	256.1	23.0
1976	DEC	30	17:25	20:21	DIESEL	0.26	2.9	67.5	23.0
1976	DEC	31	17:28	18:33	DIESEL	0.26	1.1	24.9	23.0
1977	JAN	4	8:53	9:49	DIESEL	0.29	0.9		
1977	JAN	4	17:15	20:22	DIESEL	0.29	3.1	93.1	23.0
1977	JAN	5	8:53	15:24	DIESEL	0.29	6.5	149.9	23.0
1977	JAN	18	10:46	13:00	DIESEL	0.29	2.2		
1977	JAN	18	14:34	14:55	DIESEL	0.29	0.3		
1977	JAN	18	20:58	22:40	DIESEL	0.29	1.7	98.5	23.0
1977	JAN	31	9:00	9:47	DIESEL	0.29	0.8		
1977	JAN	31	10:13	15:00	DIESEL	0.29	4.8	128.0	23.0
1977	FEB	9	12:59	13:42	DIESEL	0.29	0.7	16.5	23.0
1977	FEB	11	8:54	11:49	DIESEL	0.29	2.9	67.1	23.0
1977	FEB	16	10:52	11:10	DIESEL	0.29	0.3	6.9	23.0
1977	APR	18	18:24	19:58	DIESEL	0.29	1.6	36.0	23.0
1977	APR	29	8:40	10:00	DIESEL	0.29	1.3	30.7	23.0
1977	MAY	6	15:55	16:04	DIESEL	0.29	0.2	3.5	23.0
1977	MAY	14	7:58	15:28	DIESEL	0.29	7.5	172.5	23.0
1977	MAY	19	14:51	16:45	DIESEL	0.29	1.9	43.7	23.0
1977	MAY	23	8:03	8:31	DIESEL	0.29	0.5		
1977	MAY	23	10:00	14:10	DIESEL	0.29	4.2	106.6	23.0
1977	JUN	20	10:30	11:45	DIESEL	0.29	1.3	28.8	23.0
1977	JUL	25	12:38	24:00	DIESEL	0.29	11.4	261.4	23.0
1977	JUL	26	15:08	16:31	DIESEL	0.29	1.4	31.8	23.0
1977	JUL	29	13:37	14:25	DIESEL	0.29	0.8		
1977	JUL	29	14:40	16:24	DIESEL	0.29	1.7	58.3	23.0
1977	AUG	3	10:21	18:38	DIESEL	0.29	8.3	190.5	23.0
1977	AUG	5	15:20	15:32	DIESEL	0.29	0.2		
1977	AUG	5	16:05	16:10	DIESEL	0.29	0.1	6.5	23.0
1977	AUG	9	13:32	13:53	DIESEL	0.29	0.3	8.0	23.0
1977	AUG	26	9:06	16:45	DIESEL	0.29	7.6	175.9	23.0
1977	SEP	22	11:30	12:00	DIESEL	0.29	0.5	11.5	23.0
1977	OCT	4	12:21	16:15	DIESEL	0.29	3.9		
1977	OCT	4	18:29	19:52	DIESEL	0.29	1.4	121.5	23.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	OCT	29	10:49	11:45	DIESEL	0.29	0.9	21.5	23.0
1977	NOV	6	14:14	15:28	DIESEL	0.29	1.2	28.4	23.0
1977	NOV	15	10:18	13:51	DIESEL	0.29	3.5	81.6	23.0
1977	NOV	21	8:35	12:58	DIESEL	0.29	4.4		
1977	NOV	21	16:39	20:42	DIESEL	0.29	4.0	194.0	23.0
1977	NOV	22	7:49	14:20	DIESEL	0.29	6.5		
1977	NOV	22	17:29	18:21	DIESEL	0.29	0.9	169.8	23.0
1977	NOV	23	17:17	18:43	DIESEL	0.29	1.4	33.0	23.0
1977	NOV	30	17:06	19:10	DIESEL	0.29	2.1	47.5	23.0
1977	DEC	7	16:49	18:01	DIESEL	0.29	1.2	27.6	23.0
1977	DEC	12	17:08	17:57	DIESEL	0.29	0.8	18.8	23.0
1977	DEC	31	17:45	19:00	DIESEL	0.29	1.3	28.8	23.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	16	12:18	12:41	DIESEL	0.30	0.4	8.8	23.0
1975	JAN	30	10:25	11:40	DIESEL	0.30	1.3	28.8	23.0
1975	FEB	28	8:08	8:35	DIESEL	0.30	0.4	10.3	23.0
1975	MAR	13	12:47	12:58	DIESEL	0.30	0.2		
1975	MAR	13	13:25	14:45	DIESEL	0.30	1.3	34.9	23.0
1975	MAR	14	8:20	9:00	DIESEL	0.30	0.7		
1975	MAR	14	10:55	13:04	DIESEL	0.30	2.1		
1975	MAR	14	15:02	15:58	DIESEL	0.30	0.9	86.2	23.0
1975	MAR	19	11:04	14:42	DIESEL	0.30	3.6	83.6	23.0
1975	APR	10	8:25	12:30	DIESEL	0.30	4.1	93.9	23.0
1975	APR	19	17:53	21:39	DIESEL	0.30	3.8	86.6	23.0
1975	APR	21	7:04	22:41	DIESEL	0.30	15.6	359.2	23.0
1975	APR	24	13:29	13:50	DIESEL	0.30	0.3	8.0	23.0
1975	APR	29	19:52	19:56	DIESEL	0.30	0.1	1.5	23.0
1975	MAY	1	15:21	15:46	DIESEL	0.30	0.4	9.6	23.0
1975	MAY	23	9:47	13:38	DIESEL	0.30	3.8	88.5	23.0
1975	JUN	17	9:45	10:40	DIESEL	0.30	0.9	21.1	23.0
1975	JUL	10	11:46	22:26	DIESEL	0.30	10.7		
1975	JUL	10	22:46	23:32	DIESEL	0.30	0.8	263.0	23.0
1975	JUL	11	12:32	13:49	DIESEL	0.30	1.3	29.5	23.0
1975	JUL	14	9:45	10:54	DIESEL	0.30	1.1	26.4	23.0
1975	AUG	22	10:33	11:45	DIESEL	0.30	1.2	27.6	23.0
1975	AUG	25	10:00	22:27	DIESEL	0.30	12.4	286.3	23.0
1975	SEP	4	14:49	15:18	DIESEL	0.30	0.5	11.1	23.0
1975	SEP	6	9:26	9:54	DIESEL	0.30	0.5	10.7	23.0
1975	SEP	12	7:05	7:15	DIESEL	0.30	0.2		
1975	SEP	12	7:25	7:38	DIESEL	0.30	0.2		
1975	SEP	12	8:54	9:01	DIESEL	0.30	0.1	11.5	23.0
1975	SEP	16	12:33	15:22	DIESEL	0.30	2.8	64.8	23.0
1975	SEP	23	13:53	14:07	DIESEL	0.30	0.2		
1975	SEP	23	17:38	17:56	DIESEL	0.30	0.3		
1975	SEP	23	18:00	18:54	DIESEL	0.30	0.9	33.0	23.0
1975	NOV	11	15:21	19:22	DIESEL	0.30	4.0	92.4	23.0
1975	NOV	12	7:31	22:08	DIESEL	0.30	14.6	336.2	23.0
1975	NOV	13	7:11	23:58	DIESEL	0.30	16.8	386.0	23.0
1975	NOV	14	6:51	24:00	DIESEL	0.30	17.1	394.4	23.0
1975	NOV	18	7:16	11:31	DIESEL	0.30	4.3	97.8	23.0
1975	NOV	24	9:18	14:10	DIESEL	0.30	4.9		
1975	NOV	24	15:37	15:58	DIESEL	0.30	0.3		

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	NOV	24	16:51	19:05	DIESEL	0.30	2.2		
1975	NOV	24	19:05	21:11	DIESEL	0.30	2.1	219.6	23.0
1975	NOV	26	6:42	14:40	DIESEL	0.30	8.0	183.2	23.0
1975	DEC	2	13:25	14:15	DIESEL	0.30	0.8	19.2	23.0
1975	DEC	4	15:48	17:09	DIESEL	0.30	1.3	31.0	23.0
1975	DEC	5	8:38	9:20	DIESEL	0.30	0.7	16.1	23.0
1975	DEC	16	10:45	12:15	DIESEL	0.30	1.5	34.5	23.0
1976	JAN	6	7:37	11:04	DIESEL	0.26	3.4	79.3	23.0
1976	JAN	8	12:14	12:57	DIESEL	0.26	0.7		
1976	JAN	8	15:04	15:07	DIESEL	0.26	0.0	17.6	23.0
1976	JAN	10	17:21	18:48	DIESEL	0.26	1.4	33.3	23.0
1976	JAN	21	4:17	6:00	DIESEL	0.26	1.7	39.5	23.0
1976	FEB	5	17:26	18:53	DIESEL	0.26	1.4	33.3	23.0
1976	FEB	12	8:11	16:21	DIESEL	0.26	8.2		
1976	FEB	12	21:47	21:52	DIESEL	0.26	0.1	189.7	23.0
1976	FEB	23	9:51	14:50	DIESEL	0.26	5.0		
1976	FEB	23	16:43	19:55	DIESEL	0.26	3.2	188.2	23.0
1976	FEB	27	9:23	11:32	DIESEL	0.26	2.1	49.4	23.0
1976	FEB	28	18:11	19:56	DIESEL	0.26	1.8	40.3	23.0
1976	MAR	1	15:10	20:45	DIESEL	0.26	5.6	128.4	23.0
1976	MAR	4	7:19	14:29	DIESEL	0.26	7.2	164.8	23.0
1976	MAR	5	8:19	15:00	DIESEL	0.26	6.7	153.7	23.0
1976	MAR	15	6:08	9:15	DIESEL	0.26	3.1	71.7	23.0
1976	MAR	16	6:24	24:00	DIESEL	0.26	17.6	404.8	23.0
1976	MAR	17	0:00	0:18	DIESEL	0.26	0.3	6.9	23.0
1976	APR	6	17:58	21:38	DIESEL	0.26	3.7	84.3	23.0
1976	APR	7	3:28	4:23	DIESEL	0.26	0.9	21.1	23.0
1976	APR	19	19:04	20:09	DIESEL	0.26	1.1	24.9	23.0
1976	APR	30	9:18	15:35	DIESEL	0.26	6.3	144.5	23.0
1976	MAY	13	10:52	13:00	DIESEL	0.26	2.1		
1976	MAY	13	20:02	20:16	DIESEL	0.26	0.2	54.4	23.0
1976	MAY	16	15:43	15:45	DIESEL	0.26	0.0		
1976	MAY	16	15:45	15:55	DIESEL	0.26	0.2		
1976	MAY	16	16:30	17:17	DIESEL	0.26	0.8	22.6	23.0
1976	MAY	19	17:50	21:08	DIESEL	0.26	3.3	75.9	23.0
1976	MAY	26	13:36	15:03	DIESEL	0.26	1.4	33.3	23.0
1976	MAY	27	15:18	21:35	DIESEL	0.26	6.3	144.5	23.0
1976	JUN	5	10:45	11:15	DIESEL	0.26	0.5	11.5	23.0
1976	JUN	8	14:41	14:57	DIESEL	0.26	0.3	6.1	23.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JUN	10	10:38	10:39	DIESEL	0.26	0.0	0.4	23.0
1976	JUN	21	9:15	12:35	DIESEL	0.26	3.3	76.7	23.0
1976	JUN	27	14:34	16:22	DIESEL	0.26	1.8		
1976	JUN	27	16:47	16:53	DIESEL	0.26	0.1	43.7	23.0
1976	JUN	30	10:47	10:55	DIESEL	0.26	0.1	3.1	23.0
1976	JUL	4	16:49	16:59	DIESEL	0.26	0.2	3.8	23.0
1976	JUL	14	7:45	15:39	DIESEL	0.26	7.9	181.7	23.0
1976	AUG	2	10:58	12:26	DIESEL	0.26	1.5	33.7	23.0
1976	AUG	4	11:27	11:41	DIESEL	0.26	0.2	5.4	23.0
1976	AUG	12	6:38	7:25	DIESEL	0.26	0.8	18.0	23.0
1976	AUG	19	8:27	9:57	DIESEL	0.26	1.5	34.5	23.0
1976	AUG	23	14:05	14:10	DIESEL	0.26	0.1	1.9	23.0
1976	SEP	4	14:20	15:31	DIESEL	0.26	1.2	27.2	23.0
1976	SEP	10	0:54	1:18	DIESEL	0.26	0.4	9.2	23.0
1976	SEP	17	10:58	11:24	DIESEL	0.26	0.4		
1976	SEP	17	13:08	13:22	DIESEL	0.26	0.2	15.3	23.0
1976	SEP	24	11:27	11:52	DIESEL	0.26	0.4		
1976	SEP	24	12:15	12:17	DIESEL	0.26	0.0	10.3	23.0
1976	SEP	29	15:57	17:00	DIESEL	0.26	1.0	24.1	23.0
1976	OCT	5	10:15	12:03	DIESEL	0.26	1.8	41.4	23.0
1976	OCT	29	18:18	20:15	DIESEL	0.26	1.9	44.8	23.0
1976	OCT	31	8:03	8:44	DIESEL	0.26	0.7	15.7	23.0
1976	NOV	3	15:21	18:21	DIESEL	0.26	3.0	69.0	23.0
1976	NOV	11	16:32	19:21	DIESEL	0.26	2.8	64.8	23.0
1976	NOV	12	16:41	19:14	DIESEL	0.26	2.5	58.6	23.0
1976	NOV	18	16:48	20:05	DIESEL	0.26	3.3	75.5	23.0
1976	NOV	19	16:39	18:41	DIESEL	0.26	2.0	46.8	23.0
1976	NOV	22	17:07	18:52	DIESEL	0.26	1.8	40.3	23.0
1976	NOV	23	17:55	21:01	DIESEL	0.26	3.1	71.3	23.0
1976	NOV	24	16:37	18:36	DIESEL	0.26	2.0	45.6	23.0
1976	NOV	28	17:08	19:27	DIESEL	0.26	2.3	53.3	23.0
1976	DEC	29	12:10	12:40	DIESEL	0.26	0.5		
1976	DEC	29	13:30	13:40	DIESEL	0.26	0.2		
1976	DEC	29	17:25	18:36	DIESEL	0.26	1.2	42.5	23.0
1976	DEC	30	17:25	18:54	DIESEL	0.26	1.5	34.1	23.0
1977	JAN	3	17:17	19:14	DIESEL	0.26	1.9	44.8	23.0
1977	JAN	4	8:36	9:53	DIESEL	0.26	1.3		
1977	JAN	4	17:15	20:05	DIESEL	0.29	2.8	94.7	23.0
1977	JAN	5	8:53	15:36	DIESEL	0.29	6.7		

NEG = NEGLIGIBLE

HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JAN	5	17:02	18:56	DIESEL	0.29	1.9	198.2	23.0
1977	JAN	6	9:23	11:11	DIESEL	0.29	1.8		
1977	JAN	6	11:11	12:16	DIESEL	0.29	1.1	66.3	23.0
1977	JAN	18	20:58	23:01	DIESEL	0.29	2.0	47.1	23.0
1977	FEB	8	8:53	12:18	DIESEL	0.26	3.4	78.6	23.0
1977	MAR	1	10:32	12:12	DIESEL	0.29	1.7	38.3	23.0
1977	MAR	21	15:05	16:00	DIESEL	0.29	0.9	21.1	23.0
1977	MAR	22	13:45	15:10	DIESEL	0.29	1.4	32.6	23.0
1977	APR	4	10:25	11:43	DIESEL	0.29	1.3	29.9	23.0
1977	APR	18	18:31	18:47	DIESEL	0.29	0.3		
1977	APR	18	19:37	19:58	DIESEL	0.29	0.3	14.2	23.0
1977	APR	21	13:18	14:57	DIESEL	0.29	1.6	37.9	23.0
1977	APR	23	9:05	9:42	DIESEL	0.29	0.6	14.2	23.0
1977	APR	29	14:17	15:13	DIESEL	0.29	0.9		
1977	APR	29	15:28	15:43	DIESEL	0.29	0.3		
1977	APR	29	19:02	19:41	DIESEL	0.29	0.6	42.2	23.0
1977	MAY	5	10:20	17:56	DIESEL	0.29	7.6	174.8	23.0
1977	MAY	20	14:59	18:53	DIESEL	0.29	3.9	89.7	23.0
1977	MAY	25	13:16	14:28	DIESEL	0.29	1.2	27.6	23.0
1977	MAY	26	16:15	20:00	DIESEL	0.29	3.8	86.3	23.0
1977	JUN	13	11:01	16:02	DIESEL	0.29	5.0	115.4	23.0
1977	JUN	19	11:28	12:27	DIESEL	0.29	1.0	22.6	23.0
1977	JUN	22	14:09	14:29	DIESEL	0.29	0.3	7.7	23.0
1977	JUN	23	8:15	17:36	DIESEL	0.29	9.3	215.0	23.0
1977	JUL	25	9:52	11:22	DIESEL	0.29	1.5		
1977	JUL	25	13:32	19:07	DIESEL	0.29	5.6		
1977	JUL	25	20:08	21:45	DIESEL	0.29	1.6	200.1	23.0
1977	JUL	26	11:29	13:44	DIESEL	0.29	2.3		
1977	JUL	26	15:08	17:23	DIESEL	0.29	2.3	103.5	23.0
1977	JUL	28	12:50	15:50	DIESEL	0.29	3.0	69.0	23.0
1977	JUL	29	13:37	14:29	DIESEL	0.29	0.9		
1977	JUL	29	14:52	16:18	DIESEL	0.29	1.4	52.9	23.0
1977	AUG	3	10:56	18:38	DIESEL	0.29	7.7	177.1	23.0
1977	AUG	5	16:05	16:10	DIESEL	0.29	0.1	1.9	23.0
1977	AUG	9	13:32	13:37	DIESEL	0.29	0.1	1.9	23.0
1977	AUG	22	10:10	10:59	DIESEL	0.29	0.8	18.8	23.0
1977	AUG	30	15:00	15:40	DIESEL	0.29	0.7		
1977	AUG	30	16:02	16:30	DIESEL	0.29	0.5	26.1	23.0
1977	SEP	15	9:11	9:20	DIESEL	0.29	0.1		

NEG = NEGLIGIBLE

[illegible] PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NORTH ISLAND STATION

UNIT NUMBER: 2

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	SEP	15	9:35	9:54	DIESEL	0.29	0.3		
1977	SEP	15	10:15	12:00	DIESEL	0.29	1.8	51.0	23.0
1977	SEP	28	13:57	14:12	DIESEL	0.29	0.3		
1977	SEP	28	14:27	14:43	DIESEL	0.29	0.3	11.9	23.0
1977	OCT	4	12:36	16:25	DIESEL	0.29	3.8	87.8	23.0
1977	OCT	29	10:29	10:51	DIESEL	0.29	0.4		
1977	OCT	29	11:25	11:49	DIESEL	0.29	0.4	17.6	23.0
1977	OCT	31	13:36	13:55	DIESEL	0.29	0.3	7.3	23.0
1977	NOV	1	7:06	8:06	DIESEL	0.29	1.0		
1977	NOV	1	11:36	15:10	DIESEL	0.29	3.6	105.0	23.0
1977	NOV	3	10:56	13:08	DIESEL	0.29	2.2	50.6	23.0
1977	NOV	15	8:30	8:38	DIESEL	0.29	0.1		
1977	NOV	15	9:46	11:13	DIESEL	0.29	1.4	36.4	23.0
1977	NOV	17	17:00	19:35	DIESEL	0.29	2.6	59.4	23.0
1977	NOV	18	17:03	19:10	DIESEL	0.29	2.1	48.7	23.0
1977	NOV	19	17:06	19:27	DIESEL	0.29	2.3	54.0	23.0
1977	NOV	20	17:02	20:41	DIESEL	0.29	3.6	83.9	23.0
1977	NOV	21	8:10	13:01	DIESEL	0.29	4.8		
1977	NOV	21	16:59	20:14	DIESEL	0.29	3.3	186.3	23.0
1977	NOV	22	7:41	14:29	DIESEL	0.29	6.8		
1977	NOV	22	16:59	19:23	DIESEL	0.29	2.4	211.6	23.0
1977	NOV	23	17:05	18:14	DIESEL	0.29	1.1	26.4	23.0
1977	NOV	30	16:59	19:31	DIESEL	0.29	2.5	58.3	23.0
1977	DEC	2	17:28	18:45	DIESEL	0.29	1.3	29.5	23.0
1977	DEC	3	18:25	20:08	DIESEL	0.29	1.7	39.5	23.0
1977	DEC	4	17:03	18:06	DIESEL	0.29	1.0	24.1	23.0
1977	DEC	5	17:27	18:15	DIESEL	0.29	0.8	18.4	23.0
1977	DEC	6	14:12	15:57	DIESEL	0.29	1.8		
1977	DEC	6	17:01	18:15	DIESEL	0.29	1.2	68.6	23.0
1977	DEC	12	17:12	18:18	DIESEL	0.29	1.1	25.3	23.0
1977	DEC	23	16:13	17:04	DIESEL	0.29	0.9		
1977	DEC	23	18:09	18:37	DIESEL	0.29	0.5	30.3	23.0
1977	DEC	28	16:41	17:45	DIESEL	0.29	1.1	24.5	23.0
1977	DEC	29	16:35	17:00	DIESEL	0.29	0.4		
1977	DEC	29	23:30	23:57	DIESEL	0.29	0.4	19.9	23.0
1977	DEC	30	16:30	18:08	DIESEL	0.29	1.6	37.6	23.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	9	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	11	0:00	0:24	COMBINED FUEL B	0.30	0.4		
1975	JAN	11	1:58	24:00	COMBINED FUEL B	0.30	22.0	358.9	16.0
1975	JAN	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	15	0:00	8:00	COMBINED FUEL B	0.30	8.0		
1975	JAN	15	15:13	24:00	COMBINED FUEL B	0.30	8.8	268.5	16.0
1975	JAN	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	23	0:00	11:05	COMBINED FUEL B	0.30	11.1		
1975	JAN	23	17:10	24:00	COMBINED FUEL B	0.30	6.8	286.7	16.0
1975	JAN	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JAN	27	0:00	4:40	COMBINED FUEL B	0.30	4.7		
1975	JAN	27	8:36	24:00	COMBINED FUEL B	0.30	15.4	321.1	16.0
1975	JAN	31	0:00	12:52	COMBINED FUEL B	0.30	12.9		
1975	JAN	31	13:08	24:00	COMBINED FUEL B	0.30	10.9	379.7	16.0
1975	FEB	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	3	0:00	14:05	COMBINED FUEL B	0.30	14.1		
1975	FEB	3	16:27	24:00	COMBINED FUEL B	0.30	7.5	346.1	16.0
1975	FEB	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	FEB	7	0:00	16:03	COMBINED FUEL B	0.30	16.0		
1975	FEB	7	16:19	24:00	COMBINED FUEL B	0.30	7.7	379.7	16.0
1975	FEB	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	9	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	10	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	11	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	15	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	19	0:00	8:40	COMBINED FUEL B	0.30	8.7		
1975	FEB	19	8:58	24:00	COMBINED FUEL B	0.30	15.0	379.2	16.0
1975	FEB	20	0:00	4:40	COMBINED FUEL B	0.30	4.7		
1975	FEB	20	4:58	9:10	COMBINED FUEL B	0.30	4.2		
1975	FEB	20	11:07	24:00	COMBINED FUEL B	0.30	12.9	348.0	16.0
1975	FEB	21	0:00	7:30	COMBINED FUEL B	0.30	7.5		
1975	FEB	21	15:40	24:00	COMBINED FUEL B	0.30	8.3	253.3	16.0
1975	FEB	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	23	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	FEB	28	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	8	0:00	20:25	COMBINED FUEL B	0.30	20.4	326.7	16.0
1975	MAR	9	3:32	24:00	COMBINED FUEL B	0.30	20.5	327.5	16.0
1975	MAR	10	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	11	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	MAR	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	15	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	23	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	29	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	30	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAR	31	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	4	0:00	8:00	COMBINED FUEL B	0.30	8.0		
1975	APR	4	11:50	24:00	COMBINED FUEL B	0.30	12.2	322.7	16.0
1975	APR	5	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	6	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	7	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	8	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	9	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	10	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	11	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	12	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	13	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	14	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	15	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	16	11:50	24:00	COMBINED FUEL B	0.30	12.2	194.7	16.0
1975	APR	17	0:00	2:35	COMBINED FUEL B	0.30	2.6		
1975	APR	17	12:25	24:00	COMBINED FUEL B	0.30	11.6	226.7	16.0
1975	APR	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	APR	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	23	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	APR	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	9	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	10	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	11	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	15	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	23	0:00	15:27	COMBINED FUEL B	0.30	15.4		
1975	MAY	23	16:13	24:00	COMBINED FUEL B	0.30	7.8	371.7	16.0
1975	MAY	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	28	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	29	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	30	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	MAY	31	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JUN	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	9	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	10	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	11	0:00	3:59	COMBINED FUEL B	0.30	4.0		
1975	JUN	11	12:20	24:00	COMBINED FUEL B	0.30	11.7	250.4	16.0
1975	JUN	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	15	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	23	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	28	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	29	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUN	30	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JUL	9	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	10	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	11	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	15	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	23	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	28	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	29	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	30	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	JUL	31	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	6	0:00	6:52	COMBINED FUEL B	0.30	6.9		
1975	AUG	6	14:46	24:00	COMBINED FUEL B	0.30	9.2	257.6	16.0
1975	AUG	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	9	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	10	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	11	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	15	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	AUG	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	19	0:00	11:05	COMBINED FUEL B	0.30	11.1		
1975	AUG	19	11:14	24:00	COMBINED FUEL B	0.30	12.8	381.6	16.0
1975	AUG	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	22	0:00	20:16	COMBINED FUEL B	0.30	20.3	324.3	16.0
1975	AUG	23	1:45	24:00	COMBINED FUEL B	0.30	22.3	356.0	16.0
1975	AUG	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	28	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	29	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	AUG	30	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	9	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	10	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	11	0:00	11:00	COMBINED FUEL B	0.30	11.0		
1975	SEP	11	15:28	24:00	COMBINED FUEL B	0.30	8.5	312.5	16.0
1975	SEP	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	15	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	SEP	23	0:00	12:12	COMBINED FUEL B	0.30	12.2		
1975	SEP	23	14:15	15:25	COMBINED FUEL B	0.30	1.2		
1975	SEP	23	16:15	17:01	COMBINED FUEL B	0.30	0.8		
1975	SEP	23	18:04	23:20	COMBINED FUEL B	0.30	5.3	310.4	16.0
1975	SEP	24	1:15	24:00	COMBINED FUEL B	0.30	22.8	364.0	16.0
1975	SEP	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	28	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	29	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	SEP	30	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	2	0:00	11:23	COMBINED FUEL B	0.30	11.4	182.1	16.0
1975	OCT	3	13:00	24:00	COMBINED FUEL B	0.30	11.0	176.0	16.0
1975	OCT	4	0:00	9:11	COMBINED FUEL B	0.30	9.2		
1975	OCT	4	10:55	24:00	COMBINED FUEL B	0.30	13.1	356.3	16.0
1975	OCT	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	6	0:00	0:15	COMBINED FUEL B	0.30	0.3	4.0	16.0
1975	OCT	10	13:55	24:00	COMBINED FUEL B	0.30	10.1	161.3	16.0
1975	OCT	11	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	13	0:00	20:01	COMBINED FUEL B	0.30	20.0	320.3	16.0
1975	OCT	15	0:30	0:40	COMBINED FUEL B	0.30	0.2		
1975	OCT	15	0:55	1:20	COMBINED FUEL B	0.30	0.4		
1975	OCT	15	20:20	22:03	COMBINED FUEL B	0.30	1.7	36.8	16.0
1975	OCT	16	0:02	0:12	COMBINED FUEL B	0.30	0.2		
1975	OCT	16	1:00	24:00	COMBINED FUEL B	0.30	23.0		
1975	OCT	16	0:22	0:31	COMBINED FUEL B	0.30	0.1	373.1	16.0
1975	OCT	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	23	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	OCT	28	0:00	7:30	COMBINED FUEL B	0.30	7.5		
1975	OCT	28	10:50	24:00	COMBINED FUEL B	0.30	13.2	330.7	16.0
1975	OCT	29	0:00	12:58	COMBINED FUEL B	0.30	13.0		
1975	OCT	29	12:58	24:00	COMBINED FUEL B	0.30	11.0	384.0	16.0
1975	OCT	30	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	OCT	31	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	1	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	4	0:00	15:00	COMBINED FUEL B	0.30	15.0		
1975	NOV	4	16:08	24:00	COMBINED FUEL B	0.30	7.9	365.9	16.0
1975	NOV	5	0:00	7:42	COMBINED FUEL B	0.30	7.7		
1975	NOV	5	14:25	24:00	COMBINED FUEL B	0.30	9.6	276.5	16.0
1975	NOV	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	9	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	10	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	11	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	15	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	17	0:00	13:37	COMBINED FUEL B	0.30	13.6		
1975	NOV	17	14:00	24:00	COMBINED FUEL B	0.30	10.0	377.9	16.0
1975	NOV	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	23	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	28	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	29	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	NOV	30	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

[illegible] GENERATING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	DEC	1	0:00	9:47	COMBINED FUEL B	0.30	9.8		
1975	DEC	1	11:27	24:00	COMBINED FUEL B	0.30	12.5	357.3	16.0
1975	DEC	2	0:00	7:30	COMBINED FUEL B	0.30	7.5		
1975	DEC	2	8:17	24:00	COMBINED FUEL B	0.30	15.7	371.5	16.0
1975	DEC	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	9	0:00	7:40	COMBINED FUEL B	0.30	7.7		
1975	DEC	9	9:50	11:40	COMBINED FUEL B	0.30	1.8		
1975	DEC	9	11:59	24:00	COMBINED FUEL B	0.30	12.0	344.3	16.0
1975	DEC	10	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	11	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	12	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	15	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	21	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	22	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	23	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	28	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	29	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	30	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1975	DEC	31	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	JAN	1	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	2	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	3	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	4	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JAN	5	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	6	0:00	7:30	COMBINED FUEL B	0.26	7.5		
1976	JAN	6	14:45	14:50	COMBINED FUEL B	0.26	0.1		
1976	JAN	6	15:00	24:00	COMBINED FUEL B	0.26	9.0	265.3	16.0
1976	JAN	7	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	8	0:00	15:58	COMBINED FUEL B	0.26	16.0		
1976	JAN	8	16:16	24:00	COMBINED FUEL B	0.26	7.7	379.2	16.0
1976	JAN	9	9:56	10:46	COMBINED FUEL B	0.26	0.8	13.3	16.0
1976	JAN	10	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	11	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	12	0:00	11:58	COMBINED FUEL B	0.26	12.0		
1976	JAN	12	12:12	24:00	COMBINED FUEL B	0.26	11.8	380.3	16.0
1976	JAN	13	0:00	19:56	COMBINED FUEL B	0.26	19.9		
1976	JAN	13	21:05	24:00	COMBINED FUEL B	0.26	2.9	365.6	16.0
1976	JAN	14	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	15	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	16	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	17	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	18	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	19	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	20	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	21	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	22	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	23	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	24	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	25	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	26	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	27	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	28	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	29	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	30	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JAN	31	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	1	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	2	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	3	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	4	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	5	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	6	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	7	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	FEB	8	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	9	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	10	0:00	10:34	COMBINED FUEL B	0.26	10.6		
1976	FEB	10	12:55	24:00	COMBINED FUEL B	0.26	11.1	346.4	16.0
1976	FEB	11	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	12	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	13	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	14	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	15	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	16	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	17	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	18	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	19	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	20	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	21	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	22	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	23	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	24	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	25	0:00	15:00	COMBINED FUEL B	0.26	15.0		
1976	FEB	25	16:20	24:00	COMBINED FUEL B	0.26	7.7	362.7	16.0
1976	FEB	26	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	FEB	27	0:00	8:00	COMBINED FUEL B	0.26	8.0	128.0	16.0
1976	FEB	28	12:14	24:00	COMBINED FUEL B	0.26	11.8	188.3	16.0
1976	FEB	29	0:00	21:55	COMBINED FUEL B	0.26	21.9	350.7	16.0
1976	MAR	1	16:06	21:56	COMBINED FUEL B	0.26	5.8	93.3	16.0
1976	MAR	2	16:06	20:52	COMBINED FUEL B	0.26	4.8	76.3	16.0
1976	MAR	3	9:35	24:00	COMBINED FUEL B	0.26	14.4	230.7	16.0
1976	MAR	4	11:50	15:36	COMBINED FUEL B	0.26	3.8	60.3	16.0
1976	MAR	5	0:00	16:08	COMBINED FUEL B	0.26	16.1	258.1	16.0
1976	MAR	9	16:40	24:00	COMBINED FUEL B	0.26	7.3	117.3	16.0
1976	MAR	10	0:00	12:20	COMBINED FUEL B	0.26	12.3	197.3	16.0
1976	MAR	16	1:15	24:00	COMBINED FUEL B	0.26	22.8	364.0	16.0
1976	MAR	17	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	18	0:00	10:00	COMBINED FUEL B	0.26	10.0	160.0	16.0
1976	MAR	20	6:10	24:00	COMBINED FUEL B	0.26	17.8	285.3	16.0
1976	MAR	21	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	22	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	23	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	24	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	MAR	25	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	26	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	27	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	28	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	29	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	30	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAR	31	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	APR	1	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	APR	2	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	APR	3	0:00	21:23	COMBINED FUEL B	0.26	21.4	342.1	16.0
1976	APR	8	8:50	12:40	COMBINED FUEL B	0.26	3.8	61.3	16.0
1976	APR	20	12:01	24:00	COMBINED FUEL B	0.26	12.0	191.7	16.0
1976	APR	21	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	APR	22	0:00	16:30	COMBINED FUEL B	0.26	16.5	264.0	16.0
1976	APR	25	13:38	24:00	COMBINED FUEL B	0.26	10.4	165.9	16.0
1976	APR	26	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	APR	27	0:00	21:39	COMBINED FUEL B	0.26	21.6	346.4	16.0
1976	APR	28	18:07	24:00	COMBINED FUEL B	0.26	5.9	94.1	16.0
1976	APR	29	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	APR	30	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	1	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	2	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	3	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	4	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	5	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	6	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	7	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	8	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	9	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	10	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	11	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	12	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	13	0:00	21:00	COMBINED FUEL B	0.26	21.0	336.0	16.0
1976	MAY	17	18:35	24:00	COMBINED FUEL B	0.26	5.4	86.7	16.0
1976	MAY	18	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	19	0:00	17:39	COMBINED FUEL B	0.26	17.6	282.4	16.0
1976	MAY	21	14:00	24:00	COMBINED FUEL B	0.26	10.0	160.0	16.0
1976	MAY	22	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	23	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	MAY	24	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	25	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	26	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	27	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	28	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	29	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	30	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	MAY	31	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	1	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	2	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	3	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	4	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	5	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	6	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	7	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	8	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	9	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	10	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	12	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	13	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	14	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	15	0:00	7:55	COMBINED FUEL B	0.26	7.9		
1976	JUN	15	10:50	12:55	COMBINED FUEL B	0.26	2.1		
1976	JUN	15	13:19	24:00	COMBINED FUEL B	0.26	10.7	330.9	16.0
1976	JUN	16	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	17	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	18	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	19	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	20	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	21	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	22	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	23	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	24	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	25	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	26	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	27	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	28	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	29	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUN	30	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	JUL	1	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	2	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	3	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	4	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	5	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	6	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	7	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	8	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	9	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	10	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	11	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	12	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	13	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	14	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	15	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	16	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	17	0:00	4:04	COMBINED FUEL B	0.26	4.1	65.1	16.0
1976	JUL	22	5:23	15:34	COMBINED FUEL B	0.26	10.2		
1976	JUL	22	16:04	24:00	COMBINED FUEL B	0.26	7.9	289.9	16.0
1976	JUL	23	0:00	10:12	COMBINED FUEL B	0.26	10.2	163.2	16.0
1976	JUL	24	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	25	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	26	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	27	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	28	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	29	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	30	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	JUL	31	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	1	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	2	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	3	0:00	7:35	COMBINED FUEL B	0.26	7.6		
1976	AUG	3	13:00	24:00	COMBINED FUEL B	0.26	11.0	297.3	16.0
1976	AUG	4	0:00	7:35	COMBINED FUEL B	0.26	7.6		
1976	AUG	4	12:10	24:00	COMBINED FUEL B	0.26	11.8	310.7	16.0
1976	AUG	5	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	6	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	7	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	8	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	9	0:00	11:12	COMBINED FUEL B	0.26	11.2	179.2	16.0

NEG = NEGLIGIBLE

UTILITY GAS TURBINE PEAKING UNIT HISTORICAL OPERATING DATA

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	AUG	10	16:05	24:00	COMBINED FUEL B	0.26	7.9	126.7	16.0
1976	AUG	11	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	12	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	13	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	14	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	15	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	16	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	AUG	17	0:00	0:12	COMBINED FUEL B	0.26	0.2		
1976	AUG	17	10:05	15:04	COMBINED FUEL B	0.26	5.0	82.9	16.0
1976	AUG	19	7:47	24:00	COMBINED FUEL B	0.26	16.2	259.5	16.0
1976	AUG	20	0:00	11:35	COMBINED FUEL B	0.30	11.6		
1976	AUG	20	11:57	19:00	COMBINED FUEL B	0.30	7.0	298.1	16.0
1976	AUG	21	5:34	24:00	COMBINED FUEL B	0.30	18.4	294.9	16.0
1976	AUG	22	0:00	7:30	COMBINED FUEL B	0.30	7.5		
1976	AUG	22	9:33	10:10	COMBINED FUEL B	0.30	0.6	129.9	16.0
1976	OCT	1	12:42	12:55	COMBINED FUEL B	0.30	0.2		
1976	OCT	1	13:08	24:00	COMBINED FUEL B	0.30	10.9	177.3	16.0
1976	OCT	2	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	4	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	5	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	6	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	7	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	8	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	9	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	11	0:00	17:37	COMBINED FUEL B	0.30	17.6	281.9	16.0
1976	OCT	15	19:16	24:00	COMBINED FUEL B	0.30	4.7	75.7	16.0
1976	OCT	16	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	17	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	18	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	19	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	20	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	21	0:00	23:46	COMBINED FUEL B	0.30	23.8	380.3	16.0
1976	OCT	22	1:32	24:00	COMBINED FUEL B	0.30	22.5	359.5	16.0
1976	OCT	23	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	24	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	25	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	26	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	OCT	27	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	OCT	28	0:00	23:13	COMBINED FUEL B	0.30	23.2	371.5	16.0
1976	NOV	1	10:04	24:00	COMBINED FUEL B	0.30	13.9	222.9	16.0
1976	NOV	2	0:00	10:53	COMBINED FUEL B	0.30	10.9		
1976	NOV	2	15:05	24:00	COMBINED FUEL B	0.30	8.9	316.8	16.0
1976	NOV	3	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	NOV	4	0:00	12:03	COMBINED FUEL B	0.30	12.0		
1976	NOV	4	12:23	24:00	COMBINED FUEL B	0.30	11.6	378.7	16.0
1976	NOV	5	0:00	19:30	COMBINED FUEL B	0.30	19.5	312.0	16.0
1976	NOV	6	8:30	24:00	COMBINED FUEL B	0.30	15.5	248.0	16.0
1976	NOV	7	8:30	24:00	COMBINED FUEL B	0.30	15.5	248.0	16.0
1976	NOV	8	8:30	24:00	COMBINED FUEL B	0.30	15.5	248.0	16.0
1976	NOV	9	8:30	24:00	COMBINED FUEL B	0.30	15.5	248.0	16.0
1976	NOV	10	0:00	1:00	COMBINED FUEL B	0.30	1.0		
1976	NOV	10	8:23	8:51	COMBINED FUEL B	0.30	0.5		
1976	NOV	10	9:22	14:56	COMBINED FUEL B	0.30	5.6		
1976	NOV	10	15:00	15:06	COMBINED FUEL B	0.30	0.1		
1976	NOV	10	15:26	24:00	COMBINED FUEL B	0.30	8.6	251.2	16.0
1976	NOV	11	0:00	12:00	COMBINED FUEL B	0.30	12.0	192.0	16.0
1976	NOV	12	17:45	24:00	COMBINED FUEL B	0.30	6.3	100.0	16.0
1976	NOV	13	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	NOV	14	0:00	24:00	COMBINED FUEL B	0.30	24.0	384.0	16.0
1976	NOV	15	0:00	2:57	COMBINED FUEL B	0.30	2.9		
1976	NOV	15	15:12	15:55	COMBINED FUEL B	0.30	0.7		
1976	NOV	15	21:48	24:00	COMBINED FUEL B	0.30	2.2	93.9	16.0
1976	NOV	16	0:00	8:40	COMBINED FUEL B	0.30	8.7		
1976	NOV	16	15:15	24:00	COMBINED FUEL B	0.30	8.8	278.7	16.0
1976	NOV	17	0:00	11:07	COMBINED FUEL B	0.30	11.1		
1976	NOV	17	12:04	13:11	COMBINED FUEL B	0.30	1.1		
1976	NOV	17	15:21	24:00	COMBINED FUEL B	0.30	8.6	334.1	16.0
1976	NOV	18	0:00	5:26	COMBINED FUEL B	0.30	5.4	86.9	16.0
1976	NOV	19	21:06	21:56	COMBINED FUEL B	0.30	0.8	13.3	16.0
1976	NOV	20	0:03	0:13	COMBINED FUEL B	0.30	0.2		
1976	NOV	20	9:23	10:00	COMBINED FUEL B	0.30	0.6		
1976	NOV	20	15:45	24:00	COMBINED FUEL B	0.30	8.3	144.5	16.0
1976	NOV	21	0:00	2:48	COMBINED FUEL B	0.30	2.8		
1976	NOV	21	10:09	15:30	COMBINED FUEL B	0.30	5.3		
1976	NOV	21	15:55	16:11	COMBINED FUEL B	0.30	0.3	134.7	16.0
1976	NOV	22	6:43	10:53	COMBINED FUEL B	0.30	4.2	66.7	16.0
1976	NOV	23	12:20	21:37	COMBINED FUEL B	0.30	9.3	148.5	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	NOV	26	10:00	24:00	COMBINED FUEL B	0.30	14.0	224.0	16.0
1976	NOV	27	0:00	9:24	COMBINED FUEL B	0.30	9.4	150.4	16.0
1976	NOV	29	9:16	24:00	COMBINED FUEL B	0.30	14.7	235.7	16.0
1976	NOV	30	0:00	8:37	COMBINED FUEL B	0.30	8.6	137.9	16.0
1976	NOV	31	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	1	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	2	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	3	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	4	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	5	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	6	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	7	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	8	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	9	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	10	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	11	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	12	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	13	0:00	7:30	COMBINED FUEL B	0.26	7.5		
1976	DEC	13	15:35	24:00	COMBINED FUEL B	0.26	8.4	254.7	16.0
1976	DEC	14	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	15	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	16	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	17	0:00	9:05	COMBINED FUEL B	0.26	9.1		
1976	DEC	17	16:03	24:00	COMBINED FUEL B	0.26	7.9	272.5	16.0
1976	DEC	18	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	19	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	20	0:00	19:30	COMBINED FUEL B	0.26	19.5		
1976	DEC	20	23:52	24:00	COMBINED FUEL B	0.26	0.1	314.1	16.0
1976	DEC	21	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	22	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	23	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	24	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	25	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	26	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	27	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	28	0:00	7:40	COMBINED FUEL B	0.26	7.7		
1976	DEC	28	15:00	24:00	COMBINED FUEL B	0.26	9.0	266.7	16.0
1976	DEC	29	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1976	DEC	30	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	DEC	31	0:00	24:00	COMBINED FUEL B	0.26	24.0	384.0	16.0
1977	JAN	1	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	2	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	3	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	4	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	5	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	6	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	7	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	8	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	9	0:00	7:40	COMBINED FUEL B	0.29	7.7		
1977	JAN	9	13:33	24:00	COMBINED FUEL B	0.29	10.4	289.9	16.0
1977	JAN	10	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	11	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	12	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	13	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	14	0:00	10:05	COMBINED FUEL B	0.29	10.1		
1977	JAN	14	13:47	24:00	COMBINED FUEL B	0.29	10.2	324.8	16.0
1977	JAN	15	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	16	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	17	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	18	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	19	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	20	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	21	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	22	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	23	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	24	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	25	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	26	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	27	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	28	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	29	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	30	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JAN	31	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	FEB	1	0:00	6:30	COMBINED FUEL B	0.29	6.5		
1977	FEB	1	8:27	11:00	COMBINED FUEL B	0.29	2.5		
1977	FEB	1	11:20	24:00	COMBINED FUEL B	0.29	12.7	347.5	16.0
1977	FEB	2	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	FEB	3	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	FEB	4	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	FEB	5	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	FEB	6	0:00	14:38	COMBINED FUEL B	0.29	14.6	234.1	16.0
1977	FEB	19	10:53	10:57	COMBINED FUEL B	0.29	0.1		
1977	FEB	19	11:05	11:25	COMBINED FUEL B	0.29	0.3		
1977	FEB	19	11:57	20:39	COMBINED FUEL B	0.29	8.7	145.6	16.0
1977	FEB	20	18:48	22:17	COMBINED FUEL B	0.29	3.5	55.7	16.0
1977	FEB	22	5:06	15:10	COMBINED FUEL B	0.29	10.1	161.1	16.0
1977	FEB	24	15:40	24:00	COMBINED FUEL B	0.29	8.3	133.3	16.0
1977	FEB	25	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	FEB	26	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	FEB	27	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	FEB	28	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	1	0:00	11:10	COMBINED FUEL B	0.29	11.2	178.7	16.0
1977	MAR	3	15:55	24:00	COMBINED FUEL B	0.29	8.1	129.3	16.0
1977	MAR	4	0:00	13:05	COMBINED FUEL B	0.29	13.1		
1977	MAR	4	13:16	24:00	COMBINED FUEL B	0.29	10.7	381.1	16.0
1977	MAR	5	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	6	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	7	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	8	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	9	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	10	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	11	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	12	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	13	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	14	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	15	0:00	5:57	COMBINED FUEL B	0.29	5.9		
1977	MAR	15	12:52	13:55	COMBINED FUEL B	0.29	1.0	112.0	16.0
1977	MAR	16	10:54	12:47	COMBINED FUEL B	0.29	1.9	30.1	16.0
1977	MAR	19	15:00	24:00	COMBINED FUEL B	0.29	9.0	144.0	16.0
1977	MAR	20	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	21	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	22	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	23	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	24	0:00	4:32	COMBINED FUEL B	0.29	4.5		
1977	MAR	24	15:05	24:00	COMBINED FUEL B	0.29	8.9	215.2	16.0
1977	MAR	25	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	26	0:00	4:32	COMBINED FUEL B	0.29	4.5		

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	MAR	26	15:05	24:00	COMBINED FUEL B	0.29	8.9	215.2	16.0
1977	MAR	27	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	28	0:00	13:05	COMBINED FUEL B	0.29	13.1		
1977	MAR	28	15:32	24:00	COMBINED FUEL B	0.29	8.5	344.8	16.0
1977	MAR	29	0:00	6:00	COMBINED FUEL B	0.29	6.0		
1977	MAR	29	15:46	24:00	COMBINED FUEL B	0.29	8.2	227.7	16.0
1977	MAR	30	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAR	31	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	APR	1	0:00	5:35	COMBINED FUEL B	0.29	5.6	89.3	16.0
1977	APR	4	16:15	19:08	COMBINED FUEL B	0.29	2.9	46.1	16.0
1977	APR	15	14:22	24:00	COMBINED FUEL B	0.29	9.6	154.1	16.0
1977	APR	16	0:00	9:47	COMBINED FUEL B	0.29	9.8	156.5	16.0
1977	APR	17	18:02	24:00	COMBINED FUEL B	0.29	6.0	95.5	16.0
1977	APR	18	0:00	3:28	COMBINED FUEL B	0.29	3.5	55.5	16.0
1977	APR	19	18:00	24:00	COMBINED FUEL B	0.29	6.0	96.0	16.0
1977	APR	20	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	APR	21	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	APR	22	0:00	14:55	COMBINED FUEL B	0.29	14.9	238.7	16.0
1977	APR	23	15:11	24:00	COMBINED FUEL B	0.29	8.8	141.1	16.0
1977	APR	24	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	APR	25	0:00	9:55	COMBINED FUEL B	0.29	9.9	158.7	16.0
1977	APR	26	12:02	24:00	COMBINED FUEL B	0.29	12.0	191.5	16.0
1977	APR	27	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	APR	28	0:00	2:00	COMBINED FUEL B	0.29	2.0	32.0	16.0
1977	APR	29	20:10	24:00	COMBINED FUEL B	0.29	3.8	61.3	16.0
1977	MAY	1	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	MAY	2	0:00	6:00	COMBINED FUEL B	0.29	6.0	96.0	16.0
1977	MAY	3	8:05	11:08	COMBINED FUEL B	0.29	3.0	48.8	16.0
1977	MAY	18	18:43	18:56	COMBINED FUEL B	0.29	0.2	3.5	16.0
1977	MAY	24	14:08	14:25	COMBINED FUEL B	0.29	0.3	4.5	16.0
1977	MAY	31	14:05	14:22	COMBINED FUEL B	0.29	0.3	4.5	16.0
1977	JUN	1	0:00	9:30	COMBINED FUEL B	0.29	9.5		
1977	JUN	1	14:15	15:00	COMBINED FUEL B	0.29	0.8		
1977	JUN	1	15:17	24:00	COMBINED FUEL B	0.29	8.7	303.5	16.0
1977	JUN	2	0:00	0:03	COMBINED FUEL B	0.29	0.0		
1977	JUN	2	16:01	24:00	COMBINED FUEL B	0.29	8.0	128.5	16.0
1977	JUN	3	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	4	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	5	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	JUN	6	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	7	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	8	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	9	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	10	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	11	0:00	16:15	COMBINED FUEL B	0.29	16.3	260.0	16.0
1977	JUN	12	6:07	24:00	COMBINED FUEL B	0.29	17.9	286.1	16.0
1977	JUN	13	0:00	5:56	COMBINED FUEL B	0.29	5.9	94.9	16.0
1977	JUN	14	6:00	24:00	COMBINED FUEL B	0.29	18.0	288.0	16.0
1977	JUN	15	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	16	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	17	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	18	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	19	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	JUN	20	0:00	0:05	COMBINED FUEL B	0.29	0.1	1.3	16.0
1977	AUG	10	10:47	11:34	COMBINED FUEL B	0.29	0.8		
1977	AUG	10	14:16	15:35	COMBINED FUEL B	0.29	1.3	33.6	16.0
1977	AUG	11	10:00	12:55	COMBINED FUEL B	0.29	2.9	46.7	16.0
1977	AUG	12	8:04	13:05	COMBINED FUEL B	0.29	5.0		
1977	AUG	12	15:27	24:00	COMBINED FUEL B	0.29	8.5	217.1	16.0
1977	AUG	13	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	AUG	14	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	AUG	15	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	AUG	16	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	AUG	17	0:00	5:30	COMBINED FUEL B	0.29	5.5		
1977	AUG	17	12:46	24:00	COMBINED FUEL B	0.29	11.2	267.7	16.0
1977	AUG	18	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	19	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	20	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	21	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	22	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	23	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	24	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	25	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	26	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	27	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	28	12:46	24:00	COMBINED FUEL B	0.29	11.2	179.7	16.0
1977	AUG	29	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	AUG	30	0:00	9:44	COMBINED FUEL B	0.29	9.7		

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	AUG	30	11:04	24:00	COMBINED FUEL B	0.29	12.9	362.7	16.0
1977	AUG	31	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	SEP	1	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	SEP	2	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	SEP	3	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	SEP	4	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	SEP	5	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	SEP	6	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	SEP	7	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	SEP	8	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	SEP	9	0:00	18:44	COMBINED FUEL B	0.29	18.7		
1977	SEP	9	19:28	24:00	COMBINED FUEL B	0.29	4.5	372.3	16.0
1977	SEP	10	0:00	21:07	COMBINED FUEL B	0.29	21.1	337.9	16.0
1977	SEP	12	16:32	24:00	COMBINED FUEL B	0.29	7.5	119.5	16.0
1977	SEP	13	0:00	8:50	COMBINED FUEL B	0.29	8.8		
1977	SEP	13	15:00	24:00	COMBINED FUEL B	0.29	9.0	285.3	16.0
1977	SEP	14	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	1	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	2	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	3	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	4	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	5	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	6	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	7	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	8	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	9	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	10	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	11	0:00	21:09	COMBINED FUEL B	0.29	21.1	338.4	16.0
1977	OCT	12	11:06	24:00	COMBINED FUEL B	0.29	12.9	206.4	16.0
1977	OCT	13	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	14	0:00	11:57	COMBINED FUEL B	0.29	11.9		
1977	OCT	14	16:25	24:00	COMBINED FUEL B	0.29	7.6	312.5	16.0
1977	OCT	15	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	16	0:00	11:30	COMBINED FUEL B	0.29	11.5		
1977	OCT	16	16:35	16:40	COMBINED FUEL B	0.29	0.1		
1977	OCT	16	16:49	16:56	COMBINED FUEL B	0.29	0.1		
1977	OCT	16	17:09	24:00	COMBINED FUEL B	0.29	6.8	296.8	16.0
1977	OCT	17	0:00	4:55	COMBINED FUEL B	0.29	4.9		
1977	OCT	17	17:05	24:00	COMBINED FUEL B	0.29	6.9	189.3	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	OCT	18	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	19	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	20	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	21	0:00	5:02	COMBINED FUEL B	0.29	5.0		
1977	OCT	21	17:48	24:00	COMBINED FUEL B	0.29	6.2	179.7	16.0
1977	OCT	22	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	23	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	24	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	25	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	26	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	27	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	28	0:00	5:10	COMBINED FUEL B	0.29	5.2	82.7	16.0
1977	OCT	29	16:40	24:00	COMBINED FUEL B	0.29	7.3	117.3	16.0
1977	OCT	30	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	OCT	31	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	NOV	1	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	NOV	2	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	NOV	3	0:00	12:15	COMBINED FUEL B	0.29	12.3		
1977	NOV	3	15:00	24:00	COMBINED FUEL B	0.29	9.0	340.0	16.0
1977	NOV	4	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	NOV	5	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	NOV	6	0:00	12:48	COMBINED FUEL B	0.29	12.8	204.8	16.0
1977	NOV	7	11:30	24:00	COMBINED FUEL B	0.29	12.5	200.0	16.0
1977	NOV	8	0:00	16:50	COMBINED FUEL B	0.29	16.8	269.3	16.0
1977	NOV	13	15:11	16:18	COMBINED FUEL B	0.29	1.1	17.9	16.0
1977	NOV	22	9:15	9:30	COMBINED FUEL B	0.29	0.3		
1977	NOV	22	9:41	23:30	COMBINED FUEL B	0.29	13.8	225.1	16.0
1977	NOV	23	15:37	24:00	COMBINED FUEL B	0.29	8.4	134.1	16.0
1977	NOV	24	0:00	3:03	COMBINED FUEL B	0.29	3.0		
1977	NOV	24	11:16	24:00	COMBINED FUEL B	0.29	12.7	252.5	16.0
1977	NOV	25	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	NOV	26	0:00	10:46	COMBINED FUEL B	0.29	10.8		
1977	NOV	26	16:18	17:30	COMBINED FUEL B	0.29	1.2		
1977	NOV	26	21:36	24:00	COMBINED FUEL B	0.29	2.4	229.9	16.0
1977	NOV	27	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	NOV	28	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	NOV	29	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	NOV	30	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	1	0:00	7:50	COMBINED FUEL B	0.29	7.8		

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E NTC STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	DEC	1	8:19	24:00	COMBINED FUEL B	0.29	15.7	376.3	16.0
1977	DEC	2	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	3	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	4	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	5	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	6	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	7	0:00	13:00	COMBINED FUEL B	0.29	13.0		
1977	DEC	7	15:08	24:00	COMBINED FUEL B	0.29	8.9	349.9	16.0
1977	DEC	8	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	9	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	10	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	11	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	12	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	13	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	14	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	15	0:00	9:38	COMBINED FUEL B	0.29	9.6		
1977	DEC	15	15:53	24:00	COMBINED FUEL B	0.29	8.1	284.0	16.0
1977	DEC	16	0:00	7:39	COMBINED FUEL B	0.29	7.6		
1977	DEC	16	15:28	24:00	COMBINED FUEL B	0.29	8.5	258.9	16.0
1977	DEC	17	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	18	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	19	0:00	22:07	COMBINED FUEL B	0.29	22.1	353.9	16.0
1977	DEC	20	12:10	24:00	COMBINED FUEL B	0.29	11.8	189.3	16.0
1977	DEC	21	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	22	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	23	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	24	0:00	18:43	COMBINED FUEL B	0.29	18.7		
1977	DEC	24	21:55	24:00	COMBINED FUEL B	0.29	2.1	332.8	16.0
1977	DEC	25	0:00	22:00	COMBINED FUEL B	0.29	22.0	352.0	16.0
1977	DEC	26	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	27	0:00	9:20	COMBINED FUEL B	0.29	9.3		
1977	DEC	27	14:14	24:00	COMBINED FUEL B	0.29	9.8	305.6	16.0
1977	DEC	28	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	29	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	30	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0
1977	DEC	31	0:00	24:00	COMBINED FUEL B	0.29	24.0	384.0	16.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E SOUTH BAY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JAN	4	9:10	9:40	JP-5	0.30	0.5	11.0	22.0
1975	JAN	8	10:23	10:30	JP-5	0.30	0.1		
1975	JAN	8	11:08	11:12	JP-5	0.30	0.1	4.0	22.0
1975	JAN	11	11:45	12:05	JP-5	0.30	0.3	7.3	22.0
1975	JAN	17	8:36	9:27	JP-5	0.30	0.9	18.7	22.0
1975	JAN	18	9:16	9:31	JP-5	0.30	0.3		
1975	JAN	18	12:30	12:32	JP-5	0.30	0.0	6.2	22.0
1975	JAN	24	8:17	8:47	JP-5	0.30	0.5	11.0	22.0
1975	FEB	1	9:15	9:40	JP-5	0.30	0.4	9.2	22.0
1975	FEB	8	8:15	8:36	JP-5	0.30	0.3	7.7	22.0
1975	FEB	10	9:27	9:51	JP-5	0.30	0.4	8.8	22.0
1975	FEB	16	9:49	10:05	JP-5	0.30	0.3	5.9	22.0
1975	FEB	23	9:35	10:05	JP-5	0.30	0.5	11.0	22.0
1975	MAR	1	9:55	10:15	JP-5	0.30	0.3	7.3	22.0
1975	MAR	4	8:15	8:20	JP-5	0.30	0.1	1.8	22.0
1975	MAR	7	11:29	11:53	JP-5	0.30	0.4	8.8	22.0
1975	MAR	15	10:02	10:15	JP-5	0.30	0.2		
1975	MAR	15	13:11	13:16	JP-5	0.30	0.1	6.6	22.0
1975	MAR	22	8:50	9:24	JP-5	0.30	0.6	12.5	22.0
1975	MAR	29	9:15	10:42	JP-5	0.30	1.4	31.9	22.0
1975	APR	5	9:15	10:23	JP-5	0.30	1.1	24.9	22.0
1975	APR	12	9:10	9:37	JP-5	0.30	0.4		
1975	APR	12	12:07	12:15	JP-5	0.30	0.1	12.8	22.0
1975	APR	19	8:30	9:00	JP-5	0.30	0.5	11.0	22.0
1975	APR	26	10:22	10:42	JP-5	0.30	0.3	7.3	22.0
1975	MAY	3	10:25	11:05	JP-5	0.30	0.7	14.7	22.0
1975	MAY	10	9:07	9:26	JP-5	0.30	0.3		
1975	MAY	10	12:00	12:05	JP-5	0.30	0.1	8.8	22.0
1975	MAY	17	8:20	8:55	JP-5	0.30	0.6	12.8	22.0
1975	MAY	24	9:37	9:48	JP-5	0.30	0.2		
1975	MAY	24	9:52	10:25	JP-5	0.30	0.6	16.1	22.0
1975	MAY	31	11:12	12:08	JP-5	0.30	0.9	20.5	22.0
1975	JUN	7	10:17	10:38	JP-5	0.30	0.3	7.7	22.0
1975	JUN	14	8:36	9:07	JP-5	0.30	0.5		
1975	JUN	14	12:58	13:12	JP-5	0.30	0.2	16.5	22.0
1975	JUN	28	12:19	12:41	JP-5	0.30	0.4	8.1	22.0
1975	JUL	6	9:12	9:33	JP-5	0.30	0.3		
1975	JUL	6	11:41	11:46	JP-5	0.30	0.1	9.5	22.0
1975	JUL	13	10:01	10:20	JP-5	0.30	0.3	7.0	22.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E SOUTH BAY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	JUL	19	11:00	11:28	JP-5	0.30	0.5	10.3	22.0
1975	JUL	26	9:38	10:10	JP-5	0.30	0.5	11.7	22.0
1975	AUG	2	9:50	10:07	JP-5	0.30	0.3	6.2	22.0
1975	AUG	9	10:07	10:35	JP-5	0.30	0.5	10.3	22.0
1975	AUG	16	12:02	12:37	JP-5	0.30	0.6	12.8	22.0
1975	AUG	23	10:16	10:55	JP-5	0.30	0.6	14.3	22.0
1975	AUG	25	14:27	14:35	JP-5	0.30	0.1	2.9	22.0
1975	AUG	31	10:27	10:59	JP-5	0.30	0.5		
1975	AUG	31	13:07	13:12	JP-5	0.30	0.1	13.6	22.0
1975	SEP	6	9:13	9:46	JP-5	0.30	0.5	12.1	22.0
1975	SEP	13	9:20	9:40	JP-5	0.30	0.3	7.3	22.0
1975	SEP	20	10:22	10:55	JP-5	0.30	0.5	12.1	22.0
1975	SEP	27	9:28	9:33	JP-5	0.30	0.1		
1975	SEP	27	9:42	9:53	JP-5	0.30	0.2	5.9	22.0
1975	OCT	4	9:00	9:05	JP-5	0.30	0.1		
1975	OCT	4	9:10	9:35	JP-5	0.30	0.4	11.0	22.0
1975	OCT	11	8:17	8:24	JP-5	0.30	0.1		
1975	OCT	11	8:38	9:32	JP-5	0.30	0.9	22.4	22.0
1975	OCT	19	11:00	11:03	JP-5	0.30	0.0		
1975	OCT	19	11:10	11:18	JP-5	0.30	0.1	4.0	22.0
1975	OCT	25	10:58	10:59	JP-5	0.30	0.0		
1975	OCT	25	11:05	11:17	JP-5	0.30	0.2	4.8	22.0
1975	NOV	9	10:11	10:20	JP-5	0.30	0.1		
1975	NOV	9	10:23	10:46	JP-5	0.30	0.4	11.7	22.0
1975	NOV	14	7:54	7:56	JP-5	0.30	0.0		
1975	NOV	14	8:00	8:03	JP-5	0.30	0.0		
1975	NOV	14	8:03	8:10	JP-5	0.30	0.1		
1975	NOV	14	8:24	8:30	JP-5	0.30	0.1		
1975	NOV	14	8:33	8:35	JP-5	0.30	0.0		
1975	NOV	14	13:51	13:57	JP-5	0.30	0.1	9.5	22.0
1975	NOV	22	10:05	10:15	JP-5	0.30	0.2		
1975	NOV	22	10:20	10:32	JP-5	0.30	0.2	8.1	22.0
1975	NOV	29	9:22	9:26	JP-5	0.30	0.1		
1975	NOV	29	9:32	10:06	JP-5	0.30	0.6	13.9	22.0
1975	DEC	5	10:14	10:50	JP-5	0.30	0.6	13.2	22.0
1975	DEC	14	10:10	10:12	JP-5	0.30	0.0		
1975	DEC	14	10:18	10:40	JP-5	0.30	0.4	8.8	22.0
1975	DEC	20	12:30	12:53	JP-5	0.30	0.4	8.4	22.0
1975	DEC	22	18:20	18:30	JP-5	0.30	0.2	3.7	22.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E SOUTH BAY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1975	DEC	27	8:50	9:38	JP-5	0.30	0.8	17.6	22.0
1976	JAN	3	8:20	8:50	JP-5	0.26	0.5	11.0	22.0
1976	JAN	7	13:30	13:45	JP-5	0.26	0.3	5.5	22.0
1976	JAN	10	9:15	9:21	JP-5	0.26	0.1		
1976	JAN	10	9:36	9:58	JP-5	0.26	0.4		
1976	JAN	10	12:26	12:31	JP-5	0.26	0.1	12.1	22.0
1976	JAN	17	8:35	8:45	JP-5	0.26	0.2		
1976	JAN	17	12:20	12:27	JP-5	0.26	0.1	6.2	22.0
1976	JAN	24	9:28	10:10	JP-5	0.26	0.7	15.4	22.0
1976	JAN	31	9:22	9:27	JP-5	0.26	0.1		
1976	JAN	31	9:32	10:05	JP-5	0.26	0.6	13.9	22.0
1976	FEB	5	17:39	18:20	JP-5	0.26	0.7	15.0	22.0
1976	FEB	14	9:08	9:39	JP-5	0.26	0.5		
1976	FEB	14	11:39	11:40	JP-5	0.26	0.0	11.7	22.0
1976	FEB	21	8:49	9:00	JP-5	0.26	0.2		
1976	FEB	21	9:00	9:30	JP-5	0.26	0.5	15.0	22.0
1976	FEB	24	11:28	11:56	JP-5	0.26	0.5	10.3	22.0
1976	FEB	28	9:18	9:20	JP-5	0.26	0.0		
1976	FEB	28	9:30	9:58	JP-5	0.26	0.5	11.0	22.0
1976	MAR	3	13:39	13:45	JP-5	0.26	0.1		
1976	MAR	3	13:48	13:52	JP-5	0.26	0.1		
1976	MAR	3	13:54	13:57	JP-5	0.26	0.0		
1976	MAR	3	13:58	14:00	JP-5	0.26	0.0		
1976	MAR	3	14:02	16:16	JP-5	0.26	2.2	54.6	22.0
1976	MAR	6	10:26	10:28	JP-5	0.26	0.0		
1976	MAR	6	10:38	11:18	JP-5	0.26	0.7	15.4	22.0
1976	MAR	10	18:01	18:03	JP-5	0.26	0.0	0.7	22.0
1976	MAR	13	9:16	9:39	JP-5	0.26	0.4	8.4	22.0
1976	MAR	18	14:24	15:01	JP-5	0.26	0.6	13.6	22.0
1976	MAR	27	9:47	10:10	JP-5	0.26	0.4	8.4	22.0
1976	APR	1	10:12	10:17	JP-5	0.26	0.1		
1976	APR	1	10:22	10:38	JP-5	0.26	0.3		
1976	APR	1	10:44	10:54	JP-5	0.26	0.2		
1976	APR	1	11:25	12:14	JP-5	0.26	0.8		
1976	APR	1	14:21	14:57	JP-5	0.26	0.6	42.5	22.0
1976	APR	2	8:23	8:38	JP-5	0.26	0.3		
1976	APR	2	8:51	9:23	JP-5	0.26	0.5	17.2	22.0
1976	APR	6	18:22	18:39	JP-5	0.26	0.3		
1976	APR	6	18:45	18:52	JP-5	0.26	0.1	8.8	22.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E SOUTH BAY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	APR	10	8:40	9:25	JP-5	0.26	0.8	16.5	22.0
1976	APR	17	8:20	8:26	JP-5	0.26	0.1		
1976	APR	17	8:35	9:05	JP-5	0.26	0.5	13.2	22.0
1976	APR	24	10:22	10:27	JP-5	0.26	0.1		
1976	APR	24	10:33	10:50	JP-5	0.26	0.3	8.1	22.0
1976	MAY	1	10:09	10:47	JP-5	0.26	0.6	13.9	22.0
1976	MAY	8	8:27	8:56	JP-5	0.26	0.5		
1976	MAY	8	12:41	12:46	JP-5	0.26	0.1	12.5	22.0
1976	MAY	12	14:10	14:13	JP-5	0.26	0.0		
1976	MAY	12	14:28	14:32	JP-5	0.26	0.1		
1976	MAY	12	14:52	14:55	JP-5	0.26	0.0		
1976	MAY	12	17:41	17:46	JP-5	0.26	0.1	5.5	22.0
1976	MAY	15	8:05	8:15	JP-5	0.26	0.2		
1976	MAY	15	8:17	8:45	JP-5	0.26	0.5	13.9	22.0
1976	MAY	22	10:18	10:40	JP-5	0.26	0.4	8.1	22.0
1976	JUN	5	9:13	9:31	JP-5	0.26	0.3		
1976	JUN	5	12:40	13:35	JP-5	0.26	0.9	26.8	22.0
1976	JUN	12	10:33	10:35	JP-5	0.26	0.0		
1976	JUN	12	10:43	11:13	JP-5	0.26	0.5	11.7	22.0
1976	JUN	19	9:34	9:56	JP-5	0.26	0.4	8.1	22.0
1976	JUN	26	10:30	10:52	JP-5	0.26	0.4		
1976	JUN	26	10:58	11:25	JP-5	0.26	0.5	18.0	22.0
1976	JUN	28	12:30	14:21	JP-5	0.26	1.8	40.7	22.0
1976	JUN	29	9:04	9:23	JP-5	0.26	0.3	7.0	22.0
1976	JUL	3	8:26	8:50	JP-5	0.26	0.4		
1976	JUL	3	11:07	11:12	JP-5	0.26	0.1	10.6	22.0
1976	JUL	10	8:35	9:05	JP-5	0.26	0.5	11.0	22.0
1976	JUL	17	10:31	11:17	JP-5	0.26	0.8	16.9	22.0
1976	JUL	24	9:18	9:47	JP-5	0.26	0.5	10.6	22.0
1976	JUL	30	11:10	11:41	JP-5	0.26	0.5	11.4	22.0
1976	AUG	2	10:58	11:02	JP-5	0.26	0.1		
1976	AUG	2	11:06	12:28	JP-5	0.26	1.4	31.5	22.0
1976	AUG	14	10:27	10:50	JP-5	0.26	0.4	8.4	22.0
1976	AUG	21	11:20	11:30	JP-5	0.26	0.2		
1976	AUG	21	11:45	12:05	JP-5	0.26	0.3	11.0	22.0
1976	AUG	28	11:15	11:21	JP-5	0.26	0.1	2.2	22.0
1976	SEP	4	8:21	8:26	JP-5	0.26	0.1		
1976	SEP	4	8:31	8:57	JP-5	0.26	0.4		
1976	SEP	4	14:33	15:10	JP-5	0.26	0.6	24.9	22.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E SOUTH BAY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1976	SEP	10	1:07	1:17	JP-5	0.26	0.2	3.7	22.0
1976	SEP	18	12:22	12:26	JP-5	0.26	0.1		
1976	SEP	18	12:38	13:01	JP-5	0.26	0.4		
1976	SEP	18	15:50	15:55	JP-5	0.26	0.1	11.7	22.0
1976	SEP	25	19:55	20:29	JP-5	0.26	0.6	12.5	22.0
1976	SEP	27	9:53	9:58	JP-5	0.26	0.1	1.8	22.0
1976	OCT	2	8:10	8:17	JP-5	0.26	0.1		
1976	OCT	2	8:22	8:55	JP-5	0.26	0.5	14.7	22.0
1976	OCT	9	8:03	8:07	JP-5	0.26	0.1		
1976	OCT	9	8:13	8:45	JP-5	0.26	0.5		
1976	OCT	9	12:22	12:28	JP-5	0.26	0.1	15.4	22.0
1976	OCT	17	10:37	11:00	JP-5	0.26	0.4		
1976	OCT	17	13:23	13:28	JP-5	0.26	0.1	10.3	22.0
1976	OCT	23	9:05	9:38	JP-5	0.26	0.5		
1976	OCT	23	11:43	11:48	JP-5	0.26	0.1	13.9	22.0
1976	OCT	26	9:58	10:00	JP-5	0.26	0.0		
1976	OCT	26	10:08	10:26	JP-5	0.26	0.3		
1976	OCT	26	10:34	15:39	JP-5	0.26	5.1	119.2	22.0
1976	OCT	27	9:07	11:30	JP-5	0.26	2.4		
1976	OCT	27	11:32	15:24	JP-5	0.26	3.9		
1976	OCT	27	16:00	18:25	JP-5	0.26	2.4	190.7	22.0
1976	OCT	28	9:31	9:39	JP-5	0.26	0.1		
1976	OCT	28	9:48	10:08	JP-5	0.26	0.3		
1976	OCT	28	17:10	17:11	JP-5	0.26	0.0	10.6	22.0
1976	OCT	29	11:29	11:34	JP-5	0.26	0.1		
1976	OCT	29	11:42	15:25	JP-5	0.26	3.7	83.6	22.0
1976	NOV	6	11:55	12:34	JP-5	0.26	0.7	14.3	22.0
1976	NOV	23	18:22	19:31	JP-5	0.26	1.1		
1976	NOV	23	19:39	20:49	JP-5	0.26	1.2	51.0	22.0
1976	DEC	4	11:08	11:56	JP-5	0.26	0.8	17.6	22.0
1976	DEC	5	9:43	10:35	JP-5	0.26	0.9	19.1	22.0
1976	DEC	9	12:32	13:36	JP-5	0.26	1.1	23.5	22.0
1976	DEC	15	13:09	13:42	JP-5	0.26	0.5	12.1	22.0
1976	DEC	30	17:24	18:50	JP-5	0.26	1.4	31.5	22.0
1977	JAN	1	7:45	7:59	JP-5	0.29	0.2		
1977	JAN	1	8:07	8:36	JP-5	0.29	0.5	15.8	22.0
1977	FEB	1	15:17	16:14	JP-5	0.29	1.0	20.9	22.0
1977	FEB	3	10:04	10:56	JP-5	0.29	0.9	19.1	22.0
1977	FEB	7	8:07	8:39	JP-5	0.29	0.5	11.7	22.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

ELECTRIC GENERATING STATION: SDG&E SOUTH BAY STATION

UNIT NUMBER: 1

YEAR	MONTH	DAY	START UP TIME	SHUT DOWN TIME	FUEL BURNED	FUEL SULFUR CONTENT (% WT)	UNIT OPERATING PERIOD (HOURS)	TOTAL POWER GENERATED (MWH)	AVERAGE UNIT LOAD (MW)
1977	FEB	9	8:42	9:14	JP-5	0.29	0.5	11.7	22.0
1977	MAR	6	8:10	8:45	JP-5	0.29	0.6	12.8	22.0
1977	APR	2	11:45	12:45	JP-5	0.29	1.0	22.0	22.0
1977	MAY	13	8:20	8:53	JP-5	0.29	0.5		
1977	MAY	13	9:00	9:48	JP-5	0.29	0.8		
1977	MAY	13	10:35	14:47	JP-5	0.29	4.2	122.1	22.0
1977	JUL	8	9:30	10:00	JP-5	0.29	0.5	11.0	22.0
1977	JUL	29	15:02	15:16	JP-5	0.29	0.2		
1977	JUL	29	15:22	15:58	JP-5	0.29	0.6	18.3	22.0
1977	AUG	3	12:52	13:02	JP-5	0.29	0.2	3.7	22.0
1977	SEP	3	9:10	9:14	JP-5	0.29	0.1		
1977	SEP	3	9:19	10:00	JP-5	0.29	0.7	16.5	22.0
1977	OCT	1	12:15	12:45	JP-5	0.29	0.5	11.0	22.0
1977	OCT	15	17:53	17:58	JP-5	0.29	0.1	1.8	22.0
1977	OCT	16	16:28	16:45	JP-5	0.29	0.3	6.2	22.0
1977	OCT	26	8:48	9:25	JP-5	0.29	0.6		
1977	OCT	26	9:34	9:43	JP-5	0.29	0.1	16.9	22.0
1977	OCT	29	15:55	16:05	JP-5	0.29	0.2		
1977	OCT	29	16:18	16:23	JP-5	0.29	0.1	5.5	22.0
1977	NOV	3	13:40	14:10	JP-5	0.29	0.5	11.0	22.0
1977	NOV	4	14:15	14:45	JP-5	0.29	0.5	11.0	22.0
1977	NOV	5	11:30	12:50	JP-5	0.29	1.3	29.3	22.0
1977	NOV	7	14:00	15:00	JP-5	0.29	1.0	22.0	22.0
1977	NOV	14	12:55	13:45	JP-5	0.29	0.8	18.3	22.0
1977	DEC	5	7:52	8:46	JP-5	0.29	0.9	19.8	22.0

NEG = NEGLIGIBLE

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E DIVISION STATION

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7:00 TO 8:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8:00 TO 9:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9:00 TO 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10:00 TO 11:00	15.0	0.0	0.0	0.0	0.0	0.0	0.0	11.7	0.0	0.0	0.0	0.0	11.7
11:00 TO 12:00	11.7	0.0	10.0	0.0	0.0	0.0	8.7	16.7	7.7	0.0	1.3	0.0	49.3
12:00 TO 13:00	0.0	0.0	20.0	0.0	0.0	0.0	3.3	0.0	20.0	0.0	7.7	0.0	52.7
13:00 TO 14:00	0.0	0.0	20.0	0.0	0.0	9.3	0.0	0.0	20.0	0.0	0.0	1.0	41.0
14:00 TO 15:00	1.3	0.0	20.0	0.0	0.0	6.0	0.0	0.0	15.0	0.0	0.0	20.0	64.3
15:00 TO 16:00	0.0	0.0	0.0	0.0	0.0	5.3	0.0	0.0	0.0	0.0	0.0	0.0	27.3
16:00 TO 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.3
17:00 TO 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
18:00 TO 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
19:00 TO 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20:00 TO 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
21:00 TO 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22:00 TO 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	28.0	0.0	70.0	0.0	0.0	20.7	12.0	28.3	62.7	0.0	9.0	21.0	251.7

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDGEE)

STATION: SDGRE DIVISION STATION

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	0.0	0.0	0.0	2.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.0	0.0	0.0	0.0	6.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	10.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10.7
4:00 TO 5:00	14.3	0.0	4.3	7.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0
5:00 TO 6:00	16.7	0.0	26.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	42.7
6:00 TO 7:00	0.0	4.0	40.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	44.0
7:00 TO 8:00	11.0	20.0	32.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	63.3
8:00 TO 9:00	20.0	25.3	40.0	0.0	0.0	0.0	0.0	0.0	0.0	17.0	0.0	0.0	102.3
9:00 TO 10:00	20.0	53.0	40.3	0.0	0.0	2.7	0.0	0.0	10.3	15.7	9.0	11.7	162.7
10:00 TO 11:00	1.0	75.0	40.0	14.3	0.0	18.3	0.0	0.7	0.0	11.7	20.0	0.0	181.0
11:00 TO 12:00	0.0	47.7	40.0	20.0	0.0	8.3	0.0	30.7	0.0	0.0	25.3	0.0	172.0
12:00 TO 13:00	0.0	28.0	22.3	1.7	0.0	20.0	0.0	9.0	0.0	0.0	40.0	0.0	121.0
13:00 TO 14:00	0.0	9.7	36.7	0.0	2.3	20.0	13.0	0.0	11.7	0.0	40.0	0.0	133.3
14:00 TO 15:00	0.0	20.0	20.0	0.0	0.0	26.0	20.0	0.0	31.7	0.0	3.3	0.0	121.0
15:00 TO 16:00	0.0	20.0	2.3	0.0	0.0	20.0	20.0	0.0	11.7	7.3	0.0	0.0	81.3
16:00 TO 17:00	0.0	12.0	0.0	0.0	8.3	20.0	5.7	0.0	0.0	0.0	36.3	0.0	82.3
17:00 TO 18:00	21.7	58.0	18.0	0.0	19.7	17.3	0.0	0.0	0.0	0.0	123.0	12.7	270.3
18:00 TO 19:00	22.7	98.7	80.0	21.0	2.3	0.0	0.0	0.0	0.0	12.7	117.3	12.3	367.0
19:00 TO 20:00	10.0	61.7	73.3	40.0	0.0	0.0	0.0	0.0	0.0	7.7	55.0	0.0	247.7
20:00 TO 21:00	0.0	38.3	55.7	30.0	0.0	0.0	15.0	0.0	0.0	0.0	21.7	0.0	160.7
21:00 TO 22:00	0.0	6.7	12.0	1.7	0.0	0.0	13.7	0.0	0.0	0.0	20.0	0.0	54.0
22:00 TO 23:00	0.0	0.0	0.0	0.0	2.0	0.0	0.0	0.0	0.0	0.0	2.3	0.0	4.3
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	137.3	578.0	583.3	146.7	34.7	152.7	87.3	40.3	73.3	72.0	513.3	36.7	2455.7

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E EL CAJON STATION

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	6.3	0.0	0.0	0.0	0.0	4.9	26.9	0.0	0.0	38.1
7:00 TO 8:00	0.0	0.0	0.0	21.0	0.0	0.0	0.0	0.0	55.3	105.3	14.7	16.8	213.1
8:00 TO 9:00	17.8	0.0	0.0	67.5	0.0	0.0	21.3	5.6	81.5	147.0	42.0	35.0	417.9
9:00 TO 10:00	37.8	0.0	21.0	112.0	0.0	0.0	35.3	0.0	108.5	157.8	42.0	55.3	569.8
10:00 TO 11:00	64.4	4.5	21.0	115.5	21.0	12.9	35.3	0.0	162.4	160.6	84.7	23.8	706.3
11:00 TO 12:00	38.8	13.6	21.0	116.2	37.8	21.0	42.0	0.0	160.3	157.1	60.5	0.0	668.5
12:00 TO 13:00	0.0	0.0	23.8	93.1	42.0	13.6	79.1	0.0	167.6	147.0	29.7	6.6	602.7
13:00 TO 14:00	2.8	0.0	63.0	52.5	53.2	33.6	68.6	5.3	175.7	147.0	55.3	21.0	677.9
14:00 TO 15:00	0.0	0.0	84.0	30.4	42.0	21.0	57.0	8.7	169.7	112.3	33.9	7.7	567.0
15:00 TO 16:00	10.5	0.0	61.2	21.0	42.7	21.0	82.9	0.0	171.1	86.8	10.8	0.0	508.2
16:00 TO 17:00	21.0	0.0	2.8	21.0	21.0	3.8	27.6	2.8	154.0	74.2	40.6	30.1	399.0
17:00 TO 18:00	58.4	0.0	0.0	2.1	9.4	0.0	0.0	5.9	72.1	54.6	157.5	213.5	573.6
18:00 TO 19:00	61.9	0.0	13.3	24.5	0.0	0.0	0.0	12.2	93.8	57.8	133.7	159.9	557.2
19:00 TO 20:00	32.2	0.0	44.1	81.5	0.0	9.4	0.0	2.4	84.0	57.7	64.0	42.3	417.9
20:00 TO 21:00	15.0	0.0	54.6	120.0	0.0	24.5	12.2	0.0	84.0	21.0	12.2	10.1	353.8
21:00 TO 22:00	0.0	0.0	11.9	41.6	0.0	25.5	4.2	0.0	22.0	9.1	0.0	0.0	114.4
22:00 TO 23:00	0.0	0.0	0.0	21.0	0.0	4.2	0.0	0.0	0.0	0.0	0.0	0.0	25.2
23:00 TO 24:00	0.0	0.0	0.0	1.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.4
TOTAL	360.8	18.2	421.7	948.8	269.1	190.7	465.8	43.0	1767.1	1522.5	781.9	622.3	7412.3

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E EL CAJON STATION

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.1	0.0	0.0	0.0	2.1
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.9	0.0	0.0	0.0	5.9
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	11.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11.2
4:00 TO 5:00	15.0	0.0	0.0	7.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22.7
5:00 TO 6:00	21.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	21.0
6:00 TO 7:00	13.3	0.0	17.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8.0	0.0	39.2
7:00 TO 8:00	21.0	0.0	21.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	42.0
8:00 TO 9:00	16.8	0.0	36.4	0.0	0.0	3.5	0.0	5.3	0.0	0.0	0.0	0.0	61.9
9:00 TO 10:00	0.0	0.0	37.4	0.0	0.0	36.4	11.2	46.9	0.0	0.0	0.0	0.0	131.9
10:00 TO 11:00	0.0	0.0	46.5	14.3	16.8	58.1	60.5	79.8	0.0	0.0	19.2	0.0	295.4
11:00 TO 12:00	0.0	0.0	42.0	12.2	21.0	95.9	93.1	122.1	0.0	0.0	30.4	0.0	416.8
12:00 TO 13:00	0.0	0.0	43.4	4.9	24.1	79.1	70.7	93.1	0.0	0.0	66.8	0.0	382.2
13:00 TO 14:00	0.0	0.0	68.2	0.0	42.0	116.5	80.5	67.5	0.0	0.0	72.4	0.0	447.3
14:00 TO 15:00	0.0	0.0	58.4	0.0	42.0	89.9	86.8	43.0	14.0	7.0	63.0	0.0	404.2
15:00 TO 16:00	0.0	0.0	21.0	0.0	42.0	65.4	79.4	52.1	21.0	8.4	42.0	0.0	331.4
16:00 TO 17:00	0.0	0.0	21.0	0.0	33.2	44.8	39.2	32.5	0.7	5.9	46.9	7.3	231.7
17:00 TO 18:00	59.8	0.0	21.7	0.0	8.0	47.3	20.3	9.1	0.0	21.0	100.1	52.8	340.2
18:00 TO 19:00	80.5	0.0	42.0	14.3	21.0	25.9	0.0	0.0	0.0	21.0	91.3	53.5	349.6
19:00 TO 20:00	43.4	0.0	35.7	19.2	6.3	0.0	0.0	0.0	42.3	21.0	43.4	24.5	235.9
20:00 TO 21:00	21.7	0.0	21.0	0.0	18.2	33.2	0.0	0.0	64.0	13.6	22.7	0.3	194.9
21:00 TO 22:00	1.4	0.0	1.7	0.0	21.0	12.6	0.0	0.0	16.4	0.0	21.0	0.0	74.2
22:00 TO 23:00	0.0	0.0	0.0	0.0	8.7	0.0	0.0	0.0	0.0	0.0	11.2	0.0	19.9
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	294.0	0.0	535.5	84.0	304.5	708.7	541.8	551.6	166.6	98.0	638.7	138.6	4062.1

GAS TURBINE PEAKING UNIT DAILY OPERATING PATTERN

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E EL CAJON STATION

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	13.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.6
4:00 TO 5:00	0.0	21.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	21.0
5:00 TO 6:00	0.0	20.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	20.6
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7:00 TO 8:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8:00 TO 9:00	0.0	0.0	0.0	2.8	0.0	0.0	4.9	12.9	0.0	0.7	0.0	0.0	21.3
9:00 TO 10:00	0.0	0.0	0.0	21.0	0.0	0.0	41.3	21.0	17.5	21.0	5.3	0.0	127.0
10:00 TO 11:00	18.9	0.0	0.0	8.4	27.6	4.5	71.0	29.7	21.0	29.4	17.5	0.0	228.2
11:00 TO 12:00	0.0	0.0	0.0	0.0	26.3	21.0	113.0	30.8	21.0	63.0	0.0	0.0	275.1
12:00 TO 13:00	0.0	17.5	0.0	0.0	21.0	21.0	144.9	70.7	37.1	63.0	0.0	0.0	375.2
13:00 TO 14:00	0.0	38.1	1.0	12.2	21.0	21.0	150.8	74.5	35.0	49.7	0.0	0.0	403.5
14:00 TO 15:00	0.0	8.0	28.7	5.9	21.0	8.4	126.0	91.0	41.3	46.9	0.0	0.0	377.3
15:00 TO 16:00	0.0	21.0	0.0	9.1	4.9	0.0	112.7	85.7	26.6	27.3	0.0	0.0	287.3
16:00 TO 17:00	0.0	1.7	0.0	0.0	0.0	0.0	115.5	63.3	24.5	21.0	1.7	0.0	227.8
17:00 TO 18:00	15.8	0.0	0.0	0.0	0.0	0.0	121.4	42.0	21.0	24.5	80.5	19.9	325.1
18:00 TO 19:00	25.9	0.0	0.0	5.9	0.0	0.0	57.7	26.6	3.5	30.1	92.4	21.0	263.2
19:00 TO 20:00	0.0	0.0	0.0	6.6	0.0	0.0	43.0	9.4	0.0	21.0	53.5	5.2	138.9
20:00 TO 21:00	1.7	0.0	0.0	0.0	0.0	0.0	78.4	21.0	0.0	5.3	36.8	0.0	143.1
21:00 TO 22:00	21.0	0.0	0.0	0.0	0.0	0.0	79.4	0.7	0.0	0.0	17.1	0.0	118.3
22:00 TO 23:00	21.0	0.0	0.0	0.0	0.0	0.0	14.3	0.0	0.0	0.0	0.0	0.0	35.3
23:00 TO 24:00	15.0	0.0	0.0	0.0	11.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.2
TOTAL	119.3	141.7	29.7	72.1	133.0	75.9	1274.7	579.6	248.5	402.8	304.8	46.2	3428.6

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E ENCINA STATION

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	9.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9.3
6:00 TO 7:00	0.0	0.0	0.0	6.0	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.7
7:00 TO 8:00	0.0	0.0	0.0	20.0	0.0	0.0	0.0	0.0	0.0	0.0	19.0	9.3	48.3
8:00 TO 9:00	0.0	0.0	19.0	33.3	0.0	7.7	2.3	11.7	0.0	0.0	20.0	21.0	115.0
9:00 TO 10:00	0.0	0.0	30.7	57.3	0.0	18.3	23.3	23.0	41.0	13.7	38.3	32.0	277.7
10:00 TO 11:00	0.0	0.0	49.3	72.7	14.7	0.0	72.0	69.7	60.0	34.0	46.0	8.7	427.0
11:00 TO 12:00	0.0	0.0	60.7	77.7	12.7	0.0	82.7	64.7	60.0	57.7	43.3	0.0	459.3
12:00 TO 13:00	0.0	0.0	59.3	47.3	0.0	16.7	60.0	92.0	67.3	40.0	24.3	13.7	420.7
13:00 TO 14:00	16.3	0.0	47.7	57.0	0.0	13.3	60.0	80.0	100.0	40.0	2.3	33.7	450.3
14:00 TO 15:00	26.3	0.0	20.0	54.0	1.3	0.0	43.3	80.0	100.0	40.0	0.0	27.0	392.0
15:00 TO 16:00	14.0	0.0	20.0	51.3	5.7	0.0	40.0	61.7	100.0	59.7	0.0	20.0	372.3
16:00 TO 17:00	0.0	0.0	12.0	91.7	0.0	0.0	53.0	60.0	100.0	58.3	8.7	52.3	436.0
17:00 TO 18:00	0.0	0.0	0.0	55.3	0.0	0.0	37.3	54.0	100.0	44.7	122.7	149.7	563.7
18:00 TO 19:00	0.0	0.0	13.0	21.3	0.0	0.0	1.7	28.3	73.0	78.0	117.7	134.7	467.7
19:00 TO 20:00	0.0	0.0	27.0	40.0	0.0	0.0	0.0	0.0	73.7	94.0	39.7	76.7	351.0
20:00 TO 21:00	0.0	0.0	28.0	56.0	0.0	7.7	70.7	0.0	50.0	10.7	3.3	25.7	252.0
21:00 TO 22:00	0.0	0.0	20.0	40.0	0.0	7.7	53.0	0.0	10.7	0.0	0.0	0.0	131.3
22:00 TO 23:00	0.0	0.0	1.7	27.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	28.7
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	56.7	0.0	408.3	808.0	44.3	71.3	599.3	625.0	935.7	570.7	485.3	604.3	5209.0

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E ENCINA STATION

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	0.0	0.0	0.0	2.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6.0	0.0	0.0	0.0	6.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.0	13.0
7:00 TO 8:00	0.0	10.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	17.7	28.0
8:00 TO 9:00	9.0	36.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	45.0
9:00 TO 10:00	38.0	40.0	0.0	0.0	0.0	11.0	0.0	11.0	0.0	0.0	0.0	0.0	100.0
10:00 TO 11:00	20.0	40.0	0.0	11.7	0.0	32.7	6.7	26.3	8.3	0.0	0.0	4.0	149.7
11:00 TO 12:00	26.0	34.0	0.0	17.7	0.0	39.0	37.3	12.3	30.7	10.0	0.0	20.0	227.0
12:00 TO 13:00	2.7	22.0	0.0	10.3	0.0	40.0	60.0	54.0	27.0	13.3	4.3	20.0	253.7
13:00 TO 14:00	30.3	53.3	0.0	2.7	0.0	40.0	60.0	77.7	40.0	25.3	10.0	20.0	359.3
14:00 TO 15:00	30.7	31.0	0.0	0.7	0.0	26.0	48.3	59.3	51.0	11.3	0.0	20.0	278.3
15:00 TO 16:00	0.0	15.0	0.0	0.0	12.0	20.0	40.0	57.0	49.0	0.0	0.0	20.0	213.0
16:00 TO 17:00	0.0	20.0	0.0	0.0	20.0	20.0	43.0	52.3	5.3	0.0	16.7	20.0	197.3
17:00 TO 18:00	40.3	37.3	0.0	0.0	3.0	20.0	22.7	41.0	0.0	0.0	36.0	32.0	232.3
18:00 TO 19:00	29.0	27.3	0.0	0.0	0.0	20.0	3.3	19.0	0.0	0.0	49.3	40.0	188.0
19:00 TO 20:00	20.0	20.0	0.0	0.0	0.0	20.0	0.0	8.7	2.0	0.0	20.0	40.0	130.7
20:00 TO 21:00	2.0	20.0	0.0	0.0	0.0	6.7	0.0	19.3	6.3	0.0	20.0	17.3	91.7
21:00 TO 22:00	0.0	14.0	0.0	0.0	0.0	0.0	0.0	13.3	0.0	0.0	12.0	0.0	39.3
22:00 TO 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	248.0	420.3	0.0	43.0	35.0	295.3	321.3	451.3	227.7	60.0	168.3	284.0	2554.3

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E ENCINA STATION

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	16.0	0.0	0.0	0.0	8.3	0.0	0.0	0.0	0.0	8.0	0.0	32.3
4:00 TO 5:00	0.0	4.0	0.0	0.0	0.0	20.0	0.0	0.0	0.0	0.0	14.3	0.0	38.3
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.3
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.0	0.0	4.0
7:00 TO 8:00	0.0	0.0	0.0	0.0	9.3	0.0	0.0	0.0	0.0	0.0	20.0	0.0	29.3
8:00 TO 9:00	0.0	0.0	0.0	0.0	40.0	0.0	0.0	0.0	0.0	0.0	22.0	0.0	62.0
9:00 TO 10:00	0.0	0.0	0.0	0.0	40.0	0.0	0.0	11.3	0.0	10.0	40.0	0.0	101.3
10:00 TO 11:00	0.0	0.0	0.0	0.0	51.0	0.0	0.0	0.0	0.0	0.0	25.7	0.0	76.7
11:00 TO 12:00	0.0	0.0	0.0	0.0	73.0	0.0	4.7	0.0	11.7	4.7	20.0	0.0	114.0
12:00 TO 13:00	0.0	1.3	0.0	0.0	49.0	0.0	38.3	3.7	20.0	20.0	20.0	0.0	152.3
13:00 TO 14:00	0.0	8.0	0.0	0.0	20.0	0.0	56.3	0.0	20.0	20.0	20.0	0.0	144.3
14:00 TO 15:00	0.0	16.3	0.0	0.0	20.0	0.0	73.0	0.0	20.0	20.0	20.0	0.0	169.3
15:00 TO 16:00	0.0	12.7	11.0	0.0	11.7	0.0	60.0	0.0	8.3	20.0	20.0	0.0	143.7
16:00 TO 17:00	0.0	0.0	0.0	0.0	2.7	0.0	49.3	0.0	0.0	20.0	20.0	0.0	92.0
17:00 TO 18:00	0.0	7.0	0.0	0.0	0.0	0.0	30.3	16.0	0.0	3.3	38.0	16.7	111.3
18:00 TO 19:00	0.0	10.0	0.0	0.0	0.0	0.0	7.0	20.0	0.0	0.0	40.0	2.3	79.3
19:00 TO 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.7	0.0	0.0	35.7	0.0	36.3
20:00 TO 21:00	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	20.0	0.0	21.0
21:00 TO 22:00	20.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9.0	3.3	0.0	32.3
22:00 TO 23:00	9.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9.7
23:00 TO 24:00	10.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10.0
TOTAL	40.7	75.3	11.0	0.0	316.7	28.7	319.0	51.7	80.0	127.0	391.0	19.0	1460.0

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E KEARNY STATION 1

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	6.3	6.3	0.0	0.0	0.0	0.0	0.0	5.3	0.0	17.8
7:00 TO 8:00	0.0	0.0	1.0	21.0	21.0	0.0	0.0	0.0	4.5	0.0	49.0	8.7	105.3
8:00 TO 9:00	0.0	4.9	21.0	30.8	30.8	0.0	0.0	0.0	21.0	19.2	24.5	66.5	218.7
9:00 TO 10:00	37.1	21.7	35.0	48.3	48.3	0.0	29.4	0.0	61.9	4.5	21.0	92.7	400.0
10:00 TO 11:00	35.3	21.0	51.8	42.0	42.0	0.0	102.5	0.0	183.4	21.0	21.0	112.3	632.4
11:00 TO 12:00	31.5	15.8	60.5	42.0	42.0	11.2	143.8	0.0	213.5	34.6	21.0	101.5	717.5
12:00 TO 13:00	6.3	0.0	36.0	27.3	27.3	21.0	147.0	19.2	154.3	37.8	21.0	71.4	568.7
13:00 TO 14:00	21.3	32.5	21.0	42.0	42.0	34.6	138.9	21.3	133.7	57.8	26.9	61.6	633.8
14:00 TO 15:00	21.3	0.0	17.5	66.5	66.5	24.8	130.9	42.0	126.0	52.8	2.4	42.3	593.2
15:00 TO 16:00	0.0	6.6	2.8	64.7	64.7	21.0	146.3	31.1	125.0	42.0	0.0	42.0	547.4
16:00 TO 17:00	0.0	5.9	0.0	84.0	84.0	3.8	33.6	21.0	119.0	40.9	14.3	65.4	472.1
17:00 TO 18:00	9.4	0.7	0.0	52.5	52.5	0.0	3.8	21.0	104.6	49.3	165.2	249.9	709.1
18:00 TO 19:00	10.1	28.3	33.2	60.9	60.9	0.0	21.0	20.3	54.2	115.8	151.5	213.1	769.6
19:00 TO 20:00	0.0	33.9	51.8	89.6	89.6	0.0	21.0	12.6	90.3	153.6	54.2	34.3	631.0
20:00 TO 21:00	0.0	3.5	60.2	132.3	134.0	0.0	35.3	42.0	107.1	52.5	1.0	0.0	568.0
21:00 TO 22:00	0.0	0.0	30.1	54.6	54.6	0.0	42.7	24.1	31.8	21.0	0.0	0.0	259.0
22:00 TO 23:00	0.0	0.0	9.1	32.9	32.9	0.0	1.4	7.7	6.3	0.0	0.0	0.0	90.3
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	172.5	175.0	431.2	897.7	899.5	116.5	997.8	262.5	1537.9	703.1	578.5	1162.0	7934.5

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E KEARNY STATION 1

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.1	0.0	0.0	0.0	2.1
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	12.2	5.9	0.0	0.0	0.0	18.2
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	11.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11.2
4:00 TO 5:00	15.0	0.0	0.0	8.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	23.1
5:00 TO 6:00	21.0	0.0	4.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	25.5
6:00 TO 7:00	23.8	0.0	23.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.4	49.0
7:00 TO 8:00	25.5	0.0	46.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.6	98.3
8:00 TO 9:00	51.4	24.1	91.3	0.0	0.0	0.0	31.8	8.4	0.0	0.0	0.0	21.0	228.2
9:00 TO 10:00	42.0	63.0	117.6	1.0	0.0	21.3	44.4	44.8	7.0	12.9	0.0	31.5	385.7
10:00 TO 11:00	39.9	63.0	121.8	0.0	0.0	48.3	45.5	49.0	17.1	0.0	16.4	37.4	438.5
11:00 TO 12:00	21.7	67.2	120.4	0.0	0.0	63.0	42.0	123.2	26.6	9.1	21.0	48.3	542.5
12:00 TO 13:00	0.0	42.0	109.2	4.5	0.0	78.7	70.3	123.9	42.0	45.5	33.6	42.0	591.8
13:00 TO 14:00	21.0	42.0	110.6	0.0	0.0	101.5	105.0	117.9	72.8	42.3	35.7	22.7	671.6
14:00 TO 15:00	16.8	21.0	116.9	0.0	0.0	135.8	91.3	74.9	63.0	62.6	32.5	12.2	627.2
15:00 TO 16:00	0.0	18.5	63.3	0.0	0.0	141.7	63.0	84.0	40.2	49.0	38.1	3.8	501.9
16:00 TO 17:00	0.0	0.0	24.5	0.0	0.0	108.8	78.0	84.0	21.0	42.0	54.9	8.7	422.1
17:00 TO 18:00	35.7	25.2	21.0	7.0	0.0	96.9	57.7	76.6	5.6	52.1	271.6	165.6	816.2
18:00 TO 19:00	63.0	69.3	122.1	54.6	0.0	58.1	21.0	52.1	0.0	128.1	251.6	214.9	1034.9
19:00 TO 20:00	51.4	40.9	81.9	128.4	0.0	1.7	21.0	34.6	105.0	198.8	67.5	45.1	776.6
20:00 TO 21:00	20.6	21.0	21.0	65.8	0.0	17.5	30.4	78.0	128.1	31.8	23.8	21.0	459.2
21:00 TO 22:00	0.0	14.0	4.5	21.0	0.0	8.0	0.0	37.4	24.8	0.0	0.0	11.9	121.8
22:00 TO 23:00	0.0	7.3	0.0	0.0	0.0	0.0	0.0	9.1	0.0	0.0	8.7	0.0	25.2
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	449.0	518.7	1200.8	301.7	0.0	881.6	701.7	1010.4	561.4	674.4	855.7	715.4	7871.1

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E KEARNY STATION 1

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	4.2	0.0	0.0	0.0	0.0	0.0	4.2
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	22.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	22.2
4:00 TO 5:00	0.0	2.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.9
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7:00 TO 8:00	16.8	0.0	8.7	1.0	0.0	0.0	0.0	0.0	0.0	0.0	16.1	0.0	42.7
8:00 TO 9:00	38.5	0.0	21.0	12.9	0.0	0.0	0.0	47.9	1.7	5.9	11.9	0.0	140.0
9:00 TO 10:00	86.4	11.1	5.9	0.0	9.1	0.0	28.0	52.8	21.0	28.0	21.0	0.0	263.4
10:00 TO 11:00	92.0	29.0	0.0	24.5	32.2	15.8	61.2	42.0	21.0	52.1	21.0	0.0	390.8
11:00 TO 12:00	48.4	29.0	12.9	34.3	67.9	21.0	45.8	31.1	21.0	28.3	21.0	0.0	369.9
12:00 TO 13:00	18.8	29.0	35.0	42.0	43.7	21.0	49.3	21.0	54.6	21.0	21.0	15.0	371.6
13:00 TO 14:00	21.0	48.8	38.5	43.4	42.0	21.0	90.3	28.3	71.7	4.5	21.0	28.0	458.7
14:00 TO 15:00	26.6	35.3	4.2	45.5	33.2	8.7	86.1	15.7	63.0	3.5	21.0	0.7	343.6
15:00 TO 16:00	0.0	57.5	0.0	21.0	8.0	0.0	71.7	16.4	46.9	20.3	21.0	0.0	263.0
16:00 TO 17:00	0.0	29.0	0.0	21.7	3.8	0.0	42.0	0.0	42.0	0.7	23.4	2.1	164.8
17:00 TO 18:00	125.9	32.9	8.4	10.8	1.7	0.0	24.1	12.2	33.9	1.7	256.5	207.9	716.3
18:00 TO 19:00	215.0	125.7	80.5	15.4	21.0	0.0	23.1	16.4	22.4	70.3	213.8	163.1	966.8
19:00 TO 20:00	34.8	40.1	30.4	24.1	21.0	0.0	0.0	29.7	90.3	61.6	70.3	26.2	428.8
20:00 TO 21:00	3.4	0.0	22.7	25.2	23.8	0.0	60.5	82.6	98.0	0.0	21.0	0.0	337.3
21:00 TO 22:00	29.0	0.0	0.0	0.0	1.7	0.0	51.8	11.2	5.3	0.0	21.0	0.0	120.0
22:00 TO 23:00	29.0	0.0	0.0	0.0	0.0	0.0	32.9	0.0	0.0	0.0	21.0	0.0	82.9
23:00 TO 24:00	20.3	0.0	0.0	0.0	0.0	0.0	27.3	0.0	0.0	0.0	21.0	0.0	68.6
TOTAL	806.0	492.5	268.4	322.0	309.4	87.5	698.6	407.7	592.9	298.2	823.2	443.1	5549.6

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E KEARNY STATION 2-3

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	10.7	0.0	0.0	0.0	0.0	0.0	21.0	0.0	0.0	40.0	71.7
1:00 TO 2:00	0.0	0.0	141.3	0.0	0.0	0.0	0.0	0.0	23.0	0.0	0.0	0.0	164.3
2:00 TO 3:00	0.0	0.0	4.0	0.0	0.0	0.0	0.0	0.0	60.0	0.0	0.0	0.0	64.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	34.0	0.0	0.0	0.0	34.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7:00 TO 8:00	0.7	1.3	0.0	0.0	0.0	13.3	0.0	135.0	0.0	0.0	8.0	20.0	178.3
8:00 TO 9:00	27.7	30.0	168.0	115.3	102.3	187.3	59.3	136.7	104.7	74.0	136.3	117.0	1258.7
9:00 TO 10:00	88.0	147.0	305.7	300.3	267.7	316.3	122.7	38.0	375.3	209.3	185.7	142.0	2498.0
10:00 TO 11:00	219.7	240.7	363.7	426.0	344.0	353.3	226.3	104.3	678.7	317.3	179.7	206.0	3659.7
11:00 TO 12:00	136.7	159.7	336.7	421.3	322.0	376.3	276.3	191.0	733.7	369.7	191.0	254.0	3768.3
12:00 TO 13:00	68.0	88.3	173.0	294.7	214.7	241.3	382.7	186.7	690.0	290.3	122.0	186.0	2937.7
13:00 TO 14:00	155.7	33.3	130.0	273.7	209.3	275.0	405.3	268.3	778.3	458.3	42.0	212.7	3242.0
14:00 TO 15:00	155.3	20.0	91.0	248.0	218.0	279.3	300.3	261.3	831.3	432.7	28.0	206.0	3071.3
15:00 TO 16:00	115.3	4.0	31.3	255.0	233.0	185.3	195.3	228.3	843.0	312.0	13.7	175.3	2591.7
16:00 TO 17:00	43.3	0.0	9.3	115.7	132.7	43.0	34.7	248.7	776.3	278.0	72.7	224.7	1979.0
17:00 TO 18:00	37.3	45.0	0.0	71.3	85.3	24.3	20.0	279.3	738.3	311.3	486.7	581.0	2680.0
18:00 TO 19:00	67.0	136.7	105.0	172.0	172.0	20.0	14.0	105.7	675.7	194.3	501.7	584.0	2748.0
19:00 TO 20:00	65.0	169.3	209.3	245.7	235.7	56.7	0.0	50.7	729.3	290.3	288.3	363.0	2703.3
20:00 TO 21:00	13.3	117.7	236.3	315.0	256.0	160.0	15.0	75.0	483.7	152.0	34.3	144.3	2002.7
21:00 TO 22:00	0.0	19.0	96.0	195.7	151.7	130.7	14.3	27.7	264.0	29.7	0.0	43.7	972.3
22:00 TO 23:00	0.0	0.0	0.0	54.7	25.7	66.7	0.0	0.0	289.3	0.0	0.0	0.0	436.3
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	127.3	0.0	0.0	32.0	159.3
TOTAL	1193.0	1212.0	2411.3	3504.3	2970.0	2729.0	2066.3	2336.7	9257.0	3719.3	2290.0	3531.7	37220.6

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E KEARNY STATION 2-3

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.0	0.0	0.0	0.0	16.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	74.7	0.0	0.0	0.0	74.7
2:00 TO 3:00	0.0	0.0	128.0	0.0	0.0	0.0	0.0	12.7	0.0	10.0	0.0	0.0	150.7
3:00 TO 4:00	0.0	0.0	97.3	63.0	0.0	0.0	0.0	20.0	0.0	20.0	0.0	0.0	200.3
4:00 TO 5:00	114.7	0.0	80.0	1.3	0.0	0.0	0.0	20.0	0.0	20.0	0.0	0.0	236.0
5:00 TO 6:00	160.0	0.0	90.0	0.0	0.0	0.0	0.0	20.0	0.0	20.0	0.0	0.0	290.0
6:00 TO 7:00	164.7	0.0	141.7	0.0	0.0	0.0	0.0	20.0	0.0	20.0	13.3	52.0	411.7
7:00 TO 8:00	263.7	0.0	216.0	0.0	7.7	0.0	20.0	48.7	0.0	21.0	41.3	154.7	773.0
8:00 TO 9:00	272.0	173.0	125.3	0.0	54.3	77.0	137.7	165.3	0.0	42.0	37.3	95.3	1179.3
9:00 TO 10:00	218.0	195.3	48.7	7.7	95.0	321.7	190.7	429.7	28.0	71.7	89.3	85.0	1780.7
10:00 TO 11:00	199.7	138.7	27.0	24.3	133.0	360.7	361.0	724.3	58.0	104.7	128.7	119.7	2379.7
11:00 TO 12:00	185.0	67.0	28.7	20.0	221.0	484.3	523.3	734.0	90.7	153.0	148.0	176.0	2831.0
12:00 TO 13:00	149.0	30.7	21.0	3.3	183.0	468.7	682.0	625.3	185.7	174.0	146.3	110.0	2779.0
13:00 TO 14:00	70.7	20.3	35.7	0.0	216.3	732.0	768.3	660.0	302.7	260.3	265.3	115.3	3447.0
14:00 TO 15:00	18.3	11.0	43.7	31.0	200.0	885.3	711.0	577.7	324.7	228.0	320.0	22.3	3373.0
15:00 TO 16:00	33.3	11.7	0.0	29.0	238.7	793.7	500.7	539.7	314.7	85.3	251.7	16.0	2814.3
16:00 TO 17:00	0.0	4.0	0.0	5.7	112.0	560.3	350.3	394.3	160.0	50.3	238.3	0.0	1875.3
17:00 TO 18:00	22.7	151.7	12.0	0.0	74.0	410.0	190.3	153.3	9.7	37.3	669.0	218.3	1948.3
18:00 TO 19:00	187.0	180.0	40.0	94.0	5.7	71.3	102.7	88.3	7.0	64.3	546.0	223.0	1609.3
19:00 TO 20:00	91.0	153.0	36.0	266.0	47.3	0.0	29.0	101.7	145.3	197.0	213.3	140.0	1419.7
20:00 TO 21:00	8.7	95.3	4.3	178.3	181.0	68.0	32.7	145.0	281.3	170.0	124.7	140.0	1429.3
21:00 TO 22:00	0.0	68.0	0.0	5.3	54.0	45.0	9.3	49.7	215.0	33.0	93.0	135.0	707.3
22:00 TO 23:00	0.0	1.0	0.0	0.0	2.7	0.0	0.0	5.7	91.7	0.0	19.0	36.0	156.0
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	2158.3	1300.7	1175.3	729.0	1825.7	5278.0	4609.0	5535.3	2305.0	1782.0	3344.7	1838.7	31881.6

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E KEARNY STATION 2-3

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	58.0	0.0	0.0	0.0	0.0	0.0	81.7	0.0	0.0	0.0	0.0	0.0	139.7
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	18.3	0.0	0.0	0.0	0.0	0.0	18.3
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	11.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	11.3
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	130.7	0.0	0.0	0.0	130.7
7:00 TO 8:00	0.0	0.0	0.0	24.3	49.0	0.0	34.3	117.7	80.0	6.0	12.0	8.3	179.7
8:00 TO 9:00	0.0	11.7	0.0	203.7	120.0	0.0	407.3	125.7	44.3	126.7	72.0	27.7	758.0
9:00 TO 10:00	54.0	20.0	6.7	260.3	149.3	101.0	882.0	171.7	196.7	278.0	131.7	59.7	1790.3
10:00 TO 11:00	68.3	41.3	24.0	297.3	219.3	106.3	1083.0	204.7	286.0	286.7	172.3	60.0	2615.3
11:00 TO 12:00	68.3	56.7	56.0	308.3	262.0	80.3	1175.7	216.0	248.3	247.7	250.3	53.3	2919.0
12:00 TO 13:00	51.7	92.0	56.3	367.7	150.7	90.0	1296.0	306.3	185.0	278.7	218.7	41.0	2923.3
13:00 TO 14:00	76.3	38.3	49.0	366.3	136.0	114.3	1387.0	269.3	130.7	290.7	194.0	21.3	3019.3
14:00 TO 15:00	58.3	4.0	21.7	321.7	47.3	72.7	1337.0	323.3	149.7	242.7	193.0	29.0	2796.3
15:00 TO 16:00	25.0	20.0	26.3	102.3	27.0	29.3	1112.7	334.0	164.7	188.7	179.7	25.3	2448.7
16:00 TO 17:00	22.3	13.3	0.0	106.0	0.0	5.0	801.0	245.0	123.3	109.3	172.3	43.7	2042.0
17:00 TO 18:00	332.0	61.0	6.7	120.0	0.0	0.0	401.3	186.7	100.0	48.7	750.7	617.7	3082.7
18:00 TO 19:00	416.3	98.7	106.3	50.7	0.0	0.0	184.0	31.7	100.0	288.0	745.3	511.7	2905.0
19:00 TO 20:00	186.7	27.3	65.7	10.7	0.0	0.0	218.0	37.0	90.0	434.0	300.3	140.3	1470.7
20:00 TO 21:00	60.3	0.0	3.7	8.0	0.0	0.0	187.0	0.0	72.0	267.7	112.0	19.0	797.7
21:00 TO 22:00	83.0	0.0	0.0	0.0	0.0	0.0	160.7	0.0	34.3	220.7	44.3	0.0	569.3
22:00 TO 23:00	80.0	0.0	0.0	0.0	0.0	0.0	199.0	0.0	0.0	28.3	4.7	0.0	273.7
23:00 TO 24:00	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	279.0
TOTAL	1720.7	495.7	422.3	2547.3	1160.7	595.0	10966.0	2569.0	2135.7	3342.3	3553.3	1658.0	31169.9

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E MIRAMAR STATION

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	C.0	C.C	C.0	6.9	12.3	19.2
1:00 TO 2:00	0.0	C.C	C.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	23.0	0.0	23.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	C.C	10.3	13.8	0.0	23.0	0.0	47.1
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	C.C	22.2	23.0	C.0	23.0	0.0	68.2
4:00 TO 5:00	0.C	C.C	0.0	0.0	0.0	C.0	0.0	0.0	23.0	0.0	23.0	0.0	46.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	C.0	0.0	C.0	23.C	C.0	23.0	0.0	46.0
6:00 TO 7:00	0.0	0.0	11.5	6.9	0.0	0.0	0.0	0.0	23.0	C.0	52.5	0.0	93.9
7:00 TO 8:00	4.6	1.9	0.0	3C.7	0.0	0.0	0.0	0.0	30.7	26.1	137.6	1.9	233.5
8:00 TO 9:00	83.6	72.8	45.2	47.5	1.5	C.0	0.0	23.0	24.4	46.0	146.8	52.5	543.4
9:00 TO 10:00	128.0	122.7	117.7	90.5	44.5	0.0	60.6	71.3	141.9	46.0	144.5	99.7	1067.3
10:00 TO 11:00	147.2	76.7	185.9	65.5	69.0	C.0	122.7	83.9	269.4	60.9	170.2	106.2	1357.7
11:00 TO 12:00	145.7	67.1	193.6	55.2	62.9	7.7	168.3	83.9	368.3	26.4	102.0	113.1	1394.1
12:00 TO 13:00	113.5	24.9	146.8	39.1	85.9	23.0	191.7	149.5	323.0	62.3	57.5	62.1	1279.3
13:00 TO 14:00	125.0	37.6	80.5	35.3	111.9	23.0	223.1	158.3	320.9	66.0	13.4	87.0	1282.0
14:00 TO 15:00	91.6	26.4	69.0	64.4	40.6	0.8	175.2	133.0	378.1	53.8	0.0	67.1	1100.1
15:00 TO 16:00	72.8	9.6	56.7	106.6	46.0	0.0	147.2	138.0	377.3	43.0	0.0	43.7	1040.9
16:00 TO 17:00	24.9	0.0	10.7	110.8	46.0	C.0	90.5	143.4	333.3	8.9	37.6	62.9	868.8
17:00 TO 18:00	88.5	9.6	0.0	146.4	15.3	0.0	56.7	164.4	303.7	69.4	342.3	343.8	1540.3
18:00 TO 19:00	115.0	57.9	39.5	153.3	C.C	C.0	44.1	128.8	267.7	165.6	285.2	316.6	1573.7
19:00 TO 20:00	43.7	69.0	89.3	184.4	32.6	0.0	0.8	78.2	250.7	264.5	160.6	189.7	1363.5
20:00 TO 21:00	23.8	30.7	49.4	259.9	49.4	29.9	19.9	156.8	243.5	150.1	87.8	51.0	1152.2
21:00 TO 22:00	23.0	C.0	0.0	151.4	19.5	14.6	23.0	74.7	89.7	40.1	35.6	0.0	471.8
22:00 TO 23:00	7.3	0.0	0.0	81.6	0.0	0.0	2.3	8.0	C.C	2.3	23.0	0.0	124.6
23:00 TO 24:00	0.0	0.C	0.0	18.8	0.0	0.0	0.0	0.0	0.0	0.0	12.6	33.7	65.2
TOTAL	1238.2	606.8	1095.9	1648.3	625.2	98.9	1325.9	1628.0	3828.5	1131.4	1931.2	1643.3	16801.8

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E MIRAMAR STATION

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.3	0.0	0.0	0.0	2.3
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	7.7	0.0	0.0	0.0	7.7
2:00 TO 3:00	0.0	0.0	0.0	19.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	19.5
3:00 TO 4:00	0.0	0.0	0.0	13.0	10.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	23.4
4:00 TO 5:00	33.0	0.0	0.0	0.0	27.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	60.6
5:00 TO 6:00	46.0	0.0	11.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	57.9
6:00 TO 7:00	51.0	0.0	39.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.2	95.1
7:00 TO 8:00	47.9	6.5	37.9	34.1	10.7	0.0	0.0	0.0	0.0	0.0	0.0	23.0	160.2
8:00 TO 9:00	98.9	14.6	62.5	93.5	23.0	11.5	0.0	23.4	0.0	0.0	0.0	0.0	327.4
9:00 TO 10:00	77.4	10.7	59.8	123.8	63.6	134.2	37.2	118.8	0.0	0.0	0.0	21.1	646.7
10:00 TO 11:00	41.0	23.0	75.5	148.0	118.1	278.3	118.4	239.2	11.9	0.0	19.9	30.7	1104.0
11:00 TO 12:00	13.4	23.0	72.8	139.1	159.5	392.1	171.7	230.4	23.0	0.0	28.4	23.0	1276.5
12:00 TO 13:00	0.0	23.0	51.4	143.8	164.1	527.8	241.5	184.8	23.0	5.4	97.4	23.0	1485.0
13:00 TO 14:00	0.0	12.3	68.2	136.1	233.1	566.6	253.0	172.1	59.4	42.9	151.8	12.6	1708.1
14:00 TO 15:00	1.1	3.4	34.1	104.6	239.2	477.2	308.2	126.1	99.7	60.2	110.0	0.0	1564.0
15:00 TO 16:00	17.6	0.0	0.0	72.4	219.3	385.2	287.5	129.2	90.5	92.0	80.9	0.0	1374.6
16:00 TO 17:00	0.0	0.0	0.0	23.0	127.6	336.9	271.8	52.5	5.7	71.7	98.9	8.8	997.0
17:00 TO 18:00	85.1	42.2	2.3	23.0	107.7	288.3	192.8	13.4	0.0	53.7	422.8	266.0	1497.3
18:00 TO 19:00	132.2	116.9	82.8	64.4	79.0	194.7	67.8	0.0	1.5	148.0	369.9	255.3	1512.6
19:00 TO 20:00	74.0	91.2	89.3	196.3	82.8	89.7	28.0	16.5	161.8	198.2	193.6	92.8	1314.1
20:00 TO 21:00	69.0	39.1	47.9	106.2	221.6	120.0	76.3	67.5	146.4	42.2	54.8	46.0	1036.9
21:00 TO 22:00	47.1	2.7	6.9	33.3	97.0	123.0	24.9	27.6	24.9	0.0	46.0	25.7	459.2
22:00 TO 23:00	48.7	0.0	0.0	9.6	27.2	0.0	0.0	0.0	0.0	0.0	33.0	0.0	118.4
23:00 TO 24:00	19.2	0.0	0.0	0.0	28.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	47.1
TOTAL	902.7	408.6	743.3	1483.9	2039.3	3925.7	2079.2	1401.5	657.8	714.1	1707.4	832.2	16895.8

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E MIRAMAR STATION

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	29.5	0.0	0.0	0.0	0.0	0.0	29.5
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	30.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	30.7
4:00 TO 5:00	0.0	15.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	15.3
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	20.3	0.0	0.0	0.0	20.3
7:00 TO 8:00	0.0	33.7	3.4	0.0	13.0	0.0	0.0	0.0	19.2	0.0	0.0	0.4	69.8
8:00 TO 9:00	46.8	19.2	24.1	0.0	23.0	15.3	1.9	35.3	44.8	22.6	0.0	23.0	256.1
9:00 TO 10:00	70.5	0.0	46.0	25.7	69.8	22.2	67.8	31.4	103.5	82.4	0.0	23.0	542.4
10:00 TO 11:00	46.0	11.9	57.1	16.9	116.5	48.3	139.5	147.6	52.1	145.7	52.1	44.1	877.8
11:00 TO 12:00	24.5	23.0	69.0	23.0	161.0	65.2	189.7	183.6	94.3	97.8	103.1	46.0	1080.2
12:00 TO 13:00	37.6	31.4	68.2	34.9	104.6	52.9	242.6	202.4	146.4	110.4	69.0	46.0	1146.5
13:00 TO 14:00	69.0	19.5	28.0	55.2	108.9	32.6	260.3	267.2	159.1	194.7	30.3	46.0	1270.7
14:00 TO 15:00	46.4	23.0	13.0	30.7	120.7	61.3	230.4	228.5	125.0	224.3	30.7	15.3	1149.2
15:00 TO 16:00	39.5	22.2	5.0	16.9	103.5	52.9	245.3	220.4	131.5	199.7	33.3	0.0	1070.3
16:00 TO 17:00	46.0	0.0	0.0	62.1	51.0	23.0	157.9	62.1	123.4	130.7	60.9	16.9	734.1
17:00 TO 18:00	118.4	5.7	0.0	24.1	23.0	0.8	93.5	45.6	134.9	178.2	724.5	650.1	1999.1
18:00 TO 19:00	159.5	77.8	97.7	66.7	6.1	0.0	37.9	32.2	83.9	376.0	622.5	454.2	2014.8
19:00 TO 20:00	42.9	36.0	73.6	117.7	0.0	0.0	4.6	6.9	125.7	458.1	284.0	78.6	1228.2
20:00 TO 21:00	4.6	23.0	12.3	60.6	30.7	0.0	144.9	28.7	150.3	195.1	5.4	0.0	655.5
21:00 TO 22:00	46.0	3.8	0.0	7.3	14.9	0.0	119.2	1.9	40.2	95.8	0.0	0.0	329.3
22:00 TO 23:00	46.0	0.0	0.0	0.0	0.0	0.0	47.1	0.0	2.7	62.5	0.0	0.0	158.3
23:00 TO 24:00	18.8	0.0	0.0	0.0	0.0	0.0	90.5	0.0	0.0	12.3	0.0	0.0	121.5
TOTAL	862.5	376.4	497.6	541.6	946.8	374.5	2103.0	1493.8	1557.5	2586.3	2015.9	1443.6	14799.7

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E NAVAL STATION

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	43.3	0.0	0.0	0.0	43.3
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	26.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	26.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	26.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	26.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	26.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	3.5	0.0	29.5
7:00 TO 8:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	26.0	0.0	52.0
8:00 TO 9:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10.0	61.1	0.0	31.2	0.0	102.3
9:00 TO 10:00	0.0	0.0	0.0	0.0	0.0	0.0	25.1	48.1	107.5	0.0	52.0	3.5	236.2
10:00 TO 11:00	0.0	0.0	0.0	0.0	0.0	0.0	37.3	45.1	132.6	14.3	43.3	0.0	272.6
11:00 TO 12:00	0.0	0.0	0.0	0.0	0.0	0.0	51.1	74.5	75.0	17.3	52.0	0.0	270.0
12:00 TO 13:00	0.0	0.0	0.0	0.0	0.0	0.0	27.3	26.4	54.2	0.0	30.3	0.0	138.2
13:00 TO 14:00	0.0	0.0	0.0	0.0	0.0	0.0	2.6	35.5	68.5	0.0	26.0	0.0	132.6
14:00 TO 15:00	0.0	0.0	0.0	0.0	0.0	0.0	59.4	94.5	68.5	0.0	47.7	0.0	270.0
15:00 TO 16:00	0.0	0.0	0.0	0.0	0.0	0.0	69.8	53.7	75.8	0.0	42.0	0.0	241.4
16:00 TO 17:00	0.0	0.0	0.0	0.0	0.0	0.0	51.1	24.7	37.7	0.0	26.0	2.6	142.1
17:00 TO 18:00	0.0	0.0	0.0	0.0	0.0	0.0	7.8	3.5	26.0	0.0	26.0	28.2	91.4
18:00 TO 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	26.0	32.5	84.5
19:00 TO 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	33.4	26.0	85.4
20:00 TO 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	26.0	26.0	78.0
21:00 TO 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	26.0	26.0	78.0
22:00 TO 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	26.0	26.0	78.0
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	0.0	21.2	24.3	71.5
TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	331.5	416.0	1088.1	31.6	564.6	195.0	2626.9

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E NAVAL STATION

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	26.0	31.2	26.0	109.2
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	10.0	52.0	26.0	114.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	0.0	52.0	39.4	117.4
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	0.0	27.7	52.0	105.7
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	0.0	41.2	52.0	119.2
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	0.0	26.0	52.0	104.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	0.0	26.0	52.0	104.0
7:00 TO 8:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	0.0	26.0	55.0	107.0
8:00 TO 9:00	0.0	0.0	0.0	0.0	0.0	75.4	0.0	19.1	0.0	0.0	26.0	75.0	195.4
9:00 TO 10:00	0.0	0.0	0.0	0.0	1.7	118.7	21.2	45.1	10.8	17.3	42.0	59.8	316.8
10:00 TO 11:00	0.0	0.0	0.0	0.0	1.7	85.4	26.0	52.0	22.1	88.0	52.0	52.0	379.2
11:00 TO 12:00	0.0	0.0	0.0	0.0	26.4	52.0	24.3	97.5	19.1	84.9	52.0	32.5	388.7
12:00 TO 13:00	0.0	0.0	0.0	0.0	50.7	38.6	6.1	138.7	0.0	76.3	52.0	26.0	388.3
13:00 TO 14:00	0.0	0.0	0.0	0.0	65.4	26.0	26.0	153.0	4.8	87.5	52.0	13.9	428.6
14:00 TO 15:00	0.0	0.0	0.0	0.0	20.8	28.6	26.0	124.8	52.9	126.1	52.0	27.7	458.9
15:00 TO 16:00	0.0	0.0	0.0	0.0	52.0	7.8	13.9	118.3	76.7	95.3	68.5	12.1	444.6
16:00 TO 17:00	0.0	0.0	0.0	0.0	52.0	32.1	0.4	83.2	52.0	61.1	84.5	10.4	375.7
17:00 TO 18:00	0.0	0.0	0.0	0.0	52.0	52.0	8.2	71.9	43.3	28.2	112.7	26.0	394.3
18:00 TO 19:00	0.0	0.0	0.0	0.0	52.0	52.0	19.5	41.2	26.0	26.0	105.7	26.9	349.3
19:00 TO 20:00	0.0	0.0	0.0	0.0	5.2	64.6	0.0	52.0	26.0	26.0	52.0	26.0	251.8
20:00 TO 21:00	0.0	0.0	0.0	0.0	0.0	57.2	0.0	49.8	26.0	26.0	52.0	26.0	237.0
21:00 TO 22:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	17.3	26.0	52.0	44.2	165.5
22:00 TO 23:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	26.0	52.0	52.9	156.9
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	26.0	0.0	0.0	0.0	26.0	54.2	54.2	160.3
TOTAL	0.0	0.0	0.0	0.0	380.0	976.3	171.6	1046.5	377.0	856.7	1243.7	920.0	5971.8

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E NAVAL STATION

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	129.6	78.0	52.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	260.0	416.0	935.6
1:00 TO 2:00	104.0	78.0	52.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	260.0	416.0	910.0
2:00 TO 3:00	104.0	78.0	60.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	260.0	416.0	918.7
3:00 TO 4:00	104.0	75.4	60.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	263.5	403.0	906.5
4:00 TO 5:00	104.0	77.6	78.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	286.0	390.0	935.6
5:00 TO 6:00	79.7	52.0	62.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	286.0	390.0	869.7
6:00 TO 7:00	82.3	52.0	52.0	0.0	0.0	0.0	5.2	0.0	0.0	0.0	286.0	389.6	867.1
7:00 TO 8:00	140.4	102.3	59.4	0.0	0.0	0.0	26.0	0.0	0.0	0.0	306.8	364.0	998.8
8:00 TO 9:00	163.4	130.4	105.3	0.0	0.0	23.4	26.0	0.0	0.0	0.4	304.6	382.6	1136.2
9:00 TO 10:00	201.1	150.8	134.3	0.0	0.0	59.8	29.5	0.0	19.5	21.7	292.9	408.6	1318.2
10:00 TO 11:00	203.2	141.7	106.2	0.0	0.0	90.1	75.4	0.0	0.0	26.0	312.0	429.0	1383.6
11:00 TO 12:00	204.5	156.0	118.7	0.0	0.0	117.0	78.0	0.0	0.0	26.0	318.1	442.0	1450.3
12:00 TO 13:00	234.0	158.2	99.2	0.0	0.0	78.0	78.0	0.0	0.0	26.0	323.7	445.0	1442.1
13:00 TO 14:00	221.4	162.5	110.1	0.0	0.0	105.7	85.8	0.0	1.7	26.0	338.0	442.0	1493.3
14:00 TO 15:00	208.0	139.1	80.6	0.0	0.0	108.3	104.0	0.0	0.0	37.3	330.2	442.0	1449.5
15:00 TO 16:00	188.5	126.1	76.3	0.0	0.0	109.6	104.0	0.0	3.5	48.5	312.0	442.0	1410.5
16:00 TO 17:00	191.5	134.3	78.0	0.0	0.0	98.4	95.3	0.0	13.9	33.4	289.9	445.9	1380.6
17:00 TO 18:00	253.5	188.9	85.4	0.0	0.0	81.5	78.0	0.0	7.4	3.0	286.0	520.4	1504.1
18:00 TO 19:00	270.0	212.3	52.0	0.0	0.0	52.9	78.0	0.0	10.8	24.7	286.0	526.1	1512.8
19:00 TO 20:00	238.3	155.6	28.6	0.0	0.0	36.4	52.0	0.0	0.0	26.0	268.2	507.4	1312.6
20:00 TO 21:00	114.4	106.2	49.8	0.0	0.0	25.6	64.1	0.0	0.0	26.0	260.0	484.0	1130.1
21:00 TO 22:00	78.0	120.0	52.0	0.0	0.0	0.0	34.7	0.0	0.0	26.0	260.0	445.9	1016.6
22:00 TO 23:00	78.0	104.0	52.0	0.0	0.0	0.0	0.0	0.0	0.0	26.0	260.9	442.0	962.9
23:00 TO 24:00	78.0	81.0	52.0	0.0	0.0	0.0	0.0	0.0	0.0	24.7	260.0	442.0	937.7
TOTAL	3773.9	2860.4	1757.2	0.0	0.0	986.7	1014.0	0.0	56.8	401.7	6910.8	10431.6	28193.1

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E NORTH ISLAND STATION

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	18.8	6.9	10.3	0.0	36.0
7:00 TO 8:00	0.0	0.0	0.0	21.5	0.0	0.0	0.0	17.6	33.3	23.0	92.8	0.0	188.2
8:00 TO 9:00	0.0	19.2	15.3	36.4	0.0	0.0	0.0	23.0	47.9	23.0	115.0	8.4	288.3
9:00 TO 10:00	7.7	23.0	0.0	46.0	5.0	5.8	5.8	14.9	57.1	23.0	131.9	10.0	330.0
10:00 TO 11:00	36.4	40.3	1.9	46.0	28.8	15.3	20.7	48.3	46.0	23.0	146.4	10.7	463.8
11:00 TO 12:00	38.3	46.0	44.5	46.0	54.4	0.0	22.6	59.4	46.0	23.0	126.9	23.4	530.5
12:00 TO 13:00	21.5	9.6	73.2	39.9	46.0	0.0	56.7	26.1	74.0	23.0	115.0	10.0	494.9
13:00 TO 14:00	52.9	17.3	58.6	31.0	37.6	0.0	41.8	23.0	94.7	23.0	115.0	14.2	509.1
14:00 TO 15:00	48.7	10.7	56.0	23.0	23.0	0.0	23.0	23.0	120.4	17.6	88.2	8.0	441.6
15:00 TO 16:00	12.6	0.0	56.0	23.0	13.8	0.0	23.0	23.0	91.6	0.0	92.0	4.6	339.6
16:00 TO 17:00	11.9	0.0	23.0	23.0	0.0	0.0	23.0	23.0	2.7	0.0	95.4	23.0	225.0
17:00 TO 18:00	0.0	0.0	23.0	43.3	0.0	0.0	23.0	23.0	15.3	0.0	115.0	3.4	246.1
18:00 TO 19:00	0.0	0.0	23.0	69.0	0.0	0.0	23.0	23.0	38.3	0.0	115.0	0.0	291.3
19:00 TO 20:00	0.0	0.0	23.0	47.5	0.0	0.0	23.0	23.0	0.0	0.0	100.4	0.0	217.0
20:00 TO 21:00	0.0	0.0	23.0	46.0	0.0	0.0	23.0	23.0	0.0	0.0	92.0	0.0	207.0
21:00 TO 22:00	0.0	0.0	23.0	37.9	0.0	0.0	23.0	23.0	0.0	0.0	73.2	0.0	180.2
22:00 TO 23:00	0.0	0.0	23.0	15.7	0.0	0.0	15.3	10.3	0.0	0.0	49.1	0.0	113.5
23:00 TO 24:00	0.0	0.0	18.4	0.0	0.0	0.0	12.3	0.0	0.0	0.0	45.2	0.0	75.9
TOTAL	230.0	166.0	484.9	595.3	208.5	21.1	359.2	406.7	686.2	185.5	1718.9	115.8	5178.1

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E NORTH ISLAND STATION

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	6.9	0.0	0.0	0.0	0.0	0.0	4.6	0.0	0.0	0.0	11.5
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	13.8	0.0	0.0	0.0	13.8
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	24.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24.5
4:00 TO 5:00	33.0	0.0	0.0	17.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	50.6
5:00 TO 6:00	45.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	45.2
6:00 TO 7:00	13.8	0.0	33.7	0.0	14.9	0.0	0.0	8.4	0.0	0.0	0.0	0.0	70.9
7:00 TO 8:00	65.9	10.7	71.7	14.2	23.0	0.0	5.8	9.6	0.0	0.0	0.0	0.0	200.9
8:00 TO 9:00	88.2	41.8	123.4	46.0	23.0	0.0	23.0	12.6	0.0	15.7	0.0	5.4	379.1
9:00 TO 10:00	82.4	74.4	146.8	74.7	14.2	17.3	23.0	21.8	9.2	10.3	0.0	38.3	512.5
10:00 TO 11:00	97.8	115.0	151.8	69.0	3.1	37.2	23.0	1.5	3.1	26.4	0.0	46.0	573.8
11:00 TO 12:00	93.5	91.2	139.9	62.9	23.0	28.8	23.0	58.3	18.8	23.0	0.0	55.2	617.5
12:00 TO 13:00	69.8	69.0	115.0	46.0	23.0	51.4	23.0	21.1	18.0	1.1	7.7	57.5	502.5
13:00 TO 14:00	49.4	73.6	115.0	46.0	9.2	23.0	23.0	4.2	28.4	0.0	19.2	49.8	440.8
14:00 TO 15:00	53.7	69.8	80.5	46.0	23.0	45.2	23.0	14.2	57.9	0.0	0.0	46.0	459.2
15:00 TO 16:00	24.1	46.0	42.2	36.4	51.7	46.0	14.9	1.9	47.9	0.0	14.9	46.0	372.2
16:00 TO 17:00	23.0	31.4	46.0	23.0	59.4	33.7	8.0	1.9	34.9	0.0	77.4	46.0	384.9
17:00 TO 18:00	60.6	88.5	60.2	23.8	60.9	4.2	0.0	0.0	0.0	0.0	204.7	127.3	630.2
18:00 TO 19:00	91.2	166.0	136.8	46.0	69.0	0.0	0.0	0.0	0.0	32.6	207.8	149.9	899.3
19:00 TO 20:00	24.5	89.3	138.0	67.5	69.0	0.0	0.0	0.0	0.0	34.9	83.2	66.7	573.1
20:00 TO 21:00	23.0	23.0	108.5	26.8	74.4	0.0	0.0	0.0	0.0	5.8	47.9	17.2	326.6
21:00 TO 22:00	23.0	19.2	29.1	14.6	39.5	0.0	0.0	0.0	0.0	0.0	15.7	0.0	141.1
22:00 TO 23:00	23.0	0.0	23.0	0.0	14.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	60.6
23:00 TO 24:00	21.8	0.0	23.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	44.8
TOTAL	1007.0	1008.9	1591.6	685.0	594.9	286.7	189.7	155.6	236.5	149.9	678.5	751.3	7335.8

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E NORTH ISLAND STATION

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7:00 TO 8:00	0.0	0.0	0.0	0.0	0.8	0.0	0.0	0.0	0.0	0.0	32.2	0.0	33.0
8:00 TO 9:00	17.2	5.0	0.0	7.7	33.7	17.3	0.0	0.0	0.0	0.0	80.1	0.0	161.0
9:00 TO 10:00	117.3	46.0	0.0	37.2	23.0	23.0	3.1	20.7	10.7	0.0	97.4	0.0	378.3
10:00 TO 11:00	92.4	49.1	10.7	13.4	61.3	34.5	23.0	58.3	17.3	12.6	132.6	0.0	505.2
11:00 TO 12:00	115.0	45.6	23.0	16.5	69.0	75.1	20.3	69.0	34.5	26.4	152.2	0.0	646.7
12:00 TO 13:00	98.1	7.3	4.6	0.0	69.0	56.3	35.3	69.0	0.0	24.1	160.2	0.0	524.0
13:00 TO 14:00	69.0	16.1	5.8	16.1	85.9	46.0	91.2	79.0	1.1	53.3	92.0	0.0	555.4
14:00 TO 15:00	77.0	0.0	23.0	38.3	64.4	53.7	100.4	69.0	10.7	46.0	59.4	18.4	560.4
15:00 TO 16:00	23.0	0.0	24.9	10.7	81.6	46.0	151.0	88.9	0.0	46.0	14.6	21.8	508.7
16:00 TO 17:00	0.0	0.0	0.0	0.0	82.0	23.8	97.0	77.8	0.0	15.3	9.2	50.6	355.7
17:00 TO 18:00	73.2	0.0	0.0	0.0	67.5	13.8	54.8	46.0	0.0	0.0	249.9	177.1	682.3
18:00 TO 19:00	90.5	0.0	0.0	19.9	43.3	0.0	46.0	29.1	0.0	11.9	236.9	88.5	566.2
19:00 TO 20:00	51.4	0.0	0.0	45.2	23.0	0.0	25.7	0.0	0.0	19.9	121.1	23.0	309.3
20:00 TO 21:00	11.9	0.0	0.0	0.0	0.0	0.0	42.9	0.0	0.0	0.0	37.2	3.1	95.1
21:00 TO 22:00	46.0	0.0	0.0	0.0	0.0	0.0	40.3	0.0	0.0	0.0	0.0	0.0	86.3
22:00 TO 23:00	38.3	0.0	0.0	0.0	0.0	0.0	23.0	0.0	0.0	0.0	0.0	0.0	61.3
23:00 TO 24:00	0.4	0.0	0.0	0.0	0.0	0.0	23.0	0.0	0.0	0.0	0.0	10.3	33.7
TOTAL	920.8	169.0	92.0	205.1	704.6	389.5	777.0	606.8	74.4	255.7	1475.1	392.9	6062.8

[illegible] PEAKING UNIT DAILY OPERATING PATTERN

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E NTC STATION

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	422.4	448.0	464.0	240.0	480.0	480.0	496.0	464.0	464.0	365.1	480.0	496.0	5299.5
1:00 TO 2:00	416.5	448.0	464.0	240.0	480.0	480.0	496.0	468.0	476.0	373.3	480.0	496.0	5317.9
2:00 TO 3:00	432.0	448.0	464.0	233.3	480.0	480.0	496.0	480.0	480.0	368.0	480.0	496.0	5337.3
3:00 TO 4:00	432.0	448.0	471.5	224.0	480.0	479.7	496.0	480.0	480.0	368.0	480.0	496.0	5335.2
4:00 TO 5:00	426.7	443.2	480.0	224.0	480.0	464.0	496.0	480.0	480.0	368.0	480.0	496.0	5317.9
5:00 TO 6:00	416.0	448.0	480.0	224.0	480.0	464.0	496.0	480.0	480.0	368.0	480.0	496.0	5312.0
6:00 TO 7:00	416.0	448.0	480.0	224.0	480.0	464.0	496.0	477.9	480.0	368.0	480.0	496.0	5309.9
7:00 TO 8:00	416.0	440.0	480.0	224.0	480.0	464.0	496.0	464.0	480.0	360.0	475.2	482.7	5261.9
8:00 TO 9:00	406.4	427.2	480.0	208.0	480.0	464.0	496.0	464.0	480.0	352.0	464.0	475.5	5197.1
9:00 TO 10:00	416.0	418.7	480.0	208.0	480.0	464.0	496.0	464.0	480.0	338.9	464.0	479.2	5188.8
10:00 TO 11:00	416.0	416.0	480.0	208.0	480.0	464.0	496.0	464.0	480.0	340.0	464.0	480.0	5188.0
11:00 TO 12:00	401.3	430.1	480.0	242.7	480.0	464.0	496.0	461.6	464.0	358.1	464.0	483.7	5225.6
12:00 TO 13:00	397.9	432.0	480.0	425.3	480.0	474.7	496.0	464.0	451.2	352.0	464.0	496.0	5413.1
13:00 TO 14:00	397.9	432.0	480.0	432.0	480.0	480.0	496.0	464.0	448.0	369.3	457.9	496.0	5433.1
14:00 TO 15:00	400.0	417.3	480.0	432.0	480.0	480.0	496.0	467.7	460.0	384.0	473.3	496.0	5466.4
15:00 TO 16:00	412.5	421.3	480.0	432.0	471.2	480.0	496.0	480.0	463.2	384.0	464.0	496.0	5480.3
16:00 TO 17:00	416.0	436.5	480.0	432.0	476.5	480.0	496.0	480.0	476.0	384.0	477.9	496.0	5530.9
17:00 TO 18:00	429.3	448.0	480.0	432.0	480.0	480.0	496.0	480.0	464.3	384.0	480.0	496.0	5549.6
18:00 TO 19:00	432.0	448.0	480.0	432.0	480.0	480.0	496.0	480.0	478.9	384.0	480.0	496.0	5566.9
19:00 TO 20:00	432.0	448.0	480.0	432.0	480.0	480.0	496.0	480.0	480.0	384.0	480.0	496.0	5568.0
20:00 TO 21:00	432.0	448.0	470.7	432.0	480.0	480.0	496.0	468.3	480.0	378.9	480.0	496.0	5541.9
21:00 TO 22:00	432.0	448.0	464.0	432.0	480.0	480.0	496.0	464.0	480.0	384.0	480.0	496.0	5536.0
22:00 TO 23:00	432.0	448.0	464.0	432.0	480.0	480.0	496.0	464.0	480.0	368.8	480.0	496.0	5520.8
23:00 TO 24:00	432.0	448.0	464.0	432.0	480.0	480.0	496.0	464.0	469.3	368.0	480.0	496.0	5509.3
TOTAL	10062.9	10538.4	11406.1	7877.3	11507.7	11386.4	11904.0	11303.5	11354.9	8852.5	11388.3	11825.1	129407.0

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E NTC STATION

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	480.0	448.0	240.0	144.0	400.0	464.0	416.0	275.2	0.0	336.0	258.7	496.0	3957.9
1:00 TO 2:00	480.0	448.0	252.0	144.0	400.0	464.0	416.0	272.0	0.0	343.5	240.0	496.0	3955.5
2:00 TO 3:00	480.0	448.0	256.0	144.0	400.0	464.0	416.0	272.0	0.0	352.0	236.0	496.0	3964.0
3:00 TO 4:00	480.0	448.0	256.0	144.0	400.0	464.0	416.0	272.0	0.0	352.0	208.0	496.0	3936.0
4:00 TO 5:00	480.0	448.0	256.0	144.0	400.0	464.0	401.1	272.0	0.0	352.0	208.0	496.0	3921.1
5:00 TO 6:00	480.0	448.0	256.0	144.0	400.0	464.0	409.9	278.9	0.0	352.0	198.9	496.0	3927.7
6:00 TO 7:00	480.0	448.0	269.3	144.0	400.0	464.0	416.0	288.0	0.0	352.0	196.5	496.0	3953.9
7:00 TO 8:00	472.0	448.0	272.0	144.0	400.0	462.7	416.0	270.1	0.0	352.0	208.0	482.7	3927.5
8:00 TO 9:00	464.0	432.0	272.0	146.7	400.0	448.0	416.0	256.0	0.0	352.0	236.0	464.0	3885.7
9:00 TO 10:00	465.1	432.0	278.7	160.0	400.0	448.0	416.0	263.2	0.0	352.0	262.1	449.3	3926.4
10:00 TO 11:00	476.3	425.1	272.0	160.0	400.0	450.7	403.2	273.3	0.0	352.0	296.8	448.0	3957.3
11:00 TO 12:00	463.5	416.0	274.7	160.0	400.0	464.0	400.0	253.3	0.0	352.0	257.9	448.0	3889.3
12:00 TO 13:00	460.8	429.6	277.3	170.4	400.0	462.7	400.0	269.3	0.0	355.5	260.3	448.0	3933.9
13:00 TO 14:00	464.0	448.0	272.0	165.9	400.0	458.9	400.0	288.0	0.0	365.9	258.9	448.0	3969.6
14:00 TO 15:00	465.3	448.0	272.0	176.0	416.0	464.0	400.0	288.0	0.0	368.0	254.9	448.0	4000.3
15:00 TO 16:00	479.5	432.0	265.6	176.0	416.0	464.0	393.1	273.1	0.0	368.0	296.5	470.7	4034.4
16:00 TO 17:00	475.7	442.7	276.3	168.0	416.0	464.0	398.9	286.7	0.0	368.0	306.9	495.2	4098.4
17:00 TO 18:00	480.0	448.0	288.0	160.0	410.4	464.0	400.0	288.0	0.0	361.9	308.0	496.0	4104.3
18:00 TO 19:00	480.0	448.0	288.0	174.1	406.7	464.0	400.0	288.0	0.0	352.0	320.0	496.0	4116.8
19:00 TO 20:00	478.9	448.0	288.0	176.0	416.0	464.0	400.0	272.0	0.0	363.7	312.0	488.0	4106.7
20:00 TO 21:00	464.0	448.0	285.9	176.0	416.0	464.0	400.0	272.0	0.0	368.0	304.0	480.0	4077.9
21:00 TO 22:00	478.7	446.7	270.9	160.5	400.0	464.0	400.0	272.0	0.0	368.0	314.4	480.0	4055.2
22:00 TO 23:00	480.0	432.0	256.0	144.0	400.0	464.0	400.0	272.0	0.0	368.0	304.0	480.0	4000.0
23:00 TO 24:00	480.0	432.0	256.0	144.0	400.0	464.0	400.0	272.0	0.0	351.7	304.0	482.1	3985.9
TOTAL	11387.7	10592.0	6450.7	3769.6	9697.1	11082.9	9734.1	6587.2	0.0	8558.1	6350.9	11476.0	95686.1

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E NTC STATION

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	496.0	160.0	400.0	160.0	32.0	258.1	0.0	128.0	192.0	464.0	224.0	480.0	2994.1
1:00 TO 2:00	496.0	160.0	400.0	160.0	32.0	256.0	0.0	128.0	192.0	464.0	224.0	480.0	2992.0
2:00 TO 3:00	496.0	160.0	400.0	144.0	32.0	256.0	0.0	128.0	192.0	464.0	224.0	480.0	2976.0
3:00 TO 4:00	496.0	160.0	400.0	135.5	32.0	256.0	0.0	128.0	192.0	464.0	208.8	480.0	2952.3
4:00 TO 5:00	496.0	160.0	385.1	128.0	32.0	256.0	0.0	128.0	192.0	462.7	208.0	480.0	2927.7
5:00 TO 6:00	496.0	174.4	367.2	121.3	32.0	254.9	0.0	120.0	192.0	419.2	208.0	480.0	2865.1
6:00 TO 7:00	496.0	168.0	336.0	112.0	16.0	270.1	0.0	112.0	192.0	416.0	208.0	480.0	2806.1
7:00 TO 8:00	490.7	160.0	336.0	112.0	16.0	272.0	0.0	112.0	192.0	416.0	208.0	471.7	2786.4
8:00 TO 9:00	480.0	168.8	336.0	112.0	30.7	272.0	0.0	126.9	189.3	416.0	208.0	458.9	2798.7
9:00 TO 10:00	480.0	176.0	336.0	107.2	32.0	264.0	0.0	123.7	176.0	416.0	217.1	447.5	2775.5
10:00 TO 11:00	465.3	177.1	337.6	80.0	32.0	256.0	0.0	131.5	176.0	416.0	220.3	432.0	2723.7
11:00 TO 12:00	464.0	176.8	338.7	80.0	18.1	256.0	0.0	152.0	176.0	421.6	227.7	432.0	2742.9
12:00 TO 13:00	464.0	192.0	334.7	95.5	16.0	256.0	0.0	187.5	176.0	400.0	224.8	445.3	2791.7
13:00 TO 14:00	474.7	192.0	317.1	96.0	16.0	256.0	0.0	305.3	176.0	400.0	208.0	432.0	2873.1
14:00 TO 15:00	496.0	186.1	304.0	104.8	25.1	268.0	0.0	315.7	176.0	400.0	208.0	444.3	2928.0
15:00 TO 16:00	496.0	168.0	361.9	109.1	16.0	267.5	0.0	322.1	192.0	400.0	243.2	472.3	3048.0
16:00 TO 17:00	496.0	176.0	400.0	124.0	16.0	275.7	0.0	320.0	199.5	417.9	253.3	496.0	3174.4
17:00 TO 18:00	496.0	176.0	400.0	128.0	16.0	272.0	0.0	320.0	208.0	463.5	232.0	496.0	3207.5
18:00 TO 19:00	496.0	179.2	400.0	159.5	19.5	272.0	0.0	320.0	203.7	480.0	224.0	491.5	3245.3
19:00 TO 20:00	496.0	192.0	400.0	146.1	16.0	272.0	0.0	320.0	200.5	480.0	224.0	480.0	3226.7
20:00 TO 21:00	496.0	186.4	400.0	157.3	16.0	272.0	0.0	320.0	208.0	480.0	224.0	480.0	3239.7
21:00 TO 22:00	496.0	176.0	400.0	160.0	16.0	272.0	0.0	320.0	193.9	466.4	230.4	481.3	3212.0
22:00 TO 23:00	496.0	164.5	400.0	160.0	16.0	272.0	0.0	320.0	192.0	464.0	240.0	465.9	3190.4
23:00 TO 24:00	496.0	160.0	400.0	160.0	16.0	272.0	0.0	320.0	192.0	464.0	232.0	464.0	3176.0
TOTAL	11750.7	4149.3	8890.1	3052.3	541.3	6354.4	0.0	5208.8	4570.9	10555.2	5329.6	11250.7	71653.3

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E SOUTH BAY STATION

YEAR: 1975

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7:00 TO 8:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.7	0.0	0.7
8:00 TO 9:00	19.8	7.7	5.5	11.0	12.8	8.8	0.0	0.0	0.0	10.6	6.6	3.7	86.5
9:00 TO 10:00	26.4	31.2	27.1	26.4	13.9	2.6	15.8	3.7	25.3	22.7	11.7	13.9	220.7
10:00 TO 11:00	2.6	3.7	25.7	15.8	22.0	7.7	10.6	38.9	12.1	0.4	22.0	22.0	183.3
11:00 TO 12:00	7.0	0.0	8.8	0.0	19.4	0.0	12.1	0.0	0.0	8.4	0.0	0.0	55.7
12:00 TO 13:00	2.6	0.0	0.0	2.9	4.8	8.8	0.0	12.8	0.0	0.0	0.0	8.4	40.3
13:00 TO 14:00	0.0	0.0	1.8	0.0	0.0	4.4	0.0	1.8	0.0	0.0	2.2	0.0	10.3
14:00 TO 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.9	0.0	0.0	0.0	0.0	2.9
15:00 TO 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
16:00 TO 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
17:00 TO 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
18:00 TO 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.7	3.7
19:00 TO 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20:00 TO 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
21:00 TO 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22:00 TO 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	58.3	42.5	68.9	56.1	73.0	32.3	38.5	60.1	37.4	42.2	43.3	51.7	604.3

GAS TURBINE PEAKING UNIT DAILY OPERATING PATTERN

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E SOUTH BAY STATION

YEAR: 1976

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.7	0.0	0.0	0.0	3.7
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7:00 TO 8:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8:00 TO 9:00	14.7	4.0	0.0	27.5	24.6	0.0	18.0	0.0	11.4	27.9	0.0	0.0	128.0
9:00 TO 10:00	34.1	33.4	13.2	19.4	0.0	21.6	12.5	0.0	1.8	39.6	0.0	6.2	181.9
10:00 TO 11:00	5.5	0.0	12.5	19.4	22.0	15.8	10.6	9.2	0.0	49.5	0.0	12.8	157.3
11:00 TO 12:00	0.0	10.6	6.6	12.8	0.0	13.9	19.4	31.9	0.0	53.5	1.8	17.6	168.3
12:00 TO 13:00	4.4	0.0	0.0	5.1	1.8	18.3	0.0	12.1	9.5	68.2	12.5	10.3	142.3
13:00 TO 14:00	5.5	0.0	5.5	0.0	0.0	34.8	0.0	0.0	0.4	67.8	0.0	25.3	139.3
14:00 TO 15:00	0.0	0.0	34.5	13.2	3.7	7.7	0.0	0.0	9.9	66.0	0.0	0.0	134.9
15:00 TO 16:00	0.0	0.0	22.4	0.0	0.0	0.0	0.0	0.0	5.5	32.3	0.0	0.0	60.1
16:00 TO 17:00	0.0	0.0	5.9	0.0	0.0	0.0	0.0	0.0	0.0	22.0	0.0	0.0	27.9
17:00 TO 18:00	0.0	7.7	0.0	0.0	1.8	0.0	0.0	0.0	0.0	22.4	0.0	13.2	45.1
18:00 TO 19:00	0.0	7.3	0.7	8.8	0.0	0.0	0.0	0.0	0.0	9.2	13.9	18.3	58.3
19:00 TO 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.8	0.0	19.1	0.0	20.9
20:00 TO 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	10.6	0.0	18.0	0.0	28.6
21:00 TO 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22:00 TO 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	64.2	63.1	101.2	106.3	53.9	112.2	60.5	53.2	54.6	458.3	65.3	103.8	1296.5

UTILITY: SAN DIEGO GAS AND ELECTRIC COMPANY (SDG&E)

STATION: SDG&E SOUTH BAY STATION

YEAR: 1977

MEGAWATT-HOURS GENERATED BY GAS TURBINE PEAKING UNITS

DAILY OPERATING PERIOD	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
0:00 TO 1:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1:00 TO 2:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2:00 TO 3:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3:00 TO 4:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4:00 TO 5:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5:00 TO 6:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6:00 TO 7:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7:00 TO 8:00	5.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8:00 TO 9:00	10.6	18.3	12.8	0.0	12.1	0.0	0.0	0.0	0.0	0.0	0.0	2.9	8.1
9:00 TO 10:00	0.0	5.1	0.0	0.0	17.6	0.0	11.0	0.0	16.5	12.5	0.0	16.9	75.2
10:00 TO 11:00	0.0	19.1	0.0	0.0	9.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	62.7
11:00 TO 12:00	0.0	0.0	0.0	5.5	22.0	0.0	0.0	0.0	0.0	0.0	11.0	0.0	28.2
12:00 TO 13:00	0.0	0.0	0.0	16.5	22.0	0.0	0.0	2.9	0.0	11.0	20.2	0.0	38.5
13:00 TO 14:00	0.0	0.0	0.0	0.0	22.0	0.0	0.0	0.7	0.0	0.0	23.8	0.0	72.6
14:00 TO 15:00	0.0	0.0	0.0	0.0	17.2	0.0	0.0	0.0	0.0	0.0	36.7	0.0	46.6
15:00 TO 16:00	0.0	15.8	0.0	0.0	0.0	0.0	18.3	0.0	0.0	1.8	0.0	0.0	53.9
16:00 TO 17:00	0.0	5.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	9.9	0.0	0.0	35.9
17:00 TO 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.8	0.0	0.0	15.0
18:00 TO 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.8
19:00 TO 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
20:00 TO 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
21:00 TO 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22:00 TO 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
23:00 TO 24:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL	15.8	63.4	12.8	22.0	122.1	0.0	29.3	3.7	16.5	41.4	91.7	19.8	438.5