

Executive Order G-70-187

**Exhibit 1
Healy Model 400 ORVR Nozzle System
Equipment List**

| <u>Component</u> | <u>Manufacturer/Model</u> | <u>State Fire Marshal Identification Number</u> |
|---|---|---|
| Nozzle | Model 400 ORVR (w/vapor valve) (See Exhibit 2, Figure 1) | 005:027:023 |
| Vapor Pumps (Collection Unit) | 9000 Mini-Jet Pump (non-electric gasoline-driven pump) 9000-01 without siphon 9000-02 with siphon (See Exhibit 2, Figures 2A - 2D) | 005:027:009 |
| | Thomas Industries/Franklin Electric VP-500 Vane Pump (1/2 hp) (See Exhibit 2, Figure 3) | 005:027:017 |
| | 100 Jet Pump (2 each per nozzle) (non-electric gasoline driven pump) (See Exhibit 2, Figures 4A and 4B) | 005:024:004 |
| Vapor Check Valve | Healy Model 9466 | 005:027:024 |
| System Monitor Pressure Switch Vent Sensor P/V Valve | System Monitor Model 6280 Pressure Switch Model 9800-1 Vent Sensor Model 6275 Healy P/V Valve HPV 1.5 | 005:027:022 |
| Inverted Coaxial Hoses | Healy Model 75B (3/4" I. D.) | 005:027:003 |
| | Healy Model 88B (7/8" I. D.) | 005:027:004 005:027:005 |
| | OR Any inverted coaxial hose CARB-certified for use with the Healy Model 400 ORVR system. | |
| Hose Adapters | Healy Model series CX6- followed by suffix letter(s) "G", "D", "U", "VV1", "VV2", "VV3", "TCSVV", "DWVV", "VV1A", "VV2A", "VV3A", "TCSVVA", "DWVVA" | 005:027:019 |
| | Note: The "A" indicates that no valve is provided in the fitting because the vapor valve is integrated into the nozzle. | |
| | "G" Gilbarco Dispensers "D" Dresser/Wayne Dispensers "U" Universal Dispensers "VV1" Dispensers-Lowboy (with vapor valve) "VV2" Vapor Ready Balance Type "VV3" Universal Dispensers "TCSVV" Tokheim Dispensers | |

| | | |
|-------------------------------|--|-------------|
| Breakaway Couplings | "DWVV" Dresser/Wayne Dispensers | |
| | Healy Model 8701VV | 005:027:016 |
| | Healy Model 8701 | 005:027:016 |
| | w/ 715V Upgrade Kit | |
| Pressure/Vacuum Valves | Pressure/Vacuum relief valves shall be certified and have the following pressure and vacuum settings, in inches water column (wc): | |
| | <u>Pressure</u> : three plus or minus one-half inches (3.0" \pm 0.5") | |
| | <u>Vacuum</u> : eight plus or minus two inches (8 \pm 2") | |
| Certified Valves | OPW 523LP, 523LPS | 005:008:051 |
| | OPW 523V | 005:008:058 |
| | Hazlett H-PVB-1 Gold label | 005:017:004 |
| | Husky 4620 P/V | 005:021:015 |
| | Morrison Brothers 749CRB0600 AV | 005:041:001 |
| | EBW Models 802-309, 802-308 | 005:034:006 |
| | OR Any CARB-certified P/V valve which meets the required pressure/vacuum specifications. | |
| Flow Control Units | Healy Model 1301 (for 1 1/4" straight fitting) or | 005:027:020 |
| For Fueling Rate | Healy Model 1302 (for M34 fittings) | |