



Winston H. Hickox  
Agency Secretary

# Air Resources Board

Alan C. Lloyd, Ph.D.  
Chairman

2020 L Street • P.O. Box 2815 • Sacramento, California 95812 • www.arb.ca.gov



Gray Davis  
Governor


May 17, 2000

Mr. Toby Argandona  
CNI Manufacturing  
15627 Arrow Highway  
Irwindale, CA 91706

Dear Mr. Argandona:

CARB Approval of CNI Manufacturing Phase I Locking Clamp, Part # 434 # 00-05

CNI Manufacturing requested CARB approval of their Phase I Locking Clamp on July 27, 1999. The locking clamp consists of a two piece hinged unit that clamps around either the 4" fill or vapor riser. An ear on the clamp fits into a slot in the base of either the fill or vapor adapter and prevents either from rotating. CNI shall supply with the locking clamp, either the Phase I fill adapter or the poppeted vapor adapter. Loctite™ thread sealant or an equivalent shall be included with the kit. The thread sealant is to be used on the connection between the threaded riser and the spill containment bucket. The use of a thread sealant is mandatory for proper installation and insures that torque transferred through the riser does not loosen or over-tighten it to the spill bucket.



PART#	DESCRIPTION
613BC	4 X 4 TOP SEAL ADAPTER AND CLAMP
611DB4AC	3 X 4 DRY BREAK ADAPTER AND CLAMP
434	4" ADAPTER - RISER CLAMPING DEVICE

California Environmental Protection Agency

May 17, 2000

Page 2

As required by the Certification Procedures for Gasoline Vapor Recovery Systems at Service Stations, the approvals of the Department of Food and Agriculture, Division of Measurement Standards, the Department of Occupational Safety and Health, and the Department of Forestry and Fire Protection, Office of the State Fire Marshal are a precondition to certification by the Air Resources Board. The appropriate letters of approval have been received from these agencies and are listed as follows:

Department of Food and Agriculture,  
Division of Measurement Standards  
March 12, 1998

Department of Occupational Safety and Health  
November 8, 1999

Department of Forestry and Fire Protection  
Office of the State Fire Marshal  
December 8, 1999

I find that the use of the CNI Phase I Adapter Locking Clamp when used in conjunction with either a CNI supplied Phase I fill adapter or a poppetted Phase I vapor adapter when installed in accordance with the manufacture's instructions, will not adversely affect the performance of vapor recovery systems on which they are installed. Therefore, the CNI Phase I Adapter Locking Clamp assemblies, Part #'s 613BC, 611DB4AC and 434 are certified for use with Phase I vapor recovery systems.

Sincerely,

James J. Morgester, Chief  
Compliance Division

cc:  
Rosa Salcedo, Chair  
CAPCOA Vapor Recovery Committee  
APCD, County of San Diego  
9150 Chesapeake Dr.  
San Diego, CA 92123-1096