



Winston H. Hickox
Agency Secretary

Air Resources Board

Alan C. Lloyd, Ph.D.
Chairman

1001 I Street • P.O. Box 2815 • Sacramento, California 95812 • www.arb.ca.gov



Gray Davis
Governor

July 24, 2002

#02-10

Thomas J. Smith
Chief Engineer
Hirt Combustion Engineers, Inc.
Post Office Box 6816
Pico Rivera, California 90661

Dear Mr. Smith:

You requested approval of the Husky Model 4885 Pressure/Vacuum (P/V) valve with the Hirt VCS 400-7 Phase II vapor recovery system. Both of these components are currently certified, but were not approved to be used together. The California Air Resources Board (CARB) conducted field compatibility tests to verify the performance of the Husky P/V valve with the Hirt system. The tests demonstrated that the Hirt VCS 400-7 vapor recovery system operates as certified with the Husky P/V valve installed in accordance with the manufacturer's recommended installation instructions.

The 2-inch threaded Husky Model 4885 P/V valve is approved for use with the Hirt VCS 400-7 Phase II vapor recovery systems on both underground and above ground storage tank systems, as certified in Executive Orders G-70-177-AA and G-70-181, respectively.

If you have questions, please call George Lew or Laura McKinney at (916) 327-0900, or email glew@arb.ca.gov or lmckinne@arb.ca.gov.

Sincerely,

fw William V. Loscutt, Chief
Monitoring and Laboratory Division

cc: Mr. Ben Shaw
South Coast AQMD

The energy challenge facing California is real. Every Californian needs to take immediate action to reduce energy consumption. For a list of simple ways you can reduce demand and cut your energy costs, see our Website: <http://www.arb.ca.gov>.

California Environmental Protection Agency