



Terry Tamminen
Agency Secretary

Air Resources Board

Alan C. Lloyd, Ph.D.
Chairman
1001 I Street • P.O. Box 2815
Sacramento, California 95812 • www.arb.ca.gov



Arnold Schwarzenegger
Governor

September 16, 2004

#04-03

Mr. David Imler, Design Engineer
Catlow
2750 U.S. Route 40
Tipp City, Ohio 45371

Dear Mr. Imler:

Thank you for your letter requesting California Air Resources Board (ARB) approval of a Catlow Model C200CVS re-connectable breakaway modification, as shown in the enclosed Figure 1. The C200CVS breakaway was approved by ARB through the issuance of approval letter number 96-17. The C200CVS breakaway is for use with Phase II vapor recovery systems that incorporate standard coaxial hoses.

The modifications to the C200CVS breakaway affect the separation and re-connection characteristics without modification of the liquid and vapor paths. Changes by the submersible pump manufacturers have created premature separation issues. Specifically, the modification involves minor machining of the breakaway internals to prevent premature separation.

Based on information provided by Catlow, we find the use of the Catlow Model C200CVS re-connectable breakaway, when installed in accordance with the manufacturer's recommended instructions, will not adversely affect the vapor recovery systems on which they are installed. Therefore, the C200CVS re-connectable breakaway, is approved for use with the currently approved (pre-EVR) vapor recovery systems as per approval letter 96-17.

If you have questions or need further information, please contact Oscar Lopez at (916) 323-1161 or via email at olopez@arb.ca.gov.

Sincerely,

William V. Loscutoff, Chief
Monitoring and Laboratory Division

Enclosure

cc: See next page

The energy challenge facing California is real. Every Californian needs to take immediate action to reduce energy consumption. For a list of simple ways you can reduce demand and cut your energy costs, see our Website: <http://www.arb.ca.gov>.

California Environmental Protection Agency

Mr. David Imler
September 16, 2004
Page 2

cc: Mr. Lou Roberto
South Coast Air Quality Management District

Mr. John Schroeder
San Joaquin Valley Air Pollution Control District



**Figure 1:
C200CVS Catlow Breakaway**