

AIR RESOURCES BOARD

2020 L STREET
P.O. BOX 2815
SACRAMENTO, CA 95812



August 24, 1992

Add to
G-70-52
w/note
RE XA
MEANING

Wayne Tarplay
Vice President, Technical Services
Southwest Pump Division
Retail Products Systems
Schlumberger Technologies
Post Office Box 280
Bonham, TX 75418

#92-16

Dear Mr. Tarplay:


Certification of Model 4110-XA-V Dispenser

You requested California Air Resources Board (CARB) certification of the Southwest Energy Control Systems Model 4110-XA-V fuel dispenser. The hydraulics and vapor piping are similar to the previously certified Model 4110-X-V dispenser. The -A suffix signifies the use of a centralized electronic display different from the non -A models. Both dispensers are subject to the requirements of Exhibit 10 of Executive Order G-70-52-AM.

As required by the Air Resources Board certification procedures, you requested the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the Model 4110-XA-V dispenser will not adversely affect vapor recovery systems on which it may be installed. Therefore, the Southwest Pump Model 4110-XA-V dispenser is certified for use with Phase II gasoline vapor recovery systems. If you have any questions, please call Laura McKinney, Associate Air Pollution Specialist, at (916) 327-1525.

Sincerely,



James J. Morgester, Chief
Compliance Division

cc: All APCDs and AQMDs
Vapor Recovery Technical Committee Members
CAP Gasoline Marketing and Distribution Manual