STATE OF CALIFORNIA
AIR RESOURCES BOARD
1102 Q STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

PETE WILSON, Governor

January 6, 1992

B. H. Sasnett III
Vice President
Universal Epsco, Inc.
P. O. Box 93544 Martech Station
Atlanta, Georgia 30318

#92-2

Dear Mr. Sasnett:

Certification of Universal Epsco Model 8000M Dispenser

You requested California Air Resources Board (CARB) certification of the Universal Epsco Model 8000M multi product dispenser with vapor recovery piping. This dispenser differs from previously certified MPDs in that it has one meter per product, rather than one meter per side shared by all products.

Tests were conducted to verify that the vapor lines are not subject to liquid blockage or excessive backpressure, conditions which adversely affect vapor recovery systems. Test results were satisfactory.

As required by the Air Resources Board certification procedures, you requested the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the Model 8000M dispenser as defined above will not adversely affect vapor recovery systems on which it may be installed. Therefore, the Universal Epsco Model 8000M dispenser is certified for use with Phase II gasoline vapor recovery systems. If you have any questions, please contact Laura McKinney, Associate Air Pollution Specialist, at (916) 327-1525.

Sincerely,

James J. Morgester, Chief
Compliance Division

cc: All APCDs and AQMDs
Vapor Recovery Technical Committee Members
CAP Gasoline Marketing and Distribution Manual