

AIR RESOURCES BOARD

2020 L STREET
P.O. BOX 2815
SACRAMENTO, CA 95812



October 20, 1992

Len Terlizzi
National Accounts Manager
Thermoid
HBD Industries
Post Office Box 310
Oneida, Tennessee 37841-0310

#92-23

Dear Mr. Terlizzi:

Certification of Thermoid HBD Industries Hi-Vac Inverted Coaxial Hose

You requested certification of an inverted coaxial hose for use with vacuum assisted vapor recovery systems. Test hoses were installed in the Hasstech and Gilbarco test stations for the duration of the certification testing. No problems affecting the vapor recovery system were observed.

As required by the Air Resources Board certification procedures, you requested the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the Hi-Vac hose will not adversely affect the vapor recovery systems on which it may be installed. Therefore, the Thermoid HBD Industries Hi-Vac inverted coaxial hose is certified for use with Hasstech HP1000 and Gilbarco VaporVac bootless Phase II gasoline vapor recovery systems.

If you have any questions, please call Laura McKinney, Associate Air Pollution Specialist, at (916) 327-1525.

Sincerely,

A handwritten signature in black ink, appearing to read "James J. Morgester".

James J. Morgester, Chief
Compliance Division

cc: All APCDs and AQMDs
Vapor Recovery Technical Committee Members
CAP Gasoline Marketing and Distribution Manual