STATE OF CALIFORNIA
AIR RESOURCES BOARD
1102 Q STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

PETE WILSON, Governor

March 10, 1992

L. J. Elevi
Environmental Specialist
Wayne Division
Dresser Industries, Inc.
5400 Orange Avenue, Suite #125
Cypress, California 90630

Dear Mr. Elevi:

#92-6

Certification of Dresser/Wayne Vista V390D-Series and V490D-Series MGDs

You requested California Air Resources Board (CARB) certification of the Dresser Industries, Wayne Division Vista Multi-Grade Dispenser (MGD) with vapor recovery piping. The Vista MGDs to which this approval pertains are the V390D-series and the V490D-series. The V490D-series dispensers differ from the V390D-series only in that they have an additional hose for diesel product dispensing. Testing was conducted to verify that the pressure drop was within the limits specified in the certification Executive Orders for Balance and Hirt systems. The dispensers will be listed in the next revision of Executive Order G-70-52, and must comply with all applicable requirements contained therein.

As required by the Air Resources Board certification procedures, you requested the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the Dresser/Wayne V390D-series and V490D-series MGDs will not adversely affect vapor recovery systems on which they may be installed. Therefore, these dispensers are certified for use with Phase II gasoline vapor recovery systems. If you have any questions, please contact Laura McKinney, Associate Air Pollution Specialist, at (916) 327-1525.

Sincerely,

James J. Morgester, Chief
Compliance Division

cc: All APCDs and AQMDs
Vapor Recovery Technical Committee Members
CAP Gasoline Marketing and Distribution Manual