

AIR RESOURCES BOARD

2020 L STREET
P.O. BOX 2815
SACRAMENTO, CA 95812

February 4, 1993

Craig Boche
Development Engineer
The Goodyear Tire and Rubber Company
Post Office Box 579
Norfolk, NE 68701

#93-3

Dear Mr. Boche:

Certification of Goodyear Coaxial Hose Assembly with New Outer Hose

You requested California Air Resources Board (CARB) certification of a new Maxxim Vapor Recovery Hose. The New Maxxim outer vapor recovery hose features are as follows:


- Helical internal wire
- Polyurethane outer cover reinforced with Polyester yarn
- An inside diameter of the new hose is 1.320" as compared to 1.280" for the previously certified Hytrell corrugated Maxxim vapor hose.

The new Helical-wire, Polyurethane-covered and Polyester-reinforced Maxxim Coaxial Hose has met all the requirements for California Air Resources Board (CARB) certification.

As required by the Air Resources Board certification procedures, you requested the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the use of the new outer hose will not adversely affect vapor recovery systems on which they may be installed. Therefore, the Goodyear Maxxim coaxial hose assembly with the helical-wire outer hose is certified for use with CARB-certified Phase I vapor recovery systems. If you have any questions, please call Laura McKinney at (916) 327-1525.

Sincerely,


James J. Morgester, Chief
Compliance Divisioncc: All APCDs and AQMDs
Vapor Recovery Technical Committee Members