

**AIR RESOURCES BOARD**2020 L STREET  
P.O. BOX 2815  
SACRAMENTO, CA 95812

March 14, 1994

Jeffrey M. Berger  
Application Engineer  
Dayco Products, Inc.  
Springfield Technical Center  
Post Office Box 3258  
Springfield, Missouri 65808-3258

#94-5

Dear Mr. Berger:

Approval of the Catlow Vapor Mate Balance Standard Coaxial Hose

You requested California Air Resources Board (CARB) approval of the Catlow Incorporated Vapor Mate Balance standard coaxial hose on December 27, 1993. The Catlow Vapor Mate Balance hose is manufactured by Dayco Products as the Model 7574 Petroflex 2000 standard coaxial hose, and was approved by CARB on November 29, 1993. It is listed in Approval Letter #93-23.

CARB requires the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and Agriculture, Division of Measurement Standards. The necessary approvals for the Dayco 7574 Petroflex 2000 standard coaxial vapor recovery hose have previously been obtained from these agencies.

Based on the fact that the Catlow Vapor Mate Balance hoses are the same hoses which were certified as the Dayco 7574 Petroflex 2000 hoses, I find that their use, when installed in accordance with the manufacturer's instructions, will not adversely affect the performance of vapor recovery systems on which they are installed. Therefore, the Catlow Incorporated Vapor Mate Balance standard coaxial hoses are certified for use with Phase II balance type vapor recovery systems.

If you have any questions, please call Bashar at (916) 324-7343 or Laura Sullivan McKinney at (916) 327-1525.

Sincerely,

A handwritten signature in black ink, appearing to read "J. Morgester".  
James J. Morgester, Chief  
Compliance Division

cc: Vapor Recovery Technical Committee