

AIR RESOURCES BOARD

2020 L STREET
P.O. BOX 2815
SACRAMENTO, CA 95812



March 6, 1995

Mr. Donald L. Leininger
Technical Liaison Manager
OPW Fueling Components
Post Office Box 405003
Cincinnati, Ohio 45240-5003

#95-7

Dear Mr. Leininger:

Approval of the OPW C4065 Drain Valve with the Series 1 Spill Containers

Mr. William J. Brown of OPW Fueling Components requested certification of the OPW Model C4065 drain valve for use with the OPW Series 1 spill containment manholes on February 15, 1994. The OPW Series 1 spill containment manholes were CARB approved on April 13, 1992, and are listed in Approval Letter #92-7. Additional Series 1 spill containment manholes were CARB approved on December 23, 1993, and are listed in Approval Letter #93-26. The spill containment manholes approved in the above two Approval Letters are listed below:

1-2100
1C-2100
1-2115
1C-2115
1-4500
1C-4500
1-4580
1C-4580
101BG-2100
101BGS-2100
101BG-2115
101BGS-2115

Each of the above listed spill containment manholes uses an OPW Model C4091 drain valve. I understand that OPW has improved this valve by using a gasket rather than an o-ring for the poppet seat. You have modified the C4091 unit and designated it the OPW Model C4065. The C4065 valve offers the twin advantages of a larger seating area and no void area behind the seal for accumulation of dirt and debris.

As required by the Air Resources Board certification procedures, you requested the approval of the Division of Occupational Safety and Health, the Office of the State Fire Marshal and the Department of Food and

Mr. Donald L. Leininger

-2-

March 6, 1995

Agriculture, Division of Measurement Standards. The necessary approvals have been obtained from these agencies.

I find that the use of the C4065 drain valve, when installed in accordance with the manufacturer's instructions and the conditions listed in the original Series 1 spillbox approvals, will not adversely affect the performance of the Series 1 spill container on which it is installed. Therefore, the OPW Model C4065 drain valve is approved for use with the above listed OPW Series 1 spill containment manholes.

Should you have any questions or need further assistance, please contact Mr. Basharat Iqbal at (916) 324-7343 or Ms. Laura Sullivan McKinney at (916) 327-1525.

Sincerely,



James J. Morgester, Chief
Compliance Division

cc: Mr. Kenneth Kunaniec, Chairman,
CAPCOA Vapor Recovery Committee

Mr. Gary Hunter, Manager,
CARB Compliance Assistance Section