



**Cal/EPA**

California  
Environmental  
Protection  
Agency



**Air Resources Board**

P.O. Box 2815  
2020 L Street  
Sacramento, CA  
95812-2815  
<http://www.arb.ca.gov>

October 27, 1997



Pete Wilson  
Governor

Secretary for  
Environmental  
Protection

PEMCO  
Joseph Petix  
2185 West 76th Street  
Hialeah, Florida 33016

97-12

Dear Mr. Petix

Pemco Triple Access Manhole with Dual Containmentment

You requested California Air Resources Board (CARB) certification of the Pemco Triple Access Manhole with Dual Containmentment.

The Pemco 107362P2CV Triple Access Manhole features spill containment and drain valves in both the fuel and vapor risers. This drain is a push rod style which is spring loaded. The body of the housing is galvanized steel and measures 36 inches in diameter with 16 inch centers for the fuel and vapor risers.

As required by the certification Procedures for Gasoline Vapor Recovery Systems at Service Stations, the approvals of the three State agencies is a precondition to certification by the Air Resources Board. The appropriate letters of approval have been obtained from these agencies. I find that the Pemco 107362P2CV Triple Access Manhole when installed in accordance with the manufacturer's instructions, will not adversely affect the performance of vapor recovery systems on which they are installed. Therefore, the Pemco 107362P2CV Triple Access Manhole are certified for use with Phase I type vapor recovery systems. This approval does not supersede any requirements from existing Executive Orders.

If you have any questions or wish to discuss this matter further, please call Joe Guerrero at (916) 324-7343 or Laura McKinney at (916) 327-1525.

Sincerely,

**INTERNET VERSION**

James J. Morgester, Chief  
Compliance Division

cc: Mr. Jim Johnston, Chairman,  
CAPCOA Vapor Recovery Committee

Lynn LaBarber  
CARB Compliance Training Section