



Peter M. Rooney
Secretary for
Environmental
Protection

Air Resources Board

Barbara Riordan, Chairman

2020 L Street \$ P.O. Box 2815 \$ Sacramento, California 95812 \$ www.arb.ca.gov



Pete Wilson
Governor

November 23, 1998

Elmer Klop
EBW, Inc.
P.O. Box 689
Muskegon, MI 49443


98-18

Dear Mr. Klop:

EBW Model 785-400 Tank Bottom Protector

This is in response to your request for California Air Resources Board (CARB) approval of the EBW Model 785-400 Tank Bottom Protector.

The assembly is constructed of zinc plated carbon steel with 3 guide legs attached to a plastisole coated strike plate. The thickness of the strike plate is approximately 1/4 inch. The tank bottom protector is attached to the end of the fuel fill tube with 3 pop rivets and is free to slide up and down. Health and Safety Code Section 41950 (d) states that the fill tube is to have its discharge opening entirely submerged when the liquid level is six (6) inches above the bottom of the tank. The assembly is designed to extend beyond the 6 inch compliance depth, allowing the inspector to determine if the fill tube is installed correctly.



California Environmental Protection Agency

Printed on Recycled Paper

As required by the Certification Procedures for Gasoline Vapor Recovery Systems at Service Stations, the approvals of the three State agencies are a precondition to certification by the Air Resources Board. The appropriate letters of approval have been received and are listed as follows:

-Department of Food and Agriculture,
Division of Measurement Standards
March 12, 1998

-Department of Occupational Safety and Health
September 2, 1998

-Department of Forestry and Fire Protection
Office of the State Fire Marshal
November 13, 1998

I find that the use of the EBW Model 785-400 Tank Bottom Protector, when installed in accordance with the manufacturer's instructions, will not adversely affect the performance of vapor recovery systems on which they are installed. Therefore, the EBW Model 785-400 Tank Bottom Protector is certified for use with Phase I vapor recovery systems.

If you have any questions or wish to discuss this matter further, please call Joe Guerrero at (916) 324-7343 or Laura McKinney at (916) 327-1525.

Sincerely,

INTERNET VERSION

James J. Morgester, Chief
Compliance Division

cc:
Mr. Jim Johnston, Chairman,
CAPCOA Vapor Recovery Committee
Monterey Bay Unified APCD
24580 Silver Cloud Ct.
Monterey, CA 93940

Lynn Speckert
CARB Compliance Training Section