Executive Order G-70-165

Exhibit 1
Healy Model 600 System Equipment List

Component	Manufacturer/Model	State Fire Marshal Identification Number
Nozzles	Model 600 (Figure 2C-1) (with vapor valve)	005:027:018
Vapor Pumps (Collection Unit)	Model 2000C Blower (1 hp) (No bypass vacuum regulation)	005:027:014
	Thomas Industries VP 500 Vane Pump (1/2 hp)	005:027:017
	9000-01, -02 Mini-Jet Pump (non-electric gasoline-driven pump)	005:027:009
Inverted Coaxial Hoses	Healy Model 75B (3/4" I. D.)	005:027:003 005:027:004
	Healy Model 88B (7/8" I. D.)	005:027:005
	OR Any inverted coaxial hose CARB-certified for use with the Healy Model 600 system.	
Hose Adapters	Healy Model series CX6- followed by suffix letter(s) "G", "D", "U", "VV1", "VV2", "VV3", "TCSVV", "DWVV" "VV1A", "VV2A", "VV3A", "TCSVVA", "DWVVA"	005:027:019
	Note: The "A" indicates that no valve is provided in the fitting because the vapor valve is integrated into the nozzle.	
	"G" Gilbarco Dispensers "D" Dresser/Wayne Dispensers "U" Universal Dispensers "VV1" Dispensers-Lowboy (with vapor valve) "VV2" Vapor Ready Balance Type "VV3" Universal Dispensers "TCSVV" Tokheim Dispensers "DWVV" Dresser/Wayne Dispensers	

Pressure/Vacuum Valves	OPW 523LP, 523LPS (settings as specified below)	005:008:051
	Hazlett H-PVB-1 Gold label (settings as specified below)	005:017:004
	OR Any CARB-certified valve with the following pressure and vacuum settings, in inches water column (wc): Pressure: three plus or minus one-half inches (3.0 ± 0.5") wc. Vacuum: eight plus or minus two inches (8 ± 2") wc.	
Vacuum Monitor with Pressure Switch	Vacuum Monitor Model 6169 Pressure Switch Model 93928	005:027:015
Breakaway Couplings (optional component)	Healy Model 8701VV	005:027:016
	OR Any breakaway coupling with a vapor valve which is CARB-certified for use with the Healy Model 600 system	