

Executive Order G-70-186

**Exhibit 1
Healy Model 400 ORVR Nozzle System
Equipment List**

<u>Component</u>	<u>Manufacturer/Model</u>	<u>State Fire Marshal Identification Number</u>
Nozzle	Model 400 ORVR (w vapor valve) (Figure 1)	005:027:023
Vapor Pumps (Collection Unit)	9000 Mini-Jet Pump (non-electric gasoline-driven pump) 9000-01 without siphon 9000-02 with siphon (Figures 2A thru 2D)	005:027:009
	Thomas Industries VP-500 Vane Pump (1/2 hp) (Figure 3)	005:027:017
	Franklin Electric VP-500 Vane Pump (1/2 hp) (Figure 3)	
Vapor Check Valve	Healy Model 9466	005:027:024
System Monitor w Pressure Switch, Vent Sensor and P/V Valve	System Monitor Model 6280 Pressure Switch Model 93928 Vent Sensor Model 6275 (Figures 4A - 4G)	005:027:022
Inverted Coaxial Hoses	Healy Model 75B (3/4" I. D.)	005:027:003
	Healy Model 88B (7/8" I. D.)	005:027:004 005:027:005
	OR Any inverted coaxial hose CARB-certified for use with the Healy Model 400 ORVR system.	
Hose Adapters	Healy Model series CX6- followed by suffix letter(s) "G", "D", "U", "VV1", "VV2", "VV3", "TCSVV", "DWVV", "VV1A", "VV2A", "VV3A", "TCSVVA", "DWVVA"	005:027:019
	Note: The "A" indicates that no valve is provided in the fitting because the vapor valve is integrated into the nozzle.	
	"G" Gilbarco Dispensers "D" Dresser/Wayne Dispensers "U" Universal Dispensers "VV1" Dispensers-Lowboy (with vapor valve) "VV2" Vapor Ready Balance Type "VV3" Universal Dispensers "TCSVV" Tokheim Dispensers "DWVV" Dresser/Wayne Dispensers	

Breakaway Couplings	Healy Model 8701VV Healy Model 8701 w/ 715V Upgrade Kit	005:027:016 005:027:016
Pressure/Vacuum Valves	OPW 523LP, 523LPS (settings as specified below)	005:008:051
	OPW 523V (settings as specified below)	005:008:058
	Hazlett H-PVB-1 Gold label (settings as specified below)	005:017:004
	Husky 4620 P/V (settings as specified below)	005:021:015
	Morrison Brothers 749CRB0600 AV (settings as specified below)	005:041:001
	EBW Models 802-309, 802-308	005:034:006
	OR Any CARB-certified valve with the following pressure and vacuum settings, in inches water column (wc): <u>Pressure</u> : three plus or minus one-half inches (3.0 ± 0.5") wc. <u>Vacuum</u> : eight plus or minus two inches (8 ± 2") wc.	
Flow Control Units	Healy Model 1301 or 1302	005:027:020
Phase I Adaptors	Any CARB-certified device which prevents loosening or overtightening of the Phase I product and vapor adaptors. Note: For systems installed before two CARB-certified devices which prevent loosening or overtightening of the Phase I product and vapor adaptors are available, or within sixty days after that date, any CARB-certified Phase I product adaptor may be used for a period not to exceed four years from the date the second device was certified.	