

State of California
AIR RESOURCES BOARD
Executive Order G-70-9

Relating to the Certification of the 'Teed'
Vapor Recovery System for Small (\leq 2,000 Gallons)
Underground Storage Tanks

Pursuant to the authority vested in the Air Resources Board by Health and Safety Code Section 41954; and

Pursuant to the authority vested in the undersigned by Health and Safety Code Sections 39515 and 39516;

IT IS ORDERED AND RESOLVED: That, except as provided below, the 'teed' vapor recovery system, with or without a pressure-vacuum valve, is hereby certified for use on underground gasoline storage tanks. The system certified hereby is shown in Exhibit I attached.

IT IS FURTHER ORDERED AND RESOLVED: That, any underground storage tank equipped with this system and filled by a gasoline delivery tank equipped with pressure-differential activated vapor-return vent valves must have a pressure-vacuum relief valve on the vent of the underground storage tank.

IT IS FURTHER ORDERED AND RESOLVED: That use of the pressure-vacuum valve be subject to approval of the local fire chief, and that the tanks and piping be in compliance with the appropriate General Industry Safety Orders in particular the provisions in Articles 144, 145 and 146 thereof.

IT IS FURTHER ORDERED AND RESOLVED: That the system certified hereby shall in actual use return to the delivery tanks a minimum of 90 percent by weight of the gasoline vapors displaced from the underground storage tank. Compliance with this criterion shall be a condition of this certification; and if not met, shall constitute grounds for revocation, suspension or modification of this certification.

IT IS FURTHER ORDERED AND RESOLVED: That any alteration in the equipment parts, design or operation of the system certified hereby is prohibited and deemed inconsistent with this certification, unless the alteration has been approved by the undersigned.


Executed at Sacramento, California this ^{15th} day of *July*, 1977.

A handwritten signature in cursive script, reading "William H. Lewis, Jr.", written over a horizontal line.

William H. Lewis, Jr.
Executive Officer

EXHIBIT-1
EXECUTIVE ORDER G-70-9

'TEED' GASOLINE VAPOR RECOVERY SYSTEM
FOR SMALL ($\leq 2,000$ GALLONS) UNDERGROUND STORAGE TANKS



PARTS LIST *

- | | |
|---|---|
| (1) P/V VALVE (OPTIONAL). | (6) OPW60 ELBOW OR OPW60T ELBOW. |
| (2) VENT PIPE 1-1/4 INCH DIAMETER OR LARGER. | (7) ALUMINUM DROP TUBE (EXTEND TO WITHIN 6" BOTTOM OF TANK) 4" DIAMETER OR SMALLER. |
| (3) OPW 1611-AV 3" DRY BREAK WITH AN OPW 1711T OR OPW 1711TK LOCKING CAP. | (8) VAPOR RETURN HOSE 2" DIAMETER OR LARGER. |
| (4) OPW 1711-V3" ELBOW. | (9) TRUCK PRODUCT HOSE 3" DIAMETER OR SMALLER. |
| (5) OPW 61AS ADAPTOR OR OPW 633T ADAPTOR. | |

* Interchangeable fittings, dust caps, and p/v valves are given in Executive Order G-70-2-C.