

Modification Highlights for Executive Order VR-102-H

- The epoxy that seals the upper/lower drop tubes and inlet tube have been eliminated from the 61SO overfill prevention valve and replaced with elastomeric seals. The modified 61SO is renamed as 71SO.
- A coating was added to the o-rings in the product and vapor adaptors to improve lubricity. The o-ring glands were machined to accommodate the increased thickness from the new coating.
- The material for the product and vapor caps was changed from Zinc-Aluminum to Aluminum.
- A new tank gauge port adaptor and cap was added, model number 62M.
- Remote-fill configuration was added.
- Additional new 61JSK-4RMT Jack Screw Kit for Remote-fill only.
- Removed reference to 61JSK-4400 Jack Screw. This component has been discontinued.
- Component identification photos have been added for ease of reference.
- Other minor editorial changes for clarification.