

Executive Order VR-102-M: Modification Highlights

Table 1: Summary of Revisions to Executive Order

Executive Order Exhibit	Description of Amendment
All Exhibits	Throughout the headers, footers, and select paragraphs, updated the revision suffix from VR-102-L to VR-102-M
Legal Language	<ul style="list-style-type: none"> • Added new paragraph pertaining to E85 fuel compatible components: <p><i>“WHEREAS, OPW requested amendment of the Executive Order to include E85 (85% ethanol/15% gasoline) compatible components.”</i></p> <ul style="list-style-type: none"> • Added reference to new Exhibit 4: Manufacturer Warranties • Expiration date changed from May 31, 2013 to May 31, 2017
Exhibit 1	<ul style="list-style-type: none"> • Under “Spill Containers” added language pertaining to Gas/Ethanol Blends up to E85 • Under “Dust Caps” added language pertaining to Gas/Ethanol Blends up to E-85 • Under “Replacement Drain Valve Kit” indicated Gas/Ethanol Blends up to E-85 • Added OPW 61SALP-MA to “Product Adaptor” to indicate Gas/Ethanol Blends up to E-85 • Added OPW 61VSA-MA “Vapor Adaptor” to indicate Gas/Ethanol Blends up to E-85 • Added 71JSK-44MA and 71JSK-4RMT to the “Jack Screw Kit” section and indicate Gas/Ethanol Blends up to E-85 • Added OPW 61T-SS (various lengths) to the “Drop Tube” to indicate Gas/Ethanol Blends up to E-85 • Added 61SOM-412C-EVR and added 71SOM-412C indicating compatibility with Gas/Ethanol Blends up to E-85 to “Drop Tube Overfill Prevention Device” list • Added OPW 62M-MA to indicate Gas/Ethanol Blends up to E-85 to “Tank Gauge Port Components.” • Under FFS PV-Zero added language to indicate compatibility with Gas/Ethanol Blends up to E-85
Exhibit 1	<p>For identification purposes, inserted images of the following OPW E85 compatible components.</p> <p style="text-align: center;">A. E85 compatible vapor adaptor B. E85 compatible product adaptor</p>

Executive Order Exhibit	Description of Amendment
	<ul style="list-style-type: none"> C. E85 compatible drop tube D. E85 compatible overfill prevention device E. E85 compatible jack screw F. E85 compatible face seal adaptor G. E85 compatible tank gauge components H. E85 compatible caps
Exhibit 2	Added a note to the bottom of the page (under the “Face Seal Adaptor” section) indicating that the Face Seal Adaptor is not required with double wall 1-3100 series spill containers.
Exhibit 4	Added an entirely new exhibit dedicated to manufacturer warranty language

Table 2: Summary of Revisions to ARB Approved Installation, Operation, and Maintenance Manual

IOM Section	Description of Amendment
All sections pertaining to OPW components	Updated figures, text, and format per revised instruction sheets provided by OPW
All sections	Throughout the headers, footers, and select paragraphs, updated the revision suffix from VR-102-L to VR-102-M
All section pertaining to OPW components	Non-compliant warranty language removed from each IOM section
Table of Contents	Due to formatting issues, removed reference to figure numbers and relied on page numbers instead
Table of Contents	Added reference to E85 compatible Jack Screw instructions due to unique part number
Installation Checklist	Added reference to E85 compatible Jack Screw kit due to unique part number