

## **Modification Highlights for Executive Order VR-104-C**

- The following EMCO Wheaton components were added: A1100EVR Guardian Overfill Prevention Valve, Vapor Swivel Adapter model A0076-124S and Fill/Product Swivel Adapter model A0030-124S.
- Amended the EO and IOM to reflect the new P/V vent valve positive cracking pressure specification of 2.5 to 6.0 in H<sub>2</sub>O.
- Removed reference to the Extractor Assemblies and Extractor Coupling as well as the Ball Float Vent Valve in the EO and IOM.
- Added pictures to Exhibit 1 of the EO showing component identification location.
- Amended the torque values in the IOM for the vapor flange (round) and product flange (oval) to the 4 inch tank riser interface due to an offset being used.
- A Tool Rest was added to the bottom of the vapor flange (round) and product flange (oval) of the CNI Mfg. certified containment units to accommodate the CNI Mfg. Containment Installation/Removal Tool (p/n EVRSYS116).
- The torque value of the bolts for the 3 pc. Bellows Hold Down Clamps at the Snap-Tight Ring interface were also changed from 10 lb.-ft. to 10 lb.-in. due to information received and verified by ARB staff that this size of bolt does not hold up to the higher torque.
- Other minor editorial changes for clarification.