

## Modification Highlights for VR-201-J and VR-202-J

Note: With exception of Executive Order VR-202-J, the following wording are added to the Executive Exhibits and IOM. At this time we do not have the strike and add feature for Adobe InDesign. The new addition to Executive Order VR-202-J are underline. Please note minor changes such as revision levels have been incorporated into Executive Order.

- Legal Language
  - Legal language has been updated to reflect latest revision level, VR-201-J and VR-202-J.
  - VR-202-J has been updated to state the following regarding the FFS INCON ISD system, software versions 1.0.0 and 1.1.0:

*WHEREAS ARB has found that the Franklin Fueling Systems INCON In-Station Diagnostics versions 1.0.0 and 1.1.0 have not been tested and have not been demonstrated to comply with the applicable requirements of the certification and test procedures for gasoline dispensing facilities with multi-product (six-pack) dispensers.*

*IT IS FURTHER ORDERED that the certification for the FFS INCON ISD versions 1.0.0 and 1.1.0 is approved only on gasoline dispensing facilities equipped with uni-hose dispensers.*

- Exhibit 1
  - VR-202-J added a footnote number 1 on page 26 to state that:

*“INCON/TS-VRM software Versions 1.0.0 and 1.1.0 are approved for and shall be used or installed only with uni-hose dispensers.”*
  - Change footnote 1 to 2 on exhibit 1, page 26.
  - Updated footnote 11 to identify that VP1000 installation kit is applicable to the new 4V Model of the Vista Series dispensers.
- Exhibit 2
  - VR-202-J added language on page 28, under Console & VRM Software Version Number that:

*“INCON/TS-VRM software Versions 1.0.0 and 1.1.0 are approved for and shall be used or installed only with uni-hose dispensers.”*

- Exhibit 3
  - VR-202-J, added a footnote 1 on number 2 “VRM SOFTWARE” on page 6 to state that:

*“INCON/TS-VRM software Versions 1.0.0 and 1.1.0 are approved for and shall be used or installed only with uni-hose dispensers.”*

- The Installation, Operation and Maintenance (IOM) Manual
  - INCON Manual IOM22
    - The following language has been added to pages 309 and 316 as a footnote and text respectively :

*“INCON/TS-VRM software Versions 1.0.0 and 1.1.0 are approved for and shall be used or installed only with uni-hose dispensers.”*

- The dispenser interface setup on page 318 has been modified to reflect only one hose per fueling point, and deleted Grade 2 and 3 from table.

- Exhibit 10
  - VR-202-J “INCON VRM Operability Test Procedure”  
The following language has been added on page number 1 under first paragraph states that:

*“INCON/TS-VRM software Versions 1.0.0 and 1.1.0 are approved for and shall be used or installed only with uni-hose dispensers.”*

- Installation, Operation and Maintenance Manual (both EO's)
  - Updated title pages and introduction section identifying that installation kit is also applicable to 4V Model of the Vista Series dispensers.
- Header and footer updates on all exhibits and IOM to reflect new revision level of the executive orders, VR-201-J and VR-202-J.