



# Air Resources Board



Linda S. Adams  
Secretary for  
Environmental Protection

Mary D. Nichols, Chairman  
1001 I Street • P.O. Box 2815  
Sacramento, California 95812 • [www.arb.ca.gov](http://www.arb.ca.gov)

Arnold Schwarzenegger  
Governor

April 14, 2008

Mr. Jerry Usrey  
J.U.R.  
P.O. Box 4556  
Blue Jay, California 92317

Dear Mr. Usrey:

Thank you for your letter dated April 1, 2008, in which you requested the Air Resources Board's (ARB) approval of the JUR Annunciator. The JUR Annunciator is a remote audio and visual alarm component that is used in conjunction the Veeder-Root In-Station Diagnostics (ISD) system. One of the documents (see Enclosure) included with your letter states that the JUR Annunciator is a required upgrade to the ISD Enhanced Vapor Recovery (EVR) system. ARB staff would like to clarify that the only requirement for an ISD audible alarm is that it is "...installed at a location that is most likely to be occupied by the station attendant during normal station operation (e.g. cash register) to hear the alarm." This requirement can be accomplished through a variety of methods, including but not limited to the JUR Annunciator. ARB staff requests that the enclosed document be revised such that the JUR Annunciator is not stated as an ARB requirement.

ARB staff has reviewed your application and concluded that the JUR Annunciator does not affect the vapor recovery system at gasoline dispensing facilities and therefore does not require ARB approval as provided by Section 18, CP-201.

If you have questions or need further information, please contact Sam Vogt at (916) 322-8922 or via email at [svogt@arb.ca.gov](mailto:svogt@arb.ca.gov).

Sincerely,

William V. Loscutt, Chief  
Monitoring and Laboratory Division

Enclosure

*The energy challenge facing California is real. Every Californian needs to take immediate action to reduce energy consumption. For a list of simple ways you can reduce demand and cut your energy costs, see our website: <http://www.arb.ca.gov>.*

California Environmental Protection Agency

Subject: ISD- EVR Upgrades Required by CARB - Remote Annunciator

CARB is requiring the installation of remote annunciators for station locations at which the Veeder-Root unit is not in close proximity to the station attendants.

CARB requires that attendants must be able to both hear the audio alarm and see the visual alarm indicator immediately when an alarm condition exists.

Please see the attached Remote Annunciator drawing and pricing

Features: UL Listed, NEMA 4X Enclosure intrinsically safe, high decibel audible alarm.

For further information and to order, please call U.R at 909-338 2111 or Jerry Usrey's cell phone 909-816-9456.

Best regards

Jerry Usrey

J.U.R.

(909) 338-2111 Phone

(909) 338-8428 Fax

(909) 816-9456 Cell