Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Total Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor: 1.00015					**Pre-Test Leak Check -** Start Pressure: 5.052					End Pressure: 5.028						
1	5	1.11	1.08	87	4005212	0.000	4.765	4.77	36.54	7.82	0.00	0.72	1.13	1.02	-0.11	10:20 AM
2	5	1.11	1.08	87	4005212	0.000	4.756	4.76	38.86	7.34	0.00	0.73	1.15	1.22	0.07	10:24 AM
1	3	1.02	0.97	87	4005210	0.000	4.872	4.87	37.58	7.78	0.00	0.79	1.21	1.11	-0.10	10:30 AM
3	3	1.02	0.97	87	4005210	0.000	4.552	4.55	38.17	7.16	0.00	0.74	1.22	1.31	0.09	10:36 AM
4	3	1.02	0.97	87	4005210	0.000	4.675	4.68	40.08	7.00	0.00	0.76	1.22	1.11	-0.11	10:40 AM
1	2	0.99	0.97	87	4005207	0.000	4.748	4.75	38.79	7.34	0.00	0.61	0.96	0.98	0.02	10:54 AM
2	2	0.99	0.97	87	4005207	0.000	4.733	4.73	37.87	7.50	0.00	0.60	0.95	0.94	-0.01	11:00 AM
1	7	0.94	0.95	87	4005209	0.000	4.691	4.69	60.08	4.68	0.00	0.77	1.23	1.27	0.24	11:09 AM
2	7	0.94	0.95	87	4005209	0.000	4.632	4.63	60.15	4.62	0.00	0.75	1.21	1.33	0.12	11:13 AM
3	7	0.94	0.95	87	4005209	0.000	4.747	4.75	61.67	4.62	0.00	0.76	1.20	1.23	0.03	11:18 AM
1	8	1.01	1.01	87	206637	0.000	4.714	4.71	58.16	4.86	0.00	0.65	1.03	1.07	0.02	11:30 AM
1	10	0.99	0.94	87	4005213	0.000	4.724	4.72	53.60	5.29	0.00	0.62	0.98	1.21	0.23	11:36 AM
1	12	1.15	1.10	87	4005211	0.000	4.650	4.65	52.55	5.31	0.00	0.06	0.97	1.26	0.29	11:40 AM
2	12	1.15	1.10	87	4005211	0.000	4.677	4.68	53.52	5.24	0.62	0.99	0.99	1.25	0.26	11:43 AM
3	12	1.15	1.10	87	4005211	0.000	4.655	4.66	53.84	5.19	0.64	1.03	1.03	1.25	0.22	11:48 AM
							Post-Test Leak Check - Start Pressure: 5.048				End Pressure: 5.031					

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: 5.23				End Pressure: 4.57							
1	10	1.07	1.04	87	3705047	0.000	4.547	4.55	37.00	7.37	138.80	139.44	1.07	1.16	0.09	9:03 AM
2	10	1.07	1.04	91	3705047	0.000	4.556	4.56	33.44	8.17	139.45	140.13	1.13	1.20	0.07	9:17 AM
3	12	0.89	0.94	87	4705137	0.000	4.598	4.60	36.22	7.62	140.13	140.73	0.99	1.07	0.08	9:25 AM
4	12	0.89	0.94	91	4705137	0.000	4.577	4.58	32.19	8.53	140.74	141.36	1.03	1.05	0.02	9:31 AM
5	8	0.96	0.98	87	4404453	0.000	4.557	4.56	39.78	6.87	141.37	141.99	1.03	1.09	0.06	9:39 AM
6	4	0.88	0.94	87	3705050	0.000	4.532	4.53	32.27	8.43	141.99	142.60	1.02	1.01	-0.01	9:45 AM
7	2	0.84	0.94	87	3705024	0.000	4.622	4.62	34.85	7.96	142.97	143.56	0.97	1.06	0.09	10:05 AM
8	2	0.84	0.94	91	3705024	0.000	4.589	4.59	32.62	8.44	143.60	144.17	0.94	1.04	0.10	10:12 AM
9	5	0.95	1.01	87	3705525	0.000	4.616	4.62	33.78	8.20	144.21	144.83	1.02	1.05	0.03	10:29 AM
10	5	0.95	1.1	91	3705525	0.000	4.594	4.59	33.43	8.25	144.84	145.49	1.07	1.09	0.02	10:33 AM
							Post-Test Leak Check - Start Pressure: 5.41				End Pressure: 4.77					

V/L CALCULATIONS

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: 5.77					End Pressure: 5.78						
1	3	0.92		87	3805311	0.000	4.556	4.56	33.67	8.12	0.000	0.619	1.01	1.05	0.04	10:26 AM
1	4	0.94		87	3705043	0.000	4.540	4.54	32.91	8.28	0.000	0.558	0.91	0.88	-0.03	10:29 AM
2	4	0.94		87	3705043	0.000	4.580	4.58	33.11	8.30	0.000	0.558	0.91	0.87	-0.04	10:33 AM
3	4	0.94		87	3705043	0.000	4.560	4.56	33.34	8.21	0.000	0.553	0.90	0.85	-0.05	10:35 AM
1	2	0.93		87	206767	0.000	4.574	4.57	32.53	8.44	0.000	0.606	0.99	0.96	-0.03	10:38 AM
1	1	0.92		87	206773	0.000	4.577	4.58	33.12	8.29	0.000	0.540	0.88	0.88	0.00	10:41 AM
2	1	0.92		87	206773	0.000	4.588	4.59	33.40	8.24	0.000	0.536	0.87	0.89	0.02	10:44 AM
3	1	0.92		87	206773	0.000	4.581	4.58	33.34	8.24	0.000	0.538	0.87	0.86	-0.01	10:48 AM
1	7	0.98		87	3705041	0.000	4.580	4.58	34.66	7.93	0.000	0.573	0.93	0.94	0.01	10:53 AM
2	7	0.98		87	3705041	0.000	4.583	4.58	34.41	7.99	0.000	0.567	0.92	0.90	-0.02	10:57 AM
3	7	0.98		87	3705041	0.000	4.580	4.58	34.03	8.08	0.000	0.562	0.91	0.91	0.00	11:00 AM
1	8	1.10		87	3705045	0.000	4.590	4.59	34.30	8.03	0.000	0.701	1.14	1.13	-0.01	11:05 AM
1	6	1.10		87	206772	0.000	4.583	4.58	33.72	8.15	0.000	0.686	1.11	1.12	0.01	11:11 AM
1	5	0.97		87	206768	0.000	4.590	4.59	33.28	8.28	0.000	0.600	0.97	0.81	-0.16	11:23 AM
2	5	0.97		87	206768	0.000	4.584	4.58	33.53	8.20	0.000	0.580	0.95	0.99	0.04	11:25 AM
3	5	0.97		87	206768	0.000	4.549	4.55	32.62	8.37	0.000	0.560	0.92	0.92	0.00	11:28 AM
1	5	0.97		91	206768	0.000	4.554	4.55	34.10	8.01	0.000	0.545	0.89	0.86	-0.03	11:41 AM
2	5	0.97		91	206768	0.000	4.542	4.54	33.84	8.05	0.000	0.532	0.87	0.85	-0.02	11:43 AM
3	5	0.97		91	206768	0.000	4.593	4.59	34.12	8.08	0.000	0.542	0.88	0.83	-0.05	11:46 AM
1	6	1.10		91	206772	0.000	4.561	4.56	33.71	8.12	0.000	0.675	1.10	1.06	-0.04	11:49 AM
1	8	1.10		91	3705045	0.000	4.581	4.58	33.85	8.12	0.000	0.693	1.13	1.08	-0.05	11:53 AM
1	7	0.98		91	3705041	0.000	4.607	4.61	35.10	7.88	0.000	0.582	0.94	0.79	-0.15	11:59 AM
2	7	0.98		91	3705041	0.000	4.582	4.58	34.47	7.98	0.000	0.579	0.94	0.94	0.00	12:02 PM
3	7	0.98		91	3705041	0.000	4.557	4.56	34.59	7.90	0.000	0.575	0.94	0.93	-0.01	12:05 PM
1	2	0.93		91	206767	0.000	4.594	4.59	33.67	8.19	0.000	0.599	0.97	0.98	0.01	12:15 PM
1	1	0.92		91	206773	0.000	4.593	4.59	35.35	7.80	0.000	0.538	0.87	0.86	-0.01	12:19 PM
2	1	0.92		91	206773	0.000	4.558	4.56	35.03	7.81	0.000	0.529	0.86	0.86	0.00	12:21 PM
3	1	0.92		91	206773	0.000	4.574	4.57	35.60	7.71	0.000	0.529	0.86	0.86	0.00	12:23 PM
1	3	0.92		91	3805311	0.000	4.567	4.57	34.59	7.92	0.000	0.658	1.07	1.09	0.02	12:30 PM
1	4	0.94		91	3705043	0.000	4.691	4.69	39.30	7.16	0.000	0.604	0.96	0.97	0.01	12:34 PM
					Post-Test Leak Check - Start Pressure: 5.46					End Pressure: 5.45						

V/L CALCULATIONS

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure:				End Pressure:							
1	12			87	2406023	0.000	4.655	4.655	39.64	7.05	983.31	983.92	1.00	1.03	0.03	11:02 AM
2	12			87	2406023	0.000	4.646	4.646	41.50	6.72	983.92	984.52	0.97	0.99	0.02	11:05 AM
3	10			87	2406024	0.000	4.649	4.649	33.96	8.21	984.52	985.15	1.01	1.03	0.02	11:08 AM
4	10			87	2406024	0.000	4.651	4.651	33.42	8.35	985.15	985.77	1.00	1.06	0.06	11:10 AM
5	8			87	206758	0.000	4.654	4.654	34.65	8.06	985.77	986.38	0.98	0.98	0.00	11:14 AM
6	8			87	206758	0.000	4.663	4.663	35.26	7.93	986.38	986.97	0.95	1.00	0.05	11:16 AM
7	1	0.91		87	405066	0.000	4.639	4.639	35.70	7.80	987.34	987.98	1.03	1.04	0.01	11:32 AM
8	1	0.91		87	405066	0.000	4.658	4.658	35.80	7.81	987.98	988.63	1.04	1.03	-0.01	11:35 AM
9	4			87	406055	0.000	4.650	4.650	36.58	7.63	988.63	989.19	0.90	0.90	0.00	11:38 AM
10	4			87	406055	0.000	4.671	4.671	37.07	7.56	989.19	989.73	0.86	0.91	0.05	11:41 AM
11	6			87	206073	0.000	4.666	4.666	34.71	8.07	989.73	990.36	1.01	1.03	0.02	11:43 AM
12	6			87	206073	0.000	4.636	4.636	35.60	7.81	990.36	990.99	1.02	1.12	0.10	11:45 AM
							Post-Test Leak Check - Start Pressure:				End Pressure:					

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure:				End Pressure:							
1	9	0.96		87	3305005	0.000	4.560	4.56	37.69	7.26	13315.36	13315.97	1.00	1.10	0.10	10:15 AM
2	9	0.96		89	3305005	0.000	4.569	4.57	33.19	8.26	13315.97	13316.63	1.08	1.14	0.06	10:21 AM
3	9	0.96		91	3305005	0.000	4.553	4.55	32.69	8.36	13316.63	13317.27	1.05	1.14	0.09	10:28 AM
4	7	1.14		87	5205233	0.000	4.576	4.58	35.16	7.81	13317.27	13317.99	1.18	1.04	-0.14	10:34 AM
5	7	1.14		89	5205233	0.000	4.575	4.58	30.04	9.14	13317.99	13318.71	1.18	1.19	0.01	10:39 AM
6	7	1.14		91	5205233	0.000	4.542	4.54	32.09	8.49	13318.71	13319.42	1.17	1.15	-0.02	10:41 AM
7	2	0.86		87	4405141	0.000	4.538	4.54	41.88	6.50	13319.42	13320.01	0.97	0.97	0.00	10:47 AM
8	2	0.86		89	4405141	0.000	4.563	4.56	33.19	8.25	13320.01	13320.61	0.99	1.02	0.03	10:51 AM
9	2	0.86		91	4405141	0.000	4.572	4.57	32.44	8.46	13320.61	13321.21	0.98	1.00	0.02	10:54 AM
10	4	1.00		87	3305006	0.000	4.562	4.56	38.63	7.09	13321.21	13321.85	1.05	1.10	0.05	10:58 AM
							Post-Test Leak Check - Start Pressure: 5.06" WC				End Pressure: 4.79" WC					

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: 5.31/5.11						End Pressure: 4.74/4.55					
1	10	1.15	1.05	87	3705047	0.000	4.679	4.68	33.47	8.39	146.03	146.74	1.18	N/A	N/A	10:00 AM
2	10	1.15	1.05	91	3705047	0.000	4.746	4.75	32.44	8.78	146.74	147.48	1.18	1.20	0.02	10:10 AM
3	12	1.08	1.12	87	4705137	0.000	4.659	4.66	34.79	8.04	147.48	148.16	1.11	1.20	0.09	10:20 AM
4	12	1.08	1.12	91	4705137	0.000	5.154	5.15	35.94	8.60	148.16	148.92	1.12	1.15	0.03	10:26 AM
5	11	1.18	1.09	87	3705049	0.000	4.663	4.66	35.62	7.85	148.92	149.63	1.16	1.21	0.05	10:33 AM
6	9	1.13	1.09	87	3205011	0.000	4.711	4.71	35.40	7.98	149.63	150.40	1.24	1.29	0.05	10:40 AM
7	6	0.92	1.08	87	3705046	0.000	4.699	4.70	32.75	8.61	150.41	151.16	1.21	1.20	-0.01	10:59 AM
8	6	0.92	1.08	87	3705046	0.000	5.414	5.41	38.18	8.51	151.16	152.07	1.28	1.36	0.08	11:05 AM
9	6	0.92	1.08	87	3705046	0.000	4.586	4.59	32.81	8.39	152.07	152.85	1.29	1.28	-0.01	11:13 AM
10	8	1.05	1.09	87	4405453	0.000	4.625	4.63	37.37	7.43	152.85	153.53	1.12	1.18	0.06	11:18 AM
11	4	0.97	0.94	87	1606139	0.000	4.683	4.68	34.75	8.09	153.53	154.19	1.07	1.02	-0.05	11:26 AM
12	2	1.05	1.04	87		0.000	4.815	4.82	35.19	8.21	154.19	154.92	1.15	1.16	0.01	11:33 AM
1	6	1.06	1.07	87	3705049	0.000	4.874	4.87	34.88	8.38	155.73	156.52	1.23	1.28	0.05	9:11 AM
2	6	1.06	1.07	87	3705049	0.000	4.811	4.81	33.72	8.56	156.52	157.31	1.25	1.29	0.04	9:14 AM
3	6	1.06	1.07	87	3705049	0.000	4.825	4.83	33.94	8.53	157.31	158.10	1.24	1.32	0.08	9:18 AM
4	5	1.09	1.09	87	3705025	0.000	4.677	4.68	31.57	8.89	158.10	158.81	1.15	1.21	0.06	9:22 AM
5	5	1.09	1.09	87	3705025	0.000	4.782	4.78	31.66	9.06	158.81	159.57	1.21	1.23	0.02	9:25 AM
6	5	1.09	1.09	87	3705025	0.000	4.803	4.80	33.19	8.68	159.57	160.33	1.20	1.25	0.05	9:27 AM
					Post-Test Leak Check - Start Pressure: 5.21/5.38						End Pressure: 4.60/4.76					

V/L CALCULATIONS

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: 5.77						End Pressure: 5.78					
1	1	1.00		87	206773	0.000	4.566	4.57	33.46	8.19	0.000	0.560	0.91	0.97	0.06	9:46 AM
2	1	1.00		87	206773	0.000	4.559	4.56	32.78	8.34	0.000	0.551	0.90	0.89	-0.01	9:48 AM
3	1	1.00		87	206773	0.000	4.561	4.56	32.78	8.35	0.000	0.540	0.88	0.93	0.05	9:50 AM
1	2	1.05		87	206767	0.000	4.553	4.55	32.48	8.41	0.000	0.603	0.99	1.01	0.02	9:56 AM
1	7	0.99		87	3705041	0.000	4.555	4.56	33.91	8.06	0.000	0.553	0.90	0.89	-0.01	9:59 AM
2	7	0.99		87	3705041	0.000	4.549	4.55	33.80	8.08	0.000	0.553	0.90	0.86	-0.04	10:02 AM
3	7	0.99		87	3705041	0.000	4.547	4.55	33.92	8.04	0.000	0.553	0.90	0.90	0.00	10:04 AM
1	8	1.24		87	3705045	0.000	4.553	4.55	33.93	8.05	0.000	0.695	1.14	1.14	0.00	10:07 AM
1	6	1.15		87	206772	0.000	4.552	4.55	32.78	8.33	0.000	0.677	1.11	1.12	0.01	10:11 AM
1	5	0.86		87	206765	0.000	4.575	4.58	32.78	8.37	0.000	0.582	0.95	0.94	-0.01	10:24 AM
1	4	0.97		87	3705043	0.000	4.552	4.55	32.09	8.51	0.000	0.588	0.96	0.99	0.03	10:28 AM
1	3	0.97		87	3805311	0.000	4.568	4.57	32.96	8.32	0.000	0.582	0.95	0.98	0.03	10:31 AM
1	3	0.97		91	3805311	0.000	4.537	4.54	34.36	7.92	0.000	0.580	0.95	0.95	0.00	10:42 AM
1	4	0.97		91	3705043	0.000	4.570	4.57	35.04	7.83	0.000	0.566	0.92	0.91	-0.01	10:47 AM
2	4	0.97		91	3705043	0.000	4.569	4.57	34.46	7.96	0.000	0.560	0.91	0.89	-0.02	10:49 AM
3	4	0.97		91	3705043	0.000	4.558	4.56	34.46	7.94	0.000	0.556	0.91	0.85	-0.06	10:51 AM
1	2	1.05		91	206767	0.000	4.567	4.57	33.30	8.23	0.000	0.604	0.98	1.02	0.04	10:55 AM
1	1	1.00		91	206773	0.000	4.546	4.55	34.65	7.87	0.000	0.547	0.90	0.92	0.02	10:58 AM
2	1	1.00		91	206773	0.000	4.575	4.58	34.59	7.94	0.000	0.534	0.87	0.84	-0.03	11:00 AM
3	1	1.00		91	206773	0.000	4.531	4.53	34.30	7.93	0.000	0.530	0.87	0.83	-0.04	11:02 AM
1	8	1.24		91	3705045	0.000	4.562	4.56	33.98	8.06	0.000	0.754	1.23	1.17	-0.06	11:09 AM
2	8	1.24		91	3705045	0.000	4.560	4.56	34.06	8.03	0.000	0.728	1.19	1.13	-0.06	11:12 AM
3	8	1.24		91	3705045	0.000	4.568	4.57	33.80	8.11	0.000	0.714	1.16	1.11	-0.05	11:15 AM
1	7	0.99		91	3705041	0.000	4.558	4.56	34.42	7.95	0.000	0.575	0.94	0.93	-0.01	11:17 AM
2	7	0.99		91	3705041	0.000	4.546	4.55	34.21	7.97	0.000	0.573	0.94	0.87	-0.07	11:21 AM
3	7	0.99		91	3705041	0.000	4.551	4.55	34.42	7.93	0.000	0.573	0.94	0.97	0.03	11:23 AM
1	5	0.86		91	206765	0.000	4.561	4.56	34.09	8.03	0.000	0.516	0.84	0.85	0.01	11:26 AM
2	5	0.86		91	206765	0.000	4.573	4.57	34.12	8.04	0.000	0.534	0.87	0.85	-0.02	11:29 AM
3	5	0.86		91	206765	0.000	4.558	4.56	34.04	8.03	0.000	0.534	0.87	0.87	0.00	11:30 AM
1	6	1.15		91	206772	0.000	4.552	4.55	33.48	8.16	0.000	0.662	1.08	1.09	0.01	11:33 AM
					Post-Test Leak Check - Start Pressure: 5.15						End Pressure: 5.10					

V/L CALCULATIONS

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: +5.16 "W.C.					End Pressure: +5.15 "W.C.						
1	12			87	2406023	0.000	4.656	4.656	39.97	6.99	4991.67	4992.28	0.98	1.01	0.03	11:21 AM
2	10			87	2406024	0.000	4.639	4.639	33.70	8.26	4992.28	4992.93	1.05	1.06	0.01	11:25 AM
3	8			87	2406015	0.000	4.645	4.645	35.74	7.80	4992.93	4993.49	0.90	0.84	-0.06	11:28 AM
4	7	1.05		87	406060	0.000	4.676	4.676	36.25	7.74	4993.49	4994.14	1.04	1.05	0.01	11:32 AM
5	9	1.03		87	5205238	0.000	4.616	4.616	33.54	8.26	4994.14	4994.79	1.05	1.06	0.01	11:35 AM
6	11	1.01		87	4805411	0.000	4.740	4.740	38.54	7.38	4994.79	4995.38	0.93	0.95	0.02	11:38 AM
7	12			91	2406023	0.000	4.683	4.683	35.48	7.92	4995.38	4995.96	0.93	0.96	0.03	11:51 AM
8	10			91	2406024	0.000	4.654	4.654	35.90	7.78	4995.96	4996.59	1.01	1.04	0.03	11:53 AM
9	8			91	2406015	0.000	4.717	4.717	36.61	7.73	4996.59	4997.17	0.92	0.96	0.04	11:56 AM
10	7	1.05		91	406060	0.000	4.833	4.833	37.39	7.76	4997.17	4997.85	1.05	1.09	0.04	11:59 AM
11	9	1.03		91	5205238	0.000	4.707	4.707	34.61	8.16	4997.85	4998.50	1.03	1.07	0.04	12:02 PM
12	11	1.01		91	4805411	0.000	4.642	4.642	35.31	7.89	4998.50	4999.09	0.95	0.96	0.01	12:04 PM
13	6			87	2406016	0.000	4.657	4.657	34.86	8.02	4999.09	4999.67	0.93	1.01	0.08	12:18 PM
14	4			87	405085	0.000	4.607	4.607	35.08	7.88	4999.67	5000.24	0.93	0.96	0.03	12:21 PM
16	1	0.99		87	2406011	0.000	4.638	4.638	37.30	7.46	5000.74	5001.35	0.98	0.98	0.00	12:31 PM
17	3	1.06		87	406068	0.000	4.674	4.674	36.01	7.79	5001.35	5001.98	1.01	1.00	-0.01	12:34 PM
18	5	0.99		87	206198	0.000	4.620	4.620	37.57	7.38	5001.98	5002.58	0.97	1.03	0.06	12:37 PM
19	6			91	2406016	0.000	4.683	4.683	35.68	7.88	5002.58	5003.18	0.96	0.98	0.02	12:51 PM
20	4			91	405085	0.000	4.636	4.636	35.54	7.83	5003.18	5003.77	0.95	0.98	0.03	12:53 PM
22	1	0.99		91	2406011	0.000	4.628	4.628	35.57	7.81	5003.77	5004.40	1.02	1.02	0.00	12:56 PM
23	3	1.06		91	406068	0.000	4.638	4.638	35.93	7.75	5004.40	5005.03	1.02	1.05	0.03	12:59 PM
24	5	0.99		91	206198	0.000	4.619	4.619	36.26	7.64	5005.03	5005.62	0.96	0.97	0.01	1:01 AM
					Post-Test Leak Check - Start Pressure: 5.27					End Pressure: 5.28						

V/L CALCULATIONS

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: 5.50" WC					End Pressure: 4.83" WC						
1	8	0.97		87	3305003	0.000	4.656	4.656	32.28	8.65	13321.85	13322.50	1.05	0.86	-0.19	9:55 AM
2	8	0.97		89	3305003	0.000	4.571	4.571	30.06	9.12	13322.50	13323.18	1.11	1.02	-0.09	10:01 AM
3	8	0.97		91	3305003	0.000	4.567	4.567	31.63	8.66	13323.18	13323.85	1.10	1.11	0.01	10:06 AM
4	10	0.90		87	4905246	0.000	4.587	4.587	30.62	8.99	13323.85	13324.49	1.05	1.08	0.03	10:11 AM
5	10	0.90		89	4905246	0.000	4.578	4.578	29.12	9.43	13324.49	13325.12	1.03	1.07	0.04	10:16 AM
6	10	0.90		91	4905246	0.000	4.561	4.561	31.22	8.77	13325.12	13325.73	1.00	1.04	0.04	10:19 AM
7	3	1.08		87	506133	0.000	4.565	4.565	31.07	8.82	13325.74	13326.39	1.07	1.10	0.03	10:27 AM
8	3	1.08		89	506133	0.000	4.595	4.595	29.21	9.44	13326.39	13327.04	1.06	1.12	0.06	10:30 AM
9	3	1.08		91	506133	0.000	4.570	4.570	30.88	8.88	13327.04	13327.71	1.10	1.11	0.01	10:33 AM
10	1	1.00		87	4905243	0.000	4.565	4.565	31.41	8.72	13327.71	13328.39	1.12	1.17	0.05	10:38 AM
							Post-Test Leak Check - Start Pressure: 5.50" WC				End Pressure: 5.09" WC					

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: 5.20					End Pressure: 4.97						
1	9	1.14	1.19	87	3205011	0.000	4.595	4.60	35.03	7.87	161.09	161.84	1.24	1.30	0.06	9:43 AM
2	9	1.14	1.19	91	3205011	0.000	4.679	4.68	31.10	9.03	161.84	162.60	1.23	1.30	0.07	9:46 AM
3	12	1.09	1.12	87	4705137	0.000	4.634	4.63	34.37	8.09	163.30	164.04	1.21	1.26	0.05	9:58 AM
4	12	1.09	1.12	91	4705137	0.000	4.651	4.65	32.22	8.66	164.04	164.78	1.21	1.23	0.02	10:03 AM
5	8	1.11	1.12	87	4405453	0.000	4.616	4.62	35.44	7.81	164.78	165.47	1.14	1.18	0.04	10:10 AM
6	6	1.11	1.10	87	3705046	0.000	4.651	4.65	36.21	7.71	165.47	166.20	1.19	1.26	0.07	10:18 AM
7	2	1.08	1.10	87	3706024	0.000	4.622	4.62	36.32	7.64	166.20	166.86	1.08	1.06	-0.02	10:35 AM
8	2	1.08	1.10	91	3706024	0.000	4.674	4.67	32.31	8.68	166.86	167.56	1.14	1.13	-0.01	10:38 AM
9	3	1.05	1.14	87	3705522	0.000	4.594	4.59	33.13	8.32	167.56	168.24	1.12	1.17	0.05	10:43 AM
10	3	1.05	1.14	91	3705522	0.000	4.761	4.76	32.31	8.84	168.24	168.90	1.05	1.04	-0.01	10:47 AM
							Post-Test Leak Check - Start Pressure: 5.22				End Pressure: 4.89					

V/L CALCULATIONS

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: 5.27					End Pressure: 5.29						
1	3	1.01		87	406293	0.000	4.574	4.57	30.86	8.89	0.000	0.697	1.13	1.15	0.02	9:22 AM
1	4	0.84		87	3705043	0.000	4.545	4.55	31.10	8.77	0.000	0.545	0.89	0.94	0.05	9:25 AM
2	4	0.84		87	3705043	0.000	4.554	4.55	31.48	8.68	0.000	0.549	0.90	0.87	-0.03	9:27 AM
3	4	0.84		87	3705043	0.000	4.571	4.57	31.17	8.80	0.000	0.549	0.89	0.86	-0.03	9:28 AM
1	7	1.00		87	3705041	0.000	4.558	4.56	32.34	8.46	0.000	0.566	0.92	0.90	-0.02	9:32 AM
2	7	1.00		87	3705041	0.000	4.581	4.58	32.78	8.38	0.000	0.547	0.89	0.97	0.08	9:35 AM
3	7	1.00		87	3705041	0.000	4.552	4.55	32.29	8.46	0.000	0.562	0.92	0.91	-0.01	9:37 AM
1	8	1.19		87	3705645	0.000	4.560	4.56	32.46	8.43	0.000	0.699	1.14	1.18	0.04	9:43 AM
1	6	1.13		87	206772	0.000	4.554	4.55	31.28	8.74	0.000	0.682	1.11	1.09	-0.02	9:47 AM
1	5	0.93		87	206768	0.000	4.548	4.55	31.71	8.61	0.000	0.525	0.86	0.83	-0.03	9:52 AM
2	5	0.93		87	206768	0.000	4.563	4.56	31.37	8.73	0.000	0.532	0.87	0.85	-0.02	9:59 AM
3	5	0.93		87	206768	0.000	4.559	4.56	31.12	8.79	0.000	0.525	0.86	0.82	-0.04	10:01 AM
1	2	1.06		87	206767	0.000	4.552	4.55	30.41	8.98	0.000	0.597	0.98	1.04	0.06	10:04 AM
1	1	0.98		87	206773	0.000	4.528	4.53	30.84	8.81	0.000	0.540	0.89	0.93	0.04	10:06 AM
2	1	0.98		87	206773	0.000	4.612	4.61	31.48	8.79	0.000	0.549	0.89	0.92	0.03	10:08 AM
3	1	0.98		87	206773	0.000	4.551	4.55	31.15	8.77	0.000	0.542	0.89	0.89	0.00	10:10 AM
1	1	0.98		91	206773	0.000	4.527	4.53	34.56	7.86	0.000	0.566	0.93	0.95	0.02	10:20 AM
2	1	0.98		91	206773	0.000	4.543	4.54	34.59	7.88	0.000	0.551	0.90	0.92	0.02	10:22 AM
3	1	0.98		91	206773	0.000	4.533	4.53	34.43	7.90	0.000	0.543	0.89	0.91	0.02	10:25 AM
1	2	1.06		91	206767	0.000	4.542	4.54	33.54	8.13	0.000	0.597	0.98	0.99	0.01	10:27 AM
1	4	0.84		91	3705043	0.000	4.540	4.54	34.46	7.90	0.000	0.538	0.88	0.91	0.03	10:30 AM
2	4	0.84		91	3705043	0.000	4.560	4.56	34.55	7.92	0.000	0.529	0.86	0.82	-0.04	10:32 AM
3	4	0.84		91	3705043	0.000	4.544	4.54	34.78	7.84	0.000	0.523	0.86	0.78	-0.08	10:34 AM
1	3	1.01		91	406293	0.000	4.538	4.54	34.37	7.92	0.000	0.575	0.94	0.92	-0.02	10:37 AM
2	3	1.01		91	406293	0.000	4.547	4.55	34.28	7.96	0.000	0.569	0.93	0.87	-0.06	10:39 AM
3	3	1.01		91	406293	0.000	4.552	4.55	34.34	7.95	0.000	0.569	0.93	0.86	-0.07	10:40 AM
1	7	1.00		91	3705041	0.000	4.535	4.54	34.91	7.79	0.000	0.545	0.89	0.84	-0.05	10:43 AM
2	7	1.00		91	3705041	0.000	4.548	4.55	35.09	7.78	0.000	0.547	0.89	0.86	-0.03	10:45 AM
3	7	1.00		91	3705041	0.000	4.531	4.53	35.28	7.71	0.000	0.547	0.90	0.86	-0.04	10:47 AM
1	8	1.19		91	3705645	0.000	4.565	4.57	33.99	8.06	0.000	0.680	1.11	1.09	-0.02	10:50 AM
1	5	0.93		91	206768	0.000	4.571	4.57	34.05	8.05	0.000	0.555	0.90	0.91	0.01	11:03 AM
2	5	0.93		91	206768	0.000	4.528	4.53	33.65	8.07	0.000	0.540	0.89	0.90	0.01	11:05 AM
3	5	0.93		91	206768	0.000	4.508	4.51	33.53	8.07	0.000	0.530	0.87	0.88	0.01	11:08 AM
1	6	1.13		91	206772	0.000	4.539	4.54	33.41	8.15	0.000	0.671	1.10	1.15	0.05	11:11 AM
					Post-Test Leak Check - Start Pressure: 5.30					End Pressure: 5.34						

V/L CALCULATIONS

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: +5.10 "W.C.					End Pressure: +4.95 "W.C.						
1	12			87	2406023	0.000	4.673	4.673	43.89	6.39	5006.30	5006.91	0.98	0.97	-0.01	11:38 AM
2	10			87	2406024	0.000	4.732	4.732	34.50	8.23	5006.91	5007.56	1.03	1.10	0.07	11:41 AM
3	8			87	2406015	0.000	4.640	4.640	37.66	7.39	5007.56	5008.16	0.97	0.99	0.02	11:45 AM
4	7	1.05		87	406060	0.000	4.681	4.681	37.83	7.42	5008.16	5008.81	1.04	1.09	0.05	11:48 AM
5	9	1.04		87	1516019	0.000	4.641	4.641	34.35	8.11	5008.81	5009.45	1.03	1.07	0.04	11:50 AM
7	6			87	2406016	0.000	4.669	4.669	38.49	7.28	5009.98	5010.69	1.14	0.94	-0.20	12:09 PM
8	4			87	2406021	0.000	4.658	4.658	37.68	7.42	5010.69	5011.41	1.16	1.18	0.02	12:13 PM
9	2			87	906078	0.000	4.639	4.639	36.97	7.53	5011.41	5011.99	0.94	0.96	0.02	12:17 PM
10	1	0.95		87	2406011	0.000	4.632	4.632	39.52	7.03	5011.99	5012.57	0.94	0.92	-0.02	12:20 PM
11	3	1.04		87	406058	0.000	4.640	4.640	36.68	7.59	5012.57	5013.18	0.98	1.07	0.09	12:26 PM
12	5	0.9		87	3106054	0.000	4.645	4.645	40.00	6.97	5013.18	5013.77	0.95	0.96	0.01	12:29 PM
333	6			87	2406011	0.000	4.654	4.654	38.40	7.27	5013.77	5014.38	0.98	0.97	-0.01	12:33 PM
							Post-Test Leak Check - Start Pressure: 5.01				End Pressure: 4.91					

Run	Pump #	ISD V/L Daily Average	ISD V/L Weekly Average	Fuel Grade	Nozzle Name / Serial #	Initial Dispenser Totalizer, Gallons	Final Dispenser Totalizer Gallons	Total Gas Pumped Gallons	Time Seconds	Flow Rate, gpm	Initial Meter Reading ft3	Final Meter Reading ft3	Calculated V/L (A)	ISD V/L Instantaneous (B)	V/L Difference (A-B)	Time of Each Test
Meter Correction Factor:					**Pre-Test Leak Check -** Start Pressure: 5.24" WC					End Pressure: 4.73" WC						
1	9	1.02		87	3305005	0.000	4.524	4.52	33.12	8.20	12073.54	12074.16	1.03	1.07	0.04	9:50 AM
2	9	1.02		89	3305005	0.000	4.542	4.54	31.00	8.79	12074.16	12074.83	1.10	1.10	0.00	9:54 AM
3	9	1.02		91	3305005	0.000	4.531	4.53	31.53	8.62	12074.83	12075.49	1.09	1.10	0.01	9:57 AM
4	8	0.95		87	3305003	0.000	4.555	4.56	33.19	8.23	12075.50	12076.17	1.10	1.14	0.04	10:07 AM
5	8	0.95		89	3305003	0.000	4.559	4.56	30.85	8.87	12076.17	12076.86	1.13	1.17	0.04	10:09 AM
6	8	0.95		91	3305003	0.000	4.563	4.56	32.06	8.54	12076.86	12077.56	1.15	1.13	-0.02	10:12 AM
7	2	0.84		87	4405141	0.000	4.543	4.54	33.41	8.16	12077.56	120.78.17	1.01	1.01	0.00	10:20 AM
8	2	0.84		87	4405141	0.000	4.563	4.56	33.25	8.23	12078.18	12078.78	0.98	1.04	0.06	10:24 AM
9	2	0.84		87	4405141	0.000	4.532	4.53	33.57	8.10	12078.78	12079.39	1.01	1.04	0.03	10:27 AM
10	1	1.08		87	4905243	0.000	4.588	4.59	33.69	8.17	12079.39	12080.12	1.19	1.18	-0.01	10:33 AM
11	1	1.08		89	4905243	0.000	4.565	4.57	31.79	8.62	12080.12	12080.85	1.20	1.21	0.01	10:37 AM
12	1	1.08		91	4905243	0.000	4.554	4.55	31.19	8.76	12080.85	12081.58	1.20	1.23	0.03	10:40 AM
							Post-Test Leak Check - Start Pressure: 5.13" WC				End Pressure: 4.66" WC					

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
2005	Pontiac	Grand Prix	9	9:56:06 AM	14.775	0.40	YES	YES
1994	Pontiac	Bonneville	9	10:03:31 AM	1.654	1.07	NO	YES
2005	Lexus	IS300	9	10:09:30 AM	15.159	0.26	YES	YES
2004	Chevy	Trailblazer	12	10:16:45 AM	5.163	0.34	YES	YES
2004	Ford	Mustang	10	10:20:50 AM	12.853	0.44	YES	YES
2006	Toyota	Avalon	11	10:40:54 AM	6.213	1.13	YES	**NO**
1992	Toyota	4Runner	1	10:53:51 AM	3.227	1.00	NO	YES
2005	Toyota	Sienna	10	10:58:31 AM	8.775	0.46	YES	YES
2003	PT Cruiser	4.2L Turner	9	11:15:35 AM	6.710	0.66	YES	**NO**
1999	Ford	F150	2	9:53:00 AM	6.910	0.82	NO	YES
2005	Ford	Escape	6	9:59:00 AM	14.119	0.38	YES	YES
2003	Mitsubishi	Galant	7	10:07:00 AM	10.548	0.47	YES	YES
1996	Buick	3800	7	10:13:00 AM	9.506	1.11	NO	YES
1995	Saturn		7	10:38:00 AM	8.285	1.13	NO	YES
2003	Honda	CR-V	12	10:43:00 AM	12.466	0.39	YES	YES
2001	Buick	Regal	11	10:45:00 AM	8.067	1.23	YES	**NO**
2000	Volkswagen	Jetta	4	10:49:00 AM	14.438	0.27	YES	YES
2001	Buick	Ultra	12	10:53:00 AM	10.002	0.42	YES	YES
1991	Toyota	MR2	11	10:59:00 AM	9.681	1.01	NO	YES
2005	Nissan	Titan	4	11:03:00 AM	21.620	0.30	YES	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
2004	Ford	Mustang	2	8:49:00 AM	13.00	0.25	YES	YES
2004	BMW	X5	4	9:05:00 AM	14.73	0.27	YES	YES
2000	Chrysler	Cirrus	6	9:10:00 AM	14.93	0.22	YES	YES
2001	Nissan	Sentra GXE	7	9:14:00 AM	4.75	0.33	YES	YES
2006	Volvo	S40	7	9:19:00 AM	9.27	0.83	YES	**NO**
2005	Toyota	Matrix	1	9:39:00 AM	10.40	0.24	YES	YES
1995	Ford	F150 XL	11	10:00:00 AM	3.17	0.96	NO	YES
2004	Volkswagon	Jetta	6	8:51:00 AM	12.63	0.20	YES	YES
1990	Chrysler	Grand Marquis	1	9:03:00 AM	6.33	1.11	NO	YES
2002	Toyota	Corolla	8	9:05:00 AM	11.40	0.35	YES	YES
1997	Chevrolet	S-10	2	9:14:00 AM	6.33	0.96	NO	YES
2004	Honda	Civic	2	9:20:00 AM	10.04	0.25	YES	YES
2000	Volkswagon	Jetta	11	9:45:00 AM	6.33	0.32	YES	YES
2000	Chevrolet	Alero	8	9:55:00 AM	9.50	0.25	YES	YES
1996	Toyota	Tocoma	12	10:16:00 AM	15.78	0.96	NO	YES

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
1989	Cadillac	Seville	6	9:52:20 AM	14.68	1.17	NO	YES
2000	Ford	Explorer	1	10:09:10 AM	3.17	0.90	NO	YES
2003	Honda	Accord	6	10:11:12 AM	5.29	0.36	YES	YES
2004	Honda	Pilot	7	10:13:48 AM	13.06	0.32	YES	YES
2005	Toyota	Sienna	2	10:21:25 AM	10.11	0.39	YES	YES
2001	Honda	Civic	8	10:25:30 AM	4.75	0.36	YES	YES
2001	BMW	Z3	7	10:26:48 AM	10.90	0.19	YES	YES
1993	Honda	Civic	7	10:32:28 AM	6.14	0.89	NO	YES
1996	Cheverolet	Tahoe	1	10:34:20 AM	3.17	0.90	NO	YES
1987	Lincoln	Continental	5	10:35:40 AM	12.66	0.84	NO	YES
2004	Honda	CRV	6	10:40:05 AM	13.99	0.32	YES	YES
2001	Cadillac	Seville	4	10:43:15 AM	6.41	0.23	YES	YES
1990	Honda	Accord	8	10:46:55 AM	14.64	1.15	NO	YES
2003	Nissan	Xterra	5	10:49:55 AM	7.67	1.04	YES	**NO**
1993	Ford	Probe	2	11:08:10 AM	3.17	0.94	NO	YES
1992	Lexus	ES300	6	12:00:05 PM	11.08	0.50	NO	**NO**
1989	Volkswagon	Cabriolet	5	12:05:58 PM	3.17	0.35	NO	**NO**
1992	Mazda	MPV	7	12:30:04 PM	10.47	0.92	NO	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
1988	Honda	Civic	9	10:48:00 AM	6.258	1.06	NO	YES
2000	Toyota	Camry	7	10:50:00 AM	9.382	0.26	YES	YES
2003	Toyota	Camry XLE	11	10:53:00 AM	5.923	0.32	YES	YES
1992	Chevrolet	Camaro	4	11:05:00 AM	12.505	0.73	NO	YES
2002	Pontiac	Sunfire	3	11:08:00 AM	6.392	0.33	YES	YES
1995	Ford	Escort	4	11:12:00 AM	3.126	0.51	NO	YES
2003	Kia	Sorento	3	11:14:00 AM	6.252	1.28	YES	**NO**
1987	Honda	Accord	4	11:18:00 AM	11.351	0.93	NO	YES
1992	Nissan	Pathfinder	3	11:22:00 AM	3.126	0.90	NO	YES
2004	Ford	Explorer	3	11:25:00 AM	18.678	1.27	YES	**NO**
1991	Honda	Prelude	11	11:31:00 AM	6.252	0.95	NO	YES
2003	Ford	Focus	9	11:44:00 AM	8.913	0.21	YES	YES
1986	Mazda	B2000	3	10:46:00 AM	4.600	1.19	NO	YES
2004	Honda	Pilot	4	10:51:00 AM	6.200	0.25	YES	YES
1990	Ford	F-250	1	11:04:00 AM	6.800	1.05	NO	YES
2000	Honda	Civic	2	11:10:00 AM	11.700	1.20	YES	**NO**
1993	Honda	Civic	11	11:16:00 AM	3.100	0.84	NO	YES
1983	Honda	Accord	5	11:33:00 AM	3.100	0.96	NO	YES
1991	Chevrolet	Camaro	8	11:49:00 AM	9.300	1.03	NO	YES
1993	Nissan	Sentra	7	11:52:00 AM	6.200	1.02	NO	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
1999	Ford	Explorer	3	10:09:00 AM	12.930	1.05	NO	YES
2007	Totota	Camry	7	10:10:00 AM	14.889	0.21	YES	YES
1997	Jaguar	X16	10	10:42:00 AM	10.470	0.82	NO	YES
2002	Ford	F150	10	11:04:00 AM	22.734	0.97	NO	YES
2003	Acura		3	11:05:00 AM	13.400	0.30	YES	YES
2006	BMW	750Li	3	11:10:00 AM	22.867	0.25	YES	YES
1997	Honda	CRV	8	11:12:00 AM	6.062	1.05	NO	YES
1994	Pontiac	Grand Prix	7	11:16:00 AM	5.001	1.05	NO	YES
2004	Nissan	Altima	7	11:20:00 AM	6.015	0.47	YES	YES
1997	Ford	Explorer	9	11:26:00 AM	9.757	0.89	NO	YES
2000	Lexus	RX300	4	11:29:00 AM	14.585	0.26	YES	YES
2005	Toyota	Camry	1	11:34:00 AM	9.093	0.37	YES	YES
1997	Ford	Explorer	9	11:37:00 AM	15.153	0.86	NO	YES
1993	Ford	Mustang	7	11:38:00 AM	6.062	0.98	NO	YES
2001	Honda	Accord	8	11:42:00 AM	13.987	0.24	YES	YES
2002	Honda	Accord	4	11:48:00 AM	13.049	0.33	YES	YES
1995	Acura	SLX	9	11:51:00 AM	8.573	0.89	NO	YES
1995	Nissan	Hard Body	7	11:51:00 AM	4.860	1.05	NO	YES
1997	Ford	Econoline 250	4	11:59:00 AM	8.239	0.92	NO	YES
1994	Porsche	Speedster	2	11:59:00 AM	5.000	0.84	NO	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assessment?
2000	Mitsubishi	Galant	6	10:57:00	8.33	0.42	yes	yes
1998	Chevrolet	Cheyenne	6	11:07:00	24.27	0.98	no	yes
2004	Nissan	Altima	5	11:05:00	6.67	0.50	yes	yes
2006	GMC	Sierra	4	11:09:00	21.57	0.20	yes	yes
2006	Toyota	Avalon	2	11:10:00	4.98	0.45	yes	yes
1997	Nissan	Quest	8	11:18:00	10.00	0.97	no	yes
1998	Toyota	T100 PU	5	11:24:00	6.45	0.74	no	yes
2000	Toyota	Echo	7	11:24:00	6.67	0.26	yes	yes
2003	Hyundai	Sante Fe	9	11:30:00	10.00	0.29	yes	yes
2004	GMC	Yukon	4	11:31:00	10.86	0.32	yes	yes
1997	Honda	Accord	6	11:34:00	6.67	0.97	no	yes
2000	Mercury	Mtneer	1	11:39:00	13.33	1.02	no	yes
1972	Pontiac	Lamans	4	11:45:0076	10.00	1.04	no	yes
2000	Dodge	Stratus	9	11:56:00	14.06	0.27	yes	yes

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
1996	Toyota	Tacoma	10	11:47:00 AM	6.90	1.01	NO	YES
2005	Chevy	Impala	5	11:53:00 AM	5.52	0.44	YES	YES
1996	Saturn		1	11:59:00 AM	8.77	1.18	NO	YES
2005	Infiniti	G35	2	12:04:00 PM	15.34	1.09	YES	**NO**
1984	Toyota	4Runner	1	12:12:00 PM	5.06	1.16	NO	YES
2004	Honda	Civic	7	12:14:00 PM	9.55	0.30	YES	YES
2003	Honda	Odyssey	12	11:53:00 AM	14.48	0.23	YES	YES
2004	GMC	Sierra	11	11:56:00 AM	22.94	0.54	YES	**NO**
2000	Audi	A4	12	12:02:00 PM	9.22	0.24	YES	YES
1996	Buick	Park Avenue	10	12:13:00 PM	8.68	0.71	NO	YES
1997	Jeep	Grand Cherokee	11	12:16:00 PM	7.30	1.10	NO	YES
1996	Acura	3.2 TL	11	12:20:00 PM	7.88	1.06	NO	YES
2003	Ford	Windstar	3	11:56:00 AM	23.23	0.30	YES	YES
1995	Ford	Crown Victoria	6	11:55:00 AM	17.37	1.16	NO	YES
2004	GMC	Denali Yukon	11	12:10:00 PM	6.45	0.28	YES	YES
2000	Toyota	Avalon	2	12:15:00 PM	10.42	1.09	YES	**NO**
2003	Lincoln	LS	6	12:20:00 PM	3.23	0.80	YES	**NO**

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
2005	Nissan	Murano	7	9:45:00 AM	16.59	0.27	YES	YES
2006	BMW	650I	6	9:54:04 AM	15.80	0.34	YES	YES
2000	Cadillac	Deville	1	10:01:45 AM	9.56	0.26	YES	YES
1992	Ford	Crown Victoria	1	10:08:11 AM	7.08	0.90	NO	YES
2001	Mercedes Benz	C230	6	10:16:35 AM	7.71	1.15	YES	**NO**
2005	Toyota	Tacoma	5	10:20:50 AM	12.35	1.12	YES	**NO**
2002	Chrysler	Sebring	1	10:38:11 AM	9.89	0.30	YES	YES
2003	Volkswagon	Jetta	3	10:42:20 AM	13.18	0.26	YES	YES
1996	Chevrolet	Camaro	1	11:07:45 AM	3.29	1.04	NO	YES
1996	Chevrolet	S-10	9	11:26:50 AM	3.29	0.88	NO	YES
2004	Chevrolet	Impala	8	11:35:13 AM	15.13	0.20	YES	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
1993	Lexus	ES400	3	9:00:01 AM	11.37	0.95	NO	YES
1993	Toyota	Pickup	5	9:02:20 AM	14.15	0.93	NO	YES
1995	Ford	Contour	7	9:07:25 AM	11.57	0.95	NO	YES
2002	Toyota	Prius	1	9:10:50 AM	7.32	0.54	YES	YES
2005	Dodge	Neon	4	9:11:00 AM	5.80	0.72	YES	**NO**
2002	Mitsubishi	GT	5	9:17:43 AM	3.25	0.41	YES	YES
1996	Honda	Civic	8	9:18:00 AM	8.12	1.17	NO	YES
2003	Toyota	Altis	4	9:19:35 AM	10.39	0.96	YES	**NO**
2006	Chrysler	300 Hemi	7	9:25:15 AM	17.44	0.15	YES	YES
1996	Nissan	Maxima	6	9:26:22 AM	16.72	1.19	NO	YES
2006	Toyota	Prius	7	9:28:15 AM	9.22	0.27	YES	YES
2005	Mercedes	C230 Kompressor	5	9:29:50 AM	10.31	1.02	YES	**NO**
2005	Honda	Accord	4	9:36:05 AM	14.30	0.38	YES	YES
1985	Oldsmobile	Cutlass Supreme	7	9:39:47 AM	3.25	0.91	NO	YES
2004	Saturn	VUE	3	9:40:52 AM	12.22	0.23	YES	YES
1984	Toyota	Cressida	4	9:45:25 AM	6.40	0.92	NO	YES
1989	Cheverolet	Celebrity	8	9:50:56 AM	3.25	1.14	NO	YES
1988	Sierra	GMC	5	9:55:08 AM	21.99	0.89	NO	YES
1989	Toyota	Camry	2	10:14:08 AM	9.49	1.05	NO	YES
1986	Mercedes	190E	7	10:20:45 AM	4.74	0.98	NO	YES
1988	Toyota	Corolla	7	10:25:23 AM	6.97	0.96	NO	YES
2000	Cheverolet	Silerado 2500	7	10:31:18 AM	24.68	0.93	NO	YES
2007	Ford	Taurus	7	10:44:05 AM	9.31	0.31	YES	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
2000	Honda	Civic	7	10:22:00 AM	8.300	0.24	YES	YES
1996	Ford	Aerostar	7	10:27:00 AM	6.200	1.03	NO	YES
2005	Honda	Accord	6	10:30:00 AM	6.200	0.40	YES	YES
1995	Dodge	Caravan	9	10:31:36 AM	6.392	1.03	NO	YES
1992	Nissan	Maxima	2	10:33:00 AM	6.200	1.02	NO	YES
2004	Nissan	Altima	9	10:38:22 AM	6.291	1.21	YES	**NO**
1993	Ford	Escort	5	10:43:00 AM	6.200	0.96	NO	YES
1995	Ford	Explorer	6	10:48:00 AM	12.200	1.03	NO	YES
2002	Nissan	Maxima	9	10:52:25 AM	7.550	0.63	YES	YES
2006	Nissan	Titan	7	10:56:50 AM	15.728	0.46	YES	YES
1992	Nissan	Stanza	4	10:58:00 AM	6.200	0.94	NO	**NO**
1993	Toyota	Corolla	9	11:01:50 AM	6.291	0.22	NO	**NO**
2000	Cadillac	El Dorado	5	11:03:00 AM	11.500	0.27	YES	YES
1991	Mitsubishi	Eclipse	11	11:04:30 AM	6.291	0.95	NO	YES
2000	Ford	Ranger	7	11:08:45 AM	12.583	1.05	NO	YES
2005	Ford	Mustang	4	11:10:00 AM	12.700	0.94	YES	**NO**
1996	Cadillac	STS	1	11:13:15 AM	7.666	1.03	NO	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
1990	Nissan	Hard Body SE	8	11:03:00 AM	5.422	0.97	NO	YES
2004	Infiniti	G-35	8	11:10:00 AM	3.125	1.13	YES	**NO**
2001	BMW	330i	3	11:16:00 AM	14.215	1.16	YES	**NO**
1996	Ford	Thunderbird LX	1	11:23:00 AM	6.251	1.05	NO	YES
1996	Honda	Accord	10	11:25:00 AM	9.573	0.91	NO	YES
1998	Toyota	Camry	7	11:29:00 AM	10.789	0.30	YES	YES
1996	Nissan	200 SX	4	11:30:00 AM	4.688	0.95	NO	YES
1994	Toyota	Camry	2	11:32:00 AM	6.565	0.84	NO	YES
1992	Nissan	Hard Body	8	11:36:00 AM	5.410	1.00	NO	YES
1989	Toyota	Corolla	2	11:36:00 AM	8.164	0.83	NO	YES
2005	Chevrolet	Uplander LT	4	11:40:00 AM	17.350	1.18	YES	**NO**
1992	Audi	100 CS	3	11:43:00 AM	6.251	0.92	NO	YES
1992	Nissan	Hard Body	8	11:44:00 AM	6.126	0.97	NO	YES
2004	Toyota	Sienna	2	11:45:00 AM	12.953	0.27	YES	YES
1995	Mitsubishi	Montero	7	11:48:00 AM	15.629	1.04	NO	YES
2005	Dodge	Caravan	8	11:51:00 AM	9.727	0.20	YES	YES
2006	Scion	tC	1	11:58:00 AM	4.688	0.39	YES	YES
2003	BMW	530	4	12:02:00 PM	8.774	0.25	YES	YES
2005	Toyota	Matrix XR	9	12:07:00 PM	8.339	0.20	YES	YES
2004	Cadillac	DeVille	3	12:09:00 PM	11.020	1.21	YES	**NO**

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
2006	Jeep	Liberty 4x4	5	9:24:00 AM	17.84	0.23	YES	YES
2006	Saturn	Vue	5	9:45:00 AM	13.57	0.26	YES	YES
2006	GMC	Yukon	5	10:01:00 AM	17.88	0.25	YES	YES
1990	Chevrolet	Retro	2	10:06:00 AM	5.82	0.96	NO	YES
2006	Cadillac	CTS	1	10:20:00 AM	14.50	0.20	YES	YES
2004	Jeep	Cherokee	7	10:34:00 AM	7.76	0.36	YES	YES
2000	Ford	Expedition	8	10:56:00 AM	8.14	1.10	NO	YES
1994	Toyota	Corolla	4	11:11:00 AM	8.30	0.88	NO	YES
2006	Mazda	"6"	6	11:17:00 AM	7.20	0.25	YES	YES
1995	GMC	1500	8	11:33:00 AM	9.69	1.12	NO	YES
2005	Saturn	Vue	9	11:45:00 AM	3.88	0.35	YES	YES
1993	Ford	Mustang	11	12:07:00 PM	6.91	1.09	NO	YES
1995	Hyundia	Accent	12	12:12:00 PM	7.77	0.29	NO	**NO**
2005	Honda	Accord	8	12:36:00 PM	9.74	0.50	YES	YES
1995	Chevrolet	Suburban	6	12:44:00 PM	7.75	1.17	NO	YES
1994	GMC	Sierra	1	12:56:00 PM	22.12	1.04	NO	YES
2000	Chevrolet	Monte Carlo	10	1:02:00 AM	5.82	0.34	YES	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
2000	Nissan	Quest	2	9:00:15 AM	5.48	0.68	YES	YES
1998	Chevrolet	Silverado	1	9:05:08 AM	16.80	0.95	NO	YES
2001	Honda	Civic	4	9:07:40 AM	4.30	0.35	YES	YES
1990	Ford	Thunderbird	5	9:08:05 AM	3.65	0.83	NO	YES
2001	Honda	Odyssey	4	9:12:35 AM	14.18	0.30	YES	YES
2006	Chevrolet	Trailblazer	7	9:16:05 AM	11.05	0.52	YES	**NO**
2002	Honda	Odyssey	2	9:22:50 AM	11.20	0.28	YES	YES
1993	Toyota	Pickup	6	9:23:30 AM	9.19	1.19	NO	YES
1993	Toyota	Pickup	5	9:31:50 AM	5.48	0.87	NO	YES
1989	Ford	Bronco	3	9:42:55 AM	8.06	0.97	NO	YES
2006	Chrystler	300	4	9:48:02 AM	14.62	0.32	YES	YES
2003	BMW	330i	2	9:50:37 AM	4.20	0.27	YES	YES
2003	Ford	Windstar	1	9:54:11 AM	14.66	0.53	YES	**NO**
1991	Acura	Integra	4	9:56:38 AM	3.65	0.74	NO	YES
1990	Chevrolet	1500	3	10:10:26 AM	3.52	0.92	NO	YES
2004	BMW	525i	5	10:14:28 AM	15.53	0.55	YES	**NO**
1995	Lexus	ES300	5	10:24:00 AM	14.47	0.89	NO	YES
1983	GMC	Vandura	7	10:31:33 AM	9.13	0.88	NO	YES
1979	Toyota	Pickup	4	10:45:30 AM	5.48	0.80	NO	**NO**
2003	Toyota	Camry	4	10:50:25 AM	7.30	0.19	YES	YES
2005	Scion	xB	3	10:54:45 AM	9.21	0.26	YES	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
1996	Toyota	Avalon	2	10:17:00 AM	7.249	0.99	NO	YES
2000	Toyota	Corolla	4	10:19:00 AM	9.061	0.26	YES	YES
2005	Toyota	Tundra	6	10:26:00 AM	6.995	0.25	YES	YES
2000	Toyota	Camry LE	5	10:36:00 AM	7.249	0.24	YES	YES
2001	Mazda	Miata MX5	6	10:39:00 AM	8.990	0.69	YES	**NO**
1995	Ford	F-150	4	10:50:00 AM	14.498	1.17	NO	YES
1990	Chrysler	New Yorker	5	10:55:00 AM	6.306	0.87	NO	YES
2007	Toyota	Yaris	7	11:00:00 AM	7.300	0.76	YES	**NO**
1991	Acura	Integra LS	6	11:07:00 AM	3.625	0.98	NO	YES
2000	Toyota	Echo	4	11:15:00 AM	3.625	0.65	YES	**NO**
1996	Dodge	Dakota	6	11:22:00 AM	3.625	1.03	NO	YES
2004	Nissan	Sentra	5	11:26:00 AM	5.437	0.16	YES	YES
1985	Oldsmobile	Calais	7	10:19:00 AM	11.300	1.08	NO	YES
1993	Toyota	Del Sol	9	10:25:00 AM	10.800	1.05	NO	YES
2000	Honda	Accord LX	2	10:36:00 AM	3.600	0.43	YES	YES
2002	Honda	Accord	1	10:39:00 AM	13.600	0.28	YES	YES
2006	Toyota	Corolla	11	10:45:00 AM	10.900	0.36	YES	YES
1996	Ford	Taurus LX	4	10:56:00 AM	6.100	1.17	NO	YES
1986	Chevrolet	Silverado	7	11:10:00 AM	10.800	1.08	NO	YES
1986	Dodge	Dynasty	11	11:14:00 AM	3.000	0.99	NO	YES
1994	Nissan	Sentra	7	11:25:00 AM	7.200	1.03	NO	YES

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
2000	Jaguar	XKR	10	10:15:00 AM	11.200	0.22	YES	YES
1990	Nissan	Hardbody SE-V6	2	11:04:00 AM	5.257	0.82	NO	YES
1998	Chevrolet	Silverado 1-Ton	10	11:07:00 AM	21.429	0.86	NO	YES
2000	Ford	Ranger XLT	1	11:15:00 AM	7.306	1.08	NO	YES
2004	Jeep	Grand Cherokee	8	11:17:00 AM	18.620	0.64	YES	**NO**
2005	Jeep	Rambler	10	11:17:00 AM	12.804	0.25	YES	YES
1992	Toyota	Camary	8	11:23:00 AM	13.877	0.99	NO	YES
2000	Hyundai	Accent	1	11:32:00 AM	5.825	0.36	YES	YES
1993	Nissan	NX	1	11:41:00 AM	3.650	1.00	NO	YES
1992	Nissan	Hardbody SE-V6	9	11:45:00 AM	7.805	0.88	NO	YES
1995	Nissan	Hardbody SE-V6	2	11:48:00 AM	5.546	0.86	NO	**NO**
2000	Infinity	I-30	1	11:52:00 AM	5.013	0.36	YES	YES
2005	Accura	TSX	8	11:53:00 AM	15.010	0.20	YES	YES
2006	Ford	Mustang	2	11:56:00 AM	12.118	0.21	YES	YES
2003	Honda	Accord	9	11:59:00 AM	13.785	0.23	YES	YES
1996	Toyota	Land Cruiser	7	11:59:00 AM	21.414	1.05	NO	YES
2002	BMW	330i	1	12:06:00 PM	11.205	0.25	YES	YES
2004	Jeep	Grand Cherokee	10	12:14:00 PM	18.765	1.15	YES	**NO**

ORVR VEHICLE DETERMINATION DATA

Year	Make	Model	Fueling Point	Starting Dispensing Time	Gallons Dispensed	V/L from TLS	ORVR Vehicle?	Did ISD Make Correct Assesment?
1997	Dodge	Caravan	4	10:08:00 AM	3.60	0.92	NO	YES
2001	Saturn	SL	7	10:10:00 AM	8.69	0.23	YES	YES
2001	Toyota	Avalon	9	10:14:00 AM	13.14	0.66	YES	**NO**
2004	Mitsubishi	Montero Sport	11	10:17:00 AM	5.72	0.33	YES	YES
1994	Pontiac	GrandAm	4	10:20:00 AM	2.97	0.99	NO	YES
2006	Toyota	Avalon	9	10:45:00 AM	7.36	0.25	YES	YES
2006	Chrysler	300	9	10:58:00 AM	14.71	0.34	YES	YES
2001	Toyota	Solara	3	11:03:00 AM	11.45	0.38	YES	YES
1995	Mercedes Benz	SL500	11	11:14:00 AM	16.59	0.99	NO	YES
1997	Plymouth	Neon	6	10:13:00 AM	9.03	1.08	NO	YES
1993	Ford	Ranger	2	10:19:00 AM	3.85	0.97	NO	YES
2001	BMW	330i	12	10:39:00 AM	4.97	0.48	YES	YES
1997	Mercury	Villager	8	10:43:00 AM	4.64	0.75	NO	YES
2006	Honda	Odyssey	12	10:54:00 AM	17.16	0.25	YES	YES
2006	Honda	Civic	11	10:58:00 AM	8.42	0.41	YES	YES
1989	Toyota	22RE P/U	4	11:08:00 AM	8.78	0.95	NO	YES
2001	Ford	Taurus	6	11:12:00 AM	11.69	0.31	YES	YES

VAPOR PRESSURE SENSOR AMBIENT REFERENCE TEST

TEST 1

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	1	2

Pressure Sensor Serial Number	
Serial Number:	1227

Non-Calibrated Sensor Value		
Inches of Water Column:	0.099	Must be between +0.20 and -0.20

TEST 2

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	9	10

Pressure Sensor Serial Number	
Serial Number:	1232

Non-Calibrated Sensor Value		
In. of Water Column:	-0.021	Must be between +0.20 and -0.20

TEST 3

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	3	4

Pressure Sensor Serial Number	
Serial Number:	1163

Non-Calibrated Sensor Value		
Inches of Water Column:	0.037	Must be between +0.20 and -0.20

TEST 4

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	11	12

Pressure Sensor Serial Number	
Serial Number:	1258

Non-Calibrated Sensor Value		
Inches of Water Column:	-0.08	Must be between +0.20 and -0.20

TEST 5

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	9	10

Pressure Sensor Serial Number	
Serial Number:	1124

Non-Calibrated Sensor Value		
Inches of Water Column:	0.057	Must be between +0.20 and -0.20

VAPOR PRESSURE SENSOR AMBIENT REFERENCE TEST

TEST 1

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	1	2

Pressure Sensor Serial Number	
Serial Number:	

Non-Calibrated Sensor Value		
In. of Water Column:	0.098	Must be between +0.20 and -0.20

TEST 2

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	9	10

Pressure Sensor Serial Number	
Serial Number:	1232

Non-Calibrated Sensor Value		
In. of Water Column:	-0.021	Must be between +0.20 and -0.20

TEST 3

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	3	4

Pressure Sensor Serial Number	
Serial Number:	1163

Non-Calibrated Sensor Value		
In. of Water Column:	0.033	Must be between +0.20 and -0.20

TEST 4

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	11	12

Pressure Sensor Serial Number	
Serial Number:	1258

Non-Calibrated Sensor Value		
In. of Water Column:	-0.076	Must be between +0.20 and -0.20

TEST 5

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	9	10

Pressure Sensor Serial Number	
Serial Number:	1124

Non-Calibrated Sensor Value		
In. of Water Column:	0.058	Must be between +0.20 and -0.20

VAPOR PRESSURE SENSOR AMBIENT REFERENCE TEST

TEST 6

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	9	10

Pressure Sensor Serial Number	
Serial Number:	1232

Non-Calibrated Sensor Value		
In. of Water Column:	-0.025	Must be between +0.20 and -0.20

TEST 7

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	3	4

Pressure Sensor Serial Number	
Serial Number:	1163

Non-Calibrated Sensor Value		
In. of Water Column:	0.033	Must be between +0.20 and -0.20

TEST 8

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	1	

Pressure Sensor Serial Number	
Serial Number:	1227

Non-Calibrated Sensor Value		
In. of Water Column:	0.09	Must be between +0.20 and -0.20

TEST 9

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	11	12

Pressure Sensor Serial Number	
Serial Number:	1258

Non-Calibrated Sensor Value		
In. of Water Column:	-0.113	Must be between +0.20 and -0.20

TEST 10

Pressure Sensor Location		
	FP	FP
Fueling Point Numbers:	9	10

Pressure Sensor Serial Number	
Serial Number:	1124

Non-Calibrated Sensor Value		
In. of Water Column:	0.058	Must be between +0.20 and -0.20

DATA SHEET FOR DETERMINATION OF PRESSURE IN UNDERGROUND GASOLINE STORAGE TANKS

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	10:00 AM	Initial Ambient Temperature (Degrees F):	81.5	-5.660	-6.000	*
Stop Time:	10:10 AM	Final Ambient Temperature (Degrees F):	82.1	-5.411	-6.000	*
		Ambient Temperature Change (Degrees F):	0.6			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:		Initial Ambient Temperature (Degrees F):	96.2	-3.350	-3.297	0.053
Stop Time:		Final Ambient Temperature (Degrees F):	97.5	-3.700	-3.765	-0.065
		Ambient Temperature Change (Degrees F):	1.3			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:54 AM	Initial Ambient Temperature (Degrees F):	79	-1.270	-1.323	-0.053
Stop Time:	10:04 AM	Final Ambient Temperature (Degrees F):	80.1	-0.890	-0.903	-0.013
		Ambient Temperature Change (Degrees F):	1.1			

* Difference is not shown because TLS console reading max/min is +/- 6.0

DATA SHEET FOR DETERMINATION OF PRESSURE IN UNDERGROUND GASOLINE STORAGE TANKS

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	10:29 AM	Initial Ambient Temperature (Degrees F):	88	-9.543	-6.000	*
Stop Time:	10:39 AM	Final Ambient Temperature (Degrees F):	91.1	-9.089	-6.000	*
		Ambient Temperature Change (Degrees F):	3.1			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:36 AM	Initial Ambient Temperature (Degrees F):	80.9	-3.910	-3.984	-0.074
Stop Time:	9:46 AM	Final Ambient Temperature (Degrees F):	81.1	-4.230	-4.347	-0.117
		Ambient Temperature Change (Degrees F):	0.2			

* Difference is not shown because TLS console reading max/min is +/- 6.0

DATA FOR DETERMINATION OF PRESSURE IN UNDERGROUND GASOLINE STORAGE TANKS

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:30 AM	Initial Ambient Temperature (Degrees F):	78	-1.948	-1.863	0.085
Stop Time:	9:40 AM	Final Ambient Temperature (Degrees F):	79.6	-3.421	-3.350	0.071
		Ambient Temperature Change (Degrees F):	1.6			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:36 AM	Initial Ambient Temperature (Degrees F):	89.4	-0.550	-0.621	-0.071
Stop Time:	9:46 AM	Final Ambient Temperature (Degrees F):	89.4	-0.830	-0.894	-0.064
		Ambient Temperature Change (Degrees F):	0			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:28 AM	Initial Ambient Temperature (Degrees F):	63.5	-1.790	-1.816	-0.026
Stop Time:	9:38 AM	Final Ambient Temperature (Degrees F):	63.7	-1.800	-1.783	0.017
		Ambient Temperature Change (Degrees F):	0.2			

* Difference is not shown because TLS console reading max/min is +/- 6.0

DATA FOR DETERMINATION OF PRESSURE IN UNDERGROUND GASOLINE STORAGE TANKS

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	10:28 Hours	Initial Ambient Temperature (Degrees F):	71.4	-9.781	-6.000	*
Stop Time:	10:38 Hours	Final Ambient Temperature (Degrees F):	73.7	-9.700	-6.000	*
		Ambient Temperature Change (Degrees F):	2.3			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:18 AM	Initial Ambient Temperature (Degrees F):	76.1	-6.180	-6.000	*
Stop Time:	9:28 AM	Final Ambient Temperature (Degrees F):	78.4	-6.290	-5.954	0.336
		Ambient Temperature Change (Degrees F):	2.3			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:03 AM	Initial Ambient Temperature (Degrees F):	77.7	-5.950	-5.963	-0.013
Stop Time:	9:13 AM	Final Ambient Temperature (Degrees F):	78.6	-5.600	-5.629	-0.029
		Ambient Temperature Change (Degrees F):	0.9			

* Difference is not shown because TLS console reading max/min is +/- 6.0

DATA FOR DETERMINATION OF PRESSURE IN UNDERGROUND GASOLINE STORAGE TANKS

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:05 AM	Initial Ambient Temperature (Degrees F):	65.4	-2.700	-2.667	0.033
Stop Time:	9:15 AM	Final Ambient Temperature (Degrees F):	69.3	-2.950	-2.905	0.045
		Ambient Temperature Change (Degrees F):	3.9			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Delta
Start Time:	10:34 Hours	Initial Ambient Temperature (Degrees F):	75.8	-8.75	-6.000	*
Stop Time:	10:44 Hours	Final Ambient Temperature (Degrees F):	76.2	-8.26	-6.000	*
		Ambient Temperature Change (Degrees F):	0.4			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:15 AM	Initial Ambient Temperature (Degrees F):	70.3	-5.830	-5.765	0.065
Stop Time:	9:25 AM	Final Ambient Temperature (Degrees F):	70	-6.170	-5.935	0.235
		Ambient Temperature Change (Degrees F):	-0.3			

Test Start/Stop Times		Observed Ambient Temperature (Cannot Exceed +/- 5 degrees F)		Observed Underground Storage Tank Pressure		
				Manometer Reading (inches H2O)	TLS Reading (inches H2O)	Difference
Start Time:	9:34 AM	Initial Ambient Temperature (Degrees F):	66	-7.516	-6.000	*
Stop Time:	9:44 AM	Final Ambient Temperature (Degrees F):	66.5	-7.187	-6.000	*
		Ambient Temperature Change (Degrees F):	0.5			

* Difference is not shown because TLS console reading max/min is +/- 6.0

ISD VAPOR FLOW METER OPERABILITY TEST DATA

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
1	11	6565	1.15	0.97	0.18	F	0.99	1.03	1.00	0.15	P
2	5	6566	1.11	1.13	-0.02	P					
3	9	6567	0.99	0.98	0.01	P					
4	7	6527	0.94	1.23	-0.29	F	1.21	1.2	1.21	-0.27	F
4	7	6527	1.01	1.03	-0.02	P					
5	1	6518	0.99	0.96	0.03	P					
6	3	6564	1.02	1.21	-0.19	F	1.22	1.22	1.22	-0.20	F
6	3	6564	1.17	1.2	-0.03	P					

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
7	10	6349	1.07	1.07	0.00	P					
8	12	6374	0.89	0.99	-0.10	P					
9	8	6372	0.96	1.03	-0.07	P					
10	4	6336	0.88	1.02	-0.14	P					
11	2	6353	0.84	0.97	-0.13	P					
12	5	6345	0.95	1.02	-0.07	P					

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
13	9	6298	0.96	1.00	-0.04	P					
14	7	6295	1.14	1.18	-0.04	P					
15	2	6299	0.86	0.97	-0.11	P					
16	4	6300	1.00	1.05	-0.05	P					

ISD VAPOR FLOW METER OPERABILITY TEST DATA

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
17	3	6333	0.92	1.01	-0.09	P					
18	4	6333	0.94	0.91	0.03	F	0.91	0.90	0.91	0.03	P
19	2	6418	0.93	0.99	-0.06	P					
20	1	6418	0.92	0.88	0.04	F	0.87	0.87	0.87	0.05	P
21	7	6419	0.98	0.93	0.05	F	0.92	0.91	0.92	0.06	P
22	8	6419	1.10	1.14	-0.04	P					
23	6	6373	1.10	1.11	-0.01	P					
24	5	6373	0.97	0.97	0.00	F	0.95	0.92	0.95	0.02	P
25	5	6373	0.97	0.89	0.08	F	0.87	0.88	0.88	0.09	P
26	6	6373	1.10	1.10	0.00	P					
27	8	6419	1.10	1.13	-0.03	P					
28	7	6419	0.98	0.94	0.04	F	0.94	0.94	0.94	0.04	P
29	2	6418	0.93	0.97	-0.04	P					
30	1	6418	0.92	0.87	0.05	F	0.86	0.86	0.86	0.06	P
31	3	6333	0.92	1.07	-0.15	P					
32	4	6333	0.94	0.96	-0.02	P					

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
33	1	6789	0.91	1.03	-0.12	P					
34	3	6352	0.85	0.90	-0.05	P					
35	5	6408	0.98	1.01	-0.03	P					
36	7	6405	0.98	0.98	0.00	P					
37	9	6401	0.96	1.01	-0.05	P					
38	11	6409	0.96	1.00	-0.04	P					

ISD VAPOR FLOW METER OPERABILITY TEST DATA

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
39	2	6353	1.05	1.15	-0.10	P					
40	4	6336	0.97	1.07	-0.10	P					
41	6	6345	0.92	1.21	-0.29	F	1.28	1.29	1.26	-0.34	F
41	8	6372	1.05	1.12	-0.07	P					
42	10	6349	1.15	1.12	0.03	P					
43	12	6374	1.08	1.18	-0.10	P					
44	6	6345	1.06	1.23	-0.17	F	1.25	1.24	1.24	-0.18	F
44	5	6345	1.09	1.15	-0.06	P	1.21	1.20	1.19	-0.10	P

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
45	1	6299	1.00	1.12	-0.12	P					
46	3	6300	1.08	1.07	0.01	P					
47	8	6295	0.97	1.05	-0.08	P					
48	10	6298	0.90	1.05	-0.15	P					

ISD VAPOR FLOW METER OPERABILITY TEST DATA

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
49	1	6418	1.00	0.91		F	0.90	0.88	0.90	0.10	P
50	2	6418	1.05	0.99	0.06	P					
51	7	6419	0.99	0.90		F	0.90	0.90	0.90	0.09	P
52	8	6419	1.24	1.14	0.10	P					
53	6	6373	1.15	1.11	0.04	P					
54	5	6373	0.86	0.95	-0.09	P					
55	4	6333	0.97	0.96	0.01	P					
56	3	6333	0.97	0.95	0.02	P					
57	3	6333	0.97	0.95	0.02	P					
58	4	6333	0.97	0.92		F	0.91	0.91	0.91	0.06	P
59	2	6418	1.05	0.98	0.07	P					
60	1	6418	1.00	0.90		F	0.87	0.87	0.88	0.12	P
61	8	6419	1.24	1.23		F	1.19	1.16	1.19	0.05	P
62	7	6419	0.99	0.94		F	0.94	0.94	0.94	0.05	P
63	5	6373	0.86	0.84		F	0.87	0.87	0.86	0.00	P
64	6	6373	1.15	1.08	0.07	P					

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
65	1	6789	0.99	0.98	0.01	P					
66	3	6352	1.06	1.01	0.05	P					
67	5	6408	0.99	0.97	0.02	P					
68	7	6405	1.05	1.04	0.01	P					
69	9	6401	1.03	1.05	-0.02	P					
70	11	6409	1.01	0.93	0.08	P					

ISD VAPOR FLOW METER OPERABILITY TEST DATA

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
71	9	6349	1.14	1.24	-0.10	P					
72	12	6374	1.09	1.21	-0.12	P					
73	8	6372	1.11	1.14	-0.03	P					
74	6	6345	1.11	1.19	-0.08	P					
75	2	6353	1.08	1.08	0.00	P					
76	3	6336	1.05	1.12	-0.07	P					

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
77	3	6333	1.01	1.13	-0.12	P					
78	4	6333	0.84	0.89	-0.05	F	0.90	0.89	0.89	-0.05	P
79	7	6419	1.00	0.92	0.08	F	0.89	0.92	0.91	0.09	P
80	8	6419	1.19	1.14	0.05	P					
81	6	6373	1.13	1.11	0.02	P					
82	5	6373	0.93	0.86	0.07	F	0.87	0.86	0.86	0.07	P
83	2	6418	1.06	0.98	0.08	P					
84	1	6418	0.98	0.89	0.09	F	0.89	0.89	0.89	0.09	P
85	1	6418	0.98	0.93	0.05	F	0.90	0.89	0.91	0.07	P
86	2	6418	1.06	0.98	0.08	P					
87	4	6333	0.84	0.88	-0.04	F	0.86	0.86	0.87	-0.03	P
88	3	6333	1.01	0.94	0.07	F	0.93	0.93	0.93	0.08	P
89	7	6419	1.00	0.89	0.11	F	0.89	0.90	0.89	0.11	P
90	8	6419	1.19	1.11	0.08	P					
91	5	6373	0.93	0.90	0.03	F	0.89	0.87	0.89	0.04	P
92	6	6373	1.13	1.10	0.03	P					

ISD VAPOR FLOW METER OPERABILITY TEST DATA

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
93	1	6789	0.95	0.94	0.01	P					
94	3	6352	1.04	0.98	0.06	P					
95	5	6408	0.90	0.95	-0.05	P					
96	7	6405	1.05	1.04	0.01	P					
97	9	6401	1.04	1.03	0.01	P					
98	11	6409	0.97	0.98	-0.01	P					

Test Run	Dispenser Fueling Point	Vapor Flow Meter serial number	ISD Daily Gross V/L Value:	V/L Test Result (1)	Difference bet. Daily Gross and (1)	Pass (P) or Fail (F)? (+/-0.15)	V/L Test Result(2)	V/L Test Result(3)	Average of (1),(2),(3)	Difference bet. Daily Gross and Average of (1),(2),(3)	Pass (P) or Fail (F)?
99	1	6299	1.08	1.19	-0.11	P					
100	2	6299	0.84	1.01	-0.17	F	0.98	1.01	1.00	-0.16	F
101	8	6295	0.95	1.10	-0.15	P					
102	9	6298	1.02	1.03	-0.01	P					